
**STRUCTURAL WELDING
INSPECTION: 2001 CBC**

IR 17-3.01

References:

California Code of Regulations (CCR) Title 24
Part 1, California Administrative Code, Section 4-333(c).
Part 2, 2001 California Building Code (CBC),
Sections 1701A.5, Item 5, 2203A, 2231A.

Revised 10-11-11
Revised 03-10-11
Revised 04-07-08
Revised 01-02-08
Issued 05-15-08 as CR 17-3

Discipline: Structural

This Interpretation of Regulations (IR) is intended for use by the Division of the State Architect (DSA) staff, and as a resource for design professionals, to promote more uniform statewide criteria for plan review and construction inspection of projects within the jurisdiction of DSA which includes State of California public elementary and secondary schools (grades K-12), community colleges, and state-owned or state-leased essential services buildings. This IR indicates an acceptable method for achieving compliance with applicable codes and regulations, although other methods proposed by design professionals may be considered by DSA.

This IR is reviewed on a regular basis and is subject to revision at any time. Please check the DSA web site for currently effective IRs. Only IRs listed in the document at <http://www.dgs.ca.gov/dsa/Resources/IRManual.aspx> at the time of plan submittal to DSA are considered applicable.

This IR applies also to testing laboratories, technicians and special inspectors working under DSA jurisdiction.

- 1. Purpose:** The purpose of this Interpretation of Regulations (IR) is to clarify the minimum requirements and responsibilities for personnel conducting structural welding inspections for projects submitted to DSA under the 2001 California Building Code (CBC). It is applicable to shop and field welding activities. For projects submitted to DSA for review under later editions of the CBC, see IR 17-3.
- 2. Background:** The 2001 California Building Code requires constant special inspection of all welding operations except that continuous inspection is permitted for certain weld types in accordance with the 2001 CBC, Section 1701A.5.
 - 2.1** For welding, "constant" means constant presence of the welding inspector at point of welding, and that he or she inspects each pass as it is being done prior to subsequent weld layers. Constant inspection is applicable to the following types of welds: Multi-pass fillet welds, partial penetration groove welds and complete penetration groove welds.
 - 2.2** For welding, "continuous" means the welding inspector must be in the vicinity of the welding during all phases, and shall inspect in a timely manner, before subsequent operations are performed. Continuous inspection is applicable to single pass fillet welds, deck welding, shear studs, hand rails, etc.
- 3. Qualifications:** Welding inspectors shall meet the following minimum requirements:
 - 3.1** Have valid certification as an American Welding Society (AWS) certified welding inspector (CWI) or senior certified welding inspector (SCWI) as defined in the provisions of ANSI/AWS QC1,
 - 3.2** Have taken the AWS Open Code Book examination on ANSI/AWS D1.1, Structural Welding Code – Steel.
 - 3.3** Be not less than 25 years of age, and

3.4 Must possess knowledge of the administrative requirements of Title 24 Part 1 and special welding inspection requirements of Title 24, Part 2.

4. Approval: A welding inspector shall be approved for each specific project prior to performing any work in accordance with Section 4-333 (c) of Title 24, Part 1 and 2231A of the 2001 CBC. To be approved for a project the welding inspector may be required to demonstrate the following to the satisfaction of DSA:

4.1 The minimum requirements defined in Section 3 above,

4.2 At least 3 years experience in construction or inspection work on projects similar to the project for which the inspector is applying, and

4.3 That adequate time and attention will be devoted to the project.

5. Inspection Duties:

5.1 Review and understand the applicable portions of the DSA approved plans, specifications, field changes and other DSA approved documents. Approved shop drawings, erection drawings, referenced codes and standards must also be reviewed and understood. (Note that shop/erection drawings are NOT DSA approved documents and shall NOT be used as a basis for determining compliance).

5.2 Review manufacturer's Material Test Report (MTR). Verify that all materials properties (e.g. grade, type, size, thickness) are as specified by the DSA approved documents, and that all materials are readily identifiable and traceable to an MTR. Sample any unidentifiable material for testing. All testing of materials must be performed by a laboratory accepted in the DSA Laboratory Evaluation and Acceptance (LEA) Program.

5.3 For seam welds in hollow structural sections (HSS), conduct a thorough visual examination of the seam weld area for visible discontinuities. Visual examination should include, as a minimum, the exterior of the seam weld and the interior at each end.

5.4 For structural plate, conduct a thorough visual examination of surfaces for visible lamination discontinuities.

5.5 Verify that all applicable welder, welding operator, and tack welder qualifications are available, current, and accurate.

5.6 Verify that a written Welding Procedure Specification (WPS) is available on site for each type of weld, that the WPS is in compliance with all requirements, and that the WPS has been approved as required by the construction documents.

5.7 Witness all Procedure Qualification Tests required for non-prequalified welds and verify that Procedure Qualification Records (PQR) are compliant with all applicable requirements.

5.8 Verify that all welding consumables comply with the DSA approved documents and the approved WPS. Verify that all electrodes are properly stored.

5.9 Verify that the welding current and voltage are within the WPS parameters by using a calibrated hand-held volt/amp meter. Readings should be taken as near the arc as possible.

- 5.10 Verify that joint preparation, assembly practice, preheat temperatures, interpass temperatures, welding techniques, welder performance, and post-weld heat treatment meet the requirements of the DSA approved documents, WPS, and applicable AWS code.
- 5.11 Conduct visual inspection of the work: Verify size, length, and location of all welds. Verify that all welds conform to the requirements of the AWS code and the DSA approved documents. Weld size and contour shall be measured with suitable gauges.
- 5.12 Mark completed welds, parts, and joints that have been inspected and accepted with a distinguishing mark, tag or dye stamp. The inspector's mark shall be placed near the fabricator's piece mark and be visible through the steel erection process. Inspector's mark shall include: the special inspector's initials, inspection date, and testing laboratory identification (if applicable).
- 5.13 Schedule or notify those responsible for nondestructive testing (NDT) technicians in a timely manner, after visual inspection and acceptance is complete, and the assembly has cooled. See DSA [IR 17-2](#) for further information regarding NDT.

6. Reporting:

- 6.1 Provide daily inspection reports that clearly describe the inspection process. The report shall document all inspection duties listed in Section 5. above. Reports shall include a systematic list of accepted and rejected welds, parts, or joints. Reports shall clearly document weld locations by grid line, elevation or other acceptable means.
- 6.2 Reports shall reference the details on the DSA approved documents used as a basis for inspection.
- 6.3 Inspection reports must state that the work was inspected in accordance with, and met the requirements of, the DSA approved documents. Reports must be submitted as required by Title 24, Part 1, Section 4-333 (c). A sample special inspection form ([DSA-250](#)) is available on the DSA web site.
- 6.4 Reports shall be sent to the school district and copied to the architect, structural engineer, project inspector and DSA within 14 days of the date of the inspection. For field welding, reports shall also be presented to the project inspector on a daily basis. Reports indicating non-compliance shall be submitted immediately.
- 6.5 At the conclusion of the work, the welding inspector is required to sign and submit a verified report. The verified report shall be made on form ([DSA-292](#)) available on the DSA website.

7. Failure to Perform: Failure to inspect in a professional and competent manner, report defective work, file all required reports in a truthful and timely manner, or fulfill any other duties defined by the code may result in withdrawal of DSA acceptance or approval. This includes but is not limited to withdrawal of acceptance or approval to work on any current or future projects under DSA jurisdiction.