

**FIRE DEPARTMENT & EMERGENCY ACCESS
ROADWAYS AND SCHOOL DROP OFF AREAS****Policy 07-03**

References: Title 19 California Code of Regulations (CCR) Public Safety,
Chapter 1, Subchapter 1, Article 3, Section 3.05
California Vehicle Code, Section 22500.1

Revised 06-29-09
Issued 08-08-07

Discipline: Fire and Life Safety

A policy is based on law and code objectives, addressing any aspect of DSA's Fire and Life Safety plan review program that is not clearly addressed by statute or regulations. Policy may specify administrative or technical requirements that are not currently addressed within Title 24 or its Referenced Standards, but are deemed necessary to fulfill DSA program objectives. DSA Policies are reviewed on a regular basis and subject to revision at any time.

Purpose: The purpose of this policy is to establish requirements based on State Fire Marshal Regulations, Title 19 California Code of Regulations (CCR), and the California Vehicle Code for fire and emergency access roadways on public school or community college campuses, including fire and emergency access roadways combined with student drop-off and pick-up areas. Title 19 CCR does not address issues where the Vehicle Code may impose additional requirements.

Background: In the case of Fire Department access, Title 19 CCR, Article 3, Section 3.05 requires that "Access roads from every building to a public street shall be all-weather hard-surfaced (suitable for use by fire apparatus) right-of-way not less than 20 feet in width." Such right-of-way shall be unobstructed and maintained only as access to the public street.

The California Vehicle Code Section 22500.1 states, "In addition to Section 22500, no person shall stop, park, or leave standing any vehicle, whether attended or unattended, except when necessary to avoid conflict with other traffic or in compliance with the directions of a peace officer or an official traffic control device along the edge of any highway, at any curb, or in any location in a publicly or privately owned or operated off-street parking facility, designated as a fire lane by the fire department or fire district with jurisdiction over the area in which the place is located."

Many California schools have drop-off or pick-up areas for children to either enter or exit a vehicle before and/or after school. In most cases these areas have a minimum width of 10 feet, and in some cases are parallel with the fire access lane. Approval for deviation from these requirements, obtained from the Local Fire Authority, shall be given the highest consideration. DSA remains the Authority Having Jurisdiction and has final approval responsibility for all deviations.

1. POLICY:

1.1 Fire/Emergency access lanes under the jurisdiction of DSA shall be a minimum of 20 feet wide and have a clear height no less than 13 feet, 6 inches. Other heights will be accepted at the request of, or approval of, the Local Fire Authority and where justification is provided. DSA remains the Authority Having Jurisdiction and has final approval responsibility in all cases.

Each site submittal shall be evaluated and retrofit of existing or previously approved configurations will not be required, until modifications or modernizations include fire access lanes or student drop-off and pick-up areas.

- 1.2 Fire/Emergency access lanes shall not be combined with or overlap student drop-off/pick-up areas, per the California Vehicle Code, nor shall the student drop-off/pick-up areas reduce the required 20 foot width of the fire access lanes.
- 1.3 Where vehicle drop-off areas are parallel with a designated fire access lane, the minimum total combined required width shall be no less than 30 feet, and clearly marked per Section 1.5 below.
- 1.4 Student drop-off/pick-up areas shall be configured in such a manner so as to not obstruct the Fire or Emergency vehicles when private vehicles arrive and depart and passengers enter or exit vehicles, per CCR Title 19 and the California Vehicle Code.
- 1.5 The designation of the fire lane(s) shall be indicated per the California Vehicle Code Section 22500.1, by one or more of the following means:
 - "(1) by a sign posted immediately adjacent to, and visible from, the designated place clearly stating in letters not less than one inch in height that the place is a fire lane, or
 - "(2) by outlining or painting the place in red and, in contrasting color, marking the place with the words 'FIRE LANE', which are clearly visible from a vehicle, or
 - "(3) by a red curb or red paint on the edge of the roadway upon which is clearly marked the words 'FIRE LANE'."
- 1.6 Distances between posted signs shall be no more than 30 feet, or as required by the Local Fire Authority, and shall continue the full length of the fire access lane, or until one or more of the other approved indication methods are utilized.
- 1.7 Vehicles parked in designated fire access lanes on public school campuses are subject to the California Vehicle Code and may be cited, towed, or impounded by local law enforcement authorities.