

**45-DAY EXPRESS TERMS  
FOR  
PROPOSED EMERGENCY BUILDING STANDARDS  
OF THE  
DEPARTMENT OF HOUSING AND COMMUNITY DEVELOPMENT  
REGARDING THE 2013 CALIFORNIA GREEN BUILDING STANDARDS CODE  
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 11  
(INDOOR POTABLE WATER USE REDUCTION STANDARDS)  
(HCD EF 03/15)**

The Department of Housing and Community Development (HCD) proposes to make necessary changes to be included in the 2013 edition of the California Green Building Standards Code (CGBC), also known as CALGreen, as presented on the following pages:

**LEGEND FOR EXPRESS TERMS:**

1. **Existing California text or language being modified:** All language is shown in normal Arial 9 point; modified language is underlined or shown in ~~strikeout~~.
2. **Existing text not being modified:** All language not displayed in full is shown as “...” (i.e., ellipsis).
3. **Repealed text:** All language appears in ~~strikeout~~.
4. **Amended, adopted or repealed language after public hearing:** All language is shown in double underline or ~~double-strikeout~~.
5. **Notation:** Authority and Reference citations are provided at the end of each section.

**SUMMARY OF REGULATORY ACTION**

**HCD PROPOSES TO:**

- Modify the 2013 California Green Building Code (CALGreen) to accommodate changes resulting from amendments in Title 20, Appliance Efficiency Regulations, adopted by the California Energy Commission.

1. **HCD proposes new amendments in Chapter 4, Division 4.3 Water Efficiency and Conservation, for adoption into the 2013 California Green Building Code as follows:**

CHAPTER 4  
RESIDENTIAL MANDATORY MEASURES

*Division 4.3 Water Efficiency and Conservation*

SECTION 4.303  
INDOOR WATER USE

**4.303.1.2 Urinals.** On or after January 1, 2016, The the effective flush volume of wall mounted urinals shall not exceed 0.5 0.125 gallons per flush. The effective flush volume of all other urinals shall not exceed 0.5 gallons per flush.

**4.303.1.4.1 Residential lavatory faucets.** On or after July 1, 2016, The the maximum flow rate of residential lavatory faucets shall not exceed 4.5 1.2 gallons per minute at 60 psi. The minimum flow rate of residential lavatory faucets shall not be less than 0.8 gallons per minute at 20 psi.