

STATE OF CALIFORNIA  
STATE AND CONSUMER SERVICES AGENCY  
CALIFORNIA BUILDING STANDARDS COMMISSION  
2525 NATOMAS PARK DR., SUITE 130  
SACRAMENTO, CA 95833  
(916) 263-0916 Phone  
(916) 263-0959 Fax  
Email: BSC@dgs.ca.gov

Office Use Item No. \_\_\_\_\_

**PARTICIPATION COMMENTS FOR THE NOTICE DATED AUGUST 28, 2009**  
Written comments are to be sent to the above address.

**WRITTEN COMMENT DEADLINE: OCTOBER 12, 2009**

Date: October 12, 2009

From:

Roger Richter  
Name (Print or type)

  
(Signature)

-- California Hospital Association

Agency, jurisdiction, chapter, company, association, individual, etc.

1215 K St. #800  
Street

Sacramento  
City

CA  
State

95814  
Zip

We do agree with:

The Agency proposed modifications As Submitted on Section No. OSHPD Plumbing Code Section 604.1

and request that this section or reference provision be recommended:

Approved     Disapproved     Held for Further Study     Approved as Amended

**Suggested Revisions to the Text of the Regulations: NONE**

The California Hospital Association, which represents approximately 450 hospitals and health systems in California, is pleased that OSHPD is proposing that, as an option, hospitals can choose to use CPVC piping in their buildings as is allowed in other public buildings under the model code. Hospitals can still use iron pipe where it may be more appropriate. However, the ability to use CVPC pipe, when deemed appropriate, can save hospitals and the health care system from unnecessary costs. We believe the proposal meets all nine Commission review criteria.