

**FINAL EXPRESS TERMS
FOR
PROPOSED BUILDING STANDARDS
OF THE
CALIFORNIA BUILDING STANDARDS COMMISSION (CBCS)**

**REGARDING PROPOSED AMENDMENT TO THE
2010 CALIFORNIA MECHANICAL CODE (CMC) IN THE
CALIFORNIA CODE OF REGULATIONS (CCR), TITLE 24, PART 4**

(The State agency shall draft the regulations in plain, straightforward language, avoiding technical terms as much as possible and using a coherent and easily readable style. The agency shall draft the regulation in plain English. A notation shall follow the express terms of each regulation listing the specific statutes authorizing the adoption and listing specific statutes being implemented, interpreted, or made specific. (PART 1 – ADMINISTRATIVE CODE)

LEGEND FOR FINAL EXPRESS TERMS (combination of 45-day and 15-day changes)

1. For 45-day changes, existing California amendments or code language being modified appears in *italics*, with modified language underlined.
2. For 45-day changes, repealed text appears in ~~strikeout~~.
3. For 15-day changes, existing California amendments or code language being modified appears in *italics*, with modified language double underlined.
4. For 15-day changes, repealed text appears in double ~~strikeout~~.

EXPRESS TERMS:

The California Building Standards Commission proposes to amend the 2010 California Mechanical Code (CMC) as follows:

Chapter 6 of the 2010 CMC:

**MATRIX ADOPTION TABLE
Adopt Chapter 6**

Adopting Agency	BSC	COMMENTS
Adopt entire Chapter without amendments		
Adopt Entire Chapter as amended (amended sections listed below)	X	
Adopt Only those sections that are listed below and/or Adopt Only those California promulgated sections ^{1, 2, 3} listed below		
605.0	X	

CHAPTER 6

605.0 Insulation of Ducts.

Supply-, return-air ducts and plenums of a heating or cooling system shall be insulated to achieve the minimum thermal (R) value as set forth in *Tables 6-6 A and B* ~~SMACNA/ANSI 006-2006 HVAC Duct Construction Standards - Metal and Flexible or another approved duct construction standard.~~ **[OSHPD 1, 2, 3 & 4]** Cold air ducts shall be insulated wherever necessary or to prevent condensation problems.

...

Notation

Authority: Health & Safety Code Sections 18928 and 18934.5

Reference(s): Health & Safety Code Sections 18928, 18928.1 and 18934.5