

**FINAL EXPRESS TERMS
FOR
PROPOSED BUILDING STANDARDS
OF THE
OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT

REGARDING PROPOSED CHANGES TO
CALIFORNIA PLUMBING CODE
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 5**

(The State agency shall draft the regulations in plain, straightforward language, avoiding technical terms as much as possible and using a coherent and easily readable style. The agency shall draft the regulation in plain English. A notation shall follow the express terms of each regulation listing the specific statutes authorizing the adoption and listing specific statutes being implemented, interpreted, or made specific. (PART 1 – ADMINISTRATIVE CODE)

- LEGEND FOR FINAL EXPRESS TERMS (combination of 45-day and 15-day changes)**
1. For 45-day changes, existing California amendments or code language being modified appears in *italics*, with modified language underlined.
 2. For 45-day changes, repealed text appears in ~~strikeout~~.
 3. For 15-day changes, existing California amendments or code language being modified appears in *italics*, with modified language double underlined and highlighted.
 4. For 15-day changes, repealed text appears in double ~~strikeout~~ and highlighted.

EXPRESS TERMS

**CHAPTER 4
PLUMBING FIXTURES AND FIXTURE FITTINGS**

**TABLE 4-2
[OSHPD 1, 2, 3 & 4²⁴] MINIMUM PLUMBING FACILITIES**

At any page break repeat column headers for this table

SPACE	HANDWASHING FIXTURE	SCRUB SINKS	TOILETS	BATHTUBS OR SHOWERS	SERVICE SINKS ¹	CLINIC SINKS
OSHPD 1						
<i>General Acute Care Hospitals^{1,20} and Acute Psychiatric Hospitals^{1,20}</i>						
Administration Lobby						
<i>Public Toilet - Male</i>	<u>1²</u>		1			
<i>Public Toilet - Female</i>	<u>1²</u>		1			
<i>Airborne infection isolation room</i>	1					
<i>Airborne infection isolation toilet room</i>	<u>1²</u>		1 ⁵	1 ⁵		
<i>Cardiac Catheterization procedure room</i>		1 ⁴				
<i>Central Sterile Supply</i>	<u>1¹⁵</u>					
Cesarean/Delivery Service Space						
<i>Labor Rooms</i>	1		1 ⁹	1 ⁹		
<i>Recovery Room</i>	1					1
<i>Drug distribution station</i>	1					
<i>Cesarean operating room</i>		2 ¹⁰				
<i>Delivery room</i>		1 ¹⁰				
<i>Staff lounge toilet</i>						
<i>Staff Toilet - Male</i>	<u>1²</u>		1:1-15			
<i>Staff Toilet - Female</i>	<u>1²</u>		1:1-15			

SPACE	HANDWASHING FIXTURE	SCRUB SINKS	TOILETS	BATHTUBS OR SHOWERS	SERVICE SINKS ¹	CLINIC SINKS
LDR or LDRP room	1		1	1		
Waiting area / room						
Public Toilet - Male	1 ²		1			
Public Toilet - Female	1 ²		1			
Clinical Laboratory Service Space ¹¹	1					
Dietetic Service Space					<u>1</u>	
Kitchen	1 ²					
Food serving area	1 ²					
Food Preparation	1 ²					
Dietary Staff Toilet - Male	1 ²		1:1-15			
Dietary Staff Toilet - Female	1 ²		1:1-15			
Emergency Service Treatment room	1					
Open plan	1:4 cubicles					
Observation units	1:4 cubicles					
Trauma / Cardiac, Emergency surgery, Cystoscopy, Cast Room or Special procedure room		1 ⁴				
Intensive Care Units⁷					<u>1</u>	1
Open plan	1:3 beds					
Patient rooms ²⁸	1					
Newborn Intensive Care Unit (NICU)	1:4 bassinets ¹⁷				<u>1</u>	1
Control station	1					
Staff lounge						
Staff Toilet - Male	1 ²		1:1-15			
Staff Toilet - Female	1 ²		1:1-15			
Employee dressing rooms and Lockers						
Staff Toilet - Male	1 ²		1:1-15			
Staff Toilet - Female	1 ²		1:1-15			
Exam and treatment rooms	1					
Housekeeping room ¹					1	
Laboratories	1 ¹⁵					
Laundry soiled linen, receiving, holding and sorting	1					
Medicine preparation rooms or station	1 ¹⁹					
Morgue and Autopsy	1					
Nourishment area	1+1 ²					
Nuclear Medicine room	1					
Mold room	1					
Patient room	1					
Patient toilet and bath facilities ¹³	1 ²		1:4 beds	1:12 ¹⁶		
Multi-purpose rooms	1		1			
Central bathing facility			1			
Medicine preparation room	4					
Administration Center or Nurses' Stations ²⁷	1					
Newborn / well baby nursery	1:6 bassinets				<u>1</u>	
Gastrointestinal endoscopy procedure room	1					
Pediatric and Adolescent Unit toilet room	1 ^{2,26}		1 ²⁶			
Pharmacy	1 ²⁵					
Staff Toilet - Male	1 ²		1:1-15			
Staff Toilet - Female	1 ²		1:1-15			
Compounding area for parenteral solutions	1					

SPACE	HANDWASHING FIXTURE	SCRUB SINKS	TOILETS	BATHTUBS OR SHOWERS	SERVICE SINKS ¹	CLINIC SINKS
Postanesthesia care units (PACU)	1					1
Protective environment room	1					
Protective environment toilet room	1 ²		1 ⁵	1 ⁵		
Psychiatric unit patient room	1		1			
Radiological/Imaging Services Space²⁹	1		1 ²⁹			
Computerized tomography (CT) ²⁹	1					
Ultrasound ⁸	1		1 ³⁰			
Angiography ²⁹	1	1 ^{4,31}				
Flouroscoy ⁸	1		1 ³⁰			
Staff Toilet ¹⁸ - Male	1 ²		1:1-15			
Staff Toilet ¹⁸ - Female	1 ²		1:1-15			
Rehabilitation Therapy Space						
Training toilet			1			
Physical therapy service space	1					
Occupational therapy service space	1					
Speech pathology	1					
Renal Dialysis Service Space	1:4 stations				1	1
Bloodborne Infection Isolation Room	1					
Nurses' station	1					
Medication dispensing	1					
Home training room	1					
Repair room	1				1	
Dialysis Patient toilet	1		1 ²³			
Staff lounge						
Staff Toilet - Male	1 ²		1:1-15	1 shower		
Staff Toilet - Female	1 ²		1:1-15	1 shower		
Surgical Service Space		2 ³			1	
Staff clothing change areas						
Staff Toilet - Male	1 ²		1:1-15	1 shower		
Staff Toilet - Female	1 ²		1:1-15	1 shower		
Clean-up rooms	1					
Substerile area	1					
Anesthesia workroom	1 ⁸					
Soiled workroom or soiled holding	1					1
Cancer treatment / infusion therapy treatment	1:4 stations					
Utility / Work Room						
Clean ²¹	1					
Soiled ²²	1					1 ¹⁴
OSHPD-2						
Skilled Nursing or Intermediate Care Facilities						
Nurses' Station	4					
Utility room	4					
—Clean	4 ²⁴					
—Soiled	4 ²²					4 ¹⁴
Patient beds [Skilled Nursing/Intermediate Care Facilities]	1:8 ³²		1:6	1:20		
Administration space — public toilets			4			
Employee lockers						
—Male	4 ²		4			

SPACE	HANDWASHING FIXTURE	SCRUB SINKS	TOILETS	BATHTUBS OR SHOWERS	SERVICE SINKS ¹	CLINIC SINKS
—Female	4 ²		4			
Outpatient waiting room toilet room	4 ²		4			
Laundry	4					
Dietetic service space						
—Employee washroom	4					
Airborne infection isolation room ⁵	4		4 ⁵	4 ⁵		
Protective environment room ⁵	4 ⁵		4 ⁵	4 ⁵		
Medicine rooms ¹⁰	4 ⁵					
Optional services	4 ^{7b}					
—Physical therapy	4		4			
—Occupational therapy	4		4			
—Speech pathology/Audiology	4					
Housekeeping room	4				4	
OSHPD 3						
Licensed Clinics and any freestanding building under a hospital license where outpatient clinical services are provided						
Examination and treatment rooms	4					
Primary care clinic					4	
—Utility room	4 ^{7b}					
Birthing Clinic	4				4	
—Clean-up room	4					
—Birthing room toilet room	4 ²		4			
—Shower				4		
—Housekeeping room					4	
Surgery Clinic		2 ³			4	
—Clean-up room	4					
—Outpatient changing	4 ²		4			
—Postanesthesia recovery	4					
—Housekeeping room					4	
—Nurses' control area	4					
—Staff clothing area						
—Male	4		4			
—Female	4		4			
Chronic Dialysis					4	
—Nurse station	1:8 patients					
—Patient toilet room	4 ²		4 ²³			
—Staff lockers	4 ²		4			
—Bloodborne infection isolation room	2 ⁵		4 ⁵	4 ⁵		
—Utility room	4			4		
—Home training	4					
Rehabilitation Clinics						
—Physical therapy space	4					
—Occupational therapy	4					
—Speech pathology/Audiology ⁷	4				4	
Housekeeping room					4	
OSHPD 4²⁴						
Treatment Centers⁴						
Nurses' station	4					
Utility Room	4					
—Clean	4 ²¹					
—Soiled	4 ²²					
Patient toilet and bath facilities ¹³ [Correctional]	1:8 ²		1:6	1:12		

SPACE	HANDWASHING FIXTURE	SCRUB SINKS	TOILETS	BATHTUBS OR SHOWERS	SERVICE SINKS ¹	CLINIC SINKS
<u>Treatment Center</u>						
<u>Employee dressing rooms</u>						
—Male	4 ²		4			
—Female	4 ²		4			
<u>Outpatient services</u>			4			
<u>Airborne infection isolation room⁶ [Correctional Treatment Center]</u>	1 ⁶		1 ⁶	1 ⁶		
<u>Airborne infection isolation anteroom [Correctional Treatment Center]</u>	1					
<u>Protective environment room⁶ [Correctional Treatment Center]</u>	1 ⁶		1 ⁶	1 ⁶		
<u>Protective environment anteroom [Correctional Treatment Center]</u>	1					
<u>Medicine rooms¹⁹</u>	4 ^{4b}					
<u>Employee dressing rooms and lockers</u>						
—Male	4 ²		4			
—Female	4 ²		4			
<u>Outpatient services</u>						
—Waiting area	4 ²		4			
<u>Housekeeping room</u>						4
<u>Soiled utility room</u>	4					
<u>Pharmacy</u>	4					

- 1 Each department or nursing unit shall be served by a housekeeping room equipped with a service sink. Departments may share service closets provided the departmental services are compatible. A dedicated housekeeping room shall be provided for the following services: Surgical /Catheterization, ICU, NICU, nursery, dietary, renal dialysis and outpatient surgery.
- 2 Conventional spouts and controls on hot-and cold-water supplies are acceptable. Aerators are not permitted. Non-aerating laminar flow devices are permitted. Nourishment areas shall have a handwashing fixture in or immediately accessible from the nourishment area.
- 3 A minimum of two scrub sinks shall be provided in a surgical unit containing one operating room. Four scrub sinks shall be provided in surgical units containing two operating rooms. One additional scrub sink shall be provided per each additional operating room.
- 4 The scrub sink is in addition to the required number for surgeries.
- 5 The following fixtures shall be provided in airborne infection or protective environment rooms of hospitals only:
 - a. Within an adjoining toilet room, a lavatory, a shower containing a seat or a space for a shower chair, and toilet equipped with bedpan flushing attachment with a vacuum breaker.
 - b. A handwashing fixture within a separate anteroom.
- 6 The following fixtures shall be provided in isolation rooms of correctional treatment centers only:
 - a. Within an adjoining toilet area, a handwashing fixture, a shower containing a seat or a space for a shower chair, and water closet equipped with bedpan flushing attachment with a vacuum breaker.
 - b. A handwashing fixture within a separate anteroom.
- 7 Includes burn center spaces, acute respiratory-care service spaces, and coronary-care service spaces.
- 8 A toilet room with handwashing fixture shall **directly** adjoin each procedure room.
- 9 One toilet with lavatory and one shower may serve two labor rooms.
- 10 One additional scrub sink per cesarean or delivery operating room.
- 11 Provide emergency eye-wash and shower.
- 12 ~~Handwashing fixtures shall be located in convenient locations throughout the space. Not used.~~
- 13 Fixtures serving individual patient rooms shall not be considered as meeting the required ratios for bedrooms not served by individual adjoining toilet or bathrooms.
- 14 The clinic sink may be deleted if all bedrooms in the nursing unit are provided with adjoining toilets with bedpan flushing devices.
- 15 Conventional controls on hot-and cold-water supplies are acceptable. The water discharge points shall be 5 inches (127 millimeters) above the fixture rim. Aerators are not permitted. Non-aerating laminar flow devices are permitted.
- 16 A minimum of one bathtub is required on each floor of an acute care or acute psychiatric hospital providing skilled nursing or intermediate care services.
- 17 In a multiple-bed room, every bed position shall be within 20 feet (6 meters) of a hands-free handwashing fixture. Where an individual room concept is used, a handwashing fixture shall be provided within each infant care room.
- 18 When three or more procedure rooms are provided.
- 19 If a separate medicine room is provided, the room shall be equipped with a sink in addition to the nurses' station handwashing fixture. Hot-water supplies are optional.

- 20 ~~Chemical dependency recovery hospitals are only required to provide handwashing fixtures for exam rooms and kitchens. All other fixtures may be equipped per Footnote 2. Not used.~~
- 21 Handwashing fixtures may be deleted if room is storage and holding only.
- 22 Handwashing fixtures may be deleted if room is temporary holding of soiled materials.
- 23 Toilet shall be equipped with a bedpan flushing attachment.
- 24 Optional services approved by the licensing agency shall comply with the applicable space requirements of OSHPD 1 and 2.
- 25 Shall be provided in each separate room where open medication is handled.
- 26 Conveniently accessible throughout the unit.
- 27 Includes rooms or areas within coronary and intensive-care units and postanesthesia recovery rooms.
- 28 Modular toilet/sink combination units located within a privacy curtain may be used within each patient space or private room. The toilet fixture shall be completely contained within cabinetry when not in use.
- 29 ~~Toilet room facilities located adjacent to or in the immediate vicinity are adequate. In service spaces with procedure rooms that do not have dedicated patient toilets, provide a minimum of one patient toilet room~~ with a separate handwashing fixture within the service space. 30 Toilet room shall be accessible from the procedure room.
- 31 Scrub sink shall be located outside the staff entrance to the procedure room.
- 32 Lavatories shall be equipped with gooseneck spouts without aerators and may have conventional controls.

Notation

Authority: Health & Safety Code Sections 1226, 1275, 129790 & 129850 and Government Code Section 11152.5

Reference(s): Health & Safety Code Section 129850