

**EXPRESS TERMS
FOR
PROPOSED BUILDING STANDARDS
OF THE
OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT**

**REGARDING PROPOSED CHANGES TO
CALIFORNIA PLUMBING CODE
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 5**

LEGEND FOR EXPRESS TERMS

1. Existing California amendments or code language being modified are in italics when they appear in the model code text: All such language appears in *italics*, modified language is underlined.
2. Repealed text: All such language appears in ~~strikeout~~.

EXPRESS TERMS

CALIFORNIA PLUMBING CODE

**CHAPTER 6
WATER SUPPLY AND DISTRIBUTION**

613.0 [OSHPD 1, 2, 3 & 4] Domestic Hot-Water Distribution Systems for Health Facilities and Clinics.

...

613.2 At least two pieces of hot-water-heating equipment shall be provided to supply hot water for dishwashing and minimum patient services such as handwashing and bathing. Booster heaters for 125°F to 180°F (52°C to 82°C) water are acceptable as a second piece of equipment for dishwashing. Where storage tanks are separate from the water heater, at least two independent storage tanks shall be provided. ~~Not required for [OSHPD 3SE].~~

NOTATION:

Authority: Health and Safety Code Sections 1226, 1275, 18928, 129790 and 129850; Government Code Section 11152.5
Reference: Health and Safety Code Section 129850

REASON PROPOSING CHANGES WITHOUT REGULATORY EFFECT:

The Office of Statewide Health Planning and Development is repealing amendments of the 2013 California Plumbing Code (CPC) which were adopted by the California Building Standards Commission on April 24, 2013, and effective on January 1, 2014. Specifically, the provision being amended is Section 613.2 of the CPC. This amendment is being done as a result of the removal of the OSHPD 3SE facility definition from the 2013 CPC.