

STATE OF CALIFORNIA
GOVERNMENT OPERATIONS AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbsc@dgs.ca.gov

Office Use Item No. DSAAC 01/13

Received on 3/31/14


PARTICIPATION COMMENTS FOR THE NOTICE DATED MARCH 21, 2014
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: MAY 5, 2014

Date: 03/31/2014

From:

Martin Cooper
Name (Print or type)


(Signature)

City of Foster City

Agency, jurisdiction, chapter, company, association, individual, etc.

610 Foster City Blvd. Foster City CA 94404
Street City State Zip

I/We (do)(do not) agree with:

The Agency proposed modifications As Submitted on Section No. 11B-226.3

and request that this section or reference provision be recommended:

Approved Disapproved Held for Further Study Approved as Amended

by the reviewing Code Advisory Committee.

Suggested Revisions to the Text of the Regulations:

11B-226.3 Dining surfaces exceeding 34 inches in height. *Where food or drink is served for consumption at a counter ~~dining surface~~ exceeding 34 inches (864 mm) in height ~~is provided for the consumption of food or drink~~, a portion of the main counter ~~dining surface~~ 60 inches (1525 mm) minimum in length shall be provided in compliance with Section 11B-902.3 11B-902.*

Reason: [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

Including the word "dining" to describe counter surfaces would exclude drinking establishments. The public interest requires the adoption of these building standards.