STATE OF CALIFORNIA
GOVERNMENT OPERATIONS AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbsc@dgs.ca.gov

Office Use Item No. DSAAC 01/13
Received on 3/31/14

PARTICIPATION COMMENTS FOR THE NOTICE DATED MARCH 21, 2014
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: MAY 5, 2014

Date: 03/31/2014

From:
Martin Cooper
Name (Print or type) (Signature)

City of Foster City
Agency, jurisdiction, chapter, company, association, individual, etc.

610 Foster City Blvd. Foster City CA 94404
Street City State Zip

I/We (do)(do not) agree with:

[X] The Agency proposed modifications As Submitted on Section No. __11B-308.4_____

and request that this section or reference provision be recommended:

[ ] Approved [ ] Disapproved [ ] Held for Further Study [X] Approved as Amended

by the reviewing Code Advisory Committee.

Suggested Revisions to the Text of the Regulations:

11B-308.4 Reach ranges for children. *~~Where b~~Building elements such as coat hooks, lockers, or operable parts are designed for use primarily by children, ~~the suggested~~ shall comply with the dimensions of Table 11B-308.4 ~~may be used~~. These dimensions apply to either forward or side reaches.*

Reason: [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

Dimensions for children's water closets are currently mandated under Table 11B-604.9. Revisions to the proposed text would be consistent with requirements of the 2013 California Building Code. The proposed building standards do not conflict with, overlap, or duplicate other building standards