

STATE OF CALIFORNIA  
GOVERNMENT OPERATIONS AGENCY  
CALIFORNIA BUILDING STANDARDS COMMISSION  
2525 NATOMAS PARK DR., SUITE 130  
SACRAMENTO, CA 95833  
(916) 263-0916 Phone  
(916) 263-0959 Fax  
Email: cbsc@dgs.ca.gov

Office Use Item No. DSA ALO/13

Received on 4/1/14

**PARTICIPATION COMMENTS FOR THE NOTICE DATED MARCH 21, 2014**  
Written comments are to be sent to the above address.

**WRITTEN COMMENT DEADLINE: MAY 5, 2014**

Date: April 1, 2014

From:

Neal Casper

Name (Print or type)

Neal Casper  
(Signature)

Casper Development Resources, Inc.

Agency, jurisdiction, chapter, company, association, individual, etc.

5360 Jackson Drive, Suite 114 , La Mesa, CA 91942

Street

City

State

Zip

I/We (do)(do not) agree with:

The Agency proposed modifications As Submitted on Section No. 11B.17

and request that this section or reference provision be recommended:

Approved  Disapproved  Held for Further Study  Approved as Amended

**Suggested Revisions to the Text of the Regulations:**

Revise item to remove the prohibition that Baby Changers cannot be located within the accessible toilet compartment in multi-occupant restrooms or be located in an area where when deployed, would obstruct the accessible route.

**Reason:** [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

Prohibiting Baby Changers from being located in accessible toilet compartments or in a location where when deployed would obstruct an accessible route is not in the public interest as the result would be the removal of baby changers from most public restrooms including restrooms in retail, grocery and restaurants where they are most needed by parents. Most public restrooms are not large enough to provide a location which could meet the proposed revised code.

