

**COMMISSION ACTION MATRIX**

**AGENCY: THE OFFICE OF STATEWIDE HEALTH PLANNING AND DEV. [OSHPD 04/13]**

**TITLE (CODE)**

**CCR, TITLE 24, PART 5 (2013 CPC)**

**LEGEND:**

Item numbers refer to those presented to the Code Advisory Committees (CAC)s

**(CAC)s:**

ACCESS = Accessibility

AD-HOC = Super Committee made up of:

Building, Fire & Other, Health Facilities,

Plumbing, Electrical, Mechanical, and Energy &

Structural Design/Lateral Forces

GB = Green Building

**Actions:**

A = Accepted

AA = Approve as amended

AS = Approve as submitted

D = Disapprove

FS = Further Study

W/D = Withdrawn by agency

**Amendments, if indicated by agency:**

S = Statutory

E = Existing

N = New

**Matrix Paper Color (Used for Comm. Action Only):**

GREEN = uncontested items

YELLOW = challenged items

SALMON = W/D, no action required

**AD-HOC CODE ADVISORY COMMITTEE (OSHPD)**

**CHAPTERS 2 - DEFINITIONS AND CHAPTER 13 – HEALTH CARE FACILITIES AND MEDICAL GAS AND VACUUM SYSTEMS**

Amend sections listed below:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD 04/13-1	210 <i>Handwashing Fixtures</i>	E	STFS	A		CAC Recommends: clarify that new language in 210.0 Handwashing Fixtures (1) (d) does not preclude the use of automatic or non-touch control fixtures	
OSHPD 04/13-2	<u>1301.2.1</u>	E	AS	A			