

**EXPRESS TERMS
FOR
PROPOSED BUILDING STANDARDS
OF THE
OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
REGARDING PROPOSED CHANGES TO
CALIFORNIA PLUMBING CODE
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 5**

LEGEND FOR EXPRESS TERMS

1. Existing California amendments or code language being modified are in italics when they appear in the model code text: All such language appears in *italics*, modified language is underlined.
2. New California amendments: All such language appears underlined and in italics.
3. Repealed text: All such language appears in ~~strikeout~~.

EXPRESS TERMS

**CHAPTER 2
DEFINITIONS**

210.0

- H -

Handwashing Fixture [OSHPD 1, 2, 3 & 4]. *Handwash fixtures consist of faucet, trim and sink as described:*

- (1) *Faucets and Trim*
 - a. *Hand washing fixtures used by medical and nursing staff, patients, and food handlers shall be trimmed with valves that can be operated without the use of hands.*
 - i. *Wrist or elbow blades shall be permitted unless otherwise noted in ~~where allowed~~ per Table 4-2.*
 - ii. *Blade handles used for this purpose shall be at least 4 inches (102 mm) in length.*
 - b. *Sensor operated fixtures shall be capable of functioning during loss of normal power.*
 - c. *Faucets shall not be equipped with an aerator but may be equipped with a non-aerating laminar flow device.*
 - d. *If deck-mounted manual temperature controls are used they shall use wrist blades at least 4 inches (102 mm) in length. Faucet mounted temperature controls are prohibited.*
 - e. *...*

**CHAPTER 13
HEALTH CARE FACILITIES AND MEDICAL GAS AND VACUUM SYSTEMS**

1301.2 Health Care Facilities. This chapter applies to the special fixtures and systems in health care facilities and to the special plumbing requirements for such facilities. Other plumbing in such facilities shall comply with other applicable sections of this code.

1301.2.1 [OSHPD 1, 2, 3 & 4] *Medical gas systems for health care facilities that are regulated by OSHPD (hospitals, skilled nursing facilities, and intermediate care facilities, licensed clinics, and correctional treatment centers) shall be in accordance with NFPA 99 ~~–2005~~, Standard for Health Care Facilities. See California Building Code Table ~~1224.2- 1224.4.6.1~~ for location and number of station outlets for oxygen, vacuum, and medical air.*

Notation

Authority: Health and Safety Code Sections 1226, 1275, 1323.5, 18928, 129790 and 129850; Government 11152.5

Reference: Health and Safety Code Section 129850

**CALIFORNIA PLUMBING CODE – MATRIX ADOPTION TABLE
CHAPTER 13 - HEALTH CARE FACILITIES AND MEDICAL GAS AND VACUUM SYSTEMS**

(Matrix Adoption Tables are non-regulatory, intended only as an aid to the user. See Chapter 1 for state agency authority and building application.)

Adopting Agency	BSC	SFM	HCD			DSA			OSHPD				BSCC	DPH	AGR	DWR	CA	SL	SLC
			1	2	1-AC	AC	SS	SS/CC	1	2	3	4							
Adopt Entire Chapter																			
Adopt Entire Chapter as amended (amended sections listed below)									X	X	X	X							
Adopt only those sections that are listed below									X	X	X	X							
Chapter/Section																			
1301.2 <u>1301.2.1</u>									X	X	X	X							