

Dave Walls

COUNTY OF MARIN
ENVIRONMENTAL HEALTH SERVICES
3501 CIVIC CENTER DRIVE, RM 236
SAN RAFAEL, CA 94903
415.499.6907/ (Fax) 415.507.4120
www.co.marin.ca.us/ehs

RECEIVED

2009 DEC -7 P 1:19

CALIFORNIA BUILDING
STANDARDS COMMISSION

December 4, 2009

California Building Standards Commission
Attn: Dave Walls, Executive Director
2525 Natomas Park Drive, Suite 130
Sacramento, CA 95833

Subject: Proposed Emergency Regulations Modifying the 2007 California Plumbing Code and
Proposed Regulations Modifying the 2010 California Plumbing Code, dated November
19, 2009

Dear Mr. Walls,

This Division is in support of the proposed modifications to the 2007 California Plumbing Code and the 2010 California Plumbing Code as expressed in the November 19, 2009 draft released for the 15-day notice.


We believe the elimination of the Single Fixture System will simplify the regulations and will be more protective of health and safety by minimizing potential unknown risks.

We whole-heartedly support the inclusion of sub-sections 1612A.1(3) and (4). It clearly states the level of treatment that must be met in order to use "treated graywater" indoors. Prior to this inclusion, there were many people who would not recognize that "treated graywater" had to be treated to meet Title 22 standards. We were fearful for the health and safety of the public because of this refusal to recognize this requirement.

Thank you very much for the proposed modifications. It is believed that the changes will make our jobs, the people on the front line, much easier.

If you have any questions, please call me at (415) 499-69191 or email, rng@co.marin.ca.us.

Sincerely,



Rebecca Ng, R.E.H.S.
Deputy Director, CDA – Environmental Health Services