

**EXPRESS TERMS  
FOR  
PROPOSED BUILDING STANDARDS  
OF THE  
OFFICE OF THE STATE FIRE MARSHAL (SFM)  
REGARDING THE ADOPTION BY REFERENCE OF THE  
2009 EDITION OF THE INTERNATIONAL FIRE CODE (IFC)  
WITH AMENDMENTS INTO THE 2010 CALIFORNIA FIRE CODE (CFC)  
CALIFORNIA CODE OF REGULATIONS TITLE 24, PART 9**

---

The Office of the State Fire Marshal (SFM) proposes to adopt the 2009 edition of the International Fire Code (IFC) into the 2010 edition of the California Fire Code (CFC). SFM further proposes to:

- Repeal the adoption by reference of the 2006 International Fire Code and incorporate and adopt by reference in its place the 2009 International Fire Code for application and effectiveness in the 2010 California Fire Code.
  - Repeal certain amendments to the 2006 International Fire Code and/or California Building Standards not addressed by the model code that are no longer necessary.
  - Adopt new building standards or necessary amendments to the 2009 International Fire Code that address inadequacies of the 2009 International Fire Code as they pertain to California laws.
  - Bring forward previously existing California building standards or amendments, which represent no change in their effect from the 2007 California Building Standards Code.
  - Codify non-substantive editorial and formatting amendments from the format based upon the 2006 International Fire Code to the format of the 2009 International Fire Code.
- 

**Legend for Express Terms:**

1. **Existing California regulations or amendments brought forward with modification:** *All such language appears in Italics, modified language is underlined.*
  2. **IFC language with new California amendment:** IFC language is shown in normal Arial 9-point. California amendments to IFC text appear *underlined and in italics*.
  3. **New California regulation or amendment:** *California language appears underlined and in Italics*.
  4. **Repealed Text:** Shown as ~~*Strikeout*~~.
  5. **Existing California amendments brought forward that remove IFC language:** Shown as ~~*Strikeout*~~.
  6. **New California amendments that remove IFC language:** Shown as ~~*Strikeout*~~.
  7. **Notation:** Authority and Reference citations are provided at the end of each chapter.
-

---

[1. The SFM proposes to adopt specific Sections of Chapter 1, Division I with the following amendments and California regulations, adopt only those Sections listed the corresponding Matrix Adoption Table.]

~~(CALIFORNIA) CHAPTER 1~~  
**CALIFORNIA GENERAL CODE PROVISIONS**

CHAPTER 1

**DIVISION I**  
**CALIFORNIA ADMINISTRATION**

**SECTION 10.1**  
**GENERAL**

**401-41.1.1 Title.** *These regulations shall be known as the California Fire Code, may be cited as such and will be referred to herein as “this code.” The California Fire Code is Part 9 of twelve parts of the official compilation and publication of the adoptions, amendment, and repeal of building regulations to the California Code of Regulations, Title 24, also referred to as the California Building Standards Code. This part incorporates by adoption the ~~2006-2009~~ International Fire Code of the International Code Council with necessary California amendments.*

**401-21.1.2 Purpose.** *The purpose of this code is to establish the minimum requirements consistent with nationally recognized good practices to safeguard the public health, safety and general welfare from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures, and premises, and to provide safety and assistance to fire fighters and emergency responders during emergency operations.*

**401-31.1.3 Scope.** *The provisions of this code shall apply to the construction, alteration, movement, enlargement, replacement, repair, equipment, use and occupancy, location, maintenance, removal and demolition of every building or structure or any appurtenances connected or attached to such building structures throughout the State of California.*

*This code establishes regulations affecting or relating to buildings, structures, processes, premises and a reasonable degree of life and property safeguards regarding:*

- 1. The hazard of fire and explosion arising from the storage, handling or use of structures, materials or devices;*
- 2. Conditions hazardous to life, property or public welfare in the use of, occupancy of buildings, structures, or premises;*
- 3. Fire hazards in the buildings, structures, or on premises from use of, occupancy of, or operation;*
- 4. Matters related to the construction, extension, repair, alteration or removal of fire suppression or alarm systems,*
- 5. Conditions affecting the safety of fire fighters and emergency responders during emergency operations.*

**401-3-11.1.3.1 Nonstate-regulated buildings, structures and applications.** *Except as modified by local ordinance pursuant to Section ~~404-81.1.8~~, the following standards in the California Code of Regulations, Title 24, Parts 2, 3, 4, 5, 6, 9, 10 and 4011 shall apply to all occupancies and applications not regulated by a state agency.*

**401-3-21.1.3.2 State-regulated buildings, structures and applications.** *The model code, state amendments to the model code, and/or state amendments where there are no relevant model code provisions shall apply to the following buildings, structures, and applications regulated by state agencies as referenced in the Matrix Adoption Tables and as specified in Sections ~~4021.2~~ through ~~441.14~~, except where modified by local ordinance pursuant to Section ~~404-81.1.8~~. When adopted by a state agency, the provisions of this code shall be enforced by the appropriate enforcing agency, but only to the extent of authority granted to such agency by the state legislature.*

**Note:** See Preface to distinguish the model code provisions from the California provisions.

1. State-owned buildings, including buildings constructed by the Trustees of the California State University, and to the extent permitted by California laws, buildings designed and constructed by the Regents of the University of California, and regulated by the Building Standards Commission. See Section ~~402~~1.2 for additional scope provisions.
2. Local detention facilities regulated by the Corrections Standards Authority. See Section ~~403~~1.3 for additional scope provisions.
3. Barbering, cosmetology or electrolysis establishments, acupuncture offices, pharmacies, veterinary facilities and structural pest control locations regulated by the Department of Consumer Affairs. See Section ~~404~~1.4 for additional scope provisions.
4. Energy efficiency standards regulated by the California Energy Commission. See Section ~~405~~1.5 for additional scope provisions.
5. Dairies and places of meat inspection regulated by the Department of Food and Agriculture. See Section ~~406~~1.6 for additional scope provisions.
6. Organized camps, laboratory animal quarters, public swimming pools, radiation protection, commissaries serving mobile food preparation vehicles and wild animal quarantine facilities regulated by the Department of Public Health ~~Services~~. See Section ~~407~~1.7 for additional scope provisions.
7. Hotels, motels, lodging houses, apartment houses, dwellings, dormitories, condominiums, shelters for homeless persons, congregate residences, employee housing, factory-built housing and other types of dwellings containing sleeping accommodations with or without common toilets or cooking facilities. See Section ~~408-2-1-1.8.2.1.1~~ for additional scope provisions.
8. Accommodations for persons with disabilities in buildings containing newly constructed covered multifamily dwellings, new common use spaces serving existing covered multifamily dwellings, additions to existing buildings where the addition alone meets the definition of a ~~covered multifamily dwelling~~, "COVERED MULTIFAMILY DWELLING," and common-use spaces serving covered multifamily dwellings which are regulated by the Department of Housing and Community Development. See Section ~~408-3-1-21.8.2.1.2~~ for additional scope provisions.
9. Permanent buildings and permanent accessory buildings or structures constructed within mobilehome parks and special occupancy parks regulated by the Department of Housing and Community Development. See Section ~~408-2-1-31.8.2.1.3~~ for additional scope provisions.
10. Accommodations for persons with disabilities regulated by the Division of the State Architect. See Section ~~409-11.9.1~~ for additional scope provisions.
11. Public elementary and secondary schools, community college buildings and state-owned or state-leased essential service buildings regulated by the Division of the State Architect. See Section ~~409-21.9.2~~ for additional scope provisions.
12. Qualified historical buildings and structures and their associated sites regulated by the State Historical Building Safety Board with the Division of the State Architect. See Section ~~409-31.9.3~~ for additional scope provisions.
13. General acute care hospitals, acute psychiatric hospitals, skilled nursing and/or intermediate care facilities, clinics licensed by the Department of Public Health and correctional treatment centers regulated by the Office of Statewide Health Planning and Development. See Section ~~440~~1.10 for additional scope provisions.
14. Applications regulated by the Office of the State Fire Marshal include, but are not limited to, the following in accordance with Section ~~441.11~~:
  - 14.1. Buildings or structures used or intended for use as an:
    - 14.1-1. Asylum, jail, prison.
    - 14.1-2. Mental hospital, hospital, home for the elderly, children's nursery, children's home or institution, school or any similar occupancy of any capacity.
    - 14.1-3. Theater, dancehall, skating rink, auditorium, assembly hall, meeting hall, nightclub, fair building or similar place of assemblage where 50 or more persons may gather together in a building, room or structure for the purpose of amusement, entertainment, instruction, deliberation, worship, drinking or dining, awaiting transportation, or education.
    - 14.1-4. Small family day care homes, large family day care homes, residential facilities and residential facilities for the elderly, residential care facilities.
    - 14.1-5. State institutions or other state-owned or state-occupied buildings.
    - 14.1-6. High rise structures.
    - 14.1-7. Motion picture production studios.
    - 14.1-8. Organized camps.

- 14.1.9. Residential structures.
- 14.2. Tents, awnings or other fabric enclosures used in connection with any occupancy.
- 14.3. Fire alarm devices, equipment and systems in connection with any occupancy .
- 14.4. Hazardous materials, flammable and combustible liquids.
- 14.5. Public school automatic fire detection, alarm and sprinkler systems.
- 14.6. Wildland-urban interface fire areas.
- 15. Public libraries constructed and renovated using funds from the California Library Construction and Renovation Bond Act of 1988 and regulated by the State Librarian. See Section ~~442~~1.12 for additional scope provisions.
- 16. Graywater systems regulated by the Department of Water Resources. See Section ~~443~~1.13 for additional scope provisions.
- 17. For applications listed in Section ~~409.11.9.1~~ regulated by the Division of the State Architect—Access Compliance, outdoor environments and uses shall be classified according to accessibility uses described in Chapters 11A, 11B and 11C.
- 18. Marine Oil Terminals regulated by the California State Lands Commission. See Section ~~444~~1.14 for additional scope provisions.

**401-41.1.4 Appendices.** Provisions contained in the appendices of this code shall not apply unless specifically adopted by a state agency or adopted by a local enforcing agency in compliance with Health and Safety Code Section ~~48938 (b)~~ 18901 et. seq. for Building Standards Law, Health and Safety Code Section 17950 for State Housing Law and Health and Safety Code Section 13869.7 for Fire Protection Districts. See Section ~~448~~1.1.8 of this code.

**401-51.1.5 Referenced codes.** The codes, standards and publications adopted and set forth in this code, including other codes, standards and publications referred to therein are, by title and date of publication, hereby adopted as standard reference documents of this code. When this code does not specifically cover any subject related to building design and construction, recognized architectural or engineering practices shall be employed. The National Fire Codes, standards, and the Fire Protection Handbook of the National Fire Protection Association are permitted to be used as authoritative guides in determining recognized fire prevention engineering practices.

**401-61.1.6 Nonbuilding standards, orders and regulations.** Requirements contained in the International Fire Code, or in any other referenced standard, code or document, which are not building standards as defined in Health and Safety Code Section 18909, shall not be construed as part of the provisions of this code. For nonbuilding standards, orders and regulations, see other titles of the California Code of Regulations.

**401-71.1.7 Order of precedence and use.**

**401-7.11.1.7.1 Differences.** In the event of any differences between these building standards and the standard reference documents, the text of these building standards shall govern.

**401-7.21.1.7.2 Specific provisions.** Where a specific provision varies from a general provision, the specific provision shall apply.

**401-7.31.1.7.3 Conflicts.** When the requirements of this code conflict with the requirements of any other part of the California Building Standards Code, Title 24, the most restrictive requirements shall prevail.

**401-81.1.8 City, county or city and county amendments, additions or deletions.** The provisions of this code do not limit the authority of city, county or city and county governments to establish more restrictive and reasonably necessary differences to the provisions contained in this code pursuant to complying with Section ~~401-8-11.1.8.1~~. The effective date of amendments, additions or deletions to this code of ~~cities, counties or city and counties~~ a city, county or a city and county filed pursuant to Section ~~401-8-11.1.8.1~~ shall be the date filed. However, in no case shall the amendments, additions or deletions to this code be effective any sooner than the effective date of this code.

Local modifications shall comply with Health and Safety Code Section 18941.5 for Building Standards Law, Health and Safety Code Section 17958 for State Housing Law or Health and Safety Code Section 13869.7 for Fire Protection Districts.

**401.8.11.1.8.1 Findings and filings.**

1. The city, county or city and county shall make express findings for each amendment, addition or deletion based upon climatic, topographical or geological conditions.

**Exception:** Hazardous building ordinances and programs mitigating unreinforced masonry buildings.

2. The city, county or city and county shall file the amendments, additions or deletions expressly marked and identified as to the applicable findings. Cities, counties, cities and counties, and fire departments shall file the amendments, additions or deletions, and the findings with the California Building Standards Commission at 2525 Natomas Park Drive, Suite 130, Sacramento, CA 95833.
3. Findings prepared by fire protection districts shall be ratified by the local city, county or city and county and filed with the California Department of Housing and Community Development, Division of Codes and Standards, P.O. Box 1407, Sacramento, CA 95812-1407 or at 1800 3rd Street, Room 260, Sacramento, CA 9581495811.

**401.91.1.9 Effective date of this code.** Only those standards approved by the California Building Standards Commission that are effective at the time an application for building permit is submitted shall apply to the plans and specifications for, and to the construction performed under, that permit. For the effective dates of the provisions contained in this code, see the History Note page of this code.

**401.401.1.10 Availability of codes.** At least one ~~entire~~complete copy each of Titles 8, 19, 20, 24 and 25 with all revisions shall be maintained in the office of the building official responsible for the administration and enforcement of this code. Each state department concerned and each city, county or city and county shall have an up-to-date copy of the code available for public inspection. See Health and Safety Code Section 18942(d)(1) and (2).

**401.441.1.11 Format.** This part fundamentally adopts the International Fire Code by reference on a chapter-by-chapter basis. Such adoption is reflected in the Matrix Adoption Table of each chapter of this part. When the Matrix Adoption Tables make no reference to a specific chapter of the International Fire Code such chapter of the International Fire Code is not adopted as a portion of this code.

**401.421.1.12 Validity.** If any chapter, section, subsection, sentence, clause or phrase of this code is for any reason held to be unconstitutional, contrary to statute, exceeding the authority of the state as stipulated by statutes or otherwise inoperative, such decision shall not affect the validity of the remaining portion of this code.

**Notation:**

Authority: Health and Safety Code Sections 13108, 13143, 17921, 18949.2

References: Health and Safety Code Sections 13143, 18949.2

---

[1.1. The SFM is proposing to maintain the adoption of those existing California provisions contained Sections 1.11 through 1.11.10 as shown below with modification.]

**SECTION 441.11**  
**OFFICE OF THE STATE FIRE MARSHAL**

**441.11.11.1 SFM—Office of the State Fire Marshal.** Specific scope of application of the agency responsible for enforcement, the enforcement agency and the specific authority to adopt and enforce such provisions of this code, unless otherwise stated.

**Application:**

**Institutional, educational or any similar occupancy.** Any building or structure used or intended for use as an asylum, jail, mental hospital, hospital, sanitarium, home for the aged, children's nursery, children's home, school or any similar occupancy of any capacity.

**Authority cited—Health and Safety Code Section 13143.**

**Reference—Health and Safety Code Section 13143.**

**Assembly or similar place of assemblage.** Any theater, dancehall, skating rink, auditorium, assembly hall, meeting hall, nightclub, fair building or similar place of assemblage where 50 or more persons may gather together in a building, room or structure for the purpose of amusement, entertainment, instruction, deliberation, worship, drinking or dining, awaiting transportation, or education.

**Authority cited—Health and Safety Code Section 13143.**

**Reference—Health and Safety Code Section 13143.**

**Small family day care homes.**

**Authority cited—Health and Safety Code Sections 1597.45, 1597.54, 13143 and 17921.**

**Reference - Health and Safety Code Section 13143.**

**Large family day care homes.**

**Authority cited—Health and Safety Code Sections 1597.46, 1597.54 and 17921.**

**Reference - Health and Safety Code Section 13143.**

**Residential facilities and residential facilities for the elderly.**

**Authority cited—Health and Safety Code Section 13133.**

**Reference—Health and Safety Code Section 13143.**

**Any state institution or other state-owned or state-occupied building.**

**Authority cited—Health and Safety Code Section 13108.**

**Reference—Health and Safety Code Section 13143.**

**High-rise structures.**

**Authority cited—Health and Safety Code Section 13211.**

**Reference—Health and Safety Code Section 13143.**

**Motion picture production studios.**

**Authority cited—Health and Safety Code Section 13143.1.**

**Reference—Health and Safety Code Section 13143.**

**Organized camps.**

**Authority cited—Health and Safety Code Section 18897.3.**

**Reference—Health and Safety Code Section 13143.**

**Residential.** All hotels, motels, lodging houses, apartment houses and dwellings, including congregate residences and buildings and structures accessory thereto. Multiple-story structures existing on January 1, 1975, let for human habitation, including and limited to, hotels, motels and apartment houses, less than 75 feet (22 860 mm) above the lowest floor level having building access, wherein rooms used for sleeping are let above the ground floor.

**Authority cited—Health and Safety Code Sections 13143.2 and 17921.**

**Reference**—Health and Safety Code Section 13143.

**Residential care facilities.** Certified family care homes, out-of-home placement facilities, halfway houses, drug and/or alcohol rehabilitation facilities and any building or structure used or intended for use as a home or institution for the housing of any person of any age when such person is referred to or placed within such home or institution for protective social care and supervision services by any governmental agency.

**Authority cited**—Health and Safety Code Section 13143.6.

**Reference**—Health and Safety Code Section 13143.

**Tents, awnings or other fabric enclosures used in connection with any occupancy.**

**Authority cited**—Health and Safety Code Section 13116.

**Reference**—Health and Safety Code Section 13143.

**Enforcing agency**—Pursuant to Section 13146, Health and Safety Code.

**Fire alarm devices, equipment and systems in connection with any occupancy.**

**Authority cited**—Health and Safety Code Section 13114.

**Reference**—Health and Safety Code Section 13143.

**Hazardous materials.**

**Authority cited**—Health and Safety Code Section 13143.9.

**Reference**—Health and Safety Code Section 13143.

**Flammable and combustible liquids.**

**Authority cited**—Health and Safety Code Section 13143.6.

**Reference**—Health and Safety Code Section 13143.

**Public School Automatic Fire Detection, Alarm and Sprinkler Systems.**

**Authority cited**—Health and Safety Code Section 13143 and California Education Code Article 7.5, Sections 17074.50, 17074.52 and 17074.54.

**Reference**—Government Code Section 11152.5, Health and Safety Code Section 13143 and California Education Code Chapter 12.5, Leroy F. Greene School Facilities Act of 1998, Article 1.

**Wildland-Urban Interface Fire Area.**

**Authority cited**—Health and Safety Code Sections 13143, 13108.5(a) and 18949.2(b) and (c) and Government Code Section 51189.

**Reference**—Health and Safety Code Sections 13143, Government Code Sections 51176, 51177, 51178 and 51179 and Public Resources Code Sections 4201 through 4204.

**411.21.11.2 Duties and powers of the enforcing agency.**

**411.2.11.11.2.1 Enforcement.**

**411.2.1.11.11.2.1.1** The responsibility for enforcement of building standards adopted by the State Fire Marshal and published in the California Building Standards Code relating to fire and panic safety and other regulations of the Office of the State Fire Marshal shall except as provided in Section 1.11.2.1.2 be as follows:

1. The city, county or city and county with jurisdiction in the area affected by the standard or regulation shall delegate the enforcement of the building standards relating to fire and panic safety and other regulations of the State Fire Marshal as they relate to Group R, ~~Division 3 dwellings~~ R-3 occupancies, as described in

Section 310.1 of Part 2 of the California Building Standards Code, to either of the following:

- 1.1. The chief of the fire authority of the city, county or city and county, or an authorized representative.
- 1.2. The chief building official of the city, county or city and county, or an authorized representative.
2. The chief of any city or county fire department or of any fire protection district, and authorized representatives, shall enforce within the jurisdiction the building standards and other regulations of the State Fire Marshal, except those described in Item 1 or 4.
3. The State Fire Marshal shall have authority to enforce the building standards and other regulations of the State Fire Marshal in areas outside of corporate cities and districts providing fire protection services.
4. The State Fire Marshal shall have authority to enforce the building standards and other regulations of the State Fire Marshal in corporate cities and districts providing fire protection services on request of the chief fire official or the governing body.
5. Any fee charged pursuant to the enforcement authority of this section shall not exceed the estimated reasonable cost of providing the service for which the fee is charged pursuant to Section 66014 of the Government Code.

~~441.2.1.21.11.2.1.2~~ Pursuant to Health and Safety Code Section 13108, and except as otherwise provided in this section, building standards adopted by the State Fire Marshal published in the California Building Standards Code relating to fire and panic safety shall be enforced by the State Fire Marshal in all state-owned buildings, state-occupied buildings, and state institutions throughout the state. ~~Upon~~ Upon the written request of the chief fire official of any city, county or fire protection district, the State Fire Marshal may authorize such chief fire official and his or her authorized representatives, in their geographical area of responsibility, to make fire prevention inspections of state-owned or state-occupied buildings, other than state institutions, for the purpose of enforcing the regulations relating to fire and panic safety adopted by the State Fire Marshal pursuant to this section and building standards relating to fire and panic safety published in the California Building Standards Code. Authorization from the State Fire Marshal shall be limited to those fire departments or fire districts which maintain a fire prevention bureau staffed by paid personnel.

Pursuant to Health and Safety Code Section 13108, any requirement or order made by any chief fire official who is authorized by the State Fire Marshal to make fire prevention inspections of state-owned or state-occupied buildings, other than state institutions, may be appealed to the State Fire Marshal. The State Fire Marshal shall, upon receiving an appeal and subject to the provisions of Chapter 5 (commencing with Section 18945) of Part 2.5 of Division 13 of the Health and Safety Code, determine if the requirement or order made is reasonably consistent with the fire and panic safety regulations adopted by the ~~Office of the~~ State Fire Marshal and building standards relating to fire and panic safety published in the California Building Code.

Any person may request a code interpretation from the State Fire Marshal relative to the intent of any regulation or provision adopted by the State Fire Marshal. When the request relates to a specific project, occupancy or building, the State Fire Marshal shall review the issue with the appropriate local enforcing agency prior to rendering such code interpretation.

~~441.2.1.31.11.2.1.3~~ Pursuant to Health and Safety Code Section 13112, any person who violates any order, rule or regulation of the State Fire Marshal is guilty of a misdemeanor punishable by a fine of not less than \$100.00 or more than \$500.00, or by imprisonment for not less than six months, or by both. A person is guilty of a separate offense each day during which he or she commits, continues or permits a violation of any provision of, or any order, rule or regulation of, the State Fire Marshal as contained in this code.

Any inspection authority who, in the exercise of his or her authority as a deputy State Fire Marshal, causes any legal complaints to be filed or any arrest to be made shall notify the State Fire Marshal immediately following such action.

**441.2.21.11.2.2 Right of entry.** The fire chief of any city, county or fire protection district, or such person's authorized representative, may enter any state institution or any other state-owned or state-occupied building for the purpose of preparing a fire suppression preplanning program or for the purpose of investigating any fire in a state-occupied building.

The State Fire Marshal, his or her deputies or salaried assistants, the chief of any city or county fire department or fire protection district and his or her authorized representatives may enter any building or premises not used for dwelling purposes at any reasonable hour for the purpose of enforcing this chapter. The owner, lessee, manager or operator of any such building or premises shall permit the State Fire Marshal, his or her deputies or salaried assistants and the chief of any city or county fire department or fire protection district and his or her authorized representatives to enter and inspect them at the time and for the purpose stated in this section.

**441.2.31.11.2.3 More restrictive fire and panic safety building standards.**

**441.2.3.11.11.2.3.1** Any fire protection district organized pursuant to Health and Safety Code Part 2.7 (commencing with Section 13800) of Division 12 may adopt building standards relating to fire and panic safety that are more stringent than those building standards adopted by the State Fire Marshal and contained in the California Building Standards Code. For these purposes, the district board shall be deemed a legislative body and the district shall be deemed a local agency. Any changes or modifications that are more stringent than the requirements published in the California Building Standards Code relating to fire and panic safety shall be subject to Section ~~401.8.4~~1.1.8.1.

**441.2.3.21.11.2.3.2** Any fire protection district that proposes to adopt an ordinance pursuant to this section shall, not less than 30 days prior to noticing a proposed ordinance for public hearing, provide a copy of that ordinance, together with the adopted findings made pursuant to Section ~~441.2.3.11.11.2.3.1~~, to the city, county or city and county where the ordinance will apply. The city, county or city and county may provide the district with written comments, which shall become part of the fire protection district's public hearing record.

**441.2.3.31.11.2.3.3** The fire protection district shall transmit the adopted ordinance to the city, county or city and county where the ordinance will apply. The legislative body of the city, county or city and county may ratify, modify or deny an adopted ordinance and transmit its determination to the district within 15 days of the determination. Any modification or denial of an adopted ordinance shall include a written statement describing the reasons for any modifications or denial. No ordinance adopted by the district shall be effective until ratification by the city, county or city and county where the ordinance will apply. Upon ratification of an adopted ordinance, the city, county or city and county shall file a copy of the findings of the district, and any findings of the city, county or city and county, together with the adopted ordinance expressly marked and identified to which each finding refers, in accordance with Section ~~401.8.4.31.1.8.1~~(3).

**441.2.41.11.2.4 Request for alternate means of protection.** Requests for approval to use an alternative material, assembly or materials, equipment, method of construction, method of installation of equipment or means of protection shall be made in writing to the enforcing agency by the owner or the owner's authorized representative and shall be accompanied by a full statement of the conditions. Sufficient evidence or proof shall be submitted to substantiate any claim that may be made regarding its conformance. The enforcing agency may require tests and the submission of a test report from an approved testing organization as set forth in Title 19, California Code of Regulation, to substantiate the equivalency of the proposed alternative means of protection.

When a request for alternate means of protection involves hazardous materials, the authority having jurisdiction may consider implementation of the findings and recommendations identified in a Risk Management Plan (RMP) developed in accordance with Title 19, Division 2, Chapter 4.5, Article 3.

Approval of a request for use of an alternative material, assembly of materials, equipment, method of construction, method of installation of equipment or means of protection made pursuant to these provisions shall be limited to the particular case covered by request and shall not be construed as establishing any precedent for any future request.

**441.2.51.11.2.5 Appeals.** When a request for an alternate means of protection has been denied by the enforcing agency, the applicant may file a written appeal to the State Fire Marshal for consideration of the applicant's proposal. In considering such appeal, the State Fire Marshal may seek the advice of the State Board of Fire Services. The State Fire Marshal shall, after considering all of the facts presented, including any recommendations of the State Board of Fire Services, determine if the proposal is for the purposes intended, at least equivalent to that specified in these regulations in quality, strength, effectiveness, fire resistance, durability and safety, and shall transmit such findings and any recommendations to the applicant and to the enforcing agency.

**441.31.11.3 Construction documents.**

**441.3.41.11.3.1 Public schools.** Plans and specifications for the construction, alteration or addition to any building owned, leased or rented by any public school district shall be submitted to the Division of the State Architect, ~~Office of Regulation Services~~ for review and approval.

~~**Exception:** Upon the annual submission of a written request by the chief of any city, county or city and county fire department or fire protection district to the Division of the State Architect, Office of Regulation Services, approvals required by this subsection shall be obtained from the appropriate chief or his or her authorized representative. In such instances plans and specifications may be submitted to the State Fire Marshal for relay to the appropriate local authority or may be submitted directly to such local authority.~~

**441.3.21.11.3.2 Movable walls and partitions.** Plans or diagrams shall be submitted to the enforcing agency for approval before the installation of, or rearrangement of, any movable wall or partition in any occupancy. Approval shall be granted only if there is no increase in the fire hazard.

**441.3.31.11.3.3 New construction high-rise buildings.**

1. Complete plans or specifications, or both, shall be prepared covering all work required to comply with new construction high-rise buildings. Such plans and specifications shall be submitted to the enforcing agency having jurisdiction.
2. All plans and specifications shall be prepared under the responsible charge of an architect or a civil or structural engineer authorized by law to develop construction plans and specifications, or by both such architect and engineer. Plans and specifications shall be prepared by an engineer duly qualified in that branch of engineering necessary to perform such services. Administration of the work of construction shall be under the charge of the responsible architect or engineer except that where plans and specifications involve alterations or repairs, such work of construction may be administered by an engineer duly qualified to perform such services and holding a valid certificate under Chapter 7 (commencing with Section 65700) of Division 3 of the Business and Professions Code for performance of services in that branch of engineering in which said plans, specifications and estimates and work of construction are applicable.

This section shall not be construed as preventing the design of fire-extinguishing systems by persons holding a C-16 license issued pursuant to Division 3, Chapter 9, Business and Professions Code. In such instances, however, the responsibility charge of this section shall prevail.

**441.3.41.11.3.4 Existing high-rise buildings.**

1. Complete plans or specifications, or both, shall be prepared covering all work required by Section 3412 for existing high-rise buildings. Such plans or specifications shall be submitted to the enforcing agency having jurisdiction.
2. When new construction is required to conform with the provisions of these regulations, complete plans or specifications, or both, shall be prepared in accordance with the provisions of this subsection. As used in this section, "new construction" is not intended to include repairs, replacements or minor alterations which do not disrupt or appreciably add to or affect the structural aspects of the building.

**441.3.51.11.3.5 Retention of plans.** Refer to Building Standards Law, Health and Safety Code Sections 19850 and 19851 for permanent retention of plans.

**441.41.11.4 Fees.**

**441.4.41.11.4.1 Other fees.** Pursuant to Health and Safety Code Section 13146.2, a city, county or district which inspects a hotel, motel, lodging house or apartment house may charge and collect a fee for the inspection from the owner of the structure in an amount, as determined by the city, county or district, sufficient to pay its costs of that inspection.

**411.4.21.11.4.2 Large family day care.** Pursuant to Health and Safety Code Section 1597.46, Large Family Day Care Homes, the local government shall process any required permit as economically as possible, and fees charged for review shall not exceed the costs of the review and permit process.

**411.4.31.11.4.3 High-rise.** Pursuant to Health and Safety Code Section 13217, High-rise Structure Inspection: Fees and costs, a local agency which inspects a high-rise structure pursuant to Health and Safety Code Section 13217 may charge and collect a fee for the inspection from the owner of the high-rise structure in an amount, as determined by the local agency, sufficient to pay its costs of that inspection.

**411.4.41.11.4.4 Fire clearance preinspection.** Pursuant to Health and Safety Code Section 13235, Fire Clearance Preinspection, fee, upon receipt of a request from a prospective licensee of a community care facility, as defined in Section 1502, of a residential care facility for the elderly, as defined in Section 1569.2, or of a child day care facility, as defined in Section 1596.750, the local fire enforcing agency, as defined in Section 13244, or State Fire Marshal, whichever has primary jurisdiction, shall conduct a preinspection of the facility prior to the final fire clearance approval. At the time of the preinspection, the primary fire enforcing agency shall price consultation and interpretation of the fire safety regulations and shall notify the prospective licensee of the facility in writing of the specific fire safety regulations which shall be enforced in order to obtain fire clearance approval. A fee of not more than \$50.00 may be charged for the preinspection of a facility with a capacity to serve 25 or fewer persons. A fee of not more than \$100.00 may be charged for a preinspection of a facility with a capacity to serve 26 or more persons.

**411.4.51.11.4.5 Care facilities.** The primary fire enforcing agency shall complete the final fire clearance inspection for a community care facility, residential care facility for the elderly, or child day care facility within 30 days of receipt of the request for the final inspection, or as of the date the prospective facility requests the final preclearance inspection by the State Department of Social Services, whichever is later.

Pursuant to Health and Safety Code Section 13235, a preinspection fee of not more than \$50.00 may be charged for a facility with a capacity to serve 25 or less clients. A fee of not more than \$100.00 may be charged for a preinspection of a facility with a capacity to serve 26 or more clients.

Pursuant to Health and Safety Code Section 13131.5, a reasonable final inspection fee, not to exceed the actual cost of inspection services necessary to complete a final inspection may be charged for occupancies classified as residential care facilities for the elderly (RCFE)

Pursuant to Health and Safety Code Section 1569.84, neither the State Fire Marshal nor any local public entity shall charge any fee for enforcing fire inspection regulations pursuant to state law or regulation or local ordinance, with respect to residential care facilities for the elderly (RCFE) which service six or fewer persons.

**411.4.61.11.4.6 Requests of the Office of the State Fire Marshal.** Whenever a local authority having jurisdiction requests that the State Fire Marshal perform plan review and/or inspection services related to a building permit, the applicable fees for such shall be payable to the Office of the State Fire Marshal.

**411.51.11.5 Inspections.** Work performed subject to the provisions of this Code shall comply with the inspection requirements contained in ~~Appendix Chapter 1~~, Section 106 as adopted by the Office of the State Fire Marshal.

**411.5.41.11.5.1 Existing Group I -1 or R occupancies.** Licensed 24-hour care in a Group I-1 or R occupancy in existence and originally classified under previously adopted state codes shall be reinspected under the appropriate previous code, provided there is no change in the use or character which would place the facility in a different occupancy group.

**411.61.11.6 Certificate of Occupancy.** A Certificate of Occupancy shall be issued as specified in Title 24, Part 2, California Building Code, ~~Appendix Chapter 1~~, Section 440111.

**411.71.11.7 Temporary Structures and Uses.** See Title 24, Part 2, California Building Code, ~~Appendix Chapter 1~~, Section 107.

**441-81.11.8 Service Utilities.** See Title 24, Part 2, California Building Code, ~~Appendix Chapter 1, Section 441112.~~

**441-91.11.9 Stop Work Order.** See Title 24, Part 2, California Building Code, ~~Appendix Chapter 1, Section 441115.~~

**441-101.11.10 Unsafe Buildings, Structures and Equipment.** See Title 24, Part 2, California Building Code, ~~Appendix Chapter 1, Section 445116.~~

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[1.2. The SFM proposes to adopt specific Sections of Chapter 1, Division II with the following amendments and California regulations, adopt only those Sections listed the corresponding Matrix Adoption Table.] (IFC Chapter 1 Administrative provisions - Sections 101 through 114 relocated to Division II of Chapter 1.)**

**DIVISION II**

**PART 1—GENERAL PROVISIONS**

**SECTION 101  
GENERAL**

**TABLE 105.6.20  
PERMIT AMOUNTS FOR HAZARDOUS MATERIALS**

<b>TYPE OF MATERIAL</b>	<b>AMOUNT</b>
Combustible liquids	See Section 105.6.16
Corrosive materials	
Gases	See Section 105.6.8
Liquids	55 gallons
Solids	<del>1000</del> 500 pounds

(Remainder of Table 105.6.20 unchanged.)

**105.6.47 Additional Permits.** *In addition to the permits required by Section 105.6, the following permits shall be obtained from the Bureau of Fire Prevention prior to engaging in the following activities, operations, practices or functions:*

- 1. Production facilities.** *To change use or occupancy, or allow the attendance of a live audience, or for wrap parties.*
- 2. Pyrotechnics and special effects.** *To use pyrotechnic special effects, open flame, use of flammable or combustible liquids and gases, welding, and the parking of motor vehicles in any building or location used for the purpose of motion picture, television and commercial production.*
- 3. Live audiences.** *To install seating arrangements for live audiences in approved production facilities, production studios and sound stages. See Chapter ~~4648~~.*

**Notation:**

Authority: Health and Safety Code Sections 13108, 13143, 13143.9, 13146, 17921, 18949.2

References: Health and Safety Code Sections 13143, 18949.2

---

[2. The SFM proposes to adopt specific Sections of Chapter 2 with the following amendments and California regulations, adopt only those Sections or Definitions listed the corresponding Matrix Adoption Table.]

**CHAPTER 2  
DEFINITIONS**

**SECTION 202  
GENERAL DEFINITIONS**

**[B] CHILD CARE FACILITIES.** Facilities that provide care on a 24-hour basis to more than ~~five-six~~ children, ~~21/2~~ years of age or less under 2 years of age.

**[B] CLINIC–OUTPATIENT.** Buildings or portions thereof used to provide medical care on less than a 24-hour basis to individuals who are not classified as non-ambulatory or bedridden or rendered incapable of self-preservation by the services provided.

**DAY-CARE HOME, FAMILY.** *A home that regularly provides care, protection, and supervision for 14 or fewer children, in the provider's own home, for periods of less than 24 hours per day, while the parents or guardians are away, and is either a large family day-care home or a small family day-care home.*

**[B] DETOXIFICATION FACILITIES.** Facilities that serve patients who are provided treatment for substance abuse on a 24-hour basis and who are incapable of self-preservation or classified as non-ambulatory or bedridden or who are harmful to themselves or others.

**[B] HOSPITALS AND MENTAL HOSPITALS.** Buildings or portions thereof used on a 24-hour basis for the medical, psychiatric, obstetrical or surgical treatment of inpatients who are incapable of self-preservation or classified as non-ambulatory or bedridden.

***INFANT,*** for the purpose of these regulations, shall mean any child who because of age only, is unable to walk and requires the aid of another person to evacuate the building. In no case shall the term “infant” mean a child ~~beyond two~~ years of age 2 years of age or older.

**[B] NURSING HOMES** .Nursing homes are long-term care facilities on a 24-hour basis, including both intermediate care facilities and skilled nursing facilities, serving more than ~~five-six~~ persons and any of the persons are incapable of self-preservation or classified as non-ambulatory or bedridden.

**OCCUPANCY CLASSIFICATION**

**Assembly Group A.** Assembly Group A occupancy includes, among others, the use of a building or structure, or a portion thereof, for the gathering of persons for purposes such as civic, social or religious functions; recreation, food or drink consumption; or awaiting transportation *or Motion Picture and Television Production Studio Sound Stages, Approved Production Facilities and production locations.*

**Exceptions:**

1. A building or tenant space used for assembly purposes with an occupant load of less than 50 persons shall be classified as a Group B occupancy.
2. A room or space used for assembly purposes with an occupant load of less than 50 persons and accessory to another occupancy shall be classified as a Group B occupancy or as part of that occupancy.
3. A room or space used for assembly purposes that is less than 750 square feet (70m<sup>2</sup>) in area and accessory to another occupancy shall be classified as a Group B occupancy or as part of that occupancy.
4. Assembly areas that are accessory to Group E occupancies are not considered separate occupancies except when applying the assembly occupancy requirements of Chapter 11 of the ~~International~~ California Building Code.

5. Accessory religious educational rooms and religious auditoriums with *occupant loads* of less than 100 are not considered separate occupancies.

Assembly occupancies shall include the following:

**A-1** Assembly uses, usually with fixed seating, intended for the production and viewing of the performing arts or motion pictures including, but not limited to:

*Motion picture and television production studio Sound Stages, Approved Production Facilities and production locations. (With live audiences).*

Motion picture theaters  
Symphony and concert halls  
Television and radio studios admitting an audience  
Theaters

**A-2** Assembly uses intended for food and/or drink consumption including, but not limited to:

Banquet halls  
Night clubs  
Restaurants  
Taverns and bars

**A-3** Assembly uses intended for worship, recreation or amusement and other assembly uses not classified elsewhere in Group A including, but not limited to:

Amusement arcades  
Art galleries  
Bowling alleys  
Places of religious worship  
Community halls  
Courtrooms  
Dance halls (not including food or drink consumption)  
Exhibition halls  
Funeral parlors  
Gymnasiums (without spectator seating)  
Indoor swimming pools (without spectator seating)  
Indoor tennis courts (without spectator seating)  
Lecture halls  
Libraries  
Museums  
Waiting areas in transportation terminals  
Pool and billiard parlors

**A-4** Assembly uses intended for viewing of indoor sporting events and activities with spectator seating including, but not limited to:

Arenas  
Skating rinks  
Swimming pools  
Tennis courts

**A-5** Assembly uses intended for participation in or viewing outdoor activities including, but not limited to:

Amusement park structures  
Bleachers  
Grandstands

## Stadiums

**Business Group B.** Business Group B occupancy includes, among others, the use of a building or structure, or a portion thereof, for office, professional or service-type transactions, including storage of records and accounts. Business occupancies shall include, but not be limited to, the following:

- Airport traffic control towers
- Ambulatory health care facilities servicing five or fewer patients (see Group I-2.1 or Section 308.3.2 California Building Code for facilities servicing more than five patients)
- Animal hospitals, kennels and pounds
- Banks
- Barber and beauty shops
- Car wash
- Civic administration
- Clinic—outpatient ~~{SFM} (not classified as Group I-2.1)~~
- Dry cleaning and laundries: pick-up and delivery stations and self-service
- Educational occupancies for students above the 12th grade
- Electronic data processing
- Laboratories: testing, ~~and~~ research ~~and {SFM} instruction.~~
- Motor vehicle showrooms
- Post offices
- Print shops
- Professional services (architects, attorneys, dentists, physicians, engineers, etc.)
- Radio and television stations
- Telephone exchanges
- Training and skill development not within a school or academic program

**Group C (CAMPS, ORGANIZED).** . An organized camp is a site with programs and facilities established for the primary purpose of providing an outdoor group living experience with social, spiritual, educational or recreational objectives, for five days or more during one or more seasons of the year.

**Educational Group E.** Educational Group E occupancy includes, among others, the use of a building or structure, or a portion thereof, by ~~six or more~~ *than six* persons at any one time for educational purposes through the 12th grade. Religious educational rooms and religious auditoriums, which are accessory to churches in accordance with Section 508.3.1 of the ~~International~~ California Building Code and have occupant loads of less than 100, shall be classified as A-3 occupancies.

**Exception:** A residence used as a home school for the children who normally reside at the residence. Such residences shall remain classified as Group R-2, or Group R-3 Occupancies.

**Day care.** The use of a building or structure, or portion thereof, for educational, supervision or personal care services for more than ~~five~~ *six* children ~~older than~~ *2 1/2* years of age and older, shall be classified as a Group E occupancy.

**Exception:** A Daycare facility not otherwise classified as an R-3 Occupancy, where occupants are not capable of responding to an emergency situation without physical assistance from the staff shall be classified as Group I-4.

### **Factory Industrial F-1 Moderate-hazard Occupancy.**

Factory industrial uses which are not classified as Factory Industrial F-2 Low Hazard shall be classified as F-1 Moderate Hazard and shall include, but not be limited to, the following:

- Aircraft (manufacturing, not to include repair)
- Appliances
- Athletic equipment
- Automobiles and other motor vehicles

Bakeries  
 Beverages; over 12-percent alcohol content  
 Bicycles  
 Boats  
 Brooms or brushes  
 Business machines  
 Cameras and photo equipment  
 Canvas or similar fabric  
 Carpets and rugs (includes cleaning)  
 Construction and agricultural machinery  
 Disinfectants  
 Dry cleaning and dyeing  
 Electric generation plants  
 Electronics  
 Engines (including rebuilding)  
 Food processing  
 Furniture  
 Hemp products  
 Jute products  
 Laundries  
 Leather products  
 Machinery  
 Metals  
 Millwork (sash & door)  
*Motion picture and television production studio Sound Stages, Approved Production Facilities and production locations (without live audiences)*  
~~Motion pictures and television filming (without spectators)~~  
 Musical instruments  
 Optical goods  
 Paper mills or products  
 Photographic film  
 Plastic products  
 Printing or publishing  
 Recreational vehicles  
 Refuse incineration  
 Shoes  
 Soaps and detergents  
 Textiles  
 Tobacco  
 Trailers  
 Upholstering  
 Wood; distillation  
 Woodworking (cabinet)

**High-hazard Group H.** High-hazard Group H occupancy includes, among others, the use of a building or structure, or a portion thereof, that involves the manufacturing, processing, generation or storage of materials that constitute a physical or health hazard in quantities in excess of those allowed in control areas complying with Section 2703.8.3, based on the maximum allowable quantity limits for control areas set forth in Tables 2703.1.1(1) and 2703.1.1(2). Hazardous occupancies are classified in Groups H-1, H-2, H-3, H-4 and H-5 and shall be in accordance with this code and the requirements of Section 415 of the ~~International~~ *California Building Code*. Hazardous materials stored or used on top of roofs or canopies shall be classified as outdoor storage or use and shall comply with this code.

**Exceptions:** The following shall not be classified as Group H, but shall be classified as the occupancy that they most nearly resemble.

1. Buildings and structures occupied for the application of flammable finishes, provided that such buildings or areas conform to the requirements of Chapter 15 of this code and Section 416 of the International California Building Code.
  2. Wholesale and retail sales and storage of flammable and combustible liquids in mercantile occupancies conforming to Chapter 34.
  3. Closed piping system containing flammable or combustible liquids or gases utilized for the operation of machinery or equipment.
  4. Cleaning establishments that utilize combustible liquid solvents having a flash point of 140°F (60°C) or higher. In closed systems employing equipment listed by an approved testing agency, provided that this occupancy is separated from all other areas of the building by 1-hour fire barriers or 1-hour horizontal assemblies, or both.
  5. Cleaning establishments that utilize a liquid solvent having a flash point at or above 200°F (93°C).
  6. Liquor stores and distributors without bulk storage.
  7. Refrigeration systems.
  8. The storage or utilization of materials for agricultural purposes on the premises.
  9. Stationary batteries utilized for facility emergency power, uninterrupted power supply or telecommunication facilities, provided that the batteries are equipped with safety venting caps and ventilation is provided in accordance with the International California Mechanical Code.
  10. Corrosives shall not include personal or household products in their original packaging used in retail display or commonly used building materials.
  11. Buildings and structures occupied for aerosol storage shall be classified as Group S-1, provided that such buildings conform to the requirements of Chapter 28.
  12. Display and storage of nonflammable solid and nonflammable or noncombustible liquid hazardous materials in quantities not exceeding the maximum allowable quantity per control area in Group M or S occupancies complying with Section 2703.8.3.5.
  13. The storage of black powder, smokeless propellant and small arms primers in Groups M and R-3 and special industrial explosive devices in Groups B, F, M and S, provided such storage conforms to the quantity limits and requirements of this code.
- ~~14.~~ [SFM] Group L occupancies as defined in section 443.1.

**Institutional Group I.** Institutional Group I occupancy includes, among others, the use of a building or structure, or a portion thereof, in which people are cared for or live in a supervised environment, having physical limitations because of health or age are harbored for medical treatment or other care or treatment, or in which people are detained for penal or correctional purposes or in which the liberty of the occupants is restricted. Institutional occupancies shall be classified as Group I-1, I-2, I-3 or I-4. *Restraint shall not be permitted in any building except in Group I-3 occupancies constructed for such use. See California Building Code Section ~~308.4~~ 408.1.1.*

*Where occupancies house both ambulatory and non-ambulatory persons, the more restrictive requirements shall apply.*

**Group I-1.** *Not used. (See Group R-2.1 or Section 310.1 California Building Code)* ~~This occupancy shall include buildings, structures or parts thereof housing clients, on a 24-hour basis, who because of age, mental disability or other reasons, live in a supervised residential environment that provides personal care services.~~

~~This occupancy may contain more than six non-ambulatory and/or bedridden clients. (See Section 425 Special Provisions For Licensed 24 Hour Care Facilities in a Group I-1, R-3.1, or R-4 Occupancy). This group shall include, but not be limited to, the following:~~

- ~~Alcohol and drug centers~~
- ~~Assisted living facilities~~
- ~~Congregate care facilities~~
- ~~Convalescent facilities~~
- ~~Group homes~~
- ~~Halfway houses~~
- ~~Residential board and care facilities~~
- ~~Social rehabilitation facilities~~
- ~~Assisted living facilities such as:~~

~~Residential Care Facilities,  
Residential Care Facilities for the Elderly (RCFE's),  
Adult Residential Facilities,  
Congregate Living Health facilities,  
Group homes,  
Residential Care Facilities for the Chronically III,  
Congregate Living Health Facilities for the Terminally III.~~

~~Social rehabilitation facilities such as:  
Halfway houses,  
Community Correctional Centers,  
Community Correction Reentry Centers,  
Community Treatment Programs,  
Work Furlough Programs,  
Alcoholism or drug abuse recovery or treatment facilities.~~

~~A facility such as the above with five or fewer persons shall be classified as a Group R-3 or shall comply with the International Residential Code in accordance with Section 101.2. A facility such as above, housing at least six and not more than 16 persons, shall be classified as Group R-4.~~

**Group I-2.** This occupancy shall include buildings and structures used for medical, surgical, psychiatric, nursing or custodial care for persons who are not capable of self-preservation or classified as non-ambulatory or bedridden. This group shall include, but not be limited to, the following:

- Child care facilities
- Detoxification facilities
- Hospitals
- Mental hospitals
- Nursing homes

~~A facility such as the above with five or fewer persons shall be classified as Group R-3 or shall comply with the International Residential Code in accordance with Section 101.2.~~

**Group I-2.1 Ambulatory Health Care Facility.** *A Healthcare facility that receives persons for outpatient medical care that may render the patient incapable of unassisted self-preservation and where each tenant space accommodates more than five such patients.*

**Group I-3.** This occupancy shall include buildings *or portions of buildings* and structures that are inhabited by ~~more than five~~ *one or more* persons who are under restraint ~~or security~~. An I-3 facility is occupied by persons who are generally incapable of self-preservation ~~due to security measures not under the occupants' control~~ *restrained*. This group shall include, but not be limited to, the following:

- Correctional centers
- Detention centers
- Jails
- ~~Prerelease centers~~
- Prisons
- Reformatories
- Juvenile Halls

Buildings of Group I-3 shall be classified as one of the occupancy conditions indicated below:

**Condition 1.** This occupancy condition shall include buildings in which free movement is allowed from sleeping areas, and other spaces where access or occupancy is permitted, to the exterior via means of egress without restraint. A Condition 1 facility is permitted to be constructed as Group R.

**Condition 2.** This occupancy condition shall include buildings in which free movement is allowed from sleeping areas and any other occupied smoke compartment to one or more other smoke compartments. Egress to the exterior is impeded by locked exits.

**Condition 3.** This occupancy condition shall include buildings in which free movement is allowed within individual smoke compartments, such as within a residential unit comprised of individual sleeping units and group activity spaces, where egress is impeded by remote-controlled release of means of egress from such a smoke compartment to another smoke compartment.

**Condition 4.** This occupancy condition shall include buildings in which free movement is restricted from an occupied space. Remote-controlled release is provided to permit movement from sleeping units, activity spaces and other occupied areas within the smoke compartment to other smoke compartments.

**Condition 5.** This occupancy condition shall include buildings in which free movement is restricted from an occupied space. Staff-controlled manual release is provided to permit movement from sleeping units, activity spaces and other occupied areas within the smoke compartment to other smoke compartments.

**Group I-4, day care facilities.** This group shall include buildings and structures occupied by persons of any age who receive custodial care for less than 24 hours by individuals other than parents or guardians, relatives by blood, marriage or adoption and in a place other than the home of the person cared for. A facility such as the above with five six or fewer ~~persons~~clients shall be classified as a Group R-3 or shall comply with the ~~International California Residential Code in accordance with Section 101.2.~~ International California Residential Code in accordance with Section 101.2. Places of worship during religious functions are not included.

**Adult day care facility.** A facility that provides accommodations for less than 24 hours for more than ~~five-six~~ unrelated adults and provides supervision and personal care services shall be classified as Group I-4.

**Exception:** A facility where occupants are capable of responding to an emergency situation without physical assistance from the staff shall be classified as Group A-3.

**Child day care facility.** A facility that provides supervision and personal care on less than a 24-hour basis for more than ~~five-six~~ children ~~2 1/2 years of age or less~~ under 2 years of age shall be classified as Group I-4.

**Exception:** A child day care facility which provides care for more than ~~five-six~~ but no more than 100 children ~~2 1/2 years of age or less~~ under 2 years of age, when the rooms where such children are cared for are located on the level of exit discharge and each of these child care rooms has an exit door directly to the exterior, shall be classified as Group E.

**Group L Laboratories.** [SFM] Group L occupancy includes the use of a building or structure, or a portion thereof containing one or more laboratory suites as defined in Section 443 of the California Building Code.

**Residential Group R.** Residential Group R includes, among others, the use of a building or structure, or a portion thereof, for sleeping purposes when not classified as an Institutional Group I or when not regulated by the ~~International California Residential Code in accordance with Section 101.2.~~ International California Residential Code in accordance with Section 101.2. Residential occupancies shall include the following:

**R-1 Residential Occupancies** containing sleeping units where the occupants are primarily transient in nature, including:

- Boarding houses (transient)
- Hotels (transient)
- Motels (transient)

Congregate living facilities (transient) or congregate residences (transient) with 10 or fewer occupants are permitted to comply with the construction requirements for Group R-3.

**R-2 Residential occupancies** containing sleeping units or more than two dwelling units where the occupants are

primarily permanent in nature, including:

- Apartment houses
- Boarding houses (not transient)
- Convents
- Dormitories
- Fraternities and sororities
- Hotels (non-transient)
- Live/work units
- Monasteries
- Motels (non-transient)
- Vacation timeshare properties

Congregate living facilities or congregate residences with 16 or fewer occupants are permitted to comply with the construction requirements for Group R-3.

**R-2.1 This occupancy shall include buildings, structures or parts thereof housing clients, on a 24-hour basis, who because of age, mental disability or other reasons, live in a supervised residential environment that provides personal care services.**

This occupancy may contain more than six non-ambulatory and/or bedridden clients. (See Appendix Chapter 4, Section 425 Special Provisions For Licensed 24-Hour Care Facilities in a Group R-2.1, R-3.1, or R-4 Occupancy). This group shall include, but not be limited to, the following:

Assisted living facilities such as:

- Residential Care Facilities,
- Residential Care Facilities for the Elderly (RCFE's),
- Adult Residential Facilities,
- Congregate Living Health facilities,
- Group homes,
- Residential Care Facilities for the Chronically Ill,
- Congregate Living Health Facilities for the Terminally Ill.

Social rehabilitation facilities such as:

- Halfway houses,
- Community Correctional Centers,
- Community Correction Reentry Centers,
- Community Treatment Programs,
- Work Furlough Programs,
- Alcoholism or drug abuse recovery or treatment facilities.

**R-3 Residential occupancies where the occupants are primarily permanent in nature and not classified as Group R-1, R-2, R-2.1, R-3.1, R-4 or I, including:**

Buildings that do not contain more than two dwelling units.

Adult facilities that provide accommodations for ~~five~~ six or fewer ~~persons~~ clients of any age for less than 24-hours. Licensing categories that may use this classification include, but are not limited to: Adult Day-care Facilities, Adult Day-support Center Programs.

Child care facilities that provide accommodations for ~~five~~ six or fewer ~~persons~~ clients of any age for less than 24-hours. Licensing categories that may use this classification include, but are not limited to: Family Day-care Homes, Day-care Center for Mildly Ill Children, Infant Care Center and School Age Child Day-care Center.

Family Day-care Homes that provide accommodations for 14 or fewer children, in the provider's own home for less than 24-hours.

Congregate living facilities or congregate residences with 16 or fewer persons.

Adult and child care facilities that are within a single-family home are permitted to comply with the ~~International~~

California Residential Code.

**R-3.1** This occupancy group may include facilities licensed by a governmental agency for a residentially based 24-hour care facility providing accommodations for six or fewer clients of any age. Clients may be classified as ambulatory, nonambulatory or bedridden. A Group R-3.1 occupancy shall meet the requirements for construction as defined for Group R-3, except as otherwise provided for in ~~Section 419.4~~ Appendix Chapter 4 Special Provisions For Licensed 24-Hour Care Facilities in a Group ~~1-4R-2.1~~, R-3.1 or R-4 Occupancy. This group may include:

Adult Residential Facilities

Congregate Living Health Facilities

Foster Family Homes

Group Homes

Intermediate Care Facilities for the Developmentally Disabled Habilitative

Intermediate Care Facilities for the Developmentally Disabled Nursing

Nurseries for the full-time care of children under the age of six, but not including "infants" as defined in Section 349202

Residential Care Facilities for the Elderly

Small Family Homes and Residential Care Facilities for the Chronically Ill

**Exception:** Group Homes licensed by the Department of Social Services which provide nonmedical board, room and care for six or fewer ambulatory children or children two years of age or younger, and which do not have any nonambulatory clients shall not be subject to regulations found in Section 419.4 Appendix Chapter 4, Section 425.

Pursuant to Health and Safety Code Section 13143 with respect to these exempted facilities, no city, county, or public district shall adopt or enforce any requirement for the prevention of fire or for the protection of life and property against fire and panic unless the requirement would be applicable to a structure regardless of the special occupancy. Nothing shall restrict the application of state or local housing standards to such facilities if the standards are applicable to residential occupancies and are not based on the use of the structure as a facility for ambulatory children. For the purpose of this exception, ambulatory children does not include relatives of the licensee or the licensee's spouse.

**R-4** Residential occupancies shall include buildings arranged for occupancy as residential care/assisted living facilities including more than ~~five six but not more than 16~~ ambulatory occupants clients, excluding staff.

Group R-4 occupancies shall meet the requirements for construction as defined for Group R-3, except as otherwise provided for in this code or shall comply with the ~~International~~ California Residential Code provided the building is protected by an automatic sprinkler system installed in accordance with Section 903.2.7.

This occupancy classification may include a maximum six nonambulatory or bedridden clients (see Appendix Chapter 4, Section 419.4425 Special Provisions For Licensed 24-Hour Care Facilities in a Group ~~1-4R-2.1~~, R-3.1, or R-4 Occupancy.) Group R-4 occupancies shall include the following:

Assisted living facilities such as:

Residential care facilities,

Residential Care Facilities for the Elderly (RCFE's),

Adult Residential Facilities,

Congregate Living Health facilities,

Group homes.

Social rehabilitation facilities such as:

Halfway houses,

Community Correctional Centers,

Community Correction Reentry Centers,

Community Treatment Programs,

Work Furlough Programs,

Alcoholism or drug abuse recovery or treatment facilities.

**PHOTOLUMINESCENT** (See Section 1002).

**PORTABLE BUILDING.** Portable Building is a classroom building or structure of modular design and construction that houses and or serves student, regardless of occupancy classification, from kindergarten through twelfth grade (K-12) and is funded pursuant to the Education Code, commencing with section 17070.10 and meets all of the following criteria:

- The portable building or structure is designed and constructed to be relocatable and transportable over public streets.
- The portable building or structure is designed and constructed for relocation without detaching the roof or the floor from the building or structure.
- The portable building or structure is sited upon a temporary foundation in a manner that is designed to permit easy removal.
- The portable building or structure has a floor area of 2,000 square feet or less when measured from the extent of the exterior walls.
- The portable building shall be removed within three years of installation or the school administration may request a three year extension pursuant to Education Code section 17074.54 (a) and (b).

**PORTABLE BUILDING, EXEMPTED.** A portable building as defined in Section 202 as referenced by California Education Code Section 17074.54, that is certified by the public school administration as being sited on campus for less than three years.

**PROTECTIVE SOCIAL CARE FACILITY.** ~~[SFM] Protective Social Care is the housing and care of any person of any age when such person is referred to or placed within such home or facility for care and supervision services by any governmental agency. A facility housing persons, who are referred, placed or caused to be placed in the facility, by any governmental agency and for whom the services, or a portion thereof, are paid for by any governmental agency. These occupancies shall include, but are not limited to, those commonly referred to as "assisted living facilities", "social rehabilitation facilities", "certified family care homes," "out-of-home placement facilities," and "halfway houses."~~

~~**RESIDENTIAL CARE/ASSISTED LIVING FACILITIES.** A building or part thereof housing persons, on a 24 hour basis, who because of age, mental disability or other reasons, live in a supervised residential environment which provides personal care services. The occupants are capable of responding to an emergency situation without physical assistance from staff. This classification shall include, but not be limited to, the following: residential board and care facilities, assisted living facilities, halfway houses, group homes, congregate care facilities, social rehabilitation facilities, alcohol and drug abuse centers and convalescent facilities.~~

**SELF-ILUMINOUS** (See Section 1002).

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[3. The SFM proposes to adopt specific Sections of Chapter 3 with the following amendments and California regulations, adopt only those Sections listed the corresponding Matrix Adoption Table.]**

**CHAPTER 3  
GENERAL PRECAUTIONS AGAINST FIRE**

**304.1.2 Vegetation.** Weeds, grass, vines or other growth that is capable of being ignited and endangering property, shall be cut down and removed by the *owner* or occupant of the premises. Vegetation clearance requirements in urban-wildland interface areas shall be in accordance with the ~~*International Wildland Urban Interface Code Chapter 49*~~.

~~**308.3.9-308.5 Group I, R-2.1, Group R 3.1, Group R 4 occupancies or any Licensed Care Facility**~~ A person shall not utilize or allow to be utilized, an open flame in Group I, ~~Group, R-2.1, R 3.1, Group R 4 occupancies or any Licensed Care Facilities.~~

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[4. The SFM proposes to adopt specific Sections of Chapter 4 without amendment, adopt only those Sections listed the corresponding Matrix Adoption Table.]**

**CHAPTER 4  
EMERGENCY PLANNING AND PREPAREDNESS**

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[5. The SFM proposes to adopt Chapter 5 with the following amendments and California regulations.]**

**CHAPTER 5  
FIRE SERVICE FEATURES**

**507.5 Fire hydrant systems.** Fire hydrant systems shall comply with Sections 507.5.1 through 507.5.6 and Appendix C or by an approved method.

**507.5.1 Where required.** Where a portion of the facility or building hereafter constructed or moved into or within the jurisdiction is more than 400 feet (122 m) from a hydrant on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains shall be provided where required by the fire code official.

**Exceptions:**

1. For Group R-3 and Group U occupancies, equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3, the distance requirement shall be *not more than* 600 feet (183 m).
2. For buildings equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, the distance requirement shall be 600 feet (183 m).

**508.2.1 Private fire service mains.** Private fire service mains and appurtenances shall be installed in accordance with NFPA 24 as amended in Chapter 47.

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2, Education Code Section 32020

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[6. The SFM proposes to adopt Chapter 6 with the following amendments and California regulations.]**

**CHAPTER 6  
BUILDING SERVICES AND SYSTEMS**

**603.4 Portable unvented heaters.** Portable unvented fuel fired heating equipment shall be prohibited in occupancies in Groups A, E, I, R-1, R-2, R-2.1, R-3, R-3.1 and R-4.

**Exceptions:**

~~1. Listed and approved unvented fuel fired heaters, including portable outdoor gas fired heating appliances, in one and two family dwellings.~~

~~2. Portable outdoor gas-fired heating appliances shall be allowed in accordance with Section 603.4.2.~~

**604.2.14.3 Emergency systems.** *An emergency power system shall be provided for exit signs, exit illumination as required by Chapter 10, electrically powered fire pumps required to maintain pressure, and elevator car lighting are classified as emergency systems and ~~and electrically powered fire pumps required to maintain pressure~~ shall operate within 10 seconds of failure of the normal power supply and shall be capable of being transferred to the standby source.*

**Exception:** Exit sign, exit and means of egress illumination are permitted to be powered by a standby source in buildings of Group F and S occupancies.

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[7. The SFM proposes to adopt Chapter 7 with the following amendments and California regulations.]**

**CHAPTER 7  
FIRE-RESISTANCE-RATED CONSTRUCTION**

**701.1 Scope.** The provisions of this chapter shall specify the requirements for and the maintenance of fire-resistance-rated construction and requirements for enclosing floor openings and shafts in existing buildings. New construction shall comply with the ~~International~~ *California Building Code*.

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[8. The SFM proposes to Chapter 8 except those specific sections identified in the Matrix Adoption Table with the following amendments and California regulations.]**

**CHAPTER 8  
INTERIOR FINISHES**

**[B] TABLE 803.3**

**INTERIOR WALL AND CEILING FINISH REQUIREMENTS BY OCCUPANCY<sup>k</sup>**

GROUP	SPRINKLERED <sup>l</sup>			NONSPRINKLERED		
	Exit enclosures and exit passageways <sup>a, b</sup>	Corridors	Rooms and enclosed spaces <sup>c</sup>	Exit enclosures and exit passageways <sup>a, b</sup>	Corridors	Rooms and enclosed spaces <sup>c</sup>
A-1 & A-2	B	B	C	A	A <sup>d</sup>	B <sup>e</sup>
A-3 <sup>f</sup> , A-4, A-5	B	B	C	A	A <sup>d</sup>	C
B, E, M, R-1	B	C	C	A	B	C
R-4	B	C	C	A	B	B
B	C	C	C	B	C	C
H, L	B	B	C <sup>g</sup>	A	A	B
<del>I-1</del>	<del>B</del>	<del>C</del>	<del>C</del>	<del>A</del>	<del>B</del>	<del>B</del>
I-2, I-2.1	B	B	B <sup>h, i</sup>	A	A	B
I-3	A	A <sup>j</sup>	<del>C</del> B	<del>A</del> <u>NP</u>	<del>A</del> <u>NP</u>	<del>B</del> <u>NP</u>
I-4	B	B	B <sup>h, i</sup>	A	A	B
R-2	C	C	C	B	B	C
<u>R-2.1</u>	<u>B</u>	<u>C</u>	<u>C</u>	<u>A</u>	<u>B</u>	<u>B</u>
R-3, R-3.1	C	C	C	C	C	C
S	C	C	C	B	B	C
U	No restrictions			No restrictions		

For SI: 1 inch = 25.4 mm, 1 square foot = 0.0929m<sup>2</sup>.

NP = Not permitted [SFM]

- a. Class C interior finish materials shall be permitted for wainscoting or paneling of not more than 1,000 square feet of applied surface area in the grade lobby where applied directly to a noncombustible base or over furring strips applied to a noncombustible base and fire blocked as required by Section 803.4 of the *International California Building Code*.
- b. In exit enclosures of buildings less than three stories in height of other than Group I-3, Class B interior finish for nonsprinklered buildings and Class C interior finish for sprinklered buildings shall be permitted.
- c. Requirements for rooms and enclosed spaces shall be based upon spaces enclosed by partitions. Where a fire-resistance rating is required for structural elements, the enclosing partitions shall extend from the floor to the ceiling. Partitions that do not comply with this shall be considered enclosing spaces and the rooms or spaces on both sides shall be considered one. In determining the applicable requirements for rooms and enclosed spaces, the specific occupancy thereof shall be the governing factor regardless of the group classification of the building or structure.
- d. Lobby areas in Group A-1, A-2 and A-3 occupancies shall not be less than Class B materials.
- e. Class C interior finish materials shall be permitted in places of assembly with an occupant load of 300 persons or less.
- f. For places of religious worship, wood used for ornamental purposes, trusses, paneling or chancel furnishing shall be permitted.
- g. Class B material is required where the building exceeds two stories.
- h. Class C interior finish materials shall be permitted in administrative spaces.
- i. Class C interior finish materials shall be permitted in rooms with a capacity of four persons or less.

- j. Class B materials shall be permitted as wainscoting extending not more than 48 inches above the finished floor in corridors.
- k. Finish materials as provided for in other sections of this code.
- l. Applies when the exit enclosures, exit passageways, corridors or rooms and enclosed spaces are protected by a sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.
- ~~m. [SFM] Not Permitted for Group I-3~~

**806.2 Artificial vegetation.** Artificial decorative vegetation shall meet the flame propagation performance criteria of ~~NFPA 704~~California Code of Regulations, Title 19, Division 1. Meeting the flame propagation performance criteria of ~~NFPA 704~~California Code of Regulations, Title 19, Division 1 shall be documented and certified by the manufacturer in an approved manner.

**807.1 General requirements.** In occupancies in Groups A, E, I and R-1 and dormitories in Group R-2, curtains, draperies, hangings and other decorative materials suspended from walls or ceilings shall meet the flame propagation performance criteria of ~~NFPA 704~~California Code of Regulations, Title 19, Division 1 in accordance with Section 806.2 or be noncombustible.

**Exceptions:**

1. Curtains, draperies, hangings and other decorative materials suspended from walls of sleeping units and dwelling units in dormitories in Group R-2 protected by an approved automatic sprinkler system installed in accordance with Section 903.3.1 and such materials are limited to not more than 50 percent of the aggregate area of walls.
2. Decorative materials, including, but not limited to, photographs and paintings in dormitories in Group R-2 where such materials are of limited quantities such that a hazard of fire development or spread is not present.

**807.1.2 Combustible decorative materials.** The permissible amount of decorative materials meeting the flame propagation performance criteria of ~~NFPA 704~~California Code of Regulations, Title 19, Division 1 shall not exceed 10 percent of the aggregate area of walls and ceilings.

**Exceptions:**

1. In auditoriums in Group A, the permissible amount of decorative material meeting the flame propagation performance criteria of ~~NFPA 704~~California Code of Regulations, Title 19, Division 1 shall not exceed 50 percent of the aggregate area of walls and ceiling where the building is equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1, and where the material is installed in accordance with Section 803.4 of the ~~International~~ California Building Code.
2. The amount of fabric partitions suspended from the ceiling and not supported by the floor in Group B and M occupancies shall not be limited.

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

**808.1 Wastebaskets and linen containers in Group I-2 and I-3 occupancies.** Wastebaskets, linen containers and other waste containers, including their lids, located in Group I-2 and I-3 occupancies shall be constructed of noncombustible materials or of materials that meet a peak rate of heat release not exceeding 300 kW/m<sup>2</sup> when tested in accordance with ASTM E 1354 at an incident heat flux of 50 kW/m<sup>2</sup> in the horizontal orientation. Metal waste baskets and other metal waste containers with a capacity of 20 gallons (75.7 L) or more shall be *listed* in accordance with UL 1315 and shall be provided with a noncombustible lid. Portable containers exceeding 32 gallons (121 L) shall be stored in an area classified as a waste and linen collection room and constructed in accordance with Table 508.2.5 of the *International Building Code*.

**Notation:**

Authority: Health and Safety Code Sections 13143, 17921, 18949.2  
References: Health and Safety Code Sections 13143, 18949.2

**[9. The SFM proposes to adopt Chapter 9 with the following amendments and California regulations.]**

**CHAPTER 9  
FIRE PROTECTION SYSTEMS**

**901.6.1 Standards.** Fire protection systems shall be inspected, tested and maintained in accordance with the referenced standards listed in Table 901.6.1 ~~and Chapters 3 and 5, Title 19 California Code of Regulations, Title 19, Division 1, Chapters 3 and 5.~~

**TABLE 901.6.1  
FIRE PROTECTION SYSTEM MAINTENANCE STANDARDS**

<b>SYSTEM</b>	<b>STANDARD</b>
Portable fire extinguishers	<del>NFPA 10</del> <u>Title 19, California Code of Regulations, Title 19, Division 1, Chapter 3</u>
Carbon dioxide fire-extinguishing system	NFPA 12
Halon 1301 fire-extinguishing systems	NFPA 12A
Dry-chemical extinguishing systems	NFPA 17
Wet-chemical extinguishing systems	NFPA 17A
Water-based fire protection systems	<del>NFPA 25</del> <u>Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5</u>
Fire alarm systems	NFPA 72
Water-mist systems	NFPA 750
Clean-agent extinguishing systems	NFPA 2001

**903.2 Where required.** Approved automatic sprinkler systems in new buildings and structures shall be provided in the locations described in Sections 903.2.1 through 903.2.12.

**Exceptions:**

- ~~1. Spaces or areas in telecommunications buildings used exclusively for telecommunications equipment, associated electrical power distribution equipment, batteries and standby engines, provided those spaces or areas are equipped throughout with an automatic smoke detection system in accordance with Section 907.2 and are separated from the remainder of the building by not less than 1-hour fire barriers constructed in accordance with Section 707 of the International Building Code or not less than 2-hour horizontal assemblies constructed in accordance with Section 712 of the International Building Code, or both.~~
- ~~2. Automatic fire sprinkler protection for Fixed Guideway Transit Systems shall be as per Section 903.2.17.~~

**903.2.3 Group E.** ~~Except as provided for in Sections 903.2.2-1903.2.3.1 for a new public school campus and 907.2.3.6.1 (fire alarm and detection) for modernization of an existing public school campus building(s),~~ an automatic sprinkler system shall be provided for Group E occupancies as follows:

1. Throughout all Group E fire areas greater than 12,000 square feet (1115 m2) in area.
2. Throughout every portion of educational buildings below the lowest level of exit discharge serving that portion of the building.

**Exception:** An automatic sprinkler system is not required in any area below the lowest level of exit discharge serving that area where every classroom throughout the building has at least one exterior exit door at ground level.

3. [SFM] In rooms or areas with special hazards such as laboratories, vocational shops and other such areas where hazardous materials in ~~exempt amounts~~ quantities not exceeding the maximum allowable quantity are used or stored.
4. Throughout any Group E structure greater than ~~20,000 square feet (1155 m<sup>2</sup>)~~ 12,000 square feet (1115 m<sup>2</sup>) in area, which contains more than one fire area, and which is separated into two or more buildings by fire walls of less than four hour fire resistance rating without openings.

**903.2.2.1-903.2.3.1 Public Schools—Automatic Sprinkler System Requirements.**

~~903.2.2.1.1 903.2.3.1.1 New Public School Campus. A State Fire Marshal An approved automatic sprinkler system shall be provided on in all buildings of a new public school campus as defined in Section 202 regardless of occupancy classification, as and maintained in accordance with this code and Chapter 45. See Section 907.2.3.6 for automatic detection system requirements and creates a “ceiling-plenum” spaces.~~

**Exceptions:**

1. Exempted portable buildings.
2. Ticket booths and athletic field storage buildings that are less than 500 square feet in floor area and located a minimum of 100 feet from all other buildings.
3. Shade or lunch shelters that are incapable of trapping heat, smoke or other by-products of combustion and located a minimum of 20 feet from all other buildings.
4. Shade or lunch shelters that are constructed of non-combustible materials and located a minimum of 20 feet from all other buildings.

~~903.2.3.1.1.1 In buildings provided with an approved automatic fire sSprinklers system shall be installed in spaces where the ceiling creates a “ceiling-plenum” or a space above the ceiling for non-environmental air, automatic sprinklers shall be installed to protect such spaces of buildings. that house and or serve students from kindergarten through twelfth grade (K-12) and are sited on a new public school, campus. as defined in section 202.]~~

**903.2.5.4 Group H occupancies located above the 10th story.** The fire sprinkler system shall be designed and zoned to provide separate indication upon water-flow for each side of the 2-hour fire-smoke barrier above the 10th story.

**903.2.6 Group I.** An automatic sprinkler system shall be provided throughout buildings with a Group I fire area.

**Exceptions:** ~~An automatic sprinkler system installed in accordance with Section 903.3.1.2 or 903.3.1.3 shall be allowed in Group I-1 facilities.~~

1. ~~Those areas exempted by 407.5 Section 408.5 of the California Building Code.~~
2. ~~When not used in accordance with Section 504.2 or 506.3 an automatic sprinkler system installed in accordance with Section 903.3.1.2 shall be allowed in Group I-1 occupancies.~~
3. ~~Pursuant to Health and Safety Code Section 13113, Group I-1 occupancies housing ambulatory children only, none of whom are mentally ill or mentally retarded, and the buildings or portions thereof in which such children are housed are not more than two stories in height, and buildings or portions thereof housing such children shall have an automatic fire alarm system activated by approved smoke detectors.~~
4. ~~Pursuant to Health and Safety Code Section 13113 (d), Group I-1 I-2 occupancies, or any alterations thereto, located in Type IA construction in existence on March 4, 1972.~~

~~An automatic sprinkler system designed in accordance with Section 903.3.1.3 shall not be utilized in Group I-1.~~

**903.2.6.1 Group I-2.** In an existing, unsprinklered Group I-2, nurses’ station open to fire-resistive exit access corridors shall be protected by an automatic sprinkler system located directly above the nurses’ station. It shall be permitted to connect the automatic sprinkler system to the domestic water service.

**903.2.8 Group R** An automatic sprinkler system installed in accordance with Section 903.3 shall be provided throughout all buildings with a Group R fire area.

**Exceptions:**

- ~~1. Detached one and two family dwellings and multiple single family dwellings (town houses) not more than three stories above grade plane in height with a separate means of egress, unless specifically required by other sections of this Code or classified as Group R-4.~~
- ~~2. Group U private garages accessory to a Group R-3 occupancy.~~
- ~~3.1. Existing Group R-3 occupancies converted to Group R-3.1 occupancies not housing bedridden clients, not housing nonambulatory clients above the first floor, and not housing clients above the second floor.~~
- ~~4.2. Existing Group R-3 occupancies converted to Group R-3.1 occupancies housing only one bedridden client and complying with Section 425.8.3.3 of the California Building Code.~~
- ~~5.3. Pursuant to Health and Safety Code Section 13113 occupancies housing ambulatory children only, none of whom are mentally ill or mentally retarded, and the buildings or portions thereof in which such children are housed are not more than two stories in height, and buildings or portions thereof housing such children have an automatic fire alarm system activated by approved smoke detectors.~~
- ~~6.4. Pursuant to Health and Safety Code Section 13143.6 occupancies licensed for protective social care which house ambulatory clients only, none of whom is a child (under the age of 18 years), or who is elderly (65 years of age or over).~~

When not used in accordance with Section 504.2 or 506.3 of the California Building Code an automatic sprinkler system installed in accordance with Section 903.3.1.2 shall be allowed in Group R-2.1 occupancies.

An automatic sprinkler system designed in accordance with Section 903.3.1.3 shall not be utilized in Group R-2.1 or R-4 occupancies.

**903.2.10 Group S-2 enclosed parking garages.** An automatic sprinkler system shall be provided throughout buildings classified as enclosed parking garages in accordance with Section 406.4 of the ~~international~~ California Building Code as follows.

1. Where the fire area of the enclosed parking garage exceeds 12,000 square feet (1115 m<sup>2</sup>); or
2. Where the enclosed parking garage is located beneath other groups.

**Exception:** ~~Enclosed parking garages located beneath Group R-3 occupancies.~~

### **903.2.13 Reserved.**

**903.2.16.1 Group L occupancies located above the 10<sup>th</sup> story.** The automatic sprinkler system shall be designed and zoned to provide separate indication upon water-flow for each side of the 2-hour fire-smoke barrier above the 10th story.

**903.2.18 Group U private garages and carports accessory to Group R-3 occupancies.** Carports with habitable space above and attached garages, accessory to Group R-3 occupancies, shall be protected by residential fire sprinklers in accordance with this Section. Residential fire sprinklers shall be connected to, and installed in accordance with, an automatic residential fire sprinkler system that complies with Section R313 of the California Residential Code or with NFPA 13D. Fire sprinklers shall be residential sprinklers or quick-response sprinklers, designed to provide a minimum density of 0.05 gpm/ft<sup>2</sup> (2.04 mm/min) over the area of the garage and/or carport, but not to exceed two sprinklers for hydraulic calculation purposes. Garage doors shall not be considered obstructions with respect to sprinkler placement.

**Exception:** An automatic residential fire sprinkler system shall not be required when additions or alterations are made to existing carports and/or garages that do not have an automatic residential fire sprinkler system installed in accordance with this Section.

**903.3.1.1 NFPA 13 sprinkler systems.** Where the provisions of this code require that a building or portion thereof be equipped throughout with an automatic sprinkler system in accordance with this section, sprinklers shall be installed throughout in accordance with NFPA 13 as amended in Chapter 47 except as provided in Section 903.3.1.1.1.

**903.3.1.1.1 Exempt locations.** *In other than Group I-2, I-2.1 and I-3 occupancies, automatic sprinklers shall not be*

required in the following rooms or areas where such rooms or areas are protected with an approved automatic fire detection system, in accordance with Section 907.2, that will respond to visible or invisible particles of combustion. Sprinklers shall not be omitted from any room merely because it is damp, of fire-resistance-rated construction or contains electrical equipment.

1. Any room where the application of water, or flame and water, constitutes a serious life or fire hazard.
2. Any room or space where sprinklers are considered undesirable because of the nature of the contents, when approved by the fire code official.
- ~~3. Generator and transformer rooms separated from the remainder of the building by walls and floor/ceiling or roof/ceiling assemblies having a fire resistance rating of not less than 2 hours.~~
- ~~4. Rooms or areas that are of noncombustible construction with wholly noncombustible contents.~~
- ~~5. Fire service access elevator machine rooms and machinery spaces.~~
4. Spaces or areas in telecommunications buildings used exclusively for telecommunications equipment, and associated electrical power distribution equipment, provided those spaces or areas are equipped throughout with an automatic smoke detection system in accordance with Section 907.2 and are separated from the remainder of the building by not less than 1-hour fire barriers constructed in accordance with Section 707 of the California Building Code or not less than 2-hour horizontal assemblies constructed in accordance with Section 712 of the California Building Code, or both.

**903.3.1.2 NFPA 13R sprinkler systems.** Where allowed in buildings of Group R, up to and including four stories in height, automatic sprinkler systems shall be installed throughout in accordance with NFPA 13R as amended in Chapter 47

**903.3.2 Quick-response and residential sprinklers.** Where automatic sprinkler systems are required by this code, quick-response or residential automatic sprinklers shall be installed in the following areas in accordance with Section 903.3.1 and their listings:

1. Throughout all spaces within a smoke compartment containing patient sleeping units in Group I-2 in accordance with the ~~International~~ California Building Code.
2. Dwelling units and sleeping units in Group R ~~and I-1~~ occupancies.
3. Light-hazard occupancies as defined in NFPA 13.

**903.3.5.2 Secondary water supply.** A secondary on-site water supply ~~equal to the hydraulically calculated sprinkler demand, including the hose stream requirement~~ shall be provided for high-rise buildings ~~and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access~~ in Seismic Design Category C, D, E or F as determined by this code. The secondary water supply shall have a usable capacity of not less than the hydraulically calculated sprinkler demand plus 100 GPM for the inside hose stream allowance, for have a duration of not less than 30 minutes or as determined by the sprinkler system design occupancy hazard classification in accordance with NFPA 13, whichever is greater. The Class I standpipe system demand shall not be required to be included in the secondary on-site water supply calculations. In no case shall the secondary on-site water supply be less than 15,000 gallons.

**Exception:** Existing buildings.

**903.3.8 Floor control valves.** Floor control valves and waterflow detection assemblies shall be installed at each floor where any of the following occur:

1. Buildings where the floor level of the highest story is located more than 30 feet above the lowest level of fire department vehicle access.
2. Buildings that are four or more stories in height.
3. Buildings that are two or more stories below the highest level of fire department vehicle access.

**Exception:** Group R-3 and R-3.1 occupancies floor control valves and waterflow detection assemblies shall not be required.

**904.11 Commercial cooking systems.** ~~The automatic fire extinguishing system for commercial cooking systems~~

~~shall be of a type recognized for protection of commercial cooking equipment and exhaust systems of the type and arrangement protected. Preengineered automatic dry and wet chemical extinguishing systems shall be tested in accordance with UL 300 and listed and labeled for the intended application. Other types of automatic fire extinguishing systems shall be listed and labeled for specific use as protection for commercial cooking operations. The system shall be installed in accordance with this code, its listing and the manufacturer's installation instructions. Automatic fire extinguishing systems of the following types shall be installed in accordance with the referenced standard indicated, as follows:~~

- ~~1. Carbon dioxide extinguishing systems, NFPA 12.~~
- ~~2. Automatic sprinkler systems, NFPA 13.~~
- ~~3. Foam water sprinkler system or foam water spray systems, NFPA 16.~~
- ~~4. Dry chemical extinguishing systems, NFPA 17.~~
- ~~5. Wet chemical extinguishing systems, NFPA 17A.~~

~~Commercial cooking equipment that produce grease laden vapors shall be provided with a Type I Hood, in accordance with the California Mechanical Code, and an automatic fire extinguishing system that is listed and labeled for its intended use as follows:~~

1. Wet chemical extinguishing system, complying with UL 300.
2. Carbon dioxide extinguishing systems.
3. Automatic fire sprinkler systems.

~~All existing dry chemical and wet chemical extinguishing systems shall comply with UL 300, no later than the second required servicing of the system following the effective date of this section,~~

Exception Public schools kitchens, without deep-fat fryers, shall be upgraded to a UL 300 compliant system during state funded modernization projects that are under the jurisdiction of the Division of the State Architect

All systems shall be installed in accordance with the California Mechanical Code, appropriate adopted standards, their listing and the manufacturers' installation instructions.

**Exception:** Factory-built commercial cooking recirculating systems that are tested, listed, labeled and installed in accordance with UL 710B. ~~and listed, labeled and installed in accordance with Section 304.1 of the International Mechanical Code.~~

**905.3.1 Height.** In other than Group R-3 and R-3.1 occupancies, Class III standpipe systems shall be installed throughout at each floor where any of the following occur:

1. Buildings where the floor level of the highest story is located more than 30 feet (9144mm) above the lowest level of fire department vehicle access, ~~or~~
2. Buildings that are four or more stories in height.
3. Buildings where the floor level of the lowest story is located more than 30 feet (9144mm) below the highest level of fire department vehicle access.
4. Buildings that are two or more stories below the highest level of fire department vehicle access.

**Exceptions:**

1. Class I standpipes are allowed in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.
2. Class I manual standpipes are allowed in open parking garages where the highest floor is located not more than 150 feet (45 720 mm) above the lowest level of fire department vehicle access.
3. Class I manual dry standpipes are allowed in open parking garages that are subject to freezing temperatures, provided that the hose connections are located as required for Class II standpipes in accordance with Section 905.5
4. Class I manual dry standpipes are allowed in open parking garages that are subject to freezing temperatures, provided that the hose connections are located as required for Class II standpipes in accordance with Section 905.5.
5. In determining the lowest level of fire department vehicle access, it shall not be required to consider:

- 5.1 Recessed loading docks for four vehicles or less; and
- 5.2 Conditions where topography makes access from the fire department vehicle to the building impractical or impossible.

**905.4 Location of Class I standpipe hose connections.** Class I standpipe hose connections shall be provided in all of the following locations:

1. In every required stairway, a hose connection shall be provided for each floor level above or below grade. Hose connections shall be located at an intermediate floor level landing between floors, unless otherwise approved by the fire code official. See Section 909.20.3.2 for additional provisions in smokeproof enclosures.
2. On each side of the wall adjacent to the exit opening of a horizontal exit.

**Exception:** Where floor areas adjacent to a horizontal exit are reachable from the exit stairway hose connection by ~~a 30-foot hose stream from~~ a nozzle attached to 100 feet of hose as measured along the path of travel, a hose connection shall not be required at the horizontal exit.

3. In every exit passageway, at the entrance from the exit passageway to other areas of a building.

**Exception:** Where floor areas adjacent to an exit passageway are reachable from exit stairway hose connections by a 30-foot (9144 mm) hose stream from a nozzle attached to 100 feet (30 480 mm) of hose, a hose connection shall not be required at the entrance from the exit passageway to other areas of the building.

4. In covered mall buildings, adjacent to each exterior public entrance to the mall and adjacent to each entrance from an exit passageway or exit corridor to the mall.
5. Where the roof has a slope less than four units vertical in 12 units horizontal (33.3-percent slope), each standpipe shall be provided with a hose connection located either on the roof or at the highest landing of a stairway with stair access to the roof. An additional hose connection shall be provided at the top of the most hydraulically remote standpipe for testing purposes.
6. Where the most remote portion of a nonsprinklered floor or story is more than 150 (45 720 mm) feet from a hose connection or the most remote portion of a sprinklered floor or story is more than ~~200 (60 960mm)~~ 150 (45 720 mm) feet from a hose connection, the fire code official is authorized to require that additional hose connections be provided in approved locations. The distances from a hose connection shall be measured along the path of travel.

**906.1 Where required.** Portable fire extinguishers shall be installed in the following locations.

1. In new and existing Group A, B, E, F, H, I, L, M, R-1, R-2, R-2.1, R-3.1 R-4 and S occupancies.

**Exception:** ~~In new and existing Group A, B and E occupancies equipped throughout with quick response sprinklers, portable fire extinguishers shall be required only in locations specified in Items 2 through 6.~~

2. Within 30 feet (9144 mm) of commercial cooking equipment.
3. In areas where flammable or combustible liquids are stored, used or dispensed.
4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1.
5. Where required by the sections indicated in Table 906.1.
6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.
7. Large and small family day-care homes shall be equipped with a portable fire extinguisher having a minimum 2A10BC rating.
8. Where required by California Code of Regulations, Title 19, Division 1.

**906.2 General requirements.** Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and ~~NEPA 10 Chapter 3, Title 19, California Code of Regulations, Title 19, Division 1, Chapter 3.~~

**Exceptions:**

1. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.
2. Thirty-day inspections shall not be required ~~and maintenance shall be allowed to be once every three years for dry chemical or halogenated-agent~~ portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:
  - 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.
  - 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.
  - 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.
  - 2.4. Electronic monitoring devices and supervisory circuits shall be tested ~~every three years~~ when extinguisher maintenance is performed.
  - 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by ~~NFPA 10 Chapter 3, Title 19, California Code of Regulations, Title 19, Division 1, Chapter 3.~~
3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

**TABLE 906.3(1)  
FIRE EXTINGUISHERS FOR CLASS A FIRE HAZARDS**

	<b>LIGHT (Low) HAZARD OCCUPANCY</b>	<b>ORDINARY (Moderate) HAZARD OCCUPANCY</b>	<b>EXTRA (High) HAZARD OCCUPANCY</b>
Minimum Rated Single Extinguisher	2-Ac	2-A	4-Aa
Maximum Floor Area Per Unit of A	3,000 square feet	1,500 square feet	1,000 square feet
Maximum Floor Area For Extinguisher b Maximum Travel	11,250 square feet 75 feet	11,250 square feet 75 feet	11,250 square feet 75 feet

For SI: 1 foot = 304.8 mm, 1 square foot = 0.0929m<sup>2</sup>, 1 gallon = 3.785 L.

- a. Two 2 1/2-gallon water-type extinguishers shall be deemed the equivalent of one 4-A rated extinguisher.
- b. ~~Annex E.3.3 of NFPA 10 provides more details~~ *California Code of Regulations, Title 19, Division 1, Chapter 3* concerning application of the maximum floor area criteria.
- c. Two water-type extinguishers each with a 1-A rating shall be deemed the equivalent of one 2-A rated extinguisher for Light (Low) Hazard Occupancies.

**906.3.2 Class B fire hazards.** Portable fire extinguishers for occupancies involving flammable or combustible liquids with depths of less than or equal to 0.25-inch (6.35 mm) shall be selected and placed in accordance with Table 906.3(2).

Portable fire extinguishers for occupancies involving flammable or combustible liquids with a depth of greater than 0.25-inch (6.35 mm) shall be selected and placed in accordance with ~~NFPA 10~~ *California Code of Regulations, Title 19, Division 1, Chapter 3.*

**TABLE 906.3(2)  
FLAMMABLE OR COMBUSTIBLE LIQUIDS WITH  
DEPTHS OF LESS THAN OR EQUAL TO 0.25-INCH**

TYPE OF HAZARD	BASIC MINIMUM EXTINGUISHER RATING	MAXIMUM TRAVEL DISTANCE TO EXTINGUISHERS (feet)
Light (Low)	5-B	30
	10-B	50
Ordinary (Moderate)	10-B	30
	20-B	50
Extra (High)	40-B	30
	80-B	50

For SI: 1 inch = 25.4 mm, 1 foot = 304.8 mm.

**Note.** For requirements on water-soluble flammable liquids and alternative sizing criteria, see ~~Section 5.5 of NFPA 10~~ California Code of Regulations, Title 19, Division 1, Chapter 3.

**906.3.4 Class D fire hazards.** Portable fire extinguishers for occupancies involving combustible metals shall be selected and placed in accordance with ~~NFPA 10~~ California Code of Regulations, Title 19, Division 1, Chapter 3.

**907.1.2 Fire alarm shop drawings.** Shop drawings for fire alarm systems shall be submitted for review and approval prior to system installation, and shall include, but not be limited to, all of the following:

1. A floor plan that indicates the use of all rooms.
2. Locations of alarm-initiating devices.
3. Locations of alarm notification appliances, including candela ratings for visible alarm notification appliances.
4. Location of fire alarm control unit, transponders and notification power supplies.
5. Annunciators.
6. Power connection.
7. Battery calculations.
8. Conductor type and sizes.
9. Voltage drop calculations.
10. Manufacturers' data sheets indicating model numbers and listing information for equipment, devices and materials.
11. Details of ceiling height and construction.
12. The interface of fire safety control functions.
13. Classification of the supervising station.
14. All plans and shop drawings shall use the symbols identified in NFPA 170, Standard for Fire Safety and Emergency Symbols.

**Exception:** *Other symbols are allowed where approved by the enforcing agency*

**907.1.3 Equipment.** Systems and components shall be *California State Fire Marshal* listed and approved in accordance with California Code of Regulations, Title 19, Division 1 for the purpose for which they are installed.

~~**907.1.4-907.1.5 Fire alarm use** A fire alarm system shall not be used for any purpose other than fire warning or mass notification unless approved by the enforcing agency and where permitted by NFPA 72.~~

**907.2 Where required—new buildings and structures.** An approved fire alarm system installed in accordance with the provisions of this code and NFPA 72 shall be provided in new buildings and structures in accordance with Sections 907.2.1 through 907.2.23 and provide occupant notification in accordance with Section 907.6, unless other requirements are provided by another section of this code.

A minimum of one manual fire alarm box shall be provided in an *approved* location to initiate a fire alarm signal for fire alarm systems employing automatic fire detectors or water-flow detection devices. Where other sections of this code allow elimination of fire alarm boxes due to sprinklers, or automatic fire alarm systems a single fire alarm box

shall be installed at a location approved by the enforcing agency.

**Exceptions:**

1. The manual fire alarm box is not required for fire alarm ~~systems~~ control units dedicated to elevator recall control, ~~and~~ supervisory service and fire sprinkler monitoring.
2. The manual fire alarm box is not required for Group R-2 occupancies unless required by the fire code official to provide a means for fire watch personnel to initiate an alarm during a sprinkler system impairment event. Where provided, the manual fire alarm box shall not be located in an area that is accessible to the public.
3. The manual fire alarm box is not required to be installed when approved by the fire code official.

~~A minimum of one fire alarm box shall be installed for each fire alarm system at a location approved by the enforcing agency.~~

~~Exception: Fire alarm systems dedicated to elevator recall control, supervisory service and fire sprinkler monitoring only.~~

~~Where other sections of this code allow elimination of fire alarm boxes due to sprinklers, a single fire alarm box shall be installed.~~

~~Exception: Where not required to be installed by the local enforcing agency.~~

**907.2.1 Group A.** A manual fire alarm system that activates the occupant notification system in accordance with Section 907.6 shall be installed in Group A occupancies having an *occupant load* of 300 or more.

Portions of buildings that contain a Group E occupancies occupied for assembly purposes with an occupant load of less than 1000 shall be provided with a fire alarm system as required for the Group E occupancy.

~~**907.2.3.2 School Fire Alarms.** Except as provided in Section 907.3 every~~ Every Group A building used for educational purposes, regardless of occupancy classification shall be provided with an approved a manual or automatic fire alarm system. This provision shall apply to, but shall not necessarily be limited to, every elementary school, high school, community college and university.

~~Exception: Privately owned trade or vocational schools or any firm or company which provides educational facilities and instructions for its employees.~~

**907.2.1.1 System initiation in Group A occupancies with an occupant load of 1,000 or more.** Activation of the fire alarm in Group A occupancies with an occupant load of 1,000 or more shall initiate a signal using an emergency voice/alarm communications system in accordance with 907.6.2.2. *Group A occupancies with an occupant load of 10,000 or more, see Section ~~907.2.1.3~~ 907.2.1.2.*

**Exception:** Where approved, the prerecorded announcement is allowed to be manually deactivated for a period of time, not to exceed 3 minutes, for the sole purpose of allowing a live voice announcement from an approved, constantly attended location.

~~**907.2.1.3-907.2.1.2 Public address system.** Pursuant to Health and Safety Code Section 13108.9, for all buildings or structures constructed on or after July 1, 1991, which are intended for public assemblies of 10,000 or more persons a public address system with an emergency backup power system shall be required.~~

~~Existing buildings or structures intended for public assemblies of 10,000 or more persons, which, on or after January 1, 1991 have or subsequently have installed a public address system, shall have an emergency backup power system for the public address system.~~

**907.2.2 Group B.** A manual fire alarm system shall be installed in Group B occupancies where one of the following conditions exists:

1. The combined Group B occupant load of all floors is 500 or more.
2. The Group B occupant load is more than 100 persons above or below the lowest level of exit discharge.

3. The Group B fire area contains a Group B ambulatory health care facility.
4. Group B occupancies containing educational facilities, see Section 907.2.2.2.

**Exception:** Manual fire alarm boxes are not required where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 and the occupant notification appliances will activate throughout the notification zones upon sprinkler water flow.

**907.2.3.2 School Fire Alarms.** ~~Except as provided in Section 907.3 every~~ **907.2.2.2 Group B Educational facilities.** Every Group B building used for educational purposes, regardless of occupancy classification shall be provided with an approved a manual or automatic fire alarm system. This provision shall apply to, but shall not necessarily be limited to, every elementary school, high school, community college and university.

**Exception:** Privately owned trade or vocational schools or any firm or company which provides educational facilities and instructions for its employees.

**907.2.3 Group E.** A manual and automatic fire alarm system shall be installed in Group E Occupancies—~~with an occupant load of 50 or more persons or containing more than one classroom or one or more rooms used for day care purposes, in accordance with this Section.~~

~~When~~ Where automatic sprinkler systems or ~~smoke~~ automatic detectors are installed, such systems or detectors shall be connected to the building fire alarm system.

**Exceptions:**

1. ~~Group E occupancies with an occupant load of less than 50~~
2. ~~Manual fire alarm boxes are not required in Group E occupancies where all the following apply:~~
  - 2.1. ~~Interior corridors are protected by smoke detectors.~~
  - 2.2. ~~Auditoriums, cafeterias, gymnasiums and similar areas are protected by heat detectors or other approved detection devices.~~
  - 2.3. ~~Shops and laboratories involving dusts or vapors are protected by heat detectors or other approved detection devices.~~
  - 2.4. ~~The capability to activate the evacuation signal from a central point is provided.~~
  - 2.5. ~~In buildings where normally occupied spaces are provided with a two-way communication system between such spaces and a constantly attended receiving station from where a general evacuation alarm can be sounded, except in locations specifically designated by the fire code official.~~
1. Manual fire alarm boxes shall not be required in Group E occupancies where an approved automatic fire alarm system installed in accordance with this Section, and manual activation is provided from a normally occupied location.
3. ~~2.~~ Manual fire alarm boxes shall not be required in Group E occupancies where the building is equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1, the occupant notification appliances will activate on sprinkler water flow and manual activation is provided from a normally occupied location.

**907.2.3.1 System connection.** ~~When~~ Where more than one fire alarm control unit is used at the school campus, they shall be interconnected and shall operate all notification appliances.

**Exception:** Interconnection of fire alarm control units is not required when all the following are provided:

1. Buildings that are separated a minimum of 20 feet (6096 mm) and in accordance with the California Building Code; and
2. There is a method of two way communication between each classroom and the school administrative office approved by the fire enforcing agency; and
3. A method of manual activation of each fire alarm system is provided.

**907.2.3.2 School Fire Alarms Assemblies located within a Group E occupancy.** Assembly occupancies with an occupant load of less than 1000 and located within a Group E occupancy campus or building shall be provided with a fire alarm system as required for the Group E occupancy.

~~Except as provided in Section 907.3.2, every building used for educational purposes, regardless of occupancy classification shall be provided with an approved fire alarm system. This provision shall apply to, but shall not necessarily be limited to, every elementary school, high school, community college and university.~~

~~**Exception:** Privately owned trade or vocational schools or any firm or company which provides educational facilities and instructions for its employees.~~

~~**907.2.3.3 Notification.** The system notification shall be consistent with the requirements for audible and visible notification requirements of Section 907.6 and NFPA 72 as amended in Chapter 35.45. Audible notification shall comply with the American National Standards Institute (ANSI) S3.41 Emergency Evacuation Signal. An audible alarm notification appliance shall be mounted on the exterior of buildings to alert occupants in and around the playground area. The fire alarm system notification shall comply with the requirements of Section 907.6.~~

~~**907.2.3.4 Annunciation.** Annunciation of the fire alarm system shall comply with the requirements of Section 907.9.1907.7.3.1.~~

~~**907.2.3.5 Monitoring.** School fire alarm systems shall be monitored in accordance with 907.7.5.2.~~

~~**907.2.3.6 Public Schools – smoke detectors. Automatic fire alarm system.** Automatic detection shall be provided in accordance with this section.~~

~~**907.2.3.6.1 Automatic detection fire alarm system.** Smoke detectors shall be used as the primary method of automatic alarm initiation except in areas where the environment or ambient conditions exceed smoke detector installation guidelines; another method of automatic detection shall be used. In areas containing sprinklers, heat detectors may be omitted. Smoke detectors shall be designed, installed and maintained in accordance with Section 907 and NFPA 72 as amended in Chapter 45.~~

~~Smoke detectors shall be located at the ceiling of every room and area, and in “ceiling plenums” utilized for environmental air. In buildings provided with an approved automatic fire sprinkler system where the ceiling creates a “ceiling plenum” or a space above the ceiling for non-environmental air, automatic sprinklers shall be installed to protect such spaces of buildings that house and or serve students from kindergarten through twelfth grade (K-12) and are sited on a new public school, campus as defined in section 202.~~

~~Where the ceiling is attached directly to the underside of the roof structure, automatic smoke detectors shall be installed on the ceiling only. Smoke detectors shall be located at the ceiling of every room and area, and in “ceiling plenums” utilized for environmental air.~~

~~Smoke detectors shall be installed at the ceiling of every room and in “ceiling-plenums” utilized for environmental air. Where the ceiling is attached directly to the underside of the roof structure, smoke detectors shall be installed on the ceiling only.~~

~~**Exception:** Where the environment or ambient conditions exceed smoke detector installation guidelines; heat detectors or fire sprinklers shall be used.~~

~~**907.2.3.6.2 Heat detectors shall be installed in combustible spaces where sprinklers or smoke detectors are not installed.**~~

~~**907.2.3.7 Public School – Automatic Fire Alarm System Requirements.**~~

~~**907.2.3.7.1 New Public School Campus.** On or after July 1, 2002, a State Fire Marshal approved and listed An automatic fire alarm system shall be provided in all new public school campus as defined in Section 202 regardless of occupancy classification. The approved fire alarm system shall be both automatic and manual and maintained in accordance with Section 907 and Article Chapter 45. At least one manual box shall be installed for the purpose of manually initiating the fire alarm system.~~

~~**907.2.3.7.2 Modernization Project.** A State Fire Marshal approved and listed An automatic fire alarm system shall~~

be provided in all modernization projects as defined in Section 202. ~~The approved fire alarm system shall be both automatic and manual, and maintained in accordance with Section 907 and Article Chapter 45. When the requirements of this section are met, manual fire alarm boxes are not required throughout the modernization project. At least one manual box shall be installed for the purpose of manually initiating the fire alarm system.~~

#### **~~907.2.3.8 Portable Buildings – Automatic Fire Alarm System Requirements~~**

~~907.2.3.8.1 907.2.3.7.3 Permanent-Portable Buildings. A portable building that is used to serve or house students from kindergarten through twelfth grade (K-12) and is certified as a permanent building on a new public school campus by the public school administration shall comply with the requirements of Section 907.2.3.7.1. An automatic fire alarm system shall be provided in all new public school Permanent-Portable Buildings.~~

##### Exception: Exempted Portable Buildings

~~907.2.3.8.2 907.2.3.7.4. Permanent-Portable Building Modernization Project. A permanent-portable building to undergo modernization efforts, and is used to serve or house students from kindergarten through twelfth grade (K-12) that is certified as a permanent building by the public school administration shall comply with the requirements of Section 907.2.3.7.2. An automatic fire alarm system shall be provided in permanent-portable buildings which to undergo a modernization project.~~

##### Exception: Exempted Portable Buildings

~~907.2.3.7.5. Daycare, Group E or Group I-4 located on a public school campus. An automatic fire alarm system shall be provided in all buildings used as or contain a Group E or Group I-4 daycare.~~

~~907.2.3.8.3 Exempted Portable Building. A portable building as defined in Section 202 that is certified by the public school administration as being sited on campus for less than three years is not required to install an automatic fire detection system, or automatic sprinkler system.~~

~~907.2.3.8 Private Schools. An automatic fire alarm system shall be provided in new buildings of private schools.~~

Exception: Automatic detection devices are not required where an approved automatic sprinkler system is installed in accordance with Section 903.3.1.1 and the occupant notification appliances will activate on sprinkler water flow and manual activation is provided from a normally occupied location.

#### **907.2.3.9 Daycare, Group E.**

~~907.2.3.9.1 An automatic fire alarm system shall be provided in all buildings used as or containing a Group E daycare.~~

Exception: Automatic detection devices are not required where an approved automatic sprinkler system is installed in accordance with Section 903.3.1.1 and the occupant notification appliances will activate on sprinkler water flow and manual activation is provided from a normally occupied location.

~~907.2.3.9.2 Smoke detectors shall be installed in every room used for sleeping or napping.~~

~~907.2.5.2 Group H occupancies located above the 10th story. Manual fire alarm boxes shall be required on each side of the 2-hour fire-smoke barrier and at each exit above the 10th story.~~

~~907.2.6.1 Group I-1. An automatic smoke detection system shall be installed in corridors, waiting areas open to corridors and habitable spaces other than sleeping units and kitchens. The system shall be activated in accordance with Section 907.5. Reserved.~~

##### **Exceptions:**

~~1. Smoke detection in habitable spaces is not required where the facility is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1.~~

~~2. Smoke detection is not required for exterior balconies.~~

**907.2.6.2 Group I-2 and Group I-2.1** An automatic smoke detection system shall be installed in corridors in nursing homes (both intermediate care and skilled nursing facilities), detoxification facilities and spaces permitted to be open to the corridors by Section 407.2. The system shall be activated in accordance with Section 907.5. Hospitals shall be equipped with smoke detection as required in Section 407.

**Exceptions:**

~~1. Corridor smoke detection is not required in smoke compartments that contain patient sleeping units where such units are provided with smoke detectors that comply with UL 268. Such detectors shall provide a visual display on the corridor side of each patient sleeping unit and shall provide an audible and visual alarm at the nursing station attending each unit.~~

~~2. Corridor smoke detection is not required in smoke compartments that contain patient sleeping units where patient sleeping unit doors are equipped with automatic door closing devices with integral smoke detectors on the unit sides installed in accordance with their listing, provided that the integral detectors perform the required alerting function.~~

~~An approved manual and automatic fire alarm system shall be provided for Group I-2 and I-2.1 occupancies. Audible appliances shall be used in non-patient areas. Visible appliances may be used in lieu of audible appliances in patient occupied areas. Audible appliances placed in patient areas shall be only chimes or similar sounding appliances for alerting staff. An automatic smoke detection system shall be provided.~~

**Exceptions:**

~~1. Heat detectors may be used in closets, unusable space under floor areas, storage rooms, bathrooms, attics, kitchens, laundry rooms and rooms of similar use.~~

~~2. When an entire facility is used for the housing of persons, none of whom are physically or mentally handicapped or non-ambulatory, and are between the ages of 18 and 64, the buildings or structures comprising such facility shall be exempt from the provisions of this subsection relating to the installation of an automatic fire alarm system.~~

~~In occupancies housing non-ambulatory persons where restraint is practiced, staff and attendants shall be provided and housed or located in such a manner that such supervisory personnel will also be alerted upon activation of any detector required by this section.~~

~~Automatic closing doors shall comply with Section 715.4.7.3.~~

~~A manual and automatic fire alarm system shall be installed in Group I-2 and I-2.1 occupancies. Where automatic fire suppression systems or smoke detectors are installed, such systems or detectors shall be connected to the building fire alarm system.~~

~~**Exception:** Where an entire facility is used for the housing of persons, none of whom are physically or mentally handicapped or non-ambulatory, and are between the ages of 18 and 64, the buildings or structures comprising such facility shall be exempt from the provisions of this subsection relating to the installation of an automatic fire alarm system.~~

**907.2.6.2.1 Notification.** The fire alarm notification system shall be in accordance with Section 907.6.2.5.

**907.2.6.2.2 Automatic fire detection.** Smoke detectors shall be provided in accordance with this section.

1. In patient and client sleeping rooms. Actuation of such detectors shall cause a visual display on the corridor side of the room in which the detector is located and shall cause an audible and visual alarm at the respective nurses' station. A nurse call system listed for this function is an acceptable of providing the audible and visual alarm at the respective nurses' station and corridor room display. Operation of the smoke detector shall not include any alarm verification feature.

**Exception:** In patient and client rooms equipped with existing automatic door closers having integral smoke detector, the integral detector is allowed to substitute for the room smoke detector, provided it meets all the required alerting functions.

2. Group I-2 nurses' stations. A minimum of one (1) smoke detector shall be installed at the nurses' station and centrally located.

3. In waiting areas and corridors onto which they open, in the same smoke compartment, in accordance with Section 407.2.1.

~~907.2.6.2.1 Smoke detectors shall be installed in patient and client sleeping rooms. Actuation of such detectors shall cause a visual display on the corridor side of the room in which the detector is located and shall cause an audible and visual alarm at the respective nurses' station. A nurse call system listed for this function is an acceptable method of providing the audible and visual alarm at the respective nurses station.~~

~~**Exception:** In rooms equipped with existing automatic door closers having integral smoke detector, the integral detector may substitute for the room smoke detector, provided it meets all the required alerting function.~~

~~Operation of the smoke detector shall not include any alarm verification feature.~~

**907.2.6.3.3 Smoke detectors. Automatic smoke detection system.** An automatic smoke detection system shall be installed throughout resident housing areas, including sleeping units and contiguous day rooms, group activity spaces and other common spaces normally accessible to ~~residents~~ inmates.

**Exceptions:**

1. Other approved smoke detection ~~arrangements~~ providing equivalent protection including, but not limited to, placing detectors in exhaust ducts from cells or behind protective guards listed for the purpose are allowed when necessary to prevent damage or tampering. ~~may be used to prevent damage or tampering or for other purposes provided the function of detecting any fire is fulfilled and the location of the detectors is such that the speed of detection will be equivalent to that provided by the spacing and location required in accordance with NFPA 72 as referenced in Chapter 4547.~~ This may include the location of detectors in return air ducts from cells, behind grilles or in other locations. Spot type, combination duct and open area smoke detectors may be used when located not more than 14 inches (356mm) from the return air grill. For initiation and annunciation purposes, these detectors may be combined in groups of four. The fire code official having jurisdiction, however, must approve the proposed equivalent performance of the design.

~~2. Sleeping units in Use Conditions 2 and 3 as described in Section 308.~~

~~3. Smoke detectors are not required in sleeping units with four or fewer occupants in smoke compartments that are equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1.~~

2. For Department of Corrections, prison cell or cell complex automatic smoke detection system shall not be required when all of the following conditions are met:

1. All rooms, including the inmate cells are provided with an automatic sprinkler system in accordance with 903.3.1.1.

2. Building is continuously staffed by a correctional officer at all times.

3. The exception to 903.2.6.2 shall not apply.

**907.2.8 Group R-1 and Group R-4.** Fire alarm systems and smoke alarms shall be installed in Group R-1 and Group R-4 occupancies as required in Sections 907.2.8.1 through 907.2.8.3.

~~**907.2.8.4 Fire alarm systems in Group R-4 occupancies.** An approved manual and automatic fire alarm system shall be installed in Group R-4 occupancies.~~

**Exceptions:**

~~1. Protective social care occupancies housing persons none of whom are physically or mentally handicapped or nonambulatory and which provide supervisory services such as alcoholism or drug abuse recovery or treatment facilities, halfway houses operated by the California Department of Corrections, and similar facilities and are provided with a manual fire alarm box which will actuate a distinctive fire alarm signal that can be heard throughout the facility.~~

~~2. Protective social care facilities provided with an automatic sprinkler system which complies with Chapter 9 and are provided with a manual fire alarm box which will actuate a distinctive fire alarm signal that can be heard throughout the facility.~~

**907.2.9 Group R-2 and R-2.1.** Fire alarm systems and smoke alarms shall be installed in Group R-2 and R-2.1 occupancies as required in Sections 907.2.9.1 and ~~907.9.2~~907.9.3.

**907.2.9.1 Manual fire alarm system.** A manual fire alarm system that activates the occupant notification system in accordance with Section 907.5 shall be installed in Group R-2 occupancies where:

1. Any dwelling unit or sleeping unit is located three or more stories above the lowest level of exit discharge;
2. Any dwelling unit or sleeping unit is located more than one story below the highest level of exit discharge of exits serving the dwelling unit or sleeping unit; or
3. The building contains more than 16 dwelling units or sleeping units.
4. Congregate living facilities or congregate residences with more than 16 occupants.

**Exceptions:**

1. A fire alarm system is not required in buildings not more than two stories in height where all dwelling units or sleeping units and contiguous attic and crawl spaces are separated from each other and public or common areas by at least 1-hour fire partitions and each dwelling unit or sleeping unit has an exit directly to a public way, exit court or yard.
2. Manual fire alarm boxes are not required where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2 and the occupant notification appliances will automatically activate throughout the notification zones upon a sprinkler waterflow.
3. A fire alarm system is not required in buildings that do not have interior corridors serving dwelling units and are protected by an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, provided that dwelling units either have a means of egress door opening directly to an exterior exit access that leads directly to the exits or are served by open-ended corridors designed in accordance with Section 1026.6, Exception 4.

**~~907.2.6.1.4~~ 907.2.9.3 Licensed Group ~~I-4~~R-2.1 occupancies.** *Licensed Group ~~I-4~~R-2.1 occupancies housing more than six non-ambulatory, elderly clients shall be provided with an approved manual and automatic fire alarm system.*

**Exceptions:** *Buildings housing non-ambulatory clients on the first story only and which are protected throughout by the following:*

1. *An approved and supervised automatic sprinkler system, as specified in Sections 903.3.1.1 or 903.3.1.2, which upon activation will initiate the fire alarm system to notify all occupants.*
2. *A manual fire alarm system.*
3. *Smoke alarms required by Section ~~907.2.10~~907.2.11.*

**907.2.11.1.1 Group R-1.** Single- or multiple-station smoke alarms shall be installed in all of the following locations in Group R-1:

1. In sleeping areas.
2. In every room in the path of the means of egress from the sleeping area to the door leading from the sleeping unit.
3. In each story within the sleeping unit, including basements. For sleeping units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.
4. ~~In enclosed common stairwells of multiple dwelling complexes.~~

**907.2.11.2 Groups R-2, R-2.1, R-3, R-3.1, and R-4 ~~and I-4~~.** Single- or multiple-station smoke alarms shall be installed and maintained in Groups R-2, R-2.1, R-3, R-3.1, and R-4 ~~and I-4~~ regardless of occupant load at all of the following locations:

1. On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of bedrooms.
2. In each room used for sleeping purposes.
3. In each story within a dwelling unit, including basements but not including crawl spaces and uninhabitable attics. In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the

lower level is less than one full story below the upper level.

~~4. In enclosed common stairwells of apartment complexes and other multiple-dwelling complexes.~~

~~5. In a Group R-3.1 occupancies, in addition to the above, smoke alarms shall be provided throughout the habitable areas of the dwelling unit except kitchens.~~

**907.2.13 High-rise buildings and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access.** ~~High-rise buildings with a floor used for human occupancy located more than 75 feet (22 860 mm) above the lowest level of fire department building access and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access shall be provided with an automatic smoke detection system in accordance with Section 907.2.13.1, a fire department communication system in accordance with Section 907.2.13.2 and an emergency voice/alarm communication system in accordance with Section 907.6.2.2.~~

**Exceptions:**

1. Airport traffic control towers in accordance with Section 907.2.22 and Section 412 of the ~~International~~ California Building Code.

2. Open parking garages in accordance with Section 406.3 of the ~~International~~ California Building Code.

3. Buildings with an occupancy in Group A-5 in accordance with Section 303.1 of the ~~International~~ California Building Code.

4. Low-hazard special occupancies in accordance with Section 503.1.1 of the ~~International~~ California Building Code.

~~5. Buildings with an occupancy in Group H-1, H-2 or H-3 in accordance with Section 415 of the International California Building Code.~~

~~6. In Group I-1 and I-2 and R-2.1 occupancies, the alarm shall sound at a constantly attended location and general occupant notification shall be broadcast by the emergency voice/alarm communication system.~~

**907.2.13.1 Automatic smoke detection.** Automatic smoke detection in high-rise buildings shall be in accordance with Sections 907.2.13.1.1 and 907.2.13.1.2.

~~907.2.12.1.1 Smoke Detection.~~ **907.2.13.1.1 Area smoke detection.** Area smoke detectors shall be provided in accordance with this section. Smoke detectors shall be connected to an automatic fire alarm system. The activation of any detector required by this section shall operate the emergency voice/alarm communication system in accordance with Section 907.6.2.2. Smoke detectors shall be located as follows:

1. In each mechanical equipment, electrical, transformer, telephone equipment or similar room which is not provided with sprinkler protection.

2. In each elevator machine room and in elevator lobbies.

~~907.2.12.1.2 Duct smoke detection.~~ **907.2.13.1.2 Duct smoke detection.** ~~Smoke detectors listed for use in air duct systems shall be provided in accordance with this section and the California Mechanical Code. The activation of any detector required by this section shall initiate a visible and audible supervisory signal at a constantly attended location. Duct smoke detectors shall be located as follows.~~ Duct smoke detectors complying with Section 907.4.1 shall be located as follows:

1. In the main return air and exhaust air plenum of each air-conditioning system having a capacity greater than 2,000 cubic feet per minute (cfm) (0.94 m<sup>3</sup>/s). Such detectors shall be located in a serviceable area downstream of the last duct inlet.

2. At each connection to a vertical duct or riser serving two or more stories from a return air duct or plenum of an air-conditioning system. In Group R-1 and R-2 occupancies, a smoke detector is allowed to be used in each return air riser carrying not more than 5,000 cfm (2.4 m<sup>3</sup>/s) and serving not more than 10 air-inlet openings.

**907.2.24.1 Sound Stages -Solid-ceiling Sets and Platforms.** ~~Where required by Chapter 48, All interior solid-ceiling sets over 600 square feet (55.7 m<sup>2</sup>) in area, and platforms (when provided) over 600 square feet (55.7 m<sup>2</sup>) in area and which exceed 3 feet (914 mm) in height shall be protected by one of the following: 1. An approved and listed heat detector system. Heat detectors shall be spaced 30 feet (9144 mm) on center or as required by the manufacturer's installation instructions. The fire alarm system detectors shall be connected to an approved and listed~~

~~central, proprietary or remote supervising station service in accordance with Section 907.7.5 or a local alarm which will give an audible signal at a constantly attended location. Such system shall be installed in accordance with this chapter.~~

~~2. The ceiling shall be positioned to allow for the operation of the building's automatic fire sprinkler system after rehearsal, videotaping, filming, or broadcasting of programs has been completed for the day.~~

~~3. An approved fire watch.~~

~~4. Special hazards shall be reviewed by the enforcing agency (see additional fire protection systems, Section 901.4.3.).~~

**907.2.24.2 Production Locations -Solid-Ceiling Sets and Platforms.** Where required by Chapter 48 in buildings with existing fire protection systems and where production intends to construct solid-ceiling sets over 600 square feet (55.7 m<sup>2</sup>) in area, and platforms over 600 square feet (55.7 m<sup>2</sup>) in area and which exceed 3 feet (914 mm) in height shall be protected by one of the following:

1. An approved ~~and listed~~ heat detector system. Heat detectors shall be spaced 30 feet (9144 mm) on center or as required by the manufacturer's installation instructions. ~~The fire alarm system Detectors shall be connected to an approved and listed central, proprietary or remote supervising station service in accordance with Section 907.7.5 or a local alarm which will give an audible signal at a constantly attended location. Such system shall be installed in accordance with this chapter.~~

~~2. The ceiling shall be positioned to allow for the operation of the building's automatic fire sprinkler system after rehearsal, videotaping, filming, or broadcasting of programs has been completed for the day.~~

~~3. An approved fire watch.~~

~~4. Special hazards shall be reviewed by the enforcing agency (see additional fire protection systems, Section 901.4.3.).~~

**907.2.24.3 Fire alarm control units.** Fire alarm control units shall be California State Fire Marshal listed and shall be utilized in accordance with their listing. Control units ~~may~~ are permitted to be temporarily supported by sets, platforms or pedestals.

#### **907.2.24.4 Heat Detectors.**

**907.2.24.4.1** Heat detection required by this section shall be defined as a portable system as it is intended to be reinstalled when platforms or sets are changed.

**907.2.24.4.2** Heat detectors shall be secured to standard outlet boxes ~~which may~~ and are allowed to be temporarily supported by sets, platforms or pedestals.

**907.2.24.4.3** Heat detectors shall be provided for solid-ceiling sets and platforms where required by Section ~~4605-34805.3 and 4611-14811.14.~~

**907.2.25.2 Camp Fire Alarm.** Every organized camp shall provide and maintain ~~a device audible appliances,~~ or devices suitable for sounding a fire alarm. Such ~~device audible appliances~~ or devices may be of any type acceptable to the enforcing agency provided they are distinctive in tone from all other signaling devices or systems and shall be audible throughout the camp premises. When an automatic fire alarm system is provided, as required by Section 440.6.6 of the California Building Code, all ~~signaling devices~~ audible appliances required by this section shall be of the same type as that used in the automatic system.

#### **907.2.26 Fixed Guideway Transits Systems Fire Alarm and Communication Systems.**

**907.2.26.1 General.** Every fixed guideway transit station shall be provided with an approved ~~fire alarm emergency voice/alarm communication~~ system in accordance with NFPA 72. ~~The alarm and emergency voice/alarm communication systems shall be proprietary,~~ designed and installed so that damage to any one speaker will not render any paging zone of the system inoperative.

**Exception:** Open stations

~~The voice alarm and public address system may be a combined system. When approved by the fire department, a communications system may be combined with the voice alarm system and the public address system. Such combined systems shall meet the requirements of the California Electric Code.~~

**907.2.26.2 System components.** Each station fire alarm system shall consist of:

1. Fire alarm control unit at a location as permitted by the enforcing agency.
2. An alarm annunciator(s). The annunciator(s) shall be located at a point acceptable to the enforcing agency. The annunciator(s) shall indicate the type of device and general location of alarm. All alarm, supervisory and trouble signals shall be transmitted to the local annunciator(s) and the OCC-operations control center.
3. Manual fire alarm boxes shall be provided throughout passenger platforms and stations.

**Exception:** ~~Voice alarm~~ Two-way emergency communication reporting devices (emergency telephones) may be allowed to be used in lieu of manual fire alarm boxes as permitted by the enforcing agency. Such devices shall provide two-way communication between the OCC-operations control center and each device. Such devices shall be located as required for manual fire alarm boxes, and shall be distinctly identified by signs, coloring, or other means acceptable to the enforcing agency.

4. Automatic smoke detectors in all ancillary spaces.

**Exceptions:**

1. Ancillary spaces protected by an approved fixed automatic extinguishing system; or
2. Ancillary spaces protected by quick-response sprinklers.

5. Automatic control of exiting components.

**907.2.26.3 Combined Emergency voice/ alarm communication public address system.** Each station shall be provided with a ~~one-way paging~~ an emergency voice/alarm communication system (s) capable of transmitting voice, ~~tape recorded or electronically generated textual~~ messages to all areas of the station. The system(s) shall be configured such that the messages can be initiated from either the Emergency Management Panel (EMP) or the OCC operations control center.

**907.2.26.4 Emergency telephones.** A dedicated two-way emergency communication phone system designed and installed in accordance with NFPA 72 shall be provided in all underground stations to facilitate direct communications for emergency response between remote locations and the EMP.

**907.2.26.4.1** ~~The~~ Remote emergency phones shall be located at ends of station platforms, each hose outlet connection and station valve rooms.

**907.2.26.4.2** Provisions shall be made in the design of this two-way emergency communication phone system for extensions of the system to the next passenger station or guideway portal.

**907.2.28 Group L.** A manual fire alarm system shall be installed throughout buildings containing Group L occupancy. When Group L occupancies are located in mixed use buildings, at least one manual fire alarm ~~pull~~ shall be located in the Group L occupancy.

**907.2.28.1 Group L occupancies located above the 10 story.** Manual fire alarm boxes shall be required on each side of the 2 hour fire-smoke barrier and at each exit above the 10th story.

**907.4.1 Duct smoke detectors.** ~~Smoke detectors installed in ducts shall be listed for the air velocity, temperature and humidity present in the duct.~~ Smoke detectors installed in ducts shall be listed for the air velocity, temperature and humidity present in the duct. Duct smoke detectors shall be connected to the building's fire alarm control ~~panel~~ unit when a fire alarm system is ~~required by Section 907.2~~ installed. Activation of a duct smoke detector shall initiate a visible and audible supervisory signal at a constantly attended location ~~and shall perform the intended fire safety function in accordance with this code and the~~ and shall perform the intended fire safety function in accordance with this code and the California Mechanical Code. Duct smoke detectors shall not be used as a substitute for

required open-area detection.

**Exceptions:**

1. The supervisory signal at a constantly attended location is not required where duct smoke detectors activate the building's alarm notification appliances.
2. In occupancies not required to be equipped with a fire alarm system, actuation of a smoke detector shall activate a visible and audible signal in an approved location. Smoke detector trouble conditions shall activate a visible or audible signal in an approved location and shall be identified as air duct detector trouble.

~~907.2.15.1-907.4.2.1~~ *In other than Group I<sub>1</sub> Occupancies-R-2.1 and Group R-4 Occupancies for single-story buildings smoke detectors shall be installed at ceilings throughout all occupied areas and mechanical/electrical spaces. For multiple-story buildings smoke detectors shall be installed throughout all occupied areas and mechanical/electrical spaces for the story where delayed egress devices are installed. Additional detectors are required on adjacent stories where occupants of those stories utilize the same means of egress.*

~~907.2.15.2-907.4.2.2~~ *For Group I and R-2.1 Occupancies. Smoke detectors shall be installed at ceilings throughout all occupied areas and mechanical/electrical spaces of smoke-compartments where delayed egress devices are installed. Additional detectors are required in adjacent smoke-compartments where occupants of those compartments utilize the same means of egress.*

~~907.2.15.3-907.4.2.3~~ *For Group R-4 Occupancies licensed as residential care facilities for the elderly, and housing clients with Alzheimer's disease or dementia residential facilities, smoke detectors shall be installed at ceilings throughout all occupiable rooms and areas and mechanical/electrical rooms and spaces.*

**907.5.1 Protection of fire alarm control unit.** In areas that are not continuously occupied, a single smoke detector shall be provided at the location of each fire alarm control unit, notification appliance circuit power extenders and supervising station transmitting equipment.

**Exceptions:**

1. Where ambient conditions prohibit installation of smoke detector, a *heat detector* shall be permitted.
- ~~2. The smoke detector shall not be required where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.~~

**907.5.2.5 Protective covers.** The fire code official is authorized to require the installation of listed manual fire alarm box protective covers to prevent malicious false alarms or to provide the manual fire alarm box with protection from physical damage. The protective cover shall be transparent or red in color with a transparent face to permit visibility of the manual fire alarm box. Each cover shall include proper operating instructions. A protective cover that emits a local alarm signal shall not be installed unless approved. Protective covers shall not project more than that permitted by Section 1003.3.3. ~~Each cover shall not exceed a combined projection over 4 inches (102 mm) from the surface of the wall into walks, halls, corridors, passageways or aisles.~~

~~907.4.5-907.5.2.6~~ **Operation.** *Manual fire alarm boxes shall be operable with one hand including boxes with protective covers.*

**907.6.2.1.1 Average sound pressure.** The audible alarm notification appliances shall provide a sound pressure level of 15 decibels (dBA) above the average ambient sound level or 5 dBA above the maximum sound level having a duration of at least 60 seconds, whichever is greater, in every occupiable space within the building. The minimum sound pressure levels shall be: 75 dBA in occupancies in Groups R-~~and I-1~~; 90 dBA in mechanical equipment rooms and 60 dBA in other occupancies.

~~907.10.2.1-907.6.2.1.3~~ **Audible Alarm Signal.** *The audible signal shall be the standard fire alarm evacuation signal, ANSI S34.1 Audible Emergency Evacuation Signal, "three pulse temporal pattern", as described in NFPA 72.*

**Exception:** *The use of the existing evacuation signaling scheme shall be permitted where approved by the enforcing agency.*

**907.6.2.2 Emergency voice/alarm communication system.** The emergency voice/alarm communication system shall be designed and installed in accordance with NFPA 72. The operation of any automatic fire detector, sprinkler water flow device or manual fire alarm box shall automatically sound an alert tone followed by voice instructions giving approved information and directions for a general or staged evacuation in accordance with the building's fire safety and evacuation plans required by Section 404. In high-rise buildings and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access, the system shall operate on a minimum of the alarming floor, the floor above and the floor below. Speakers shall be provided throughout the building by paging zones. At a minimum, paging zones shall be provided as follows:

1. Elevator groups
2. Exit stairways
3. Each floor
4. Areas of refuge as defined in Section 1002.1

**Exception:** In Group ~~I-1 and~~ I-2 and R-2.1 occupancies, the alarm shall sound in a constantly attended area and a general occupant notification shall be broadcast over the overhead page.

**907.6.2.3 Visible alarms.** Visible alarm notification appliances shall be provided in accordance with Sections 907.6.2.3.1 through ~~907.6.2.3.4~~ 907.6.2.3.5.

**Exceptions:**

1. *In other than Group I-2 and I-2.1, visible alarm notification appliances are not required in alterations, except where an existing fire alarm system is upgraded or replaced, or a new fire alarm system is installed.*
2. *Visible alarm notification appliances shall not be required in ~~exits as defined in Section 1002.1~~ enclosed exit stairways, exterior exit stairs, and exterior exit ramps.*
3. *Visible alarm notification appliances shall not be required in elevator cars.*

**907.6.2.3.3 Groups ~~I-1 and~~ R-1 and R-2.1.** Group ~~I-1 and~~ R-1 and R-2.1 dwelling units or sleeping units in accordance with Table 907.6.2.3.3 shall be provided with a visible alarm notification appliance, activated by both the in-room smoke alarm and the building fire alarm system.

**907.6.2.3.4 Group R-2.** In Group R-2 occupancies required by Section 907 to have a fire alarm system, all dwelling units and sleeping units shall be provided with the capability to support visible alarm notification appliances in accordance with ~~ICC-A117.1~~ NFPA 72.

~~907.10.1.5~~ **907.6.2.3.5 Group ~~I-1~~R-2.1, R-3.1 and R-4** *Protective social care facilities which house persons who are hearing impaired, shall be provided with notification appliances for the hearing impaired installed in accordance with NFPA 72 and which shall be activated upon initiation of the fire alarm system or the smoke alarms.*

**907.6.2.4 Group E Schools.** *An audible alarm notification appliance shall be mounted on the exterior of buildings to alert occupants in and around the playground area.*

**907.6.2.5 Groups I-2 and I-2.1.** *Audible appliances shall be used in non-patient areas. Visible appliances are allowed to be used in lieu of audible appliances in patient occupied areas. Audible appliances located in patient areas shall be only chimes or similar sounding appliances for alerting staff.*

*In occupancies housing non-ambulatory persons where restraint is practiced, staff and attendants shall be provided and housed or located in such a manner that such supervisory personnel will also be alerted upon activation of the fire alarm system or any detector required by this section.*

**907.7.3 Zones.** *Fire alarm systems shall be divided into zones where required by this section. For the purposes of annunciation and notification, zoning shall be in accordance with the following:*

1. *Where the fire-protective signaling system serves more than one building, each building shall be considered as a separate zone.*
2. *Each floor of a building shall be considered as a separate zone.*

3. Each section of floor of a building that is separated by fire walls or by horizontal exits shall be considered as a separate zone.
4. Each floor shall be zoned separately and a zone shall not exceed 22,500 square feet (2090 m<sup>2</sup>). The length of any zone shall not exceed 300 feet (91 440 mm) in any direction.

**Exception:** Automatic sprinkler system zones shall not exceed the area permitted by NFPA 13.

5. For Group I-3 Occupancies each cell complex shall be considered a separate zone.
6. For Group H and L occupancies above the 10th story, each side of the 2 hour fire-smoke barrier shall be considered a separate zone.
7. Annunciation shall be further divided into zones where deemed necessary by the enforcing agency.

~~907.7.3.1~~ **907.7.3.1.1 Zoning indicator Annunciator Panel.** A zoning indicator annunciator panel complying with ~~907.8.1~~ ~~907.7.3.1~~ and the associated controls shall be provided in an approved remote location where deemed necessary by the Enforcing Agency. The visual zone indication shall lock in until the system is reset and shall not be canceled by the operation of an audible alarm-silencing switch.

~~907.9.4~~ **907.7.3.3 Notification Zoning.** Upon activation of initiating devices where occupant notification is required for evacuation, all notification zones shall operate simultaneously throughout the building.

**Exceptions:**

1. High-rise buildings as permitted in Section 907.2.12.2,
2. Hospitals and convalescent facilities with staff alerting notification appliances or emergency voice/alarm communication, zoning shall be in accordance with the approved fire plan.
3. Detention facilities
4. Upon approval by the fire code official in buildings which are sprinklered throughout, specific notification zoning shall be permitted where the notification zones are separated by a minimum of a 2 hour fire barrier and 2 hour fire-resistive floor assembly. The system shall have the capability to activate all other notification zones by automatic and manual means.
5. Upon approval by the fire code official in buildings which are sprinklered throughout, specific notification zoning shall be permitted where the activated initiating device or fire extinguishing system is separated from any non-active notification zones by a minimum of 300 ft horizontal distance. The system shall have the capability to activate all other notification zones by automatic and manual means.
6. Where a Group H or L occupancy is located above the 10th story, each side of the 2 hr fire-smoke barrier shall be considered a separate zone.

**907.7.5 Monitoring.** Fire alarm systems required by this chapter or the ~~International~~ California Building Code shall be monitored by an approved supervising station in accordance with NFPA 72 and this section.

**Exception:** Supervisory service is not required for:

1. Single- and multiple-station smoke alarms required by Section 907.2.11.
2. ~~Smoke detectors in~~ Group I-3 occupancies shall be monitored in accordance with Section 907.2.6.3.4.
3. Automatic sprinkler systems in one- and two-family dwellings.

~~907.2.3.5~~ ~~Supervising Station~~ **907.7.5.2 Group E schools.** Fire alarm systems shall transmit the alarm, supervisory and trouble signals to an approved supervising station in accordance with NFPA 72. The supervising station shall be listed as either UUFX (Central Station) or UUJS (remote & proprietary) by the Underwriters Laboratory Inc. (UL) or shall comply with the requirements of standard, FM 3011.

**907.8 Acceptance tests.** Upon completion of the installation, the fire alarm system and all fire alarm components, ~~fire safety function control devices and interfaces, and off-site monitoring equipment~~ shall be tested in accordance with NFPA 72.

**909.12 Detection and control systems.** Fire detection systems providing control input or output signals to mechanical smoke control systems or elements thereof shall comply with the requirements of Section 907. Such systems shall be equipped with a control unit complying with UL 864 and listed as smoke control equipment.

Control systems for mechanical smoke control systems shall include provisions for verification. Verification shall include positive confirmation of actuation, testing, manual override, the presence of power downstream of all disconnects and, through a preprogrammed weekly test sequence, report abnormal conditions audibly, visually and by printed report.

The status of dampers shall be determined using limit or proximity switches installed at the damper or incorporated into the damper actuator. Where multiple dampers are grouped together in an assembly requiring one or more actuators, each damper shall be independently controlled by a separate actuator and provided with an individual limit or proximity switch, or the dampers shall be linked together by a reliable and durable mechanical means or otherwise by permanent means into one or more groups, with each group provided with a common limit or proximity switch.

The status of fans shall be determined by sensing the air flow downstream of the fans using pressure differential switches or transmitters, or by other means of positive proof of air flow where approved by the enforcing authority.

**909.12.1 Wiring.** In addition to meeting requirements of the **NEPA-70 California Electrical Code**, all wiring, regardless of voltage, shall be fully enclosed within continuous raceways.

**914.3.1 Automatic sprinkler system.** Buildings and structures shall be equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 and a secondary water supply where required by Section 903.3.5.2. *A sprinkler water-flow alarm-initiating device and a control valve with a supervisory signal-initiating device shall be provided at the lateral connection to the riser on each floor.*

**Exception:** An automatic sprinkler system shall not be required in ~~spaces or areas of:~~

- ~~1. Open parking garages in accordance with Section 406.3 of the *International California Building Code*.~~
- ~~2. Telecommunications equipment buildings used exclusively for telecommunications equipment, associated electrical power distribution equipment, batteries and standby engines, provided that those spaces or areas are equipped throughout with an automatic fire detection system in accordance with Section 907.2 and are separated from the remainder of the building by not less than 1 hour fire barriers constructed in accordance with Section 706 of the *International Building Code* or not less than 2 hour horizontal assemblies constructed in accordance with Section 711 of the *International Building Code*, or both.~~

~~**914.11 Motion Picture and Television Production Studio Sound Stages, Approved Production Facilities and Production Locations:**~~

~~**914.11.1 Existing Sound Stages and Approved Production Facilities.** *All existing sound stages and approved production facilities equipped with an automatic fire sprinkler system shall be maintained in accordance with the provisions in this chapter.*~~

~~**914.11.2 New Sound Stages.** *All new sound stages shall be equipped with an approved automatic fire sprinkler system. The system shall be installed in accordance with the provisions in this chapter and shall meet the minimum design requirements of an Extra Hazard, Group 2 system.*~~

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2, Public Education Code 17074.50

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[10. The SFM proposes to adopt Chapter 10 with the following amendments and California regulations.]**

**CHAPTER 10**

## MEANS OF EGRESS

**1001.1 General.** Buildings or portions thereof shall be provided with a means of egress system as required by this chapter. The provisions of this chapter shall control the design, construction and arrangement of means of egress components required to provide an approved means of egress from structures and portions thereof. Sections 1003 through 1026 shall apply to new construction. Sections 1030 shall apply to existing buildings.

**Exception:** Detached one- and two-family dwellings and multiple single-family dwellings (townhouses) not more than three stories above grade plane in height with a separate means of egress and their accessory structures shall comply with the ~~International~~ California Residential Code.

### SECTION 1002

~~**[B] PHOTOLUMINESCENT** is the property of emitting light as the result of absorption of visible light, which continues for a length time after excitation.~~

~~**[B] SELF-LUMINOUS** means powered continuously by a self-contained power source other than a battery or batteries, such as radioactive tritium gas. A self luminous sign is independent of external power supplies or other energy for its operation.~~

**1003.1 Applicability.** The general requirements specified in Sections 1003 through 1013 shall apply to all three elements of the means of egress system, in addition to those specific requirements for the exit access, the exit and the exit discharge detailed elsewhere in this chapter.

**Exception:** *Exiting requirements for Fixed Guideway Transit Systems shall be as per Section 433.3 of the California Building Code.*

**1003.2 Ceiling height.** The means of egress shall have a ceiling height of not less than 7 feet 6 inches (2286 mm).

**Exceptions:**

1. Sloped ceilings in accordance with Section 1208.2.
2. Ceilings of dwelling units and sleeping units within residential occupancies in accordance with Section 1208.2 of the ~~International~~ California Building Code.
3. Allowable projections in accordance with Section 1003.3.
4. Stair headroom in accordance with Section 1009.3.
5. Door height in accordance with Section 1008.1.1.
6. Ramp headroom in accordance with Section 1010.5.2.
7. The clear height of floor levels in vehicular and pedestrian traffic areas in parking garages in accordance with Section 406.2.2.
8. Areas above and below mezzanine floors in accordance with Section 505.1.
- ~~5-9. In Group I-2, I-2.1 and I-3 occupancies, the means of egress shall have a ceiling height of not less than 8 feet (2439mm).~~

**1003.3 Protruding objects.** Protruding objects shall comply with the requirements of Sections 1003.3.1 through 1003.3.4.

**Exception:** *In Group I-2 and Group I-2.1 occupancies, protruding objects shall not extend more than 12 inches (305 mm) below the minimum ceiling height required by Section 1003.2.*

**1003.3.3.1 Horizontal projections for Group I-2 occupancies.** *Structural elements, fixtures or furnishings shall not project horizontally from either side more than 1-1/2 inches (38 mm) into the required width of an exit access corridor serving any area caring for one or more non-ambulatory or bedridden persons.*

**Exceptions:**

1. Handrails are permitted to protrude 3 1/2 inches (89 mm) from the wall.
2. Alcohol-based hand-rub dispensers are permitted to protrude 4 inches.

3. Manual fire alarm boxes with a protective cover installed are permitted to protrude 4 inches.

**1003.3.4 Clear width.** Protruding objects shall not reduce the minimum clear width of accessible routes as required in Section 1104 of the ~~International~~ California Building Code

**1003.5 Elevation change.** Where changes in elevation of less than 12 inches (305 mm) exist in the means of egress, sloped surfaces shall be used. Where the slope is greater than one unit vertical in 20 units horizontal (5-percent slope), ramps complying with Section 1010 shall be used. Where the difference in elevation is 6 inches (152 mm) or less, the ramp shall be equipped with either handrails or floor finish materials that contrast with adjacent floor finish materials.

**Exceptions:**

1. A single step with a maximum riser height of 7 inches (178 mm) is permitted for buildings with occupancies in Groups F, H, R-2 and R-3 and Groups S and U at exterior doors not required to be accessible by Chapter 11 of the ~~International~~ California Building Code.
2. A stair with a single riser or with two risers and a tread is permitted at locations not required to be accessible by Chapter 11 of the ~~International~~ California Building Code, provided that the risers and treads comply with Section 1009.4, the minimum depth of the tread is 13 inches (330 mm) and at least one handrail complying with Section 1012 is provided within 30 inches (762 mm) of the centerline of the normal path of egress travel on the stair.
3. A step is permitted in aisles serving seating that has a difference in elevation less than 12 inches (305 mm) at locations not required to be accessible by Chapter 11 of the ~~International~~ California Building Code, provided that the risers and treads comply with Section 1028.11 and the aisle is provided with a handrail complying with Section 1028.13.

Throughout a story in a Group I-2 and Group I-2.1 occupancy<sup>ies</sup>, any change in elevation in portions of the exit access that serve nonambulatory persons shall be by means of a ramp or sloped walkway.

**TABLE 1004.1.1  
MAXIMUM FLOOR AREA ALLOWANCES PER OCCUPANT**

<b>FUNCTION OF SPACE</b>	<b>FLOOR AREA IN SQ. FT. PER OCCUPANT</b>
Accessory storage areas, mechanical equipment room	300 gross
Agricultural building	300 gross
Aircraft hangars	500 gross
Airport terminal	
Baggage claim	20 gross
Baggage handling	300 gross
Concourse	100 gross
Waiting areas	15 gross
Assembly	
Gaming floors (keno, slots, etc.)	11 gross
Assembly with fixed seats	See Section 1004.7
Assembly without fixed seats	
Concentrated (chairs only-not fixed)	7 net
Standing space	5 net
Unconcentrated (tables and chairs)	15 net
Bowling centers, allow 5 persons for each lane including 15 feet of runway, and for	

additional areas	7 net
Business areas	100 gross
Courtrooms-other than fixed seating areas	40 net
Day care	35 net
Dormitories	50 gross
Educational Classroom area	20 net
Shops and other vocational room areas	50 net
Exercise rooms	50 gross
H-5 Fabrication and manufacturing areas	200 gross
Industrial areas	100 gross
Institutional areas	
Inpatient treatment areas	240 gross
Outpatient areas	100 gross
Sleeping areas	120 gross
Kitchens, commercial	200 gross
Laboratory	
Educational	50 net
Laboratories, non-educational	100 net
Laboratory suite <sup>a</sup>	200 gross
Library	
Reading rooms	50 net
Stack area	100 gross
Locker rooms	50 gross
Mercantile	
Areas on other floors	60 gross
Basement and grade floor areas	30 gross
Storage, stock, shipping areas	300 gross
Parking garages	200 gross
Residential	200 gross
Skating rinks, swimming pools	
Rink and pool	4550 gross
Decks	5015 gross
Stages and platforms	15 net
Warehouses	500 gross

For SI: 1 square foot = 0.0929 m2.

<sup>a</sup> See section 443.2 of the California Building Code.

**TABLE 1005.1 EGRESS WIDTH PER OCCUPANT SERVED**

OCCUPANCY	WITHOUT SPRINKLER SYSTEM		WITH SPRINKLER SYSTEM <sup>a</sup>	
	Stairways (inches per occupant)	Other egress components (inches per occupant)	Stairways (inches per occupant)	Other egress components (inches per occupant)
Hazardous: H-1, H-2, H-3 and H-4	NA	NA	0.7	0.4

~~b— See Section 1025~~

**1005.1 Minimum required egress width.** The means of egress width shall not be less than required by this section. The total width of means of egress in inches (mm) shall not be less than the total occupant load served by the means of egress multiplied by 0.3 inches (7.62 mm) per occupant for stairways and by 0.2 inches (5.08 mm) per occupant for other egress components. The width shall not be less than specified elsewhere in this code. Multiple means of egress shall be sized such that the loss of any one means of egress shall not reduce the available capacity to less than 50 percent of the required capacity. The maximum capacity required from any story of a building shall be maintained to the termination of the means of egress.

**Exceptions:**

1. Means of egress complying with Section 1028.
2. For Group H-1, H-2, H-3 and H-4 occupancies the total width of means of egress in inches (mm) shall not be less than the total occupant load served by the means of egress multiplied by 0.7 inches (7.62 mm) per occupant for stairways and by 0.4 inches (5.08 mm) per occupant for other egress components.

**1005.3 Door hardware encroachment.** In other than Group I-2 occupancies, ~~S~~ surface-mounted latch release hardware shall be exempt from inclusion in the 7-inch (178 mm) maximum projection requirement of Section 1005.2 when:

1. The hardware is mounted to the side of the door facing the corridor width when the door is in the open position; and
2. The hardware is mounted not less than 34 inches (865 mm) or more than 48 inches (1220 mm) above the finished floor.

**1006.1 Illumination required.** The means of egress, including the exit discharge, shall be illuminated at all times the building space served by the means of egress is occupied.

**Exceptions:**

1. Occupancies in Group U.
2. Aisle accessways in Group A.
3. Dwelling units and sleeping units in Groups R-1, R-2 and R-3.
4. Sleeping units of Group I, R-2.1 and R-4 occupancies ~~and Group R-4.~~

**1006.3 Illumination emergency power.** The power supply for means of egress illumination shall normally be provided by the premises' electrical supply.

In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas.

1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.
2. Corridors, exit enclosures and exit passageways in buildings required to have two or more exits.
3. Exterior egress components at other than the level of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.
4. Interior exit discharge elements, as permitted in Section 1027.1, in building required to have two or more exits.
5. Exterior landings, as required by Section 1008.1.6, for exit discharge doorways in buildings required to have two or more exits.

The emergency power system shall provide power for duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Chapter 27 of the ~~International~~ California Building Code.

**1007.1 Accessible means of egress required.** Accessible means of egress shall comply with this section. Accessible spaces shall be provided with not less than one accessible means of egress. Where more than one means of egress is required by Section 1015.1 or 1021.1 from any accessible space, each accessible portion of the space shall be served by ~~not less than two~~ accessible means of egress *in at least the same number as required by*

Section 1015.1 or ~~1019.1~~1021.1. In addition to the requirements of this chapter, means of egress, which provide access to, or egress from, buildings for persons with disabilities, shall also comply with the requirements of Chapters 11A or 11B of the California Building Code, as applicable.

**Exceptions:**

1. Accessible means of egress are not required in alterations to existing buildings.
2. One accessible means of egress is required from an accessible mezzanine level in accordance with Section 1007.3, 1007.4 or 1007.5.
3. In assembly spaces with sloped floors, one accessible means of egress is required from a space where the common path of travel of the accessible route for access to the wheelchair spaces meets the requirements in Section 1028.8.

**1007.2 Continuity and components.** Each required accessible means of egress shall be continuous to a public way and shall consist of one or more of the following components:

1. Accessible routes complying with Section 1104 of the ~~International~~ California Building Code.
2. Interior exit stairways complying with Sections 1007.3 and 1022.
3. Exterior exit stairways complying with Sections 1007.3 and 1026.
4. Elevators complying with Section 1007.4.
5. Platform lifts complying with Section 1007.5.
6. Horizontal exits complying with Section 1025.
7. Ramps complying with Section 1010.
8. Areas of refuge complying with Section 1007.6.

**Exceptions:**

1. Where the exit discharge is not accessible, an exterior area for assisted rescue must be provided in accordance with Section 1007.7.
2. Where the exit stairway is open to the exterior, the accessible means of egress shall include either an area of refuge in accordance with Section 1007.6 or an exterior area for assisted rescue in accordance with Section 1007.7.

**1007.4 Elevators.** In order to be considered part of an accessible means of egress, an elevator shall comply with the emergency operation and signaling device requirements of Section 2.27 of ASME A17.1. Standby power shall be provided in accordance with Section 604.2.5 of this code and Section 3003 of the ~~International~~ California Building Code. The elevator shall be accessed from either an area of refuge complying with Section 1007.6 or a horizontal exit.

1. Elevators are not required to be accessed from an area of refuge or horizontal exit in open parking garages.
2. Elevators are not required to be accessed from an area of refuge or horizontal exit in buildings and facilities equipped throughout by an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.
3. Elevators not required to be located in a shaft in accordance with Section 708.2 of the International Building Code are not required to be accessed from an area of refuge or horizontal exit.
4. Elevators are not required to be accessed from an area of refuge or horizontal exit for smoke protected seating areas complying with Section 1028.6.2.

**1007.5 Platform lifts.** Platform (wheelchair) lifts shall not serve as part of an accessible means of egress, except where allowed as part of a required accessible route in Section 1109.7, Items 1 through 9 of the ~~International~~ California Building Code. Standby power shall be provided in accordance with Section 604.2.6 for platform lifts permitted to serve as part of a means of egress.

**1007.6.1 Size.** Each area of refuge shall be sized to accommodate ~~one~~ two wheelchair spaces that are not less than 30 inches by 48 inches (762 mm by 1219 mm). ~~The total number of such 30-inch by 48-inch (762 mm by 1219 mm) spaces per story shall be not less than one for every 200 persons of calculated occupant load served by the area of rescue refuge. for each 200 occupants or portion thereof, based on the occupant load of the area of refuge and areas served by the area of refuge.~~ Such wheelchair spaces shall not reduce the required means of egress width. Access to

any of the required wheelchair spaces in an area of refuge shall not be obstructed by more than one adjoining wheelchair space

**Exception:** *The enforcing agency may reduce the size of each required area of refuge to accommodate one wheelchair space that is not less than 30 inches by 48 inches on floors where the occupant load is less than 200.*

**1007.6.2 Separation.** Each area of refuge shall be separated from the remainder of the story by a smoke barrier complying with Section 710 of the ~~International~~ *California Building Code* or a horizontal exit complying with Section 1025. Each area of refuge shall be designed to minimize the intrusion of smoke.

**Exception:** Areas of refuge located within an exit enclosure.

**1007.7 Exterior area for assisted rescue.** The exterior area for assisted rescue must be open to the outside air and meet the requirements of Section 1007.6.1. Separation walls shall comply with the requirements of Section 704 of the ~~International~~ *California Building Code* for exterior walls. Where walls or openings are between the area for assisted rescue and the interior of the building, the building exterior walls within 10 feet (3048 mm) horizontally of a nonrated wall or unprotected opening shall have a fire-resistance rating of not less than 1 hour. Openings within such exterior walls shall be protected by opening protectives having a fire protection rating of not less than  $\frac{3}{4}$  hour. This construction shall extend vertically from the ground to a point 10 feet (3048 mm) above the floor level of the area for assisted rescue or to the roof line, whichever is lower.

~~1007.9~~ **1007.12 Alarms/emergency warning systems/accessibility.** *If emergency warning systems are required, they shall activate a means of warning the hearing impaired. Emergency warning systems as part of the fire-alarm system shall be designed and installed in accordance with NFPA 72 as amended in Chapter 45.*

**1008.1.1 Size of doors.** The minimum width of each door opening shall be sufficient for the occupant load thereof and shall provide a clear width of not less than 32 inches (813 mm). Clear openings of doorways with swinging doors shall be measured between the face of the door and the stop, with the door open 90 degrees (1.57 rad). Where this section requires a minimum clear width of 32 inches (813 mm) and a door opening includes two door leaves without a mullion, one leaf shall provide a clear opening width of 32 inches (813 mm). The maximum width of a swinging door leaf shall be 48 inches (1219 mm) nominal. Means of egress doors in a Group I-2 occupancy used for the movement of beds *and litter patients* shall provide a clear width not less than ~~44.5~~ 44 inches (1054 mm). The height of doors shall not be less than 80 inches (2032 mm).

**Exceptions:**

1. The minimum and maximum width shall not apply to door openings that are not part of the required means of egress in Group R-2 and R-3 occupancies.
2. Door openings to resident sleeping units in Group I-3 occupancies shall have a clear width of not less than 28 inches (711 mm).
3. Door openings to storage closets less than 10 square feet (0.93 m<sup>2</sup>) in area shall not be limited by the minimum width.
4. Width of door leaves in revolving doors that comply with Section 1008.1.4.1 shall not be limited.
5. Door openings within a dwelling unit or sleeping unit shall not be less than 78 inches (1981 mm) in height.
6. Exterior door openings in dwelling units and sleeping units, other than the required exit door, shall not be less than 76 inches (1930 mm) in height.
7. In other than Group R-1 occupancies, the minimum widths shall not apply to interior egress doors within a dwelling unit or sleeping unit that is not required to be an Accessible unit, Type A unit or Type B unit .

**1008.1.1.1 Projections into clear width.** There shall not be projections into the required clear width lower than 34 inches (864 mm) above the floor or ground. Projections into the clear opening width between 34 inches (864 mm) and 80 inches (2032 mm) above the floor or ground shall not exceed 4 inches (102 mm).

**Exceptions:**

1. Door closers and door stops shall be permitted to be 78 inches (1980 mm) minimum above the floor.
2. *In a Group I-2 occupancy, there shall be no projections into the clear width of doors used for the movement of beds and litter patients in the means of egress.*

**1008.1.2 Door swing.** Egress doors shall be of the pivoted or side-hinged swinging type.

**Exceptions:**

1. Private garages, office areas, factory and storage areas with an occupant load of 10 or less.
2. Group I-3 occupancies used as a place of detention.
3. Critical or intensive care patient rooms within suites of health care facilities.
4. Doors within or serving a single dwelling unit in Groups R-2 and R-3.
5. In other than Group H occupancies, revolving doors complying with Section 1008.1.4.1.
6. In other than Group H occupancies, horizontal sliding doors complying with Section 1008.1.4.3 are permitted in a means of egress.
7. Power-operated doors in accordance with Section 1008.1.4.2.
8. Doors serving a bathroom within an individual sleeping unit in Group R-1.
9. In other than Group H occupancies, manually operated horizontal sliding doors are permitted in a means of egress from spaces with an occupant load of 10 or less.
- ~~9-10.~~ *In I-2 and I-2.1 occupancies, exit doors serving an occupant load of 10 or more, may be of the pivoted or balanced type.*

Doors shall swing in the direction of egress travel where serving an occupant load of 50 or more persons or a Group H occupancy. *For Group L occupancies see Section 443.6.3.*

*In a Group I-2 occupancy, all required exterior egress doors shall open in the direction of egress regardless of the occupant load served.*

**1008.1.4.3 Horizontal sliding doors.** In other than Group H occupancies, horizontal sliding doors permitted to be a component of a means of egress in accordance with Exception 5 to Section 1008.1.2 shall comply with all of the following criteria:

1. The doors shall be power operated and shall be capable of being operated manually in the event of power failure.
2. The doors shall be openable by a simple method from both sides without special knowledge or effort.
3. The force required to operate the door shall not exceed 30 pounds (133 N) to set the door in motion and 15 pounds (67 N) to close the door or open it to the minimum required width.
4. The door shall be openable with a force not to exceed 15 pounds (67 N) when a force of 250 pounds (1100 N) is applied perpendicular to the door adjacent to the operating device.
5. The door assembly shall comply with the applicable fire protection rating and, where rated, shall be self-closing or automatic closing by smoke detection in accordance with Section 715.4.8.3 of the ~~International~~ *California Building Code*, shall be installed in accordance with NFPA 80 and shall comply with Section 715 ~~International~~ *California Building Code*.
6. The door assembly shall have an integrated standby power supply.
7. The door assembly power supply shall be electrically supervised.
8. The door shall open to the minimum required width within 10 seconds after activation of the operating device.

**1008.1.4.4 Access-controlled egress doors.** The entrance doors in a means of egress in buildings with an occupancy in Group A, B, ~~E~~, M, R-1 or R-2 and entrance doors to tenant spaces in occupancies in Groups A, B, ~~E~~, M, R-1 and R-2, ~~that are equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 and an approved automatic smoke detection system installed in accordance with Section 907,~~ are permitted to be equipped with an approved entrance and egress access control system which shall be installed in accordance with all of the following criteria:

1. A sensor shall be provided on the egress side arranged to detect an occupant approaching the doors. The doors shall be arranged to unlock by a signal from or loss of power to the sensor.
2. Loss of power to that part of the access control system which locks the doors shall automatically unlock the doors.
3. The doors shall be arranged to unlock from a manual unlocking device located 40 inches to 48 inches (1016 mm to 1219 mm) vertically above the floor and within 5 feet (1524 mm) of the secured doors. Ready access

shall be provided to the manual unlocking device and the device shall be clearly identified by a sign that reads "PUSH TO EXIT." When operated, the manual unlocking device shall result in direct interruption of power to the lock—independent of the access control system electronics—and the doors shall remain unlocked for a minimum of 30 seconds.

4. Activation of the building fire alarm system, if provided, shall automatically unlock the doors, and the doors shall remain unlocked until the fire alarm system has been reset.
5. Activation of the building automatic sprinkler or fire detection system, if provided, shall automatically unlock the doors. The doors shall remain unlocked until the fire alarm system has been reset.
6. Entrance doors in buildings with an occupancy in Group A, B, ~~E-1-2~~ or M shall not be secured from the egress side during periods that the building is open to the general public.

**1008.1.4.6 Access-controlled elevator lobby egress doors.** *When approved by the fire chief, the entrance doors within an elevator lobby in a means of egress of highrise buildings serving offices that are equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 and an approved automatic smoke detection system installed in accordance with Section 907, are permitted to be equipped with an approved entrance and egress access control system which shall be installed in accordance with all of the following criteria:*

1. Locks for the elevator lobby shall be U.L. and California State Fire Marshal listed fail-safe type locking mechanisms. The locking device shall automatically release on activation of any fire alarm device on the floor of alarm (waterflow, smoke detector, manual pull station, etc.) All locking devices shall unlock, but not unlatch, upon activation.
2. A two-way voice communication system, utilizing dedicated lines, shall be provided from each locked elevator lobby to the 24-hour staffed location on site, annunciated as to location. Operating instructions shall be posted above each two-way communication device.
3. Provide an approved momentary mushroom-shaped palm button connected to the doors and installed adjacent to each locked elevator lobby exit door which will release the door locks when operated by an individual in the elevator lobby. The locks shall be reset manually at the door. Mount palm button so that center line is 48 inches above finish door.

*Provide a sign stating:*

"IN CASE OF EMERGENCY, PUSH PALM BUTTON. DOOR WILL UNLOCK AND SECURITY ALARM WILL SOUND."

*The sign lettering shall be 3/4-inch high letters by 1/8-inch width stroke on a contrasting background.*

4. Loss of power to that part of the access control system which locks the doors shall automatically unlock the doors.

~~1008.1.3.6~~ **1008.1.4.7 Special provisions.** *School classrooms constructed after January 1, 1990, not equipped with automatic sprinkler systems, which have metal grilles or bars on all their windows and do not have at least two exit doors within 3 feet (914 mm) of each end of the classroom opening to the exterior of the building or to a common hallway used for evacuation purposes, shall have an inside release for the grilles or bars on at least one window farthest from the exit doors. The window or windows with the inside release shall be clearly marked as emergency exits.*

**1008.1.7 Thresholds.** Thresholds at doorways shall not exceed 0.75 inch (19.1 mm) in height for sliding doors serving dwelling units or 0.5 inch (12.7 mm) for other doors. Raised thresholds and floor level changes greater than 0.25 inch (6.4 mm) at doorways shall be beveled with a slope not greater than one unit vertical in two units horizontal (50-percent slope).

**Exception:** The threshold height shall be limited to 7.75 inches (197 mm) where the occupancy is Group R-2 or R-3; the door is an exterior door that is not a component of the required means of egress; the door, other than an exterior storm or screen door does not swing over the landing or step; and the doorway is not on an accessible route as required by Chapter 11 of the ~~International Building Code~~ and is not part of an Accessible unit, Type A unit or Type B unit.

**1008.1.9.1 Hardware.** Door handles, pulls, latches, locks and other operating devices on doors required to be accessible by Chapter 11A or 11B of the ~~International Building Code~~ *California Building Code* shall not require tight grasping, tight pinching or twisting of the wrist to operate.

**1008.1.9.6 Special locking arrangements in Group I-2.** ~~Approved delayed egress locks shall be permitted in a Group I-2 occupancy where the clinical needs of persons receiving care require such locking. Delayed egress locks shall be permitted in such occupancies where the building is equipped throughout with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or an *approved* automatic smoke or heat detection system installed in accordance with Section 907, provided that the doors unlock in accordance with Items 1 through 6 below. A building occupant shall not be required to pass through more than one door equipped with a delayed egress lock before entering an exit.~~

- ~~1. The doors unlock upon actuation of the *automatic sprinkler system* or automatic fire detection system.~~
- ~~2. The doors unlock upon loss of power controlling the lock or lock mechanism.~~
- ~~3. The door locks shall have the capability of being unlocked by a signal from the fire command center, a nursing station or other *approved* location.~~
- ~~4. The procedures for the operation(s) of the unlocking system shall be described and *approved* as part of the emergency planning and preparedness required by Chapter 4 of the *International Fire Code*.~~
- ~~5. All clinical staff shall have the keys, codes or other means necessary to operate the locking devices.~~
- ~~6. Emergency lighting shall be provided at the door.~~

**Exception:** ~~Items 1 through 3 shall not apply to doors to areas where persons, because of clinical needs, require restraint or containment as part of the function of a mental hospital.~~

Reserved.

**1008.1.9.9 Locking arrangements in correctional facilities.** ~~In occupancies in Groups A-2, A-3, A-4, B, E, F, I-2, I-3, M and S within correctional and detention facilities, doors in means of egress serving rooms or spaces occupied by persons whose movements are controlled for security reasons shall be permitted to be locked when equipped with egress control devices which shall unlock manually and by at least one of the following means:~~

- ~~1. Activation of an automatic sprinkler system installed in accordance with Section 903.3.1.1,~~
- ~~2. Activation of an approved manual alarm box, or~~
- ~~3. A signal from a constantly attended location.~~

Reserved.

**1008.1.9.7 Delayed egress locks.** ~~Approved, listed, delayed egress locks shall be permitted to be installed on doors serving any occupancy except Group A, E, and H, and L occupancies in buildings that are equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or and an approved automatic smoke or heat detection system installed in accordance with Section 907, provided that the doors unlock in accordance with Items 1 through 6 9 below. A building occupant shall not be required to pass through more than one door equipped with a delayed egress lock before entering an exit. *Delayed egress devices shall conform to all of the following:*~~

- ~~1. The doors unlock upon actuation of the automatic sprinkler system or automatic ~~fire~~ *smoke* detection system.~~
- ~~2. The doors unlock upon loss of *electrical* power ~~controlling the lock or lock mechanism~~ to any one of the following:~~

- ~~2.1 *The egress-control device itself.*~~
- ~~2.2 *The smoke detection system.*~~
- ~~2.3 *Means of egress illumination as required by Section 1006.*~~

- ~~3. The door locks shall have the capability of being unlocked by a signal from ~~the fire command center~~ *a switch located in an approved location.*~~
- ~~4. The initiation of an irreversible process which will release the latch in not more than 15 seconds when a force of not more than 15 pounds (67 N) is applied for 1 second to the release device. Initiation of the irreversible process shall activate an audible signal in the vicinity of the door. Once the door lock has been released by the application of force to the releasing device, relocking shall be by manual means only. *The time delay established for each egress-control device shall not be field adjustable.*~~

**Exception:** ~~Where approved, In facilities housing Alzheimer's or dementia clients, a delay of not more than 30 seconds is permitted.~~

- ~~5. A sign shall be provided on the door located above and within 12 inches (305 mm) of the release device reading: ~~PUSH UNTIL ALARM SOUNDS. DOOR CAN BE OPENED IN 15 [30] SECOMDS.~~ "KEEP PUSHING. THIS DOOR WILL OPEN IN 15 [30] SECONDS. ALARM WILL SOUND" *Sign lettering shall be at least 1 inch (25mm)*~~

*in height and shall have a stroke of not less than 1/8 inch (3.2 mm). A tactile sign shall also be provided in Braille and raised characters, which complies with Section 1117B.5.1.1.*

6. Emergency lighting shall be provided at the door.
7. *Actuation of the panic bar or other door-latching hardware shall activate an audible signal at the door.*
8. *The unlatching shall not require more than one operation.*
9. *Regardless of the means of deactivation, relocking of the egress-control device shall be by manual means only at the door.*

**1008.1.9.10 Stairway doors.** Interior stairway means of egress doors shall be openable from both sides without the use of a key or special knowledge or effort.

**Exceptions:**

1. Stairway discharge doors shall be openable from the egress side and shall only be locked from the opposite side.
2. This section shall not apply to doors arranged in accordance with Section 403.5.3 of the *International California Building Code*.
3. In stairways serving not more than four stories, doors are permitted to be locked from the side opposite the egress side, provided they are openable from the egress side and capable of being unlocked simultaneously without unlatching upon a signal from the fire command center, if present, or a signal by emergency personnel from a single location inside the main entrance to the building.

**1008.1.10 Panic and fire exit hardware.** Doors serving a Group H occupancy and doors serving rooms or spaces with an occupant load of 50 or more in a Group A occupancy, *assembly area not classified as an assembly occupancy, E, I-2 or I-2.1 occupancies* shall not be provided with a latch or lock unless it is panic hardware or fire exit hardware. *For Group L occupancies see Section ~~443.6.4~~ 443.6.3.*

**Exception:** A main exit of a Group A occupancy in compliance with Section 1008.1.9.3, Item 2.

Electrical rooms with equipment rated 1,200 amperes or more and over 6 feet (1829 mm) wide that contain overcurrent devices, switching devices or control devices with exit or exit access doors shall be equipped with panic hardware or fire exit hardware. The doors shall swing in the direction of egress travel.

**1009.1 Stairway width.** The width of stairways shall be determined as specified in Section 1005.1, but such width shall not be less than 44 inches (1118 mm). See Section 1007.3 for accessible means of egress stairways.

**Exceptions:**

1. Stairways serving an occupant load of less than 50 shall have a width of not less than 36 inches (914 mm).
2. Spiral stairways as provided for in Section 1009.9.
3. Aisle stairs complying with 1028.
4. Where an incline platform lift or stairway chairlift is installed on stairways serving occupancies in Group R-3, or within dwelling units in occupancies in Group R-2, a clear passage width not less than 20 inches (508 mm) shall be provided. If the seat and platform can be folded when not in use, the distance shall be measured from the folded position.

*Means of egress stairs in a Group I-2 occupancy used for the movement of beds and litter patients shall provide a clear width not less than 44 inches (1118 mm).*

**1009.4.2 Riser height and tread depth.** Stair riser heights shall be 7 inches (178 mm) maximum and 4 inches (102 mm) minimum. The riser height shall be measured vertically between the leading edges of adjacent treads. Rectangular tread depths shall be 11 inches (279 mm) minimum measured horizontally between the vertical planes of the foremost projection of adjacent treads and at a right angle to the tread's leading edge. Winder treads shall have a minimum tread depth of 11 inches (279 mm) measured between the vertical planes of the foremost projection of adjacent treads at the intersections with the walkline and a minimum tread depth of 10 inches (254 mm) within the clear width of the stair.

**Exceptions:**

1. Alternating tread devices in accordance with Section 1009.10.
2. Ship ladders in accordance with Section 1009.11.
3. Spiral stairways in accordance with Section 1009.9.
4. Aisle stairs in assembly seating areas where the stair pitch or slope is set, for sightline reasons, by the slope of the adjacent seating area in accordance with Section 1028.11.2.
5. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; the maximum riser height shall be 7¾ inches (197 mm); the minimum tread depth shall be 10 inches (254 mm); the minimum winder tread depth at the walkline shall be 10 inches (254 mm); and the minimum winder tread depth shall be 6 inches (152 mm). A nosing not less than ¾ inch (19.1 mm) but not more than 1¼ inches (32 mm) shall be provided on stairways with solid risers where the tread depth is less than 11 inches (279 mm).
6. See Section 3404.1 for the replacement of existing stairways.
7. In Group I-3 facilities, stairways providing access to guard towers, observation stations and control rooms, not more than 250 square feet (23 m<sup>2</sup>) in area, shall be permitted to have a maximum riser height of 8 inches (203 mm) and a minimum tread depth of 9 inches (229 mm).
8. [SFM] Stairways providing access to Lifeguard towers not open to the public, not more than 250 square feet (23 m<sup>2</sup>) in area, shall be permitted to have a maximum riser height of 8 inches (203 mm) and a minimum tread depth of 9 inches (229 mm).

**1009.5 Stairway landings.** There shall be a floor or landing at the top and bottom of each stairway. The width of landings shall not be less than the width of stairways they serve. Every landing shall have a minimum dimension measured in the direction of travel equal to the width of the stairway. Such dimension need not exceed 48 inches (1219 mm) where the stairway has a straight run. Doors opening onto a landing shall not reduce the landing to less than one-half the required width. When fully open, the door shall not project more than 7 inches (178 mm) into a landing. When wheelchair spaces are required on the stairway landing in accordance with Section 1007.6.1, the wheelchair space shall not be located in the required width of the landing and doors shall not swing over the wheelchair spaces.

**Exceptions:**

1. Aisle stairs complying with Section 1028.
- ~~2.~~ *In Group R-3 occupancies a floor or landing is not required at the top of an interior flight of stairs, including stairs in an enclosed garage, provided a door does not swing over the stairs.*

**1009.12 Handrails.** Stairways shall have handrails on each side and shall comply with Section 1012. Where glass is used to provide the handrail, the handrail shall also comply with Section 2407.

**Exceptions:**

1. Handrails for aisle stairs are not required where permitted by Section 1028.13.
2. Stairways within dwelling units, spiral stairways and aisle stairs serving seating only on one side are permitted to have a handrail on one side only.
3. Decks, patios and walkways that have a single change in elevation where the landing depth on each side of the change of elevation is greater than what is required for a landing do not require handrails.
4. In Group R-3 occupancies, ~~a change in elevation consisting of a single riser at an entrance or egress door does not require handrails~~ *a continuous run of treads or flight of stairs with less than four risers does not require handrails.*
5. Changes in room elevations of three or fewer risers within dwelling units and sleeping units in Group R-2 and R-3 do not require handrails.

**1009.13.1 Roof access.** Where a stairway is provided to a roof, access to the roof shall be provided through a penthouse complying with Section 1509.2 of the ~~International~~ *California Building Code*.

**Exception:** In buildings without an occupied roof, access to the roof shall be permitted to be a roof hatch or trap door not less than 16 square feet (1.5 m<sup>2</sup>) in area and having a minimum dimension of 2 feet (610 mm).

**1011.1 Where required.** Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where the exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that no point in an exit access corridor or exit passageway is more than 100 feet (30 480 mm) or the listed viewing distance for the sign, whichever is less, from the nearest visible exit sign.

**Exceptions:**

1. Exit signs are not required in rooms or areas that require only one exit or exit access.
2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the building official.
3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2, ~~or R-3~~ *or R-3.1*.
4. Exit signs are not required ~~in dayrooms, sleeping rooms or dormitories~~ *where inmates are housed, or held in occupancies in Group I-3.*
5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of vomitories or openings into seating areas where exit signs are provided in the concourse that are readily apparent from the vomitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency.

**1011.3 Tactile exit signs.** ~~A tactile sign stating EXIT and complying with IGC A117.1 shall be provided adjacent to each door to an area of refuge, an exterior area for assisted rescue, an exit stairway, an exit ramp, an exit passageway and the exit discharge. For the purposes of Section 1011.3, the term "tactile exit signs" shall mean those required signs that comply with Section 1117B.5.1 Item 1. Tactile exit signs shall be required at the following locations:~~

1. Each grade-level exterior exit door shall be identified by a tactile exit sign with the word, "EXIT".
2. Each exit door that leads directly to a grade-level exterior exit by means of a stairway or ramp shall be identified by a tactile exit sign with the following words as appropriate:
  - A. "EXIT STAIR DOWN"
  - B. "EXIT RAMP DOWN"
  - C. "EXIT STAIR UP"
  - D. "EXIT RAMP UP"
3. Each exit door that leads directly to a grade-level exterior exit by means of an exit enclosure that does not utilize a stair or ramp, or an exit passageway shall be identified by a tactile exit sign with the words, "EXIT ROUTE".
4. Each exit access door from an interior room or area that is required to have a visual exit sign, shall be identified by a tactile exit sign with the words, "EXIT ROUTE".
5. Each exit door through a horizontal exit shall be identified by a tactile exit sign with the words, "TO EXIT".

**1011.4 Internally illuminated exit signs.** Internally illuminated exit signs shall be listed and labeled and shall be installed in accordance with the manufacturer's instructions and Chapter 27 of the ~~International~~ California Building Code. Exit signs shall be illuminated at all times.

**1011.5.3 Power source.** Exit signs shall be illuminated at all times. To ensure continued illumination for a duration of not less than 90 minutes in case of primary power loss, the sign illumination means shall be connected to an emergency power system provided from storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Chapter 27 of the ~~International~~ California Building Code.

**Exception:** Approved exit sign illumination means that provide continuous illumination independent of external power sources for a duration of not less than 90 minutes, in case of primary power loss, are not required to be connected to an emergency electrical system.

**1011.6 Floor-level exit signs.** *Where exit signs are required by Chapter 10, additional approved low-level exit signs which are internally or externally illuminated photoluminescent or self-luminous, shall be provided in all interior*

corridors of Group A, ~~E~~, ~~occupancies~~, ~~Group I~~ and ~~R-2.1~~ occupancies and in all interior rated exit corridors serving guest rooms of hotels in Group R, Division 1 occupancies.

**Exceptions:**

1. Group A occupancies that are protected throughout by an approved supervised fire sprinkler system.
2. Group E Occupancies where direct exits have been provided from each classroom.
- 2-3. Group I and R-2.1 occupancies which are provided with smoke barriers constructed in accordance with Section 407.4
- 3-4. ~~Group I, Division 3-I-3 occupancies.~~

The bottom of the sign shall not be less than 6 inches (152 mm) or more than 8 inches (203 mm) above the floor level and shall indicate the path of exit travel. For exit and exit-access doors, the sign shall be on the door or adjacent to the door with the closest edge of the sign or marker within 4 inches (102 mm) of the door frame.

**Note:** Pursuant to Health and Safety Code Section 13143, this California amendment applies to all newly constructed buildings or structures subject to this section for which a building permit is issued (or construction commenced, where no building permit is issued) on or after January 1, 1989.

**1011.7 Path marking.** When exit signs are required by Chapter 10, in addition to approved floor-level exit signs, approved path marking shall be installed at floor level or no higher than 8 inches (203 mm) above the floor level in all interior rated exit corridors of unsprinklered Group A Occupancies, and Group R-1 and R-2 Occupancies. Such marking shall be continuous except as interrupted by door-ways, corridors or other such architectural features in order to provide a visible delineation along the path of travel.

**Note:** Pursuant to Health and Safety Code Section 13143, the California amendments of this section shall apply to all newly constructed buildings or structures subject to this section for which a building permit is issued (or construction commenced, where no building permit is issued) on or after January 1, 1989.

**1012.1 Where required.** Handrails for stairways and ramps shall be adequate in strength and attachment in accordance with Section 1607.7 of the ~~International~~ California Building Code. Handrails required for stairways by Section 1009.12 shall comply with Sections 1012.2 through 1012.9. Handrails required for ramps by Section 1010.8 shall comply with Sections 1012.2 through 1012.8.

**1012.8 Projections.** On ramps, the clear width between handrails shall be 36 inches (914 mm) minimum. Projections into the required width of stairways and ramps at each handrail shall not exceed 4.5 inches (114 mm) at or below the handrail height. Projections into the required width shall not be limited above the minimum headroom height required in Section 1009.2.

In Group I-2 occupancy ramps required for exit access shall not be less than 8 ft in width and handrails are permitted to protrude 31/2 inches from the wall on both sides. ~~on Ramps used as exits and stairways used for the movement of bed and litter patients, the clear width between handrails shall be 44 inches (1118 mm) minimum.~~

**1013.1 Where required.** Guards shall be located along open-sided walking surfaces, including mezzanines, equipment platforms, stairs, ramps and landings that are located more than 30 inches (762 mm) measured vertically to the floor or grade below at any point within 36 inches (914 mm) horizontally to the edge of the open side. Guards shall be adequate in strength and attachment in accordance with Section 1607.7 of the ~~International~~ California Building Code.

**Exception:** Guards are not required for the following locations:

1. On the loading side of loading docks or piers.
2. On the audience side of stages and raised platforms, including steps leading up to the stage and raised platforms.
3. On raised stage and platform floor areas, such as runways, ramps and side stages used for entertainment or presentations.
4. At vertical openings in the performance area of stages and platforms.
5. At elevated walking surfaces appurtenant to stages and platforms for access to and utilization of special

lighting or equipment.

6. Along vehicle service pits not accessible to the public.

7. In assembly seating where guards in accordance with Section 1025.14 are permitted and provided.

**1013.1.1 Glazing.** Where glass is used to provide a guard or as a portion of the *guard* system, the *guard* shall also comply with Section 2407 of the ~~International California Building Code~~. Where the glazing provided does not meet the strength and attachment requirements in Section 1607.7 of the ~~International California Building Code~~, complying *guards* shall also be located along glazed sides of open-sided walking surfaces.

**1013.3 Opening limitations.** Required guards shall not have openings which allow passage of a sphere 4 inches (102 mm) in diameter from the walking surface to the required guard height.

**Exceptions:**

1. From a height of 36 inches (914 mm) to 42 inches (1067 mm), guards shall not have openings which allow passage of a sphere 4 3/8 inches (111 mm) in diameter.
2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 6 inches (152 mm) in diameter.
3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings which allow passage of a sphere 21 inches (533 mm) in diameter.
4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship ladders, guards shall not have openings which allow passage of a sphere 21 inches (533 mm) in diameter.
5. In assembly seating areas, guards at the end of aisles where they terminate at a fascia of boxes, balconies and galleries shall not have openings which allow passage of a sphere 4 inches in diameter (102 mm) up to a height of 26 inches (660 mm). From a height of 26 inches (660 mm) to 42 inches (1067 mm) above the adjacent walking surfaces, guards shall not have openings which allow passage of a sphere 8 inches (203 mm) in diameter.
6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings which allow passage of a sphere 4 3/8 (111 mm) inches in diameter.
7. [SFM] Lifeguard towers not open to the public, guards shall not have openings which allow passage of a sphere 21 inches (533 mm) in diameter.

**1014.2 Egress through intervening spaces.** Egress through intervening spaces shall comply with this section.

1. Egress from a room or space shall not pass through adjoining or intervening rooms or areas, except where such adjoining rooms or areas and the area served are accessory to one or the other, are not a Group H occupancy and provide a discernible path of egress travel to an exit.

**Exception:** Means of egress are not prohibited through adjoining or intervening rooms or spaces in a Group H, S or F occupancy when the adjoining or intervening rooms or spaces are the same or a lesser hazard occupancy group.

2. An exit access shall not pass through a room that can be locked to prevent egress.
3. Means of egress from dwelling units or sleeping areas shall not lead through other sleeping areas, toilet rooms or bathrooms.
4. Egress shall not pass through kitchens, storage rooms, closets or spaces used for similar purposes.

**Exceptions:**

1. Means of egress are not prohibited through a kitchen area serving adjoining rooms constituting part of the same dwelling unit or sleeping unit.
2. Means of egress are not prohibited through stockrooms in Group M occupancies when all of the following are met:
  - 2.1. The stock is of the same hazard classification as that found in the main retail area;
  - 2.2. Not more than 50 percent of the exit access is through the stockroom;
  - 2.3. The stockroom is not subject to locking from the egress side; and

2.4. There is a demarcated, minimum 44-inch-wide (1118 mm) aisle defined by full- or partial-height fixed walls or similar construction that will maintain the required width and lead directly from the retail area to the exit without obstructions.

~~35. Exits shall not pass through any room subject to locking except in Group I-3 occupancies classified as detention facilities.~~

**1014.2.2 Group I-2.** Habitable rooms or suites in Group I-2 occupancies shall have an exit access door leading directly to a corridor.

**Exceptions:** Rooms with exit doors opening directly to the outside at ground level.

~~Each suite of rooms shall be separated from the remainder of the building by not less than a one-hour fire barrier.~~

~~Egress for portions of the building outside the suite shall not require passage through the suite.~~

**1014.2.2.1 Basement exits.** All rooms below grade shall have not less than one exit access that leads directly to an exterior exit door opening directly to an exit discharge at grade plane or the public way.

**1014.2.7 Separation.** Suites in Group I-2 occupancies shall be separated from other portions of the building by a ~~smoke partition~~ not less than a one-hour fire barrier complying with Section ~~711.707~~ of the ~~International California Building Code~~. Each suite of rooms shall be separated from the remainder of the building by not less than a one-hour fire barrier.

**1014.3 Common path of egress travel.** In occupancies other than Groups H-1, H-2 and H-3, the common path of egress travel shall not exceed 75 feet (22 860 mm). In Group H-1, H-2 and H-3 occupancies, the common path of egress travel shall not exceed 25 feet (7620 mm). For common path of egress travel in Group A occupancies and assembly occupancies accessory to Group E occupancies having fixed seating, see Section 1028.8.

**Exceptions:**

1. The length of a common path of egress travel in Group B, F and S occupancies shall not be more than 100 feet (30 480 mm), provided that the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1.
2. Where a tenant space in Group B, S and U occupancies has an occupant load of not more than 30, the length of a common path of egress travel shall not be more than 100 feet (30 480 mm).
3. The length of a common path of egress travel in a Group I-3 occupancy shall not be more than 100 feet (30 480 mm).
4. The length of a common path of egress travel in a Group R-2 occupancy shall not be more than 125 feet (38 100 mm), provided that the building is protected throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.
5. Suites in a Group I-2 occupancy constructed in accordance with 1014.2.3 or 1014.2.4.

**1015.1 Exits or exit access doorways from spaces.** Two exits or exit access doorways from any space shall be provided where one of the following conditions exists:

**Exception:** Group I-2 occupancies shall comply with Section 1014.2.2 through 1014.2.7.

1. The occupant load of the space exceeds one of the values in Table 1015.1.

**Exception:** In Group R-2 and R-3 occupancies, one means of egress is permitted within and from individual dwelling units with a maximum occupant load of 20 where the dwelling unit is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.

2. The common path of egress travel exceeds one of the limitations of Section 1014.3.
3. Where required by Sections 1015.3, 1015.4, 1015.5, 1015.6 or 1015.6.1.
4. *In detention and correctional facilities and holding cells, such as are found in courthouse buildings, a minimum*

of two means of egress shall be provided when the occupant load is more than 20.

Where a building contains mixed occupancies, each individual occupancy shall comply with the applicable requirements for that occupancy. Where applicable, cumulative occupant loads from adjacent occupancies shall be considered in accordance with the provisions of Section 1004.1.

**TABLE 1015.1  
SPACES WITH ONE EXIT OR EXIT ACCESS DOORWAY**

OCCUPANCY	MAXIMUM OCCUPANT LOAD
A, B, E <sup>a</sup> , F, M, U	49
H-1, H-2, H-3	3
H-4, H-5, I-1, I-2.1, I-3, I-4, R	10
S	29
L	See Section 443.6.1 <i>California Building Code</i>

a. Day care maximum occupant load is 10.

**1015.5 Refrigerated rooms or spaces.** Rooms or spaces having a floor area larger than 1,000 square feet (93 m<sup>2</sup>), containing a refrigerant evaporator and maintained at a temperature below 68°F (20°C), shall have access to not less than two exits or exit access doors.

Travel distance shall be determined as specified in Section 1016.1, but all portions of a refrigerated room or space shall be within 150 feet (45 720 mm) of an exit or exit access door where such rooms are not protected by an approved automatic sprinkler system. Egress is allowed through adjoining refrigerated rooms or spaces.

**Exception:** Where using refrigerants in quantities limited to the amounts based on the volume set forth in the ~~International~~ *California Mechanical Code*.

**1015.7 General Large Family Day-care Home.** Every story or basement of a large family day-care home shall be provided with two exits which are remotely located from each other. Every required exit shall be of a size to permit the installation of a door not less than 32 inches (813 mm) in clear width and not less than 6 feet 8 inches (2,032 mm) in height. A manually operated horizontal sliding door may be used as one of the two required exits.

Where basements are used for day-care purposes, one of the two required exits shall provide access directly to the exterior without entering the first story. The second exit from the basement may either pass through the story above or exit directly to the exterior.

Rooms used for day-care purposes shall not be located above the first story.

**Exception:** Buildings equipped with an automatic sprinkler system throughout and which have at least one of the required exits providing access directly to the exterior. NFPA 13R may be used in large family day-care homes. The sprinkler omissions of NFPA 13R shall not apply unless approved by the enforcing agency.

Exit doors, including manually operated horizontal sliding doors, shall be openable from the inside without use of a key or any special knowledge or effort.

Table 4049.41021.1 and 4049.21021.2 are not applicable to this occupancy classification.

**TABLE 1016.1  
EXIT ACCESS TRAVEL DISTANCE<sup>a</sup>**

OCCUPANCY	WITHOUT SPRINKLER SYSTEM (feet)	WITH SPRINKLER SYSTEM (feet)
A, E, F-1, I-1, M, R, S-1	200	250 <sup>b</sup>

B	200	300 <sup>c</sup>
F-2, S-2, U	300	400 <sup>c</sup>
H-1	Not Permitted	75 <sup>c</sup>
H-2	Not Permitted	100 <sup>c</sup>
H-3	Not Permitted	150 <sup>c</sup>
H-4	Not Permitted	175 <sup>c</sup>
H-5	Not Permitted	200 <sup>c</sup>
I-2, I-2.1, I-3 <sup>d</sup> , I-4	150	200 <sup>c</sup>
L	Not Permitted	200 <sup>c</sup>

For SI: 1 foot = 304.8 mm.

a. See the following sections for modifications to exit access travel distance requirements:

Section 402.4 of the ~~International~~ *California Building Code*: For the distance limitation in malls.

Section 404.9 of the ~~International~~ *California Building Code*: For the distance limitation through an atrium space.

Section 407.4 of the ~~International~~ *California Building Code*: For the distance limitation in Group I-2.

Sections 408.6.1 and 408.8.1 of the ~~International~~ *California Building Code*: For the distance limitations in Group I-3.

Section 411.4 of the ~~International~~ *California Building Code*: For the distance limitation in special amusement buildings.

Section 1014.2.2: For the distance limitation in Group I-2 hospital suites.

Section 1015.4: For the distance limitation in refrigeration machinery rooms.

Section 1015.5: For the distance limitation in refrigerated rooms and spaces.

Section 1021.2: For buildings with one exit.

Section 1028.7: For increased limitation in assembly seating.

Section 1028.7: For increased limitation for assembly open-air seating.

Section 3103.4 of the ~~International~~ *California Building Code*: For temporary structures.

Section 3104.9 of the ~~International~~ *California Building Code*: For pedestrian walkways.

b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems in accordance with Section 903.3.1.2 are permitted.

c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1.

d. Not permitted in nonsprinklered Group I-3 occupancies.

**1017.2 Aisles in Groups B and M.** In Group B and M occupancies, the minimum clear aisle width shall be determined by Section 1005.1 for the occupant load served, but shall not be less than 36 inches (914 mm).

**Exception:** Nonpublic aisles serving less than 50 people and not required to be accessible by Chapter 11 of the ~~International~~ *California Building Code* need not exceed 28 inches (711 mm) in width.

**1018.1 Construction.** Corridors shall be fire-resistance rated in accordance with Table 1018.1. The corridor walls required to be fire-resistance rated shall comply with Section 708 of the ~~International~~ *California Building Code* for fire partitions.

**Exceptions:**

1. A fire-resistance rating is not required for corridors in an occupancy in Group E where each room that is used for instruction has at least one door opening directly to the exterior and rooms for assembly purposes have at least one-half of the required means of egress doors opening directly to the exterior. Exterior doors specified in this exception are required to be at ground level.
2. A fire-resistance rating is not required for corridors contained within a dwelling or sleeping unit in an occupancy in Group R.
3. A fire-resistance rating is not required for corridors in open parking garages
4. A fire-resistance rating is not required for corridors in an occupancy in Group B which is a space requiring only a single means of egress complying with Section 1015.1.

5. A fire-resistance rating is not required for corridors within suites in a Group I-2 occupancy constructed in accordance with 1014.2.3 or 1014.2.4.

**TABLE 1018.1 CORRIDOR FIRE-RESISTANCE RATING**

OCCUPANCY	OCCUPANT LOAD SERVED BY CORRIDOR	REQUIRED FIRE-RESISTANCE RATING (hours)	
		Without sprinkler system	With sprinkler system <sup>c</sup>
H-1, H-2, H-3	All	Not Permitted	1
H-4, H-5, L	Greater than 30	Not Permitted	1
A <sup>d</sup> , B, E, F, M, S, U	Greater than 30	1	0
R-1, R-2, R-3, R-3.1, R-4	Greater than 10	Not Permitted	0-1
I-2 <sup>a</sup> , 1-2.1, I-4	All Greater than 6	Not Permitted	0-1
I-1, I-3, R-2.1	All Greater than 6	Not Permitted	1 <sup>b</sup>
E	Greater than 10	1	1

- For requirements for occupancies in Group I-2, see Section 407.2 and 407.3 of the ~~International~~ California Building Code.
- For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 408.8 ~~International~~ California Building Code.
- Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed.
- See Section ~~4025-1028~~.

**1018.2 Corridor width.** The minimum corridor width shall be as determined in Section 1005.1, but not less than 44 inches (1118 mm).

**Exceptions:**

- Twenty-four inches (610 mm)—For access to and utilization of electrical, mechanical or plumbing systems or equipment.
- Thirty-six inches (914 mm)—With a required occupant capacity of less than 50.
- Thirty-six inches (914 mm)—Within a dwelling unit.
- Seventy-two inches (1829 mm)—In Group E with a corridor having a required capacity of 100 or more.
- Seventy-two inches (1829 mm)—In corridors and areas serving gurney traffic in occupancies where patients receive outpatient medical care, which causes the patient to be not capable of self-preservation.
- Ninety-six inches (2438 mm)—In Group I-2 and I-3 occupancies in areas where required for bed movement or corridors in Group I-2 and I-3 occupancies serving any area caring for one or more nonambulatory persons.

**1018.4 Dead ends.** Where more than one exit or exit access doorway is required, the exit access shall be arranged such that there are no dead ends in corridors more than 20 feet (6096 mm) in length.

**Exceptions:**

- In occupancies in Group I-3 of Occupancy Condition 2, 3 or 4 (see Section 308.4), the dead end in a corridor shall not exceed 50 feet (15 240 mm).
- In occupancies in Groups B, E, F, I-1, M, R-1, R-2, R-2.1, R-4, S and U, where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, the length of the dead-end corridors shall not exceed 50 feet (15 240 mm).
- A dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the least width of the dead-end corridor.

**1018.5 Air movement in corridors.** Corridors shall not serve as supply, return, exhaust, relief or ventilation air ducts.

**Exceptions:**

- Use of a corridor as a source of makeup air for exhaust systems in *small rooms of 30 sq feet or less* that open directly onto such corridors, including toilet rooms, bathrooms, dressing rooms, ~~smoking lounges~~ and janitor closets, shall be permitted, provided that each such corridor is directly supplied with outdoor air at a rate

- greater than the rate of makeup air taken from the corridor.
2. Where located within a dwelling unit, the use of corridors for conveying return air shall not be prohibited.
  3. Where located within tenant spaces of 1,000 square feet (93 m<sup>2</sup>) or less in area, utilization of corridors for conveying return air is permitted.
  4. Incidental air movement from pressurized rooms within health care facilities, provided that the corridor is not the primary source of supply or return to the room.
- 4.5. For health care facilities under the jurisdiction of the Office of Statewide Health Planning and Development (OSHPD), see the California Mechanical Code.

**1018.5.1 Corridor ceiling.** Use of the space between the corridor ceiling and the floor or roof structure above as a return air plenum is permitted for one or more of the following conditions:

1. The corridor is not required to be of fire-resistance-rated construction;
2. The corridor is separated from the plenum by fire-resistance-rated construction;
3. The air-handling system serving the corridor is shut down upon activation of the air-handling unit smoke detectors required by the *International California Mechanical Code*.
4. The air-handling system serving the corridor is shut down upon detection of sprinkler waterflow where the building is equipped throughout with an automatic sprinkler system; or
5. The space between the corridor ceiling and the floor or roof structure above the corridor is used as a component of an approved engineered smoke control system.

**1018.6 Corridor continuity.** Fire-resistance-rated corridors shall be continuous from the point of entry to an exit, and shall not be interrupted by intervening rooms.

**Exceptions:**

1. Foyers, lobbies or reception rooms constructed as required for corridors shall not be construed as intervening rooms.
2. In fully sprinklered office buildings, corridors may lead through enclosed elevator lobbies if all areas of the building have access to at least one required exit without passing through the elevator lobby

**1021.2 Single exits.** ~~Only one exit shall be required from Group R-3 occupancy buildings or from stories of other buildings as indicated in Table 1021.2.~~ Occupancies shall be permitted to have a single exit in buildings otherwise required to have more than one exit if the areas served by the single exit do not exceed the limitations of Table 1021.2. Mixed occupancies shall be permitted to be served by single exits provided each individual occupancy complies with the applicable requirements of Table 1021.2 for that occupancy. Where applicable, cumulative occupant loads from adjacent occupancies shall be considered in accordance with the provisions of Section 1004.1. Basements with a single exit shall not be located more than one story below grade plane.

**TABLE 1021.2  
STORIES WITH ONE EXIT**

STORY	OCCUPANCY	MAXIMUM OCCUPANTS (OR DWELLING UNITS) PER FLOOR AND TRAVEL DISTANCE
First story or basement	A, B <sup>d</sup> , E <sup>e</sup> , F <sup>d</sup> , M, U <sup>d</sup>	49 occupants and 75 feet travel distance
	H-2, H-3, L,	3 occupants and 25 feet travel distance
	H-4, H-5, I, R	10 occupants and 75 feet travel distance
	S <sup>a</sup>	29 occupants and 100 feet travel distance
	I-2, I-2.1	7 occupants and 50 feet travel distance
Second story	B <sup>b</sup> , F, M, S <sup>a</sup>	29 occupants and 75 feet travel distance
	R-2	4 dwelling units and 50 feet travel distance
Third story	R-2 <sup>c</sup>	4 dwelling units and 50 feet travel distance

For SI: 1 foot = 304.8 mm.

- a. For the required number of exits for parking structures, see Section 1021.1.2.
- b. For the required number of exits for air traffic control towers, see Section 412.3.

- c. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1029.
- d. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum travel distance of 100 feet.
- e. Day care occupancies shall have a maximum occupant load of 10.

**1022.1 Enclosures required.** Interior exit stairways and interior exit ramps shall be enclosed with fire barriers constructed in accordance with Section 707 of the *International California Building Code* or horizontal assemblies constructed in accordance with Section 712 of the *International California Building Code*, or both. Exit enclosures shall have a fire-resistance rating of not less than 2 hours where connecting four stories or more and not less than 1 hour where connecting less than four stories. The number of stories connected by the exit enclosure shall include any basements but not any mezzanines. Exit enclosures shall have a fire-resistance rating not less than the floor assembly penetrated, but need not exceed 2 hours. Exit enclosures shall lead directly to the exterior of the building or shall be extended to the exterior of the building with an exit passageway conforming to the requirements of Section 1023, except as permitted in Section 1027.1. An exit enclosure shall not be used for any purpose other than means of egress.

**Exceptions:**

1. In all occupancies, other than Group H, ~~and I~~ and *R-2.1* occupancies, a stairway is not required to be enclosed when the stairway serves an occupant load of less than 10 and the stairway complies with either Item 1.1 or 1.2. In all cases, the maximum number of connecting open stories shall not exceed two.
  - 1.1. The stairway is open to not more than one story above its level of exit discharge; or
  - 1.2. The stairway is open to not more than one story below its level of exit discharge.
2. Exits in buildings of Group A-5 where all portions of the means of egress are essentially open to the outside need not be enclosed.
3. Stairways serving and contained within a single residential dwelling unit or sleeping unit in Group R-1, R-2 or R-3 occupancies are not required to be enclosed.
4. Stairways in open parking structures that serve only the parking structure are not required to be enclosed.
5. Stairways in Group I-3 occupancies, as provided for in Section ~~408.3.6.1~~ *408.3.8.1* of the *International California Building Code* are not required to be enclosed.
6. Means of egress stairways as required by Sections 410.5.3 and 1015.6.1 are not required to be enclosed.
7. Means of egress stairways from balconies, galleries or press boxes as provided for in Section 1028.5.1 are not required to be enclosed.
8. Fixed guideway transit stations, constructed in accordance with Section 433 of the California Building Code.

**1022.3 Openings and penetrations.** Exit enclosure opening protectives shall be in accordance with the requirements of Section 715 of the *International California Building Code*.

Except as permitted in Section 402.4.6 of the *International California Building Code*, openings in exit enclosures other than unprotected exterior openings shall be limited to those necessary for exit access to the enclosure from normally occupied spaces and for egress from the enclosure.

Where interior exit enclosures are extended to the exterior of a building by an exit passageway, the door assembly from the exit enclosure to the exit passageway shall be protected by a fire door assembly conforming to the requirements in Section 715.4 of the of the *International California Building Code*. Fire door assemblies in exit enclosures shall comply with Section 715.4.4 of the *International California Building Code*.

Elevators shall not open into an exit enclosure.

**1022.4 Penetrations.** Penetrations into and openings through an exit enclosure are prohibited except for required exit doors, equipment and ductwork necessary for independent pressurization, sprinkler piping, standpipes, electrical raceway for fire department communication systems and electrical raceway serving the exit enclosure and terminating at a steel box not exceeding 16 square inches (0.010 m<sup>2</sup>). Such penetrations shall be protected in accordance with

Section 713 of the ~~International~~ California Building Code.

There shall be no penetrations or communication openings, whether protected or not, between adjacent exit enclosures.

**1022.5 Ventilation.** Equipment and ductwork for exit enclosure ventilation as permitted by Section 1022.4 shall comply with one of the following items:

1. Such equipment and ductwork shall be located exterior to the building and shall be directly connected to the exit enclosure by ductwork enclosed in construction as required for shafts.
2. Where such equipment and ductwork is located within the exit enclosure, the intake air shall be taken directly from the outdoors and the exhaust air shall be discharged directly to the outdoors, or such air shall be conveyed through ducts enclosed in construction as required for shafts.
3. Where located within the building, such equipment and ductwork shall be separated from the remainder of the building, including other mechanical equipment, with construction as required for shafts.

In each case, openings into the fire-resistance-rated construction shall be limited to those needed for maintenance and operation and shall be protected by opening protectives in accordance with Section 715 of the ~~International~~ California Building Code for shaft enclosures.

Exit enclosure ventilation systems shall be independent of other building ventilation systems.

**1022.6 Exit enclosure exterior walls.** Exterior walls of an exit enclosure shall comply with the requirements of Section 705 of the ~~International~~ California Building Code for exterior walls. Where nonrated walls or unprotected openings enclose the exterior of the stairway and the walls or openings are exposed by other parts of the building at an angle of less than 180 degrees (3.14 rad), the building exterior walls within 10 feet (3048 mm) horizontally of a nonrated wall or unprotected opening shall have a fire-resistance rating of not less than 1 hour. Openings within such exterior walls shall be protected by opening protectives having a fire protection rating of not less than 3/4 hour. This construction shall extend vertically from the ground to appoint 10 feet (3048mm) above the topmost landing of the stairway or to the roof line, whichever is lower.

**1022.8 Floor identification signs.** A sign shall be provided at each floor landing in exit enclosures connecting more than three stories designating the floor level, the terminus of the top and bottom of the exit enclosure and the identification of the stair or ramp. The signage shall also state the story of, and the direction to, the exit discharge and the availability of roof access from the enclosure for the fire department. The sign shall be located 5 feet (1524 mm) above the floor landing in a position that is readily visible when the doors are in the open and closed positions. ~~Floor level identification signs in tactile characters complying with ICC A117.1 shall be located at each floor level landing adjacent to the door leading from the enclosure into the corridor to identify the floor level.~~

~~**1020.1.6.2 Tactile floor designation signs in stairways.** When accessibility is required, tactile floor designation identification signs that comply with 1117B.5.1 Item 1 shall be located at the landing of each floor level, placed adjacent to the door on the latch side, in all enclosed stairways in buildings two or more stories in height to identify the floor level. At the exit discharge level, the sign shall include a raised five pointed star located to the left of the identifying floor level. The outside diameter of the star shall be the same as the height of the raised characters.~~

~~**1020.1.6.1 Sign details.** The provisions of this section shall apply to signs required by Section 1020.1.6~~

~~**1020.1.6.1.1 Size.** Signs shall be a minimum 12 inches (305mm) by 12 inches (305mm).~~

~~**1020.1.6.1.2 Stairway location.** The stairway location, such as STAIR NO. 1 or WEST STAIR, shall be placed at the top of the sign in 1 inch high (25 mm) block lettering with 1/4 inch (6 mm) strokes.~~

~~**1020.1.6.1.4 Floor level numbering.** The floor level number shall be placed in the middle of the sign in 5-inch-high (127mm) lettering with 3/4 inch (19mm) strokes. The mezzanine levels shall have the letter "M" preceding the floor level. Basement levels shall have the letter "B" preceding the floor number.~~

**1022.8.1 Signage requirements.** Stairway identification signs shall comply with all of the following requirements:

1. The signs shall be a minimum size of 18 inches (457 mm) by 12 inches (305 mm).

2. The letters designating the identification of the stair enclosure, such as STAIR NO. 1 or WEST STAIR, shall be placed at the top of the sign and shall be a minimum of 1 1/2 inches (38 mm) in height block lettering with 1/4-inch (6-mm) strokes.
3. The number designating the floor level shall be a minimum of 5 inches (127 mm) in height with 3/4-inch (19mm) strokes and located in the center of the sign. The mezzanine levels shall have the letter "M" preceding the floor level. basement levels shall have the letter "B" preceding the floor number.
4. All other lettering and numbers shall be a minimum of 1 inch (25 mm) in height.
- ~~1020.1.6.1.3 Upper terminus.~~ 5. The stairway's upper terminus, such as ROOF ACCESS or NO ROOF ACCESS, shall be placed under the stairway identification in 1-inch-high (25 mm) block lettering with 1/4-inch (6 mm) strokes.
- ~~1020.1.6.1.5 Lower terminus.~~ 6. The lower and upper terminus of the stairway shall be placed at the bottom of the sign in 1-inch-high (25 mm) block lettering with 1/4-inch (6 mm) strokes.
- ~~5.7.~~ Characters and their background shall have a nonglare finish. Characters shall contrast with their background, with either light characters on a dark background or dark characters on a light background.
- ~~6.8.~~ When signs required by Section 1022.8 are installed in interior exit enclosures of buildings subject to Section 1024, the signs shall be made of the same materials as required by Section 1024.4.

**1022.9 Smokeproof enclosures and pressurized stairways.** In buildings required to comply with Section 403 or 405 of the ~~International California Building Code~~, each of the exits ~~enclosures of a building that serves stories where the floor surface is located more than 75 feet (22 860 mm) above the lowest level of fire department vehicle access or more than 30 feet (9144 mm) below the level of exit discharge serving such floor levels~~ shall be a smokeproof enclosure or pressurized stairway in accordance with Section 909.20.

**1022.9.1 Termination and extension.** A smokeproof enclosure or pressurized stairway shall terminate at an exit discharge or a public way. The smokeproof enclosure or pressurized stairway shall be permitted to be extended by an exit passageway in accordance with Section 1022.2. The exit passageway shall be without openings other than the fire door assembly required by Section 1022.2 and those necessary for egress from the exit passageway. The exit passageway shall be separated from the remainder of the building by 2-hour fire barriers constructed in accordance with Section 707 or horizontal assemblies constructed in accordance with Section 712, or both.

**Exceptions:**

1. Openings in the exit passageway serving a smokeproof enclosure are permitted where the exit passageway is protected and pressurized in the same manner as the smokeproof enclosure, and openings are protected as required for access from other floors.
- ~~2. Openings in the exit passageway serving a pressurized stairway are permitted where the exit passageway is protected and pressurized in the same manner as the pressurized stairway.~~
- ~~3-2.~~ The fire barrier separating the smokeproof enclosure or pressurized stairway from the exit passageway is not required, provided the exit passageway is protected and pressurized in the same manner as the smokeproof enclosure or pressurized stairway.
4. A smokeproof enclosure or pressurized stairway shall be permitted to egress through areas on the level of discharge or vestibules as permitted by Section 1027.

**1022.9.2 Enclosure access.** Access to the stairway within a smokeproof enclosure shall be by way of a vestibule or an open exterior balcony.

~~**Exception:** Access is not required by way of a vestibule or exterior balcony for stairways using the pressurization alternative complying with Section 909.20.5.~~

**1023.2 Width.** The width of exit passageways shall be determined as specified in Section 1005.1 but such width shall not be less than 44 inches (1118 mm), except that exit passageways serving an occupant load of less than 50 shall not be less than 36 inches (914 mm) in width. The required width of exit passageways shall be unobstructed.

**Exception:** Doors complying with Section 1005.2.

*The clear width of exit passageways in a Group I-2 occupancy used for the movement of beds and litters shall be 44" (1118) minimum.*

~~1022.5~~ **1025.5 Ducts and air transfer openings**, Ducts and air transfer openings through fire walls or fire barriers, forming a horizontal exit, shall be designed and protected in accordance with Section 716 in order to afford safety from both fire and smoke in the refuge area. All ducts and air transfer openings shall be protected by listed combination fire/smoke dampers.

**1026.2 Use in a means of egress.** Exterior exit stairways shall not be used as an element of a required means of egress for Group I-2 occupancies. For occupancies in other than Group I-2, exterior exit ramps and stairways shall be permitted as an element of a required means of egress for buildings not exceeding six stories above grade plane or *buildings defined as a high-rise or Group I-2 occupancies* having occupied floors more than 75 feet (22 860 mm) above the lowest level of fire department vehicle access.

**Exception:** In assembly occupancies where there is no well-defined main exit or where multiple main exits are provided, exits shall be permitted to be distributed around the perimeter of the building provided that the total width of egress is not less than 100 percent of the required width. *At least one exit shall discharge on a street or an unoccupied space of not less than 20 feet (6096 mm) in width that adjoins a street or public way.*

~~Group A occupancies that have an occupant load greater than 300 shall be provided with at least 0.20 inch (5.1 mm) total exit width for each occupant served.~~

**Exception:** *Smoke-protected seating complying with Section ~~1025.6.2~~ 1028.6.2*

**1027.6 Access to a public way.** The exit discharge shall provide a direct and unobstructed access to a public way.

**Exception:** Where access to a public way cannot be provided, a safe dispersal area shall be provided where all of the following are met:

1. The area shall be of a size to accommodate at least 5 square feet (0.28 m<sup>2</sup>) for each person.
2. *For other than Group E buildings, the area shall be located on the same lot at least 50 feet (15 240 mm) away from the building requiring egress. For Group E buildings, the area shall be located on the same lot at least 50 feet (15 240 mm) away from any building.*
3. The area shall be permanently maintained and identified as a safe dispersal area.
4. The area shall be provided with a safe and unobstructed path of travel from the building.

**1028.1 General.** All occupancies in Group A and assembly occupancies accessory to Group E *including those* which contain seats, tables, displays, equipment or other material shall comply with this section.

**1028.2 Assembly main exit.** Group A occupancies and assembly occupancies accessory to Group E occupancies that have an occupant load of greater than 300 shall be provided with a main exit. The main exit shall be of sufficient width to accommodate not less than one-half of the occupant load, but such width shall not be less than the total required width of all means of egress leading to the exit. Where the building is classified as a Group A occupancy, the main exit shall front on at least one street or an unoccupied space of not less than ~~40 feet (3048 mm)~~ *20 feet (6096 mm)* in width that adjoins a street or public way.

**Exceptions:**

1. In assembly occupancies where there is no well-defined main exit or where multiple main exits are provided, exits shall be permitted to be distributed around the perimeter of the building provided that the total width of egress is not less than 100 percent of the required width. *At least one exit shall discharge on a street or an unoccupied space of not less than 20 feet (6096 mm) in width that adjoins a street or public way.*

~~Group A occupancies that have an occupant load greater than 300 shall be provided with at least 0.20 inch (5.1 mm) total exit width for each occupant served.~~

**Exception:**2. *Smoke-protected seating complying with Section ~~1025.6.2~~ 1028.6.2*

**1028.3 Assembly other exits.** In addition to having access to a main exit, each level in Group A occupancies or assembly occupancies accessory to Group E occupancies having an occupant load greater than 300, shall be provided with additional means of egress that shall provide an egress capacity for at least one-half of the total

occupant load served by that level and comply with Section 1015.2. *At least 1/2 one-half of the additional means of egress required by this section shall be directly to an exit, or through a lobby, that is not used to access the main exit, to an exit, or to a one hour rated corridor to an exit.*

**Exceptions:**

*1. In assembly occupancies where there is no well-defined main exit or where multiple main exits are provided, exits shall be permitted to be distributed around the perimeter of the building, provided that the total width of egress is not less than 100 percent of the required width. At least one exit shall discharge on a street or an unoccupied space of not less than 20 feet (6096 mm) in width that adjoins a street or public way.*

~~*Group A occupancies that have an occupant load greater than 300 shall be provided with at least 0.20 inch (5.1 mm) total exit width for each occupant served.*~~

~~*Exception: 2. Smoke-protected seating complying with Section 1025.6.2-1028.6.2*~~

~~**1025.3.1-1028.3.1 Occupant loads less than 300.** *Group A occupancies or assembly occupancies accessory to Group E occupancies that have an occupant load of 100 or more and less than 300, shall have at least one of the required means of egress directly to an exit, or through a lobby, that is not used to access the other required exit, to an exit, or to a one hour rated corridor to an exit or continuous through a one hour rated lobby to an exit. At least one exit shall discharge on a street or an unoccupied space of not less than 20 feet (6096 mm) in width that adjoins a street or public way.*~~

**1028.6.1 Without smoke protection.** The clear width of the means of egress shall provide sufficient capacity in accordance with all of the following, as applicable:

1. At least 0.3 inch (7.6 mm) of width for each occupant served shall be provided on stairs having riser heights 7 inches (178 mm) or less and tread depths 11 inches (279 mm) or greater, measured horizontally between tread nosings.
2. At least 0.005 inch (0.127 mm) of additional stair width for each occupant shall be provided for each 0.10 inch (2.5mm) of riser height above 7 inches (178 mm).
3. Where egress requires stair descent, at least 0.075 inch (1.9 mm) of additional width for each occupant shall be provided on those portions of stair width having no handrail within a horizontal distance of 30 inches (762 mm).
4. Ramped means of egress, where slopes are steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have at least 0.22 inch (5.6 mm) of clear width for each occupant served. Level or ramped means of egress, where slopes are not steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have at least 0.20 inch (5.1 mm) of clear width for each occupant served.
- ~~5. *Group A occupancies that have an occupant load greater than 300 shall be provided with at least 0.20 inch (5.1 mm) total exit width for each occupant served.*~~

**1028.10 Clear width of aisle accessways serving seating.** Where seating rows have 14 or fewer seats, the minimum clear aisle accessway width shall not be less than 12 inches (305 mm) measured as the clear horizontal distance from the back of the row ahead and the nearest projection of the row behind. Where chairs have automatic or self-rising seats, the measurement shall be made with seats in the raised position. Where any chair in the row does not have an automatic or self-rising seat, the measurements shall be made with the seat in the down position. For seats with folding tablet arms, row spacing shall be determined with the tablet arm in the used position.

~~**Exception:** *When tablet arm chairs are used, the minimum clear width of 12 inches (305 mm) between rows may be measured with tablet arms in the stored position only where all tablet arms are raised manually in one motion to a vertical position and fall to the stored position by force of gravity.*~~

**Exception:** For seats with folding tablet arms, row spacing is permitted to be determined with the tablet arm in the stored position where the tablet arm when raised manually to vertical position in one motion automatically returns to the stored position by force of gravity.

~~**1025.6.4-1028.6.4 Public address system.** See section 907.2.1-3907.2.1.2.~~

**1028.9.1 Minimum aisle width.** The minimum clear width for aisles shall be as shown:

1. Forty-eight inches (1219 mm) for aisle stairs having seating on each side.

**Exception:** Thirty-six inches (914 mm) where the aisle serves less than 50 seats.

2. Thirty-six inches (914 mm) for aisle stairs having seating on only one side.
3. Twenty-three inches (584 mm) between an aisle stair handrail or guard and seating where the aisle is subdivided by a handrail.
4. Forty-two inches (1067 mm) for level or ramped aisles having seating on both sides.

**Exceptions:**

1. Thirty-six inches (914 mm) where the aisle serves less than 50 seats.
2. Thirty inches (762 mm) where the aisle does not serve more than 14 seats.

5. Thirty-six inches (914 mm) for level or ramped aisles having seating on only one side.

**Exceptions:**

1. Thirty inches (762 mm) where the aisle does not serve more than 14 seats.
2. Twenty-three inches (584 mm) between an aisle stair handrail and seating where an aisle does not serve more than five rows on one side.

6. Libraries with open book stacks shall have main aisles not less than 44 inches (1118 mm) in width, and side, range and end aisles not less than 36 inches (914 mm) in width.

**1029.4 Operational constraints.** Emergency escape and rescue openings and any exit doors shall be maintained free of any obstructions other than those allowed by this section and shall be operational from the inside of the room without the use of keys or tools. Bars, grilles, grates or similar devices are permitted to be placed over emergency escape and rescue openings provided the minimum net clear opening size complies with Section 1029.2 and such devices shall be releasable or removable from the inside without the use of a key, tool, *special knowledge or effort* or force greater than that which is required for normal operation of the escape and rescue opening. Where such bars, grilles, grates or similar devices are installed in existing buildings, smoke alarms shall be installed in accordance with Sections 907.2.11 regardless of the valuation of the alteration. *The release mechanism shall be maintained operable at all times.*

*Such bars, grills, grates or any similar devices shall be equipped with an approved exterior release device for use by the fire department only when required by the authority having jurisdiction.*

*Where security bars (burglar bars) are installed on emergency egress and rescue windows or doors, on or after July 1, 2000, such devices shall comply with California Building Standards Code, Part 12, Chapter 12-3 and other applicable provisions of Part 2.*

**Exception:** Group R1 occupancies provided with a monitored fire sprinkler system ~~is in~~ accordance with section ~~903.2.7903.2.8~~ and designed in accordance with NFPA 13 may have operable windows permanently restricted to a maximum 4-inch (102mm) open position.

**1029.1 General.** In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group R ~~and I-1~~ occupancies. Basements and sleeping rooms below the fourth story above grade plane shall have at least one exterior emergency escape and rescue opening in accordance with this section. Where basements contain one or more sleeping rooms, emergency egress and rescue openings shall be required in each sleeping room, but shall not be required in adjoining areas of the basement. Such openings shall open directly into a public way or to a yard or court that opens to a public way.

**Exceptions:**

1. ~~In other than Group R-3 occupancies, buildings~~ *In Groups R-1 and R-2 occupancies constructed of Type I, Type IIA, Type IIIA or Type IV construction* equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1 ~~or 903.3.1.2.~~
2. ~~In other than Group R-3 occupancies, sleeping rooms provided with a door to a fire resistance rated corridor~~

~~having access to two remote exits in opposite directions.~~

32. The emergency escape and rescue opening is permitted to open onto a balcony within an atrium in accordance with the requirements of Section 404, provided the balcony provides access to an exit and the dwelling unit or sleeping unit has a means of egress that is not open to the atrium.
43. Basements with a ceiling height of less than 80 inches (2032 mm) shall not be required to have emergency escape and rescue windows.
54. High-rise buildings in accordance with Section 403.
65. Emergency escape and rescue openings are not required from basements or sleeping rooms that have an exit door or exit access door that opens directly into a public way or to a yard, court or exterior exit balcony that ~~opens~~ provides access to a public way.
76. Basements without habitable spaces and having no more than 200 square feet (18.6 m<sup>2</sup>) in floor area shall not be required to have emergency escape windows.

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[11. The SFM proposes to adopt Chapter 11 without amendment.]

**CHAPTER 11  
AVIATION FACILITIES**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[12. The SFM proposes to adopt Chapter 12 with the following amendments and California regulations.]

**CHAPTER 12  
DRY CLEANING**

**1201.1.1 Compliance alternate for dry cleaning plants. Dry cleaning plants shall be permitted to comply with the provisions of NFPA 32 in its entirety as an acceptable alternative to the requirements of this chapter.**

Authority: Health and Safety Code Sections 13201, 13143, 18949.2  
References: Health and Safety Code Sections 13143, 18949.2

---

[13. The SFM proposes to adopt Chapter 13 without amendment.]

**CHAPTER 13  
COMBUSTIBLE DUST-PRODUCING OPERATIONS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[14. The SFM proposes to adopt Chapter 14 without amendment.]

**CHAPTER 14  
FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[15. The SFM proposes to adopt Chapter 15 with the following amendments and California regulations.]

**CHAPTER 15  
FLAMMABLE FINISHES**

**1507.2 Location and clear space.** A space of at least twice the sparking distance shall be maintained between goods being painted or deteared and electrodes, electrostatic atomizing heads or conductors. The equipment manufacturer's operating instructions shall be consulted to determine the sparking distance of the equipment involved. A sign stating the sparking distance shall be conspicuously posted near the assembly.

**Exception:** Portable electrostatic paint-spraying apparatus listed for use in Class I, Division 1, locations.

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[16. The SFM proposes to not adopt Chapter 16.]

**CHAPTER 16  
FRUIT AND CROP RIPENING**

Authority: Health and Safety Code Sections 13143  
References: Health and Safety Code Section 13143

---

[17. The SFM proposes to not adopt Chapter 17.]

**CHAPTER 17  
FUMIGATION AND THERMAL INSECTICIDAL FOGGING**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

---

[18. The SFM proposes to adopt Chapter 18 without amendment.]

**CHAPTER 18  
SEMICONDUCTOR FABRICATION FACILITIES**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[19. The SFM proposes to adopt Chapter 19 without amendment.]

**CHAPTER 19  
LUMBER YARDS AND WOODWORKING FACILITIES**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[20. The SFM proposes to adopt Chapter 20 without amendment.]

**CHAPTER 20  
MANUFACTURE OF ORGANIC COATINGS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[21. The SFM proposes to adopt Chapter 21 without amendment.]

**CHAPTER 21  
INDUSTRIAL OVENS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[22. The SFM proposes to adopt Chapter 22 without amendment (see item 60 for existing SFM regulations).]

**CHAPTER 22  
MOTOR FUEL-DISPENSING FACILITIES AND REPAIR GARAGES**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[23. The SFM proposes to adopt Chapter 23 without amendment (see item 60 for existing SFM regulations).]

**CHAPTER 23  
HIGH-PILED COMBUSTIBLE STORAGE**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[24. The SFM proposes to adopt Chapter 24 with the following amendments and California regulations.]

**CHAPTER 24  
TENTS, CANOPIES AND OTHER MEMBRANE STRUCTURES**

**2401.1 Scope.** Tents and membrane structures shall comply with this chapter. The provisions of Section 2403 are applicable only to temporary tents and membrane structures. The provisions of Section 2404 are applicable to temporary and permanent tents and membrane structures.

These building standards govern the use of tents, awnings or other fabric enclosures, including membrane (air-supported and air-inflated) structures and places of assemblage, in or under which 10 or more persons may gather for any lawful purpose.

**Exceptions:**

1. Tents, awnings or other fabric enclosures used to cover or enclose private swimming pools and similar facilities on the premises of private one- and two-family dwellings.
2. Tents used to conduct committal services on the ground of a cemetery.
3. Tents, awnings or other fabric enclosures erected and used within a sound stage, or other similar structural enclosure which is equipped with an overhead automatic sprinkler system.
4. Tensioned membrane roof materials supported by rigid frames or installed on a mast and cable system provided such structures conform to the requirements of one of the types of construction as described in these regulations.
5. Fabric structures which are part of mobilehomes, recreational vehicles, or commercial coaches governed by the provisions of Division 13, Part 2, Health and Safety Code (Department of Housing and Community Development).

**2401.2 Alternate means of protection.** When approved by the enforcing agency, exceptions to the provisions of these building standards may be permitted, provided alternate means of protection which are at least equal to these regulations in quality, strength, effectiveness, fire resistance, durability and safety are provided.

**2401.3 Labor camps.** Tents used in labor camps for the housing of employees shall have tight wooden floors raised at least 4 inches (102 mm) above ground level having baseboards on all sides to a height of at least 6 inches (152 mm) or shall have concrete slabs with finished surface at least 4 inches (102mm) above grade having baseboards on all sides to a height of at least 6 inches (152 mm).

Electrical installations serving and installed within tents shall comply with the applicable requirements of the

California Electrical Code.

Tents shall not be considered suitable sleeping places when it is found necessary to provide heating facilities in order to maintain a minimum temperature of 60 F (33.3 C) within such tent during the period of occupancy.

Note: See Section 17008 of the Health and Safety Code for definition of labor camp.

**2403.8.2 Location.** Tents or membrane structures shall not be located within 20 feet (6096 mm) of *lot lines*, buildings, other tents or membrane structures, parked vehicles or internal combustion engines. For the purpose of determining required distances, support ropes and guy wires shall be considered as part of the temporary membrane structure or tent.

**Exceptions:**

1. Separation distance between membrane structures and tents not used for cooking is not required when the aggregate floor area does not exceed 15,000 square feet (1394 m<sup>2</sup>).
2. Membrane structures or tents need not be separated from buildings when all of the following conditions are met:
  - 2.1. The aggregate floor area of the membrane structure or tent shall not exceed 10,000 square feet (929 m<sup>2</sup>).
  - 2.2. The aggregate floor area of the building and membrane structure or tent shall not exceed the allowable floor area including increases as indicated in the ~~International~~ California Building Code.
  - 2.3. Required *means of egress* are provided for both the building and the membrane structure or tent including travel distances.
  - 2.4. Fire apparatus access roads are provided in accordance with Section 503.

3. When approved by the enforcing agency, tents may be located in or on permanent buildings provided such use does not constitute an undue hazard.

**2404.12 Portable fire extinguishers.** Portable fire extinguishers shall be provided as required by ~~Section 906~~ California Code of Regulations, Title 19, Division 1, Chapter 2, Article 3, Section 319.

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[25. The SFM proposes to adopt Chapter 25 with the following amendments and California regulations.]

**CHAPTER 25  
TIRE REBUILDING AND TIRE STORAGE**

**2501.1 Scope.** Tire rebuilding plants, tire storage (*including tire derived products as defined in Public Resources Code Section 42805.7(a)*) and tire byproduct facilities shall comply with this chapter, other applicable requirements of this code and NFPA 13. Tire storage in buildings shall also comply with Chapter 23.

**2503.1 Construction.** Tire rebuilding plants shall comply with the requirements of the ~~International~~ California Building Code, as to construction, separation from other buildings or other portions of the same building, and protection.

**2504.2 Sources of heat.** Open flame. Cutting, welding or heating devices shall not be operated in tire storage yards, blow torches or highly flammable materials, including but not limited to, inner tubes are prohibited within 40 feet of a waste tire pile.

**2505.1 Individual piles.** Tire storage shall be restricted to individual piles not exceeding 5,000 square feet (464.5 m<sup>2</sup>) of continuous area. Pile width shall not exceed 50 feet. Piles shall not exceed 50,000 cubic feet (1416m<sup>3</sup>) in volume or 10 feet (3048 mm) in height.

**2505.4 Distance from lot lines and buildings.** Tire storage piles shall be located at least 50 feet (15 240 mm) from lot lines and buildings.

**Exceptions:**

1. Tire storage piles containing less than 500 tires shall be permitted to be located no closer than 10 feet (3048 mm) from lot lines or from buildings. Tire storage piles shall not exceed 6 feet (1829 mm) in height when within 20 feet of any property line, building, or perimeter fencing. Side slopes shall not exceed 60 degrees. When approved by the fire code official in accordance with Section 1.11.2.4 distances of less than 10 feet (3048 mm) from lot lines or from buildings may be approved.

2. When approved by the fire code official in accordance with Section 1.11.2.4, exempted facilities defined in Public Resources Code Sections 42808(c) and 42831 and used tires as defined in 42806.5, tire storage piles shall be permitted to be located no closer than 10 feet (3 048 mm) from lot lines or from buildings. Tire storage piles shall not exceed 6 feet (1829 mm) in height when within 20 feet of any property line or perimeter fencing. Side slopes shall not exceed 60 degrees.

3. When approved by the fire code official in accordance with Section 1.11.2.4, "minor waste tire facilities" as defined in Public Resources Code Section 42808, tire storage piles shall be permitted to be located no closer than 10 feet (3 048 mm) from lot lines or 50 feet (15 240 mm) from buildings. Tire storage piles shall not exceed 6 feet (1829 mm) in height when within 20 feet of any property line or perimeter fencing. Side slopes shall not exceed 60 degrees.

4. Existing "minor waste tire storage facilities" as defined in Public Resources Code Section 42808, legally permitted prior to January 1, 2011, shall be permitted to maintain tire storage piles located no closer than 10 feet (3048 mm) from lot lines or 50 feet (15240 mm) from buildings. Tire storage piles shall not exceed 6 feet (1829 mm) in height when within 20 feet (6096 mm) of any property line or perimeter fencing. Side slopes shall not exceed 60 degrees.

**2505.7 Location of storage.** Outdoor waste tire storage shall not be located in any of the following:

1. Under bridges, elevated trestles, elevated roadways or elevated railroads.

2. In any area where they may be subjected to immersion in water during a 100-year storm unless the operator demonstrates that the facility will be designed and operated so as to prevent waste tires from migrating off site.

3. On surfaces with grades or other physical features that will interfere with firefighting equipment or personnel unless mitigating measures have been approved in writing by the local fire authority or a fire safety engineer registered by the State of California. Measures established by a fire safety engineer shall be subject to approval by the local fire authority.

**2505.8 Rim removal.** Waste tires stored on rims shall be stored separate from other waste tires.

**2505.9 Pyrolytic oil runoff.** The facility shall be designed and constructed to provide protection to by bodies of water from runoff of pyrolytic oil resulting from a potential tire fire.

**2506.1 Required access.** New and existing tire storage yards shall be provided with fire apparatus access roads in accordance with Section 503 and Section 2506.2. ~~Existing tire storage yards shall be provided with fire apparatus access roads where required in Chapter 46.~~

**2508.1 Water supply.** A public or private fire protection water supply shall be provided in accordance with Section 507 and shall be capable of delivering at least 1,000 gallons per minute for a duration of at least three hours and at least 2,000 gallons per minute for a duration of at least three hours if the sum of altered plus whole waste tires exceeds 10,000. The water supply shall be arranged such that any part of the storage yard can be reached by using not more than 500 feet (152 m) of hose.

**2508.2 Fire extinguishers.** Buildings or structures shall be provided with portable fire extinguishers in accordance with Section 906. Fuel-fired vehicles operating in the storage yard shall be equipped with a minimum ~~2-A:20-B:C-4~~ A:40-B:C rated portable fire extinguisher.

Authority: Health and Safety Code Sections 13108, 13143, 18949.2, Public Resources Code 42820 (b)

References: Health and Safety Code Sections 13143, 18949.2

---

**[26. The SFM proposes to adopt Chapter 26 without amendment.]**

**CHAPTER 26  
WELDING AND OTHER HOT WORK**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[27. The SFM proposes to adopt Chapter 27 with the following amendments and California regulations.]**

**CHAPTER 27  
HAZARDOUS MATERIALS—GENERAL PROVISIONS**

**2701.2.2.1 Physical hazards.** The material categories listed in this section are classified as physical hazards. A material with a primary classification as a physical hazard can also pose a health hazard.

1. Explosives and blasting agents.
2. Combustible liquids.
3. Flammable solids, liquids and gases.
4. Organic peroxide.
5. Oxidizer, solids or liquids.
6. Oxidizing gases.
7. Pyrophoric solids, liquids or gases.
8. Unstable (reactive) solids, liquids or gases.
9. Water-reactive ~~materials~~ solids or liquids.
10. Cryogenic fluids.

**2701.5.1 Hazardous Materials Management Plan (HMMP).** Where required by the fire code official, an application for a permit shall include an ~~Hazardous Materials Management Plan (HMMP)~~ HMMP. The HMMP shall include a facility site plan designating the following:

1. Access to each storage and use area.
2. Location of emergency equipment.
3. Location where liaison will meet emergency responders.
4. Facility evacuation meeting point locations.
5. The general purpose of other areas within the building.
6. Location of all above-ground and underground tanks and their appurtenances including, but not limited to, sumps, vaults, below-grade treatment systems and piping.
7. The hazard classes in each area.
8. Locations of all control areas and Group H occupancies.

9. Emergency exits.

*[For SFM] The HMMP shall comply with Health and Safety Code, Chapter 6.95, Sections 25500 through 25545, and Title 19, Division 2, Chapter 34.*

**2701.5.2 Hazardous Materials Inventory Statement (HMIS).** Where required by the fire code official, an application for a permit shall include an HMIS, such as ~~(SARA)~~, *the* Superfund Amendments and Reauthorization Act of 1986 Title III (SARA), Tier II Report or other approved statement. The HMIS shall include the following information:

1. Product name.
2. Component.
3. Chemical Abstract Service (CAS) number.
4. Location where stored or used.
5. Container size.
6. Hazard classification.
7. Amount in storage.
8. Amount in use-closed systems.
9. Amount in use-open systems.

*[For SFM] The HMIS shall comply with Health and Safety Code, Chapter 6.95, Sections 25500 through 25545, and Title 19, Division 2, Chapter 4.*

**2703.10. Handling and Transportation.** In addition to the requirements of Section 2703.2, the handling and transportation of hazardous materials in corridors, elevators and exit enclosures shall be in accordance with Sections 2703.10.1 through ~~2703.10.3-6~~ 2703.10.4.4

**2703.10.2 Carts and trucks required.** Liquids in containers exceeding 5 gallons (19 L) in a *corridor* or *exit* enclosure shall be transported on a cart or truck. Containers of hazardous materials having a hazard ranking of 3 or 4 in accordance with NFPA 704 and transported within *corridors* or *exit* enclosures, shall be on a cart or truck. Where carts and trucks are required for transporting hazardous materials, they shall be in accordance with Section 2703.10.3. Exceptions 1 through 4 shall not apply where elevators are utilized.

**Exceptions:**

1. Two hazardous material liquid containers, which are hand carried in acceptable safety carriers.
2. Not more than four drums not exceeding 55 gallons (208 L) each, which are transported by suitable drum trucks.
3. Containers and cylinders of *compressed gases*, which are transported by *approved* hand trucks, and containers and cylinders not exceeding 25 pounds (11 kg), which are hand carried.
4. Solid hazardous materials not exceeding 100 pounds (45 kg), which are transported by *approved* hand trucks, and a single container not exceeding 50 pounds (23 kg), which is hand carried.

**2703.10.2.1 Above the 10th story.** Above the 10th story of any occupancy, all vertical handling and transportation of hazardous materials in the building shall be in approved carts.

**2703.10.2.2 Transportation of hazardous materials above the 10th story** The handling and transportation of hazardous materials above the 10th story shall be limited to 5 percent of the maximum allowable quantities of Tables 2703.1(1) ( 2.) Quantities are permitted to be increase 100 percent in buildings with an approved automatic sprinkler system in accordance with 903.3.1.1. Materials where Foot Note G applies shall not be increased.

**2703.10.4 Elevators utilized to transport hazardous materials.**

**2703.10.4.1.** When transporting hazardous materials, elevators shall have no other passengers other than the individual(s) handling the chemical transport cart.

**2703.10.4.2.** Hazardous materials liquid containers shall have maximum capacity of 20 liters (5.28 gal).

2703.10.4.3. Toxic and highly-toxic gases shall be limited to a container of a maximum water capacity of 1 lb.

2703.10.4.4. Means shall be provided to prevent the elevator from being summoned to other floors.

Authority: Health and Safety Code Sections 13108, 13143, 13143.9, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[28. The SFM proposes to adopt Chapter 28 without amendment.]**

**CHAPTER 28  
AEROSOLS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[29. The SFM proposes to adopt Chapter 29 without amendment.]**

**CHAPTER 29  
COMBUSTIBLE FIBERS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[30. The SFM proposes to adopt Chapter 30 without amendment.]**

**CHAPTER 30  
COMPRESSED GASES**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[31. The SFM proposes to adopt Chapter 31 without amendment (see item 60 for existing SFM regulations).]**

**CHAPTER 31  
CORROSIVE MATERIALS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[32. The SFM proposes to adopt Chapter 32 without amendment.]

**CHAPTER 32  
CRYOGENIC FLUIDS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[33. The SFM proposes to adopt Chapter 33 without amendment (see item 60 for existing SFM regulations).]

**CHAPTER 33  
EXPLOSIVES AND FIREWORKS**

Authority Cited: Health and Safety Code Sections 12081, 12552, 12553, 13108.  
References: Health and Safety Code Sections 12000 through 12401 and 12500 through 12725

---

[34. The SFM proposes to adopt Chapter 34 with the following amendments and California regulations.]

**CHAPTER 34  
FLAMMABLE AND COMBUSTIBLE LIQUIDS**

~~**3404.3.1.2 Portable fuel containers.** Portable fuel containers of 10 gallons (37.85 L) or less shall be listed and approved by the California State Fire Marshal and comply with the provisions of Division 1, Chapter 1.5, Title 19 California Code of Regulations.~~

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[35. The SFM proposes to adopt Chapter 35 without amendment.]

**CHAPTER 35  
FLAMMABLE GASES**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

**[36. The SFM proposes to adopt Chapter 36 without amendment.]**

**CHAPTER 36  
FLAMMABLE SOLIDS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[37. The SFM proposes to adopt Chapter 37 without amendment (see item 60 for existing SFM regulations).]**

**CHAPTER 37  
HIGHLY TOXIC AND TOXIC MATERIALS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[38. The SFM proposes to adopt Chapter 38 without amendment (see item 60 for existing SFM regulations).]**

**CHAPTER 38  
LIQUEFIED PETROLEUM GASES**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[39. The SFM proposes to adopt Chapter 39 without amendment (see item 60 for existing SFM regulations).]**

**CHAPTER 39  
ORGANIC PEROXIDES**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[40 The SFM proposes to adopt Chapter 40 without amendment (see item 60 for existing SFM regulations).]**

**CHAPTER 40  
OXIDIZERS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[41. The SFM proposes to adopt Chapter 41 without amendment (see item 60 for existing SFM regulations).]**

**CHAPTER 41  
PYROPHORIC MATERIALS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[42. The SFM proposes to adopt Chapter 42 without amendment.]**

**CHAPTER 42  
PYROXYLIN (CELLULOSE NITRATE) PLASTICS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[43. The SFM proposes to adopt Chapter 43 without amendment (see item 60 for existing SFM regulations).]**

**CHAPTER 43  
UNSTABLE (REACTIVE) MATERIALS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[44. The SFM proposes to adopt Chapter 44 without amendment.]**

**CHAPTER 44  
WATER-REACTIVE SOLIDS AND LIQUIDS**

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

**[45. The SFM proposes to adopt Chapter 45 without amendment.]**

**CHAPTER 45**

## MARINAS

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[46. The SFM proposes to adopt specific Sections of Chapter 46 with the following amendments and California regulations, adopt only those Sections listed the corresponding Matrix Adoption Table.]

### CHAPTER 46 CONSTRUCTION REQUIREMENTS FOR EXISTING BUILDINGS

**4603.6 Fire alarm systems.** An approved fire alarm system shall be installed in existing buildings and structures in accordance with Sections 4603.6.1 through 4603.6.7 and provide occupant notification in accordance with Section 907.6 unless other requirements are provided by other sections of this code. Existing high-rise buildings shall comply with Section 4603.6.8.

**Exception:** Occupancies with an existing, previously approved fire alarm system.

~~907.3.1.3.1~~ **4603.6.3.1 Additional provisions for Existing Group I Occupancies:** *In projects requiring the Office of Statewide Health Planning and Development approval in existing Group I-2 and I-2.1 occupancies located in buildings defined as hospitals in Section 1250 of the Health and Safety Code, facilities not equipped with an automatic sprinkler system throughout shall be equipped with an automatic fire alarm system which responds to the products of combustion other than heat.*

**Exception:** Heat detectors may be used in closets, unusable spaces under floor areas, storage rooms, bathrooms, and rooms of similar use.

~~907.2.10.5~~ **4603.7.5 Additional provisions for Existing Group R-3 occupancies.**

~~907.2.1.3~~ **4606 Group A occupancy public address system.** Existing buildings or structures intended for public assemblies of 10,000 or more persons, which, on or after January 1, 1991 have or subsequently have installed a public address system, shall have an emergency backup power system for the public address system.

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[47. The SFM proposes to adopt Chapter 47 with the following amendments and California regulations.]

### CHAPTER 47 REFERENCED STANDARDS

This chapter lists the standards that are referenced in various sections of this document. The standards are listed herein by the promulgating agency of the standard, the standard identification, the effective date and title, and the section or sections of this document that reference the standard. The application of the referenced standards shall be as specified in Sections 1.1.5, 1.1.7 and 102.6.



American Society of Mechanical Engineers  
 Three Park Avenue  
 New York, NY 10016-5990

Standard reference number	Title	Referenced in code section number
<b><i>BPE – 2009</i></b>	<b><i>Bio-processing Equipment Standard</i></b>	



Factory Mutual  
 Standards Laboratories Department  
 1151 Boston-Providence Turnpike  
 Norwood, MA 02062

Standard reference number	Title	Referenced in code section number
<b><i>3260-00</i></b>	<b><i>Radiant Energy-Sensing Fire Detectors for Automatic Fire Alarm Signaling.</i></b>	
<b><i>3011-99</i></b>	<b><i>Approval Standard for Central Station Service for Fire Alarm and Protective Equipment Supervision.....</i></b>	<b><i>907.7.5.2</i></b>
<b><i>4430-80</i></b>	<b><i>Acceptance Criteria for Smoke and Heat Vents.....</i></b>	<b><i>910.3.1</i></b>



International Code Council  
 5203 Leesburg Pike, Suite 600  
 Falls Church, VA 22041

Standard reference number	Title	Referenced in code section number
<b><i>ICC/ANSI A117.1 – 03</i></b>	<b><i>Accessible and Usable Buildings and Facilities .....</i></b>	<b><i>907.6.2.3.4, 1010.1, 1010.6.5, 1010.9, 1011.3, 1022.8</i></b>
<b><i>ICC 300-07</i></b>	<b><i>Standard on Bleachers, Folding and Telescopic Seating and Grandstands .....</i></b>	<b><i>1028.1.1</i></b>
<b><i>IBC – 09</i></b>	<b><i>International Building Code®.....</i></b>	<b><i>102.3, 102.4, 102.5, 201.3, 202, 304.1.3, 306.1, 311.1.1, 311.3, 313.1, 408.7.2, 504.1, 508.1, 508.1.2, 603.2, 603.5.2, 603.6.1, 603.8, 604.1, 604.2.9, 604.2.14.1, 604.2.14.1.3, 604.2.15, 604.2.15.1.1, 604.2.16, 607.3, 608.4, 608.8, 701.1, 704.1, 801.1, 803.1, Table 803.3, 803.7.1, 803.7.2, 807.1.2, 807.4.2.2, 901.4.1, 901.4.2, 903.2, 903.2.3.2, 903.2.9.1, 903.3.2, 903.3.5.2, 903.6, 907.1.1, 907.2.6.2, 907.2.6.3.3, 907.2.7, 907.2.13, 907.2.18, 907.2.21, 907.7.5, 909.1, 909.2, 909.3, 909.4.3, 909.5, 909.5.2, 909.5.2.1, 909.10.5, 909.11, 911.2, 914.1, 914.2.1, 914.3.1, 914.5.3, Table 914.8.2, 914.10, 1003.2, 1003.5, 1006.3, 1007.2, 1007.4, 1007.5, 1007.6.2, 1007.8, 1007.9, 1008.1.4.1, 1008.1.4.3, 1008.1.7, 1008.1.9.1, 1008.1.10.1, 1009.4.2, 1009.12, 1009.13.1, 1010.1, 1010.6.3, 1010.6.4, 1010.6.5, 1010.9, 1011.4, 1011.5.3, 1012.1, 1013.1.1, 1014.2.7, Table 1016.1, 1017.2, 1018.1, Table 1018.1, 1021.1, Table 1021.2, 1022.1, 1022.2.1, 1022.3, 1022.4, 1022.8, 1022.9.1, 1023.3, 1023.5, 1025.2, 1025.3, 1027.3, 1028.1.1, 1028.6.2, 1028.14.2, 1104.6, 1106.17, 1107.1, 1107.4, 1203.3, 1207.1, 1414.1, 1502.1, 1504.2, 1504.3.1, 1504.3.2.6, 1504.3.3, 1505.2, 1801.1, 1801.4, 1803.2.2, 1803.3.1, 1803.3.2, 1803.3.3, 1803.3.4, 1803.3.8, 1803.14, 1803.14.1, 1803.15.1, 1804.3.1, 1805.2.3.2, 1805.3.1, 1805.3.2, 1805.3.3, 1903.1, 2005.1, 2009.2, 2009.4, 2009.6, 2201.1, 2201.4, 2203.1, 2207.4, 2208.3, 2208.3.1, Table 2209.3.1, 2209.3.2.3, 2209.3.2.6.1, 2209.3.3, 2210.1, 2211.1, 2211.3.1, 2211.4.1, 2211.8.1.2.3, 2301.3, Table 2306.2, 2306.3.1, 2306.3.2.1, 2306.3.2.2, 2306.8, 2307.2, 2308.2, 2402.1, 2403.8.2, 2403.8.4, 2404.1, 2503.1, 2703.2.2.2, 2703.2.8, 2703.8.1, Table 2703.8.2, 2703.8.3.1, 2703.8.4.1, 2703.9.9, 2704.13, 2705.2, 2705.3.9, 2801.1, 2904.3, 2904.4, 2904.5, 3003.16.1, 3003.16.2, 3006.2, 3203.1.2, 3203.5.2, 3204.2, 3204.2.2.2, 3204.4.3, 3205.4.1, 3304.2, Table 3304.5.2.3, 3305.5, 3401.3,</i></b>



**Revise Section 8.15.1.2.15 as follows:**

8.15.1.2.15 Exterior columns under 10 ft<sup>2</sup> (0.93m<sup>2</sup>) in total area, formed by studs or wood joist, with no sources of ignition within the column, supporting exterior canopies that are fully protected with a sprinkler system, shall not require sprinkler protection.

**Revise Section 8.15.7.1\* as follows:**

8.15.7.1\* Unless the requirements of 8.15.7.2, ~~8.15.7.3, or 8.15.7.4~~ are met, sprinklers shall be installed under exterior roofs, canopies, porte-cochere, balconies, decks, or similar projections exceeding 4 ft (1.2 m) in width.

**Revise Section 8.15.7.2\* as follows:**

8.15.7.2\* Sprinklers shall be permitted to be omitted where the canopies, roofs, ~~porte-cochere~~, balconies, decks, or similar projections are constructed with materials that are noncombustible, limited-combustible, or fire retardant treated wood as defined in NFPA 703, *Standard for Fire Retardant-Treated Wood and Fire-Retardant Coatings for Building Materials*.

**Delete Section A.8.15.7.2 of Annex**

~~A.8.15.7.2 Vehicles that are temporarily parked are not considered storage. Areas located at drive-in bank windows or porte cocheres at hotels and motels normally do not require sprinklers where there is no occupancy above, where the area is entirely constructed of noncombustible or limited combustibile materials or fire retardant treated lumber, and where the area is not the only means of egress. However, areas under exterior ceilings where the building is sprinklered should be protected due to the occupancy above.~~

**Revise Section 8.15.7.3**

8.15.7.3 Sprinklers shall be permitted to be omitted from below the canopies, roofs, ~~porte-cochere~~, balconies, decks, or similar projections are combustibile construction, provided the exposed finish material on the roof, or canopy, ~~or porte-cochere~~ is noncombustible, limited-combustible, or fire retardant treated wood as defined in NFPA 703, *Standard for Fire Retardant-Treated Wood and Fire-Retardant Coatings for Building Materials*, and the roofs, or canopies, ~~or porte-cochere~~ contains only sprinklered concealed spaces or any of the following unsprinklered combustibile concealed spaces:

- (1) Combustibile concealed spaces filled entirely with noncombustibile insulation
- (2) Light or ordinary hazard occupancies where noncombustibile or limited-combustibile ceilings are directly attached to the bottom of solid wood joists so as to create enclosed joist spaces 160 ft<sup>3</sup> (4.5 m<sup>3</sup>) or less in volume, including space below insulation that is laid directly on top or within the ceiling joists in an otherwise sprinklered attic [See 11.2.3.1.4(4)(d)].
- (3) Concealed spaces over isolated small roofs, or canopies, ~~or porte-cocheres~~ not exceeding 55 ft<sup>2</sup> (5.1

**Delete language to section 8.15.7.4 and reserve section number.**

~~8.15.7.4 Sprinklers shall be permitted to be omitted from exterior exit corridors when the exterior walls of the corridor are at least 50 percent open and when the corridor is entirely of noncombustibile construction.~~

**Revise Annex Section A.8.15.7.5 as follows:**

A. 8.15.7.5 ~~Short term transient storage, such as that for delivered packages, and~~ The presence of planters, newspaper machines and similar items ~~so forth~~, should not be considered storage ~~or handling of combustibles~~.

**Add new Sections 8.16.1.1.1.4 and 8.16.1.1.1.5 as follows:**

8.16.1.1.1.4 Where a system includes floor control valves, a hydraulic design information sign containing information for the floor shall be provided at each floor control valve. A hydraulic design information sign shall be provided for each area calculated. The installing contractor shall identify a hydraulically designed sprinkler system with a permanently marked weatherproof metal or rigid plastic sign secured with corrosion resistant wire, chain, or other approved means. Such signs shall be placed at the alarm valve, dry pipe valve, preaction valve, or deluge valve supplying the corresponding hydraulically designed area.

8.16.1.1.1.5 Control valves, check valves, drain valves, antifreeze valves shall be readily accessible for inspection, testing, and maintenance. Valves located more than 7 feet above the finished floor shall be provided with a means of opening and closing the valve from the floor level.

**Revise Section 8.16.1.5.1 as follows:**

8.16.1.5.1 ~~Large p~~Private fire service main systems shall have sectional controlling valves at appropriate points in order

to permit sectionalizing the system in the event of a break or for the making of repairs or extensions.

*Add new Sections 8.16.1.5.1.1, 8.16.1.5.1.2 and 8.16.1.5.1.3 as follows:*

8.16.1.5.1.1 Sectional control valves are not required when the fire service main system serves less than six fire appurtenances.

8.16.1.5.1.2 Sectional control valves shall be indicating valves in accordance with Section 6.7.1.3.

8.16.1.5.1.3 Sectional control valves shall be located so that no more than five fire appurtenances are affected by shut-down of any single portion of the fire service main. Each fire hydrant, fire sprinkler system riser, and standpipe riser shall be considered a separate fire appurtenance. In-rack sprinkler systems shall not be considered as a separate appurtenance.

8.16.1.5.1.4 The number of fire appurtenances between sectional control valves is allowed to be modified by the authority having jurisdiction.

*Revise Section 8.16.1.5.2 as follows:*

8.16.1.5.2 A valve shall be provided on each bank where a main crosses a body of water and or outside the building foundation(s) where the main or section of main runs under a building.

*Add new Section 9.1.3.9.1.1 as follows:*

9.1.3.9.1.1 Powder-driven studs used for attaching hangers to the building structure are prohibited in Seismic design Categories C, D, E and F.

*Add a new sentence to the beginning of Section 9.3.5.8.9 as follows:*

9.3.5.8.11 Where threaded pipe is used for sway bracing, it shall have a wall thickness of not less than Schedule 40.

*Replace Section 9.3.5.9.4 as follows:*

Lag screws or power-driven fasteners shall not be used to attach braces to the building structure.

*Add language to the beginning of Section 9.3.5.9.6 as follows:*

9.3.5.9.6 Fastening methods other than those identified in 9.3.5.9 and 9.3.7.8 The requirements of 9.3.5.9 shall not apply to other fastening methods, which shall be acceptable for use if certified by a registered professional engineer to support the loads determined in accordance with the criteria in 9.3.5.6. Calculations shall be submitted ~~where required by~~ to the authority having jurisdiction.

*Revise Section 9.3.5.9.7.2\* as follows:*

9.3.5.9.7.2\* Concrete anchors other than those shown in Figure 9.3.5.9.1 and identified in 9.3.5.8.10 shall be acceptable for use where designed in accordance with the requirements of the building code and certified by a registered professional engineer.

*Revise Section 9.3.6.1(3) as follows:*

9.3.6.1(3) No. 12, 440 lb (200Kg) wire installed at least 45 degrees from the vertical plane and anchored on both sides of the pipe. Powder-driven fasteners for attaching restraint is allowed to be used provided that the restraint component does not support the dead load.

*Revise Section 10.6.5 as follows:*

10.6.5 Pipe joints shall not be located under foundation footings. The pipe under the building or building foundation shall not contain mechanical joints.

Exceptions:

1. Where allowed in accordance with 10.6.2

2. Alternate designs may be utilized where designed by a registered professional engineer and approved by the enforcing agency.


*Revise Section 11.2.3.1.4(4)(i) as follows:*

11.2.3.1.4(4)(i) Exterior columns under 10 ft<sup>2</sup> (0.93m<sup>2</sup>) in total area, formed by studs or wood joist, with no sources of ignition within the column, supporting exterior canopies that are fully protected with a sprinkler system.

Revise Section 11.2.3.2.3.1 as follows:

11.2.3.2.3.1 Where listed quick-response sprinklers, ~~excluding~~ ~~including~~ extended coverage quick-response sprinklers, are used throughout a system or portion of a system having the same hydraulic design basis, the system area of operation shall be permitted to be reduced without revising the density as indicated in Figure 11.2.3.2.3.1 when all of the following conditions are satisfied:

- (1) Wet pipe system
- (2) Light hazard ~~or ordinary hazard~~ occupancy
- (3) 20 ft (6.1 m) maximum ceiling height
- (4) There are no unprotected ceiling pockets as allowed by 8.6.7 and 8.8.7 exceeding 32 ft<sup>2</sup> (3 m<sup>2</sup>)



Note:  $y = \frac{-3x}{2} + 55$

For ceiling height  $\geq 10$  ft and  $\leq 20$  ft,  $y = \frac{-3x}{2} + 55$

For ceiling height  $< 10$  ft,  $y = 40$

For ceiling height  $> 20$ ,  $y = 0$

For SI units, 1 ft = 0.31 m.

FIGURE 11.2.3.2.3.1 Design Area Reduction for Quick-Response Sprinklers.

Revise Section 11.2.3.2.3.2 as follows:

11.2.3.2.3.2 The number of sprinklers in the design area shall never be less than ~~five~~ seven.

Add Section 24.1(5)

**24.1 Approval of Sprinkler Systems and Private Fire Service Mains.**

The installing contractor shall do the following:

- (1) Notify the authority having jurisdiction and the property owner or property owner's authorized representative of the time and date testing will be performed.
- (2) Perform all required testing (see Section 24.2)
- (3) Complete and sign the appropriate contractor's material and test certificate(s) (see Figure 24.1)
- (4) Remove all caps and straps prior to placing the sprinkler system in service
- (5) Upon system acceptance by the authority having jurisdiction a label prescribed by Title 19 California Code of Regulations, Chapter 5 shall be affixed to each system riser.

Revise Section 24.4(2) and Add Section 24.4(3) as follows:

**24.4 Instructions.**

The installing contractor shall provide the property owner or the property owner's authorized representative with the

following:

- (1) All literature and instructions provided by the manufacturer describing proper operation and maintenance of any equipment and devices installed
- (2) NFPA 25, *Standard for the Inspection, testing, and maintenance of Water-Based Fire Protection Systems, 2006 California Edition*
- (3) *Title 19, California Code of Regulations, Chapter 5, "Fire Extinguishing Systems"*.

**Add sentence at the end of Section 24.5.1 as follows:**

**24.5.1** *"Pipe schedule systems shall be provided with a sign indicating that the system was designed and installed as a pipe schedule system and the hazard classification(s) included in the design."*

**Revise Section 24.5.2(3) and Add Sections 24.5.2(7) to (14) as follows:**

**24.5.2** The sign shall include the following information:

- (3) Required flow and residual pressure demand of the system at the base of the riser  
*(7) Required flow and pressure of the system at the water supply source.*  
*(8) Required flow and pressure of the system at the discharge side of the fire pump where a fire pump is installed.*  
*(9) Type or types and number of sprinklers or nozzles installed including the orifice size, temperature rating, orientation, K-Factor, sprinkler identification number (SIN) for sprinkler heads when applicable, and response type.*  
*(10) The minimum discharge flow rate and pressure required from the hydraulically most demanding sprinkler.*  
*(11) The required pressure settings for pressure reducing valves.*  
*(12) For deluge sprinkler systems, the required flow and pressure at the hydraulically most demanding sprinkler or nozzle.*  
*(13) The protection area per sprinkler based on the hydraulic calculations*  
*(14) The edition of NFPA 13 to which the system was designed and installed.*

**Revise Section 24.6.1 as follows:**

**24.6.1** *California Edition* NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*.

13D—07.10

Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes *as amended*\*.....903.3.1.3, 903.3.5.1.1

**NFPA 13D, Amended Sections as follows:**

**6.2\* Water Supply Sources.** *When the requirements of 6.2.2 are met, the following water supply sources shall be considered to be acceptable by this standard:*

- (1) A connection to a reliable waterworks system with or without an automatically operated pump
- (2) An elevated tank
- (3) A pressure tank designed to American Society of Mechanical Engineers (ASME) standards for a pressure vessel with a reliable pressure source
- (4) A stored water source with an automatically operated pump
- (5) A well with a pump of sufficient capacity and pressure to meet the sprinkler system demand. The stored water requirement of 6.1.2 or 6.1.3 shall be permitted to be a combination of the water in the well (including the refill rate) plus the water in the holding tank if such tank can supply the sprinkler system.

**6.2.2** Where a well, pump, and tank or combination thereof is the source of supply for a fire sprinkler system, ~~but is not a portion of the domestic water system~~ *the water supply shall serve both domestic and fire sprinkler systems, and* the following shall be met:

- (1) A test connection shall be provided downstream of the pump that creates a flow of water equal to the smallest sprinkler on the system. The connection shall return water to the tank.
- ~~(2)~~ *Pump motors using ac power shall be connected to a 240 V normal circuit.*
- ~~(3)~~ *(2) Any disconnecting means for the pump shall be approved.*
- ~~(4)~~ *(3) A method for refilling the tank shall be piped to the tank.*
- ~~(5)~~ *(4) A method of seeing the water level in the tank shall be provided without having to open the tank.*
- ~~(6)~~ *(5) The pump shall not be permitted to sit directly on the floor.*

6.2.2.1 Where a fire sprinkler system is supplied by a stored water source with an automatically operated means of pressurizing the system other than an electric pump, the water supply may serve the sprinkler system only.

6.2.3 Where a water supply serves both domestic and fire sprinkler systems, 5 gpm (19 L/min) shall be added to the sprinkler system demand at the point where the systems are connected, to determine the size of common piping and the size of the total water supply requirements where no provision is made to prevent flow into the domestic water system upon operation of a sprinkler.

8.6.4\* Sprinklers shall not be required in detached garages, open attached porches, carports with no habitable space above, and similar structures.

13R—~~07~~10

Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height as amended\* .....903.3.1.2, 903.3.5.1.1, 903.3.5.1.2, 903.4

**\*NFPA 13R, Amended Sections as follows:**

**Revise Section 2.2 and add publications as follows:**

**2.2 NFPA Publications.**

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, ~~2008~~ 2006 California edition.

**Add Section 10.1.5 as follows:**

**10.1.5 Instructions.**

The installing contractor shall provide the property owner or the property owner's authorized representative with the following:

(1) All literature and instructions provided by the manufacturer describing proper operation and maintenance of any equipment and devices installed

(2) NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems 2006 California Edition and Title 19, California Code of Regulations, Chapter 5.

(3) Once the system is accepted by the authority having jurisdiction a label as prescribed by Title 19, California Code of Regulations, Chapter 5, shall be affixed to each system riser.

14—07

Installation of Standpipe and Hose System, as amended\* .....905.2, 905.3.4, 905.4.2, 905.8

**\*NFPA 14, Amended Sections as follows:**

**Replace Section 6.3.7.1**

**6.3.7.1** System water supply valves, isolation control valves, and other valves in fire mains shall be supervised in an approved manner in the open position by one of the following methods:

(1) Where a building has a fire alarm system or a sprinkler monitoring system installed, the valve shall be supervised by:

(a) a central station, proprietary, or remote supervising station, or

(b) a local signaling service that initiates an audible signal at a constantly attended location.

(2) Where a building does not have a fire alarm system or a sprinkler monitoring system installed, the valve shall be supervised by:

(a) Locking the valves in the open position, or

(b) Sealing of valves and a approved weekly recorded inspection where valves are located within fenced enclosures under the control of the owner.

24—~~07~~10

Installation of Private Fire Service Mains and Their Appurtenances: as amended\* ..... 507.2.1, 1909.5

*\*NFPA 24, Amended Sections as follows:*

***Amend Section 4.2.1***

Section 4.2.1. Installation work shall be done by fully experienced and responsible *contractors*. *Contractors shall be appropriately licensed in the State of California to install private fire service mains and their appurtenances.*

***Revise Section 4.2.2 as follows:***

4.2.2 *Installation or modification of private fire service mains shall not begin until plans are approved and appropriate permits secured from the authority having jurisdiction.*

***Add Section 4.2.2.1 as follows:***

4.2.2.1 *As approved by the authority having jurisdiction, emergency repair of existing system may start immediately, with plans being submitted to the authority having jurisdiction within 96 hours from the start of the repair work.*

***Revise Section 5.9.1.2 as follows:***

Section 5.9.1.2 Fire department connections shall be properly supported *and protected from mechanical damage.*

***Revise Section 5.9.5.1 as follows:***

5.9.5.1 Fire department connections shall be on the street side of buildings and *as approved by the authority having jurisdiction.*

***Revise Section 6.5.1 as follows:***

6.5.1 ~~Large private~~ Private fire service main systems shall have sectional controlling valves at appropriate points in order to permit sectionalizing the system in the event of a break or for the making of repairs or extensions.

***Add Section 6.5.2.1 – 6.5.2.3***

6.5.2.1 Sectional control valves are not required when the fire service main system serves less than six fire appurtenances.

6.5.2.2 Sectional control valves shall be indicating valves in accordance with Section 6.7.1.3.

6.5.2.3 Sectional control valves shall be located so that no more than five fire appurtenances are affected by shut-down of any single portion of the fire service main. Each fire hydrant, fire sprinkler system riser, and standpipe riser shall be considered a separate fire appurtenance. In-rack sprinkler systems shall not be considered as a separate appurtenance.

6.5.2.4 The number of fire appurtenances between sectional control valves is allowed to be modified by the authority having jurisdiction.

***Revise Section 6.6.2 as follows:***

6.6.2 A sectional valve shall be provided at the following locations:

- (1) On each bank where a main crosses *a body of water*
- (2) Outside the building foundation(s) where a main or a section of a main runs under a building

***Revise Section 10.6.5 as follows:***

10.6.5 Pipe joints shall not be located under foundation footings. *The pipe under the building or building foundation shall not contain mechanical joints.*

***Exceptions:***

1. Where allowed in accordance with 10.6.2

2. Alternate designs may be utilized where designed by a registered professional engineer and approved by the enforcing agency.

***Revise Section 10.9.1 as follows:***

10.9.1 *Backfill shall be well tamped in layers or puddle under and around pipes to prevent settlement or lateral movement. Backfill shall consist of clean fill sand or pea gravel to a minimum 6" below and to a minimum of 12" above the pipe and*



~~Delete Exception No. 2:~~

~~Exception No. 2: Fully sprinklered buildings shall not require protection in accordance with 4.4.5.~~

~~5.13.4~~ The operable part of each manual fire alarm box shall be not less than 1.1 m (3-1/2 ft) and not more than 1.22 m (4 ft) above floor level.

~~5.13.8~~ Additional fire alarm boxes shall be provided so that the travel distance to the nearest fire alarm box shall not be in excess of 61 m (200 ft) measured horizontally on the same floor.

~~Exception: When individual dwelling units are served by a single exit stairway, additional boxes at other than the ground floor may be omitted.~~

~~7.4.1.2.~~ The total sound pressure level produced by combining the ambient sound pressure level with all audible notification appliances operation shall not exceed 120 ~~110~~ dBA anywhere in the occupied area.

~~7.4.3.1~~ Audible notification appliances intended for operation in the private mode shall have a sound level of not less than 45 dBA at 10 feet (3m) or more than ~~120~~ 110 dBA at the minimum hearing distance from the audible appliance.

~~7.4.3.2.1.~~ Audible notification appliances intended for operation in the public mode shall have a sound level of not less than 75 dBA at 3 m (10 ft) or more than 120 ~~110~~ dBA at the minimum hearing distance from the audible appliance.

10.3.1 Equipment constructed and installed in conformity with this Code shall be listed for the purpose for which it is used. Fire alarm Systems and components shall be California State Fire Marshal approved and listed in accordance with California Code of Regulations, Title 19, Division 1.

10.3.3 All devices and appliances that receive their power from the initiating device circuit or signaling line circuit of a control unit shall be California State Fire Marshal listed for use with the control unit.

10.6.1 Where approved by the authority having jurisdiction, ECS priority signals when evaluated by stakeholders through risk analysis in accordance with 24.4.2.2 shall be permitted to take precedence over all other signals.

14.4.7.1 Testing. Household fire alarm systems shall be tested by a qualified service technician in accordance with the manufacturer's published instructions ~~at least annually~~ according to the methods of Table 14.4.2.2.

~~5-14~~ **17.15 Fire Extinguisher Monitoring Device.** A fire extinguisher monitoring device shall indicate those conditions for a specific fire extinguisher required by California Code of Regulations, Title 19, Division 1, Chapter 1, Section 574.2 (c) and California Fire Code to a fire alarm control unit. ~~or other control unit~~

~~6.4.2.2.2~~ **23.4.2.2 Exception:** (4) Where the vertically run conductors are contained in a 2-hour rated cable assembly, or enclosed (installed) in a 2-hour rated enclosure or a listed circuit integrity (C.I.) cable, which meets or exceeds a 2-hour fire resistive rating.

~~6.8.5.1.2~~ **23.8.5.1.2 (Manual Fire Alarm Boxes)** Where connected to a supervising station, fire alarm systems employing automatic fire detectors or waterflow detection devices shall include a manual fire alarm box to initiate a signal to the supervising station.

**Exception:** Fire alarm systems dedicated to elevator recall control, ~~and~~ supervisory service and fire sprinkler monitoring only as permitted in Section ~~21.3~~.

~~6.8.5.4.1~~ **23.8.5.4.1** Systems equipped with alarm verification features shall be permitted under the following conditions:

(1) The alarm verification feature is not initially enabled unless conditions or occupant activities that are expected to cause nuisance alarms are anticipated in the area that is protected by the smoke detectors. Enabling of the alarm verification feature shall be protected by password or limited access.

(2) A smoke detector that is continuously subjected to a smoke concentration above alarm threshold does not delay the system functions of Sections ~~4.4.3, 6.8.1.1 or 6.16.2.1-10.6~~ 10.6 through 10.13, 23.8.1.1, or 21.2.1 by more than ~~4~~ 1 minute. 30 seconds.

(3) Actuation of an alarm-initiating device other than a smoke detector causes the system functions of 4.4.3, 6.8.1.1, or

6.16.2.1 without additional delay.

(4) The current status of the alarm verification feature is shown on the record of completion (see Figure 4.5.2.1, item 10).

(5) Operation of a patient room smoke detector in ~~I-1~~ and I-2 and R-2.1 Occupancies shall not include an alarm verification feature.

29.3.1 All devices, combinations of devices, and equipment to be installed in conformity with this chapter shall be approved or listed by the California State Fire Marshal for the purposes for which they are intended.

29.5.2.1.1\* **Smoke and Heat Alarms.** Unless exempted by applicable laws, codes, or standards, smoke or heat alarms used to provide a fire-warning function, and when two or more alarms are installed within a dwelling unit, suite of rooms, or similar area, shall be arranged so that the operation of any smoke or heat alarm causes all alarms within these locations to sound.

~~Exception: The arrangement for all alarms to sound shall not be required for mechanically powered single station heat alarms.~~

~~11.7.2.1~~ 29.7.2.1 The alarm verification feature shall not be used for household fire warning equipment.

~~11.7.5.7.1~~ 29.7.5.7.1 The alarm verification feature shall not be used for household fire warning equipment.

92A—0009

~~Recommended Practice for Smoke-Control Systems~~ Standard for Smoke-Control Systems Utilizing Barriers and Pressure Differences

170—06

Standard for Fire Safety and Emergency Symbols.....907.1.2

2001 — 08

Clean Agent Fire Extinguishing Systems as amended\*: .....Table 901.6.1, 904.10

\*NFPA 2001, Amended Sections as follows:

4.3.5.1.1 Alarms signals from the fire extinguishing system shall not interfere with the building fire alarm signal.

4.3.5.2.1. The lens on visual appliances shall be "red" in color.

Exception: Other lens colors are permitted where approved by the enforcing agency.

State of California  
Department of Forestry and Fire Protection  
Office of the State Fire Marshal  
P.O. Box 944246  
Sacramento, CA 94246-2460

# SFM

Standard reference number	Title	Referenced in code section number
<i>SFM 12-3</i>	<i>Releasing Systems for Security Bars in Dwellings</i>	
<i>SFM 12-7-3</i>	<i>Fire-testing Furnaces</i>	
<i>SFM 12-7A-1</i>	<i>Exterior Wall Siding and Sheathing</i>	
<i>SFM 12-7A-2</i>	<i>Exterior Window</i>	
<i>SFM 12-7A-3</i>	<i>Under Eave</i>	
<i>SFM 12-7A-4</i>	<i>Decking</i>	
<i>SFM 12-7A-4A</i>	<i>Decking Alternate Method A</i>	
<i>SFM 12-7A-5</i>	<i>Ignition Resistant Building Material</i>	
<i>SFM 12-7A-4</i>	<i>Decking</i>	
<i>SFM 12-8-100</i>	<i>Room Fire Tests for Wall and Ceiling Materials</i>	
<i>SFM 12-10-1</i>	<i>Power Operated Exit Doors</i>	
<i>SFM 12-10-2</i>	<i>Single Point Latching or Locking Devices</i>	

(The Office of the State Fire Marshal standards referred to above are found in the California Code of Regulations, Title 24, Part 12.)



Underwriters Laboratories, Inc.  
333 Pfingsten Road  
Northbrook, IL 60062-2096

Standard Reference number	Title	Referenced in code section number
13-96	Power-limited Circuit Cables	
38-99	Manually Actuated Signaling Boxes—with Revisions through February 2, 2005 as amended.*	
	*Amend Section 14.1.5 as follows:	
	14.1.5 A signaling box having a glass panel, disc, rod or similar part that must be broken to operate it for a signal or for access to its actuating means shall satisfactorily complete five part-breaking operations using the means provided with the box, without jamming of the mechanism or other interference by broken particles. It shall be practicable to remove and replace the broken parts. A signaling box shall not have a glass panel, disc, rod or similar part requiring a striking action by grasping a tool to operate it for a signal. The force required to activate controls shall be no greater than 5 pounds (22 N) of force.	
	*Add Appendix B chapter to UL 38 (1999) as follows:	
	<b>Appendix B,</b>	
	14.1.5 <b>Operation.</b> Controls and operating mechanisms shall be operable with one hand and shall not require tight grasping, pinching or twisting of the wrist.	
193-04	Alarm Valves for Fire-Protection Service	
199-95	Automatic Sprinklers for Fire Protection Service—with Revisions through August 19, 2005	
217-06	Single and Multiple Station Smoke Alarms.....	907.2.11
	<b>Amend Section 34.2.1 as follows:</b>	
	<del>Each single and multiple station smoke alarm may be provided with an automatically resettable alarm silencing means that has a fixed or variable time setting which silences the smoke alarm for a maximum of 15 minutes. Alarm silencing shall not disable the smoke alarm. It may reduce the sensitivity to no more than 4 percent obscuration (0.0177 O.D. per foot). Each device shall operate a distinctive audible trouble signal while in the silence mode. This may be done with a short beep similar to the low battery signal or by visible indication. Following the silenced period, the alarm shall restore automatically to its intended operation. Silencing of one alarm of a multiple station system shall not prevent an alarm operation from the other alarms in the system. See 34.2.1 and 34.2.2.</del>	
228-97	Door Closers/ Holders, with or without Integral Smoke Detectors—with Revisions through January 26, 2006	
260-04	Dry Pipe and Deluge Valves for Fire Protection Service	
262-04	Gate Valves for Fire Protection Service	
268A-98	Smoke Detectors for Duct Application—with Revisions through October 22, 2003	
312-04	Check Valves for Fire-Protection Service	
346-05	Waterflow Indicators for Fire Protective Signaling Systems	
464-03	Audible Signal Appliances—with Revisions through October 10, 2003	
497B-04	Protectors for Data Communication and Fire Alarm Circuits	
521-99	Heat Detectors for Fire Protective Signaling Systems—with Revisions through July 20, 2005	
539-00	Single- and Multiple-Station Heat Detectors—with Revisions through August 15, 2005	
632-00	Electrically Actuated Transmitters	
753-04	Alarm Accessories for Automatic Water Supply Valves for Fire Protection Service	
813-96	Commercial Audio Equipment—with Revisions through December 7, 1999	

864-03

*Control Units for Fire Protective Signaling Systems, as amended\*—with Revisions through July 14, 2005 . . . . .*  
909.12

*\*Amend No. 55.1 as follows:*

**RETARD-RESET-RESTART PERIOD – MAXIMUM 30 SECONDS** —No alarm obtained from control unit. Maximum permissible time is 30 seconds.

*\*Amend Section 55.2.2 as follows:*

*Where an alarm verification feature is provided, the maximum retard-reset-restart period before an alarm signal can be confirmed*

*and indicated at the control unit, including any control unit reset time and the power-up time for the detector to become operational*

*for alarm, shall not exceed 30 seconds. (The balance of the section text is to remain unchanged).*

*\*Add Section 55.2.9 as follows:*

*Smoke detectors connected to an alarm verification feature shall not be used as releasing devices.*

**Exception:** *Smoke detectors which operate their releasing function immediately upon alarm actuation independent of alarm verification feature.*

*\*Amend Section 89.1.10 as follows:*

The existing text of this section is to remain as printed with one editorial amendment as follows:

**THE TOTAL DELAY (CONTROL UNIT PLUS SMOKE DETECTORS) SHALL NOT EXCEED 30 SECONDS.**

(The balance of the section text is to remain unchanged).

Authority: Health and Safety Code Sections 13108, 13108.5(a), 13143, 13143.6, 13210, 17920(b), 18949.2(b) 18949.2(c), Government Code Section 51189, Public Education Code 17074.50.

References: Health and Safety Code Sections 13143, Government Code Sections 51176, 51177, 51178 and 51179, Public Resources Code Sections 4201 through 4204

---

**[48. The SFM proposes to maintain the adoption of Chapter 48 with editorial modification (see item 60 for existing SFM regulations).]**

**CHAPTER ~~4648~~**  
**MOTION PICTURE AND TELEVISION PRODUCTION STUDIO SOUND STAGES,  
APPROVED PRODUCTION FACILITIES, AND PRODUCTION LOCATIONS**

Authority: Health and Safety Code Sections 13143, 18949.2

References: Health and Safety Code Sections 13143, 18949.2

---

**[49. The SFM proposes to maintain the adoption of Chapter 49 with the following modifications.]**

**CHAPTER ~~4749~~**  
**REQUIREMENTS FOR WILDLAND-URBAN  
INTERFACE FIRE AREAS**

**~~SECTION 4704~~ 4901**  
**GENERAL**

**~~4704-4~~ 4901.1 Scope.** *The mitigation of conditions where a wildfire burning in vegetative fuels may readily transmit*

fire to buildings and threaten to destroy life, overwhelm fire suppression capabilities, or result in large property losses shall comply with this chapter.

**4701-2 4901.2 Purpose.** *The purpose of this code is to provide minimum standards to increase the ability of a building to resist the intrusion of flame or burning embers being projected by a vegetation fire and contributes to a systematic reduction in conflagration losses through the use of performance and prescriptive requirements.*

**4702-4902 DEFINITIONS.**

**4702-4 4902.1 General.** *For the purpose of this chapter, certain terms are defined as follows:*

**CDF DIRECTOR** means the Director of the California Department of Forestry and Fire Protection.

**FIRE PROTECTION PLAN** is a document prepared for a specific project or development proposed for a Wildland-Urban Interface Fire Area. It describes ways to minimize and mitigate potential for loss from wildfire exposure.

*The Fire Protection Plan shall be in accordance with this Article. When required by the enforcing agency for the purposes of granting modifications, a fire protection plan shall be submitted. Only locally adopted ordinances that have been filed with the California Building Standards Commission in accordance with Section 101.14 or the Department of Housing and Community Development in accordance with Section 101.15 shall apply.*

**FIRE HAZARD SEVERITY ZONES** are geographical areas designated pursuant to California Public Resources Codes Sections 4201 through 4204 and classified as Very High, High, or Moderate in State Responsibility Areas or as Local Agency Very High Fire Hazard Severity Zones designated pursuant to California Government Code Sections 51175 through 51189.

*The California Code of Regulations, Title 14, section 1280 entitles the maps of these geographical areas as "Maps of the Fire Hazard Severity Zones in the State Responsibility Area of California."*

**LOCAL AGENCY VERY HIGH FIRE HAZARD SEVERITY ZONE** means an area designated by a local agency upon the recommendation of the CDF Director pursuant to Government Code Sections 51177(c), 51178 and 5118 that is not a state responsibility area and where a local agency, city, county, city and county, or district is responsible for fire protection.

**STATE RESPONSIBILITY AREA** means lands that are classified by the Board of Forestry pursuant to Public Resources Code Section 4125 where the financial responsibility of preventing and suppressing forest fires is primarily the responsibility of the state.

**WILDFIRE** is any uncontrolled fire spreading through vegetative fuels that threatens to destroy life, property, or resources as defined in Public Resources Code Sections 4103 and 4104.

**WILDFIRE EXPOSURE** is one or a combination of radiant heat, convective heat, direct flame contact and burning embers being projected by vegetation fire to a structure and its immediate environment.

**WILDLAND-URBAN INTERFACE FIRE AREA** is a geographical area identified by the state as a "Fire Hazard Severity Zone" in accordance with the Public Resources Code Sections 4201 through 4204 and Government Code Sections 51175 through 51189, or other areas designated by the enforcing agency to be at a significant risk from wildfires. See Article 86B for the applicable referenced Sections of the Government Code and the Public Resources Code.

**SECTION-4703 4903  
PLANS [RESERVED]**

**SECTION-4704 4904  
FIRE HAZARD SEVERITY ZONES**

**4704.1 4904.1 General.** Lands in the state are classified by the CDF Director in accordance with the severity of wildfire hazard expected to prevail in those areas and the responsibility for fire protection, so that measures may be identified which will reduce the potential for losses to life, property, and resources from wildfire.

**4704.2 4904.2 Classifications.** The CDF Director classifies lands into fire hazard severity zones in accordance with California Public Resources Code Sections 4201 through 4204 for State Responsibility Areas and accordance with Government Code Sections 5117 through 51189 for areas where a local agency is responsible for fire protection.

**SECTION 4705 4905**  
**WILDLAND-URBAN INTERFACE FIRE AREA- WILDFIRE PROTECTION BUILDING CONSTRUCTION**

**4705.1 4905.1 General.** ~~Materials and Construction methods for exterior wildfire exposure protection and requirements to mitigate wildfire exposure~~ shall be applied within geographical areas where a wildfire burning in vegetative fuels may readily transmit fire to buildings and threaten to destroy life, overwhelm fire suppression capabilities, or result in large property losses.

**4705.2 4905.2 Construction Methods and Requirements within Established Limits.** Within the limits established by law, construction methods intended to mitigate wildfire exposure shall comply with the ~~California Building Code Chapter 7A, and this chapter.~~ wildfire protection building construction requirements contained in the California Building Standards Code including the following:

1. California Building Code Chapter 7A.
2. California Residential Code Section R327
3. California Reference Standards Code Chapter 12-7A
4. and this chapter.

**4705.3 4905.3 Establishment of Limits.** The establishment of limits for the Wildland-Urban Interface Fire Area's required construction methods shall be designated pursuant to the California Public Resources Code for State Responsibility areas or by a local agency following a finding supported by substantial evidence in the record that the requirements of this Section are necessary for effective fire protection within the area.

**SECTION 4706 4906**  
**HAZARDOUS VEGETATION AND FUEL MANAGEMENT ~~{RESERVED}~~**

**4906.1 General.** Hazardous vegetation and fuels shall be managed to reduce the severity of potential exterior wildfire exposure to buildings and to reduce the risk of fire spreading to buildings as required by applicable laws and regulations.

**4906.2 Application.** Buildings and structures located in the following areas shall maintain the required hazardous vegetation and fuel management:

1. All unincorporated lands designated by the State Board of Forestry and Fire Protection as State Responsibility Area (SRA) including:
  - 1.1. Moderate Fire Hazard Severity Zones
  - 1.2. High Fire Hazard Severity Zones
  - 1.3. Very-High Fire Hazard Severity Zones
2. Land designated as Very-High Fire Hazard Severity Zone by cities and other local agencies.

**4906.3 Requirements.** Hazardous vegetation and fuels around all applicable buildings and structures shall be maintained in accordance with the following laws and regulations:

1. Public Resources Code Section 4291.
2. California Code of Regulations, Title 14, Division 1.5, Chapter 7, Subchapter 3, Section 1299 (see guidance for implementation "General Guideline to Create Defensible Space").

3. California Government Code Section 51182.

4. California Code of Regulations, Title 19, Division 1, Chapter 7, Subchapter 1, Section 3.07.

## **SECTION 4707 4907 DEFENSIBLE SPACE [RESERVED]**

**4907.1 General.** Defensible space will be maintained around all buildings and structures in State Responsibility Area (SRA) as required in Public Resources Code 4290 and "SRA Fire Safe Regulations" California Code of Regulations, Title 14, Division 1.5, Chapter 7, Subchapter 2, Section 1270.

Buildings and structures within the Very High Fire Hazard Severity Zones of a Local Responsibility Areas (LRA) shall maintain defensible space as outlined in Government Code 51175 – 51189 and any local ordinance of the authority having jurisdiction.

## **SECTION 4708 MATERIALS AND CONSTRUCTION METHODS FOR EXTERIOR WILDFIRE EXPOSURE**

### **4708.1 SCOPE, PURPOSE AND APPLICATION**

~~**4708.1.1 Scope.** This Article applies to building materials, systems and or assemblies used in the exterior design and construction of new buildings located within a Wildland–Urban Interface Fire Area as defined in this chapter.~~

~~**4708.1.2 Purpose.** The purpose of this Article is to establish minimum standards for the protection of life and property by increasing the ability of a building located in any Fire Hazard Severity Zone within State Responsibility Areas or any Wildland Urban Interface Fire Area to resist the intrusion of flame or burning embers projected by a vegetation fire and contributes to a systematic reduction in conflagration losses.~~

~~**4708.1.3 Application.** New buildings located in any Fire Hazard Severity Zone within State Responsibility Areas or any Wildland Urban Interface Fire Area designated by the enforcing agency for which an application for a building permit is submitted on or after December 1, 2005, shall comply with the following Sections:~~

- ~~1. 4710.1 Roofing~~
- ~~2. 4710.2 Attic Ventilation~~

~~**4708.2 Alternates for materials, design, tests, and methods of construction.** The enforcing agency is permitted to modify the provisions of this chapter for site-specific conditions in accordance with the California Building Code Section 104.10. When required by the enforcing agency for the purposes of granting modifications, a fire protection plan shall be submitted in accordance with the Chapter 47.~~

## **SECTION 4709 STANDARDS OF QUALITY [RESERVED]**

## **SECTION 4710 MATERIALS, SYSTEMS AND METHODS OF CONSTRUCTION**

### **4710.1 ROOFING**

~~**4710.1.1 General.** Roofs shall comply with the requirements this chapter and the California Building Code, Chapter 15. Roofs shall have a roofing assembly installed in accordance with its listing and the manufacturer's installation instructions.~~

~~**4710.1.2 Roof coverings.** Where the roof profile allows a space between the roof covering and roof decking, the spaces shall be constructed to prevent the intrusion of flames and embers, be fire-stopped with approved materials or have one layer of No. 72 ASTM cap sheet installed over the combustible decking.~~

~~**4710.1.3 Roof valleys.** When provided, valley flashings shall be not less 0.019 inch (0.48 mm) (No. 26 galvanized sheet gage) corrosion-resistant metal installed over a minimum 36 inches (914 mm) wide underlayment consisting of one layer of No. 72 ASTM cap sheet running the full length of the valley.~~

~~4710.1.4 Roof gutters. Roof gutters shall be provided with the means to prevent the accumulation of leaves and debris in the gutter.~~

**4710.2 Attic ventilation.**

~~4710.2.1 General. When required by the California Building Code, Chapter 15, roof and attic vents shall resist the intrusion of flame and embers into the attic area of the structure, or shall be protected by corrosion resistant, non-combustible wire mesh with ¼ inch (6 mm) openings or its equivalent.~~

~~4710.2.2 Eave or cornice vents. Vents shall not be installed in eaves and cornices. Exception: Eave and cornice vents may be used provided they resist the intrusion of flame and burning embers into the attic area of the structure.~~

**4711 EXTERIOR WALLS. [RESERVED]**

**4712 DECKING, FLOORS AND UNDERFLOOR PROTECTION. [RESERVED]**

**4713 ANCILLARY BUILDINGS AND STRUCTURES [RESERVED]**

Authority: Health and Safety Code Sections 13108.5(a), 13143, 18949.2, Government Code Section 51189.

References: Health and Safety Code Sections 13143, Government Code Sections 51176, 51177, 51178, 51179, Public Resources Code Sections 4201 through 4204

---

[50. The SFM proposes to maintain the adoption of Appendix Chapter 4 with the following modifications.]

**APPENDIX CHAPTER 4  
SPECIAL DETAILED REQUIREMENTS BASED ON USE AND OCCUPANCY**

**SECTION 425**

**SPECIAL PROVISIONS FOR LICENSED 24-HOUR CARE FACILITIES IN A GROUP ~~I-4R-2.1~~, R-3.1, R-4 [SFM]**

**425.1 Scope.** The provisions of this section shall apply to 24-hour care facilities in a Group ~~I-4R-2.1~~, R-3.1, or R-4 occupancy licensed by a governmental agency.

**425.2 General.** The provisions in this section shall apply in addition to general requirements in this code.

**425.2.1** Restraint shall not be practiced in a Group ~~I-4R-2.1~~, R-3.1, or R-4 Occupancies.

**Exception:** Occupancies which meet all the requirements for a Group I-3 Occupancy.

**425.3.1** Group ~~I-4R-2.1~~, R-3.1, and R-4 shall be constructed in accordance with Table 503 of the California Building Code.

**425.4.1** Group ~~I-4R-2.1~~ occupancies are not permitted in non-fire-resistance-rated construction, see Health and Safety Code Section 13131.5.

**425.5.1 Smoke barriers required.** Group ~~I-4R-2.1~~ and R-4 occupancies licensed as a Residential Care Facility (RCF) with individual floor areas over 6000 square feet (557 m<sup>2</sup>) per floor, shall be provided with smoke barriers, constructed in accordance with Section ~~709710~~ of the California Building Code.

Group ~~I-4R-2.1~~ occupancies housing bedridden clients shall be provided with smoke barriers constructed in accordance with Section ~~709710~~ of the California Building Code regardless of the number of clients.

When smoke barriers are required, the area within a smoke compartment shall not exceed 22,500 square feet (2090 m<sup>2</sup>) nor shall its travel distance exceed 200 feet (60 960 mm). Such smoke barriers shall divide the floor as equally as possible.

**425.5.2 Smoke partitions.** Group ~~I-4~~R-2.1 occupancies where smoke partitions are required, framing shall be covered with noncombustible materials having an approved thermal barrier with an index of not less than 15 in accordance with FM 4880, UL 1040, NFPA 286 or UL 1715.

**425.5.3 Independent egress.** At least two means of egress shall be provided from each smoke compartment created by smoke barriers. Means of egress may pass through adjacent compartments provided it does not return through the smoke compartment from which means of egress originated.

#### **425.6 Interior finish provisions.**

**425.6.1 Interior wall and ceiling finish.** Group R-3.1 occupancies housing a bedridden client shall comply with Interior Wall and Ceiling Finish requirements specified for Group I-2 occupancies in ~~Table 803.5~~Table 903.3 of the California Building Code.

**425.7.1 Automatic sprinkler systems in Group ~~I-4~~R-2.1, R-3.1 and R-4 occupancies.** An automatic sprinkler system shall be installed where required in Section 903.

**425.7.2 Fire alarm systems in Group ~~I-4~~R-2.1 and R-4 occupancies.** An approved fire alarm system shall be installed where required in Section 907.

**425.7.3 Smoke alarms in Groups ~~I-4~~R-2.1, R-3.1, and R-4 occupancies.** Smoke alarms shall be installed where required in Section 907.2.10

**425.7.4 Hearing impaired.** See Section ~~907.9.1~~907.6.2.3.

**425.8.1 General.** In addition to the general means of egress requirements of Chapter 10, this section shall apply to Group ~~I-4~~R-2.1, R-3.1, and R-4 occupancies.

#### **425.8.2 Number of exits.**

**425.8.2.1** Group ~~I-4~~R-2.1, R-3.1, and R-4 occupancies shall have a minimum of two exits.

**Exception.** Ancillary use areas or occupancies shall have egress as required by Section ~~404~~1021.

**425.8.3.2 Group R-3.1 occupancies housing nonambulatory clients.** In a Group R-3.1 occupancy, bedrooms used by nonambulatory clients shall have access to at least one of the required exits which shall conform to one of the following:

1. Egress through a hallway or area into a bedroom in the immediate area which has an exit directly to the exterior and the corridor/hallway is constructed consistent with the dwelling unit interior walls. The hallway shall be separated from common areas by a solid wood door not less than 1 $\frac{3}{8}$  inch (35 mm) in thickness, maintained self-closing or shall be automatic closing by actuation of a smoke detector installed in accordance with Section ~~715.4.7~~715.4.8 of the California Building Code.
2. Egress through a hallway which has an exit directly to the exterior. The hallway shall be separated from the rest of the house by a wall constructed consistent with the dwelling unit interior walls and opening protected by a solid wood door not less than 1 $\frac{3}{8}$  inch (35 mm) in thickness, maintained self-closing or shall be automatic closing by actuation of a smoke detector installed in accordance with Section ~~715.4.7~~715.4.8 of the California Building Code.
3. Direct exit from the bedroom to the exterior, such doors shall be of a size as to permit the installation of a door not less than 3 feet (914 mm) in width and not less than 6 feet 8 inches (2032 mm) in height. When installed, doors shall be capable of opening at least 90 degrees and shall be so mounted that the clear width of the exit

way is not less than 32 inches (813 mm).

4. Egress through an adjoining bedroom which exits to the exterior.

**425.8.3.3 Group R-3.1 occupancies housing only one bedridden clients.** In Group R-3.1 occupancies housing a bedridden client and not provided with an approved automatic fire sprinkler system, all of the following shall apply:

1. In Group R-3.1 Occupancies housing a bedridden client, a direct exit to the exterior of the residence shall be provided from the client sleeping room.
2. Doors to a bedridden client's sleeping room shall be of a self-closing, positive latching 1- $\frac{3}{8}$  inch solid wood door. Such doors shall be provided with a gasket so installed as to provide a seal where the door meets the jam on both sides and across the top. Doors shall be maintained self-closing or shall be automatic closing by actuation of a smoke alarm in accordance with California Building Code Section ~~715.4.7~~715.4.8.
3. Group R-3.1 Occupancies housing a bedridden client, shall not have a night latch, dead bolt, security chain or any similar locking device installed on any interior door leading from a bedridden client's sleeping room to any interior area such as a corridor, hallway and or general use areas of the residence in accordance with Chapter 10.
4. The exterior exit door to a bedridden client's sleeping room shall be operable from both the interior and exterior of the residence.
5. Every required exit doorway from a bedridden client sleeping room shall be of a size as to permit the installation of a door not less than 3 feet (914 mm) in width and not less than 6 feet 8 inches (2032 mm) in height. When installed in exit doorways, exit doors shall be capable of opening at least 90 degrees and shall be so mounted that the clear width of the exit way is not less than 32 inches (813 mm).

**Note:** A sliding glass door can be used as an exterior exit doorway as long as it is operable from the inside and outside and the clear width of the exit way is not less than 32 inches (813mm).

**425.8.4.1** Unless specified by Section 425.8.4, corridors serving Group ~~I-4R-2.1~~ and Group R-4 occupancies shall comply with Section ~~4047.11018.1~~.

**425.8.4.2** The minimum clear width of a corridor shall be as follows:

1. Group ~~I-4R-2.1~~ occupancies shall have sixty inches (1524 mm) on floors housing nonambulatory clients and forty-four inches (1118 mm) on floors housing only ambulatory clients.
2. Group R-4 occupancies shall have forty-four inches (1118 mm) on floors housing clients.

**Exceptions:**

1. Corridors serving an occupant load of 10 or less shall not be less than 36 inches (914 mm) in width.
2. Corridors serving ambulatory persons only and having an occupant load of 49 or less shall not be less than 36 inches (914 mm) in width.
3. Group ~~R-3-4R-4~~ occupancies shall have thirty-six inches (914 mm) on floors housing clients.

In Group ~~I-4R-2.1~~ occupancies provided with fire sprinklers throughout and which are required to have rated corridors, door closers need not be installed on doors to client sleeping rooms.

**425.8.4.3** In a Group ~~I-4R-2.1~~ and Group ~~R-3-4R-4~~ occupancies having smoke barriers, cross-corridor doors in corridors 6 feet (1829 mm) or less in width shall have, as a minimum, a door 36 inches (914 mm) in width.

**425.8.5 Changes in level.** In Group R-3.1 occupancies housing nonambulatory clients interior changes in level up to 0.25 inch (6 mm) may be vertical and without edge treatment. Changes in level between 0.25 inch (6 mm) and 0.5 inch (12.7 mm) shall be beveled with a slope no greater than 1 unit vertical in 2 units horizontal (50% slope). Changes in level greater than 0.5 inch (12.7 mm) shall be accomplished by means of a ramp.

**425.8.6 Stairways.**

**425.8.6.1** Group ~~I-4R-2.1~~ and Group R-4 occupancies housing more than six non-ambulatory clients above the first

floor shall be provided with two vertical exit enclosures. Stairway enclosures shall be in compliance with Section 40201022. Exceptions to Section 40201022 shall not apply in facilities licensed as a 24-hour care facility.

**425.10 Temporarily bedridden clients.** Clients who become temporarily bedridden as defined in Health and Safety Code Section 1569.72, as enforced by the Department of Social Services, may continue to be housed on any story in Group ~~R-2.1~~, R-3.1, or R-4 occupancies classified as Residential Care Facilities for the Elderly (RCFE). Every Residential Care Facility for the Elderly (RCFE) admitting or retaining a bedridden resident shall, within 48 hours of the resident's admission or retention in the facility, notify the local fire authority with jurisdiction of the estimated length of time the resident will retain his or her bedridden status in the facility.

Authority: Health and Safety Code Sections 1250, 1502, 1568.02, 1569.72, 1569.78, 11159.2, 13131.5, 13133, 13143, 13143.6

References: Health and Safety Code Sections 13143, 18949.2

---

[51. The SFM proposes to not adopt Appendix A.]

#### APPENDIX A BOARD OF APPEALS

Authority: Health and Safety Code Sections 13143

References: Health and Safety Code Section 13143

---

[52. The SFM proposes to adopt Appendix B with amendment.]

#### APPENDIX B FIRE-FLOW REQUIREMENTS FOR BUILDINGS

**B105.2 Buildings other than one- and two-family dwellings.** The minimum fire-flow and flow duration for buildings other than one- and two-family dwellings shall be as specified in Table B105.1.

**Exceptions:**

1. A reduction in required fire-flow of up to 75 percent, as approved, is allowed when the building is provided with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2. The resulting fire-flow shall not be less than 1,500 gallons per minute (5678 L/min) for the prescribed duration as specified in Table B105.1.
2. [SFM] Group B, S-2 and U occupancies having a floor area not exceeding 1,000 square feet, primarily constructed of noncombustible exterior walls with wood or steel roof framing, having a Class A roof assembly, with uses limited to the following or similar uses:

- 2.1. California State Parks buildings of an accessory nature (restrooms).
- 2.2. Safety roadside rest areas, (SRRAs), public restrooms.
- 2.3. Truck inspection facilities, (TIF), CHP office space and vehicle inspection bays.
- 2.4. Sand/salt storage buildings, storage of sand and salt.

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[53. The SFM proposes to maintain the adoption of Appendix BB with modification.]

**APPENDIX BB [SFM]  
FIRE-FLOW REQUIREMENTS FOR BUILDINGS**

**SECTION BB101  
SCOPE**

**BB101.1** *The procedures determining fire-flow requirements for any school buildings or portions of buildings hereafter constructed for which review and approval is required under Subdivision (a) of Section ~~39140-17280~~ of the Education Government Code shall be in accordance with this appendix as amended by the state fire marshal. This appendix does not apply to structures other than buildings.*

Authority cited—Health and Safety Code Section 13143 and California Education Code Article 7.5, Sections 17074.50, 17074.52 and 17074.54.

Reference—Government Code Section 11152.5, Health and Safety Code Section 13143 and California Education Code Chapter 12.5, Leroy F. Greene School Facilities Act of 1998, Article 1.

---

[54. The SFM proposes to adopt Appendix C with amendment.]

**APPENDIX C  
FIRE HYDRANT LOCATIONS AND DISTRIBUTION**

**C101.1 Scope.** Fire hydrants shall be provided in accordance with this appendix for the protection of buildings, or portions of buildings, hereafter constructed.

**Exception:** *[SFM] Group B, S-2 and U occupancies having a floor area not exceeding 1,000 square feet, primarily constructed of noncombustible exterior walls with wood or steel roof framing, having a Class A roof assembly, with uses limited to the following or similar uses:*

- 1. California State Parks buildings of an accessory nature (restrooms).*
- 2. Safety roadside rest areas, (SRRA), public restrooms.*
- 3. Truck inspection facilities, (TIF), CHP office space and vehicle inspection bays.*
- 4. Sand/salt storage buildings, storage of sand and salt.*

Authority: Health and Safety Code Sections 13108, 13143, 13210, 13211, 18949.2

References: Health and Safety Code Sections 13143, 13211, 18949.2

---

[55. The SFM proposes to maintain the adoption of Appendix CC without modification (see item 60 for existing SFM regulations).]

**APPENDIX CC [SFM]  
FIRE HYDRANT LOCATIONS AND DISTRIBUTION**

Authority cited—Health and Safety Code Section 13143 and California Education Code Article 7.5, Sections 17074.50, 17074.52 and 17074.54.  
Reference—Government Code Section 11152.5, Health and Safety Code Section 13143 and California Education Code Chapter 12.5, Leroy F. Greene School Facilities Act of 1998, Article 1.

---

[56. The SFM proposes to not adopt Appendices D through G.]

**APPENDIX D  
FIRE APPARATUS ACCESS ROADS**

**APPENDIX E  
HAZARD CATEGORIES**

**APPENDIX F  
HAZARD RANKING**

**APPENDIX G  
CRYOGENIC FLUIDS—WEIGHT AND VOLUME EQUIVALENTS**

Authority: Health and Safety Code Sections 13143  
References: Health and Safety Code Section 13143

---

[57. The SFM proposes to not adopt Appendix H.]

**APPENDIX H  
~~HAZARDOUS MATERIALS MANAGEMENT PLAN (HMMP) AND  
HAZARDOUS MATERIALS INVENTORY STATEMENT (HMIS)  
INSTRUCTIONS~~**

**(Note: This appendix chapter will not be printed in the California Fire Code.)**

Authority: Health and Safety Code Sections 13143, 25500 through 25545  
References: Health and Safety Code Sections 13143, 25500 through 25545, Chapter 6.95 and Title 19, Division 2, Chapter 4

---

[58. The SFM proposes to maintain the adoption of the California Appendix H without modification (see item 60 for existing SFM regulations).]

**APPENDIX H  
HAZARDOUS MATERIALS MANAGEMENT PLANS AND  
HAZARDOUS MATERIALS INVENTORY STATEMENTS**

(See Sections 2701.5.1 and 2701.5.2)

Authority: Health and Safety Code Sections 13143, 25500 through 25545  
References: Health and Safety Code Sections 13143, 25500 through 25545, Chapter 6.95 and Title 19, Division 2, Chapter 4

---

[59. The SFM proposes to not adopt Appendix I or J.]

**APPENDIX I  
FIRE PROTECTION SYSTEMS—UNSAFE CONDITIONS**

**APPENDIX J  
EMERGENCY RESPONDER RADIO COVERAGE**

Authority: Health and Safety Code Sections 13143  
References: Health and Safety Code Section 13143

---

[60. The SFM proposes to bring forward previously existing California building standards or amendments, which represent no change in their effect from the 2007 California Building Standards Code. Furthermore, the SFM proposes to codify non-substantive editorial and formatting amendments from the format based upon the 2006 International Fire Code to the format of the 2009 International Fire Code.]

**CHAPTER 2  
DEFINITIONS**

**201.3 Terms defined in other codes.** Where terms are not defined in this Code and are defined in the *International California Building Code*, *International Fuel Gas Code*, *International California Mechanical Code* or *International California Plumbing Code*, such terms shall have the meanings ascribed to them as in those codes.

**AGED HOME OR INSTITUTION**, is a facility used for the housing of persons 65 years of age or older in need of care and supervision. (See definition of "care and supervision")

**ASSEMBLY.** The gathering together of 50 or more persons for such purposes as deliberation, education, instruction, worship, entertainment, amusement, drinking, dining or awaiting transportation.

**ASSEMBLY BUILDING** is a building or portion of a building used for the gathering together of 50 or more persons for such purposes as deliberation, education, instruction, worship, entertainment, amusement, drinking or dining, or awaiting transportation. Any building or structure or portion thereof used or intended to be used for the showing of motion pictures when an admission fee is charged and when such building or structure is open to the public and has a capacity of 10 or more persons.

**BEDRIDDEN PERSON** means a person, requiring assistance in turning and repositioning in bed, or being unable to independently transfer to and from bed, except in facilities with appropriate and sufficient care staff, mechanical devices if necessary, and safety precautions as determined in Title 22 regulations, by the Director of Social Services

or his or her designated representative.

*The Director of Social Services or his or her designated representative shall make the determination of the bedridden status of persons with developmental disabilities, in consultation with the Director of Developmental Services or his or her designated representative.*

*The Director of Social Services or his or her designated representative shall make the determination of the bedridden status of all other persons with disabilities who are not developmentally disabled.*

**BUILDING.** is any structure used or intended for supporting or sheltering any use or occupancy.

**Note:** *Building shall have the same meaning as defined in Health and Safety Code Section 17920 and 18908 for the applications specified in Section ~~441.11~~.*

**CARE AND SUPERVISION** means any one or more of the following activities provided by a person or facility to meet the needs of the clients:

*Assistance in dressing, grooming, bathing and other personal hygiene.*

*Assistance with taking medication.*

*Central storing and/or distribution of medications.*

*Arrangement of and assistance with medical and dental care.*

*Maintenance of house rules for the protection of clients.*

*Supervision of client schedules and activities.*

*Maintenance and/or supervision of client cash resources or property.*

*Monitoring food intake or special diets.*

*Providing basic services required by applicable law and regulation to be provided by the licensee in order to obtain and maintain a community-care facility license.*

**CATASTROPHICALLY INJURED**, as termed, means a person whose origin of disability was acquired through trauma or nondegenerative neurologic illness, for whom it has been determined by the Department of Health Services Certification and Licensing that active rehabilitation would be beneficial.

**CELL** is a housing unit in a detention or correctional facility for the confinement of not more than two inmates or prisoners.

**CELL COMPLEX** is a cluster or group of cells or dormitories in a jail, prison or other detention facility, together with rooms used for accessory purposes, all of which open into the cell complex, and are used for functions such as dining, counseling, exercise, classrooms, sick call, visiting, storage, staff offices, control rooms or similar functions, and interconnecting corridors all within the cell complex.

**CELL TIERS** are cells, dormitories and accessory spaces. Cell tiers are located one level above the other, and do not exceed two levels per floor. A cell tier shall not be considered a story or mezzanine.

**CHILD-CARE CENTER**, is any facility of any capacity other than a large or small family day-care home as defined in these regulations in which less than 24-hour-per-day nonmedical supervision is provided for children in a group setting.

**CHILD OR CHILDREN**, is a person or persons under the age of 18 years.

**CHRONICALLY ILL.** See "Terminally ill."

**CONGREGATE LIVING HEALTH FACILITY (CLHF)**, as termed, is a residential home with a capacity of no more than six beds, which provides inpatient care, including the following basic services: medical supervision, 24-hour skilled nursing and supportive care, pharmacy, dietary, social recreational, and at least provides services for persons who are diagnosed with a terminal illness or who are catastrophically and severely disabled.

**CONGREGATE RESIDENCE**, is any building or portion thereof that contains facilities for living, sleeping and sanitation, as required by this code, and may include facilities for eating and cooking, for occupancy by other than a family. A congregate residence may be a shelter, convent, monastery, dormitory, fraternity or sorority house, but does not include jails, hospitals, nursing homes, hotels or lodging houses.

**DAY-CARE** shall, for the purposes of these regulations, mean the care of persons during any period of a 24-hour day where permanent sleeping accommodations are not provided.

**Note:** "Day-care" shall not be construed to preclude the use of cots or mats for napping purposes, provided all employees, attendants and staff personnel are awake and on duty in the area where napping occurs.

**DAY-CARE HOME, LARGE FAMILY.** A providers own home licensed to provide day care for periods less than 24-hours per day for nine to 14 persons, including children under the age of 10 years who reside at the home.

**DAY-CARE HOME, SMALL FAMILY.** A home which provides family day-care to eight or fewer children, including children under the age of 10 years who reside at the home, in the provider's own home, for periods of less than 24 hours per day. Small family day-care homes are exempted from state fire and life safety regulations other than those state and local standards applicable to Group ~~R, division 3~~ R-3 occupancies. (See Health and Safety Code, Section 13143 (b).)

**DAY ROOM** is a room which is adjacent to a cell, or cell tier, or dormitory and which is used as a dining, exercise or other activity room for inmates.

**ENFORCING AGENCY.** Enforcing Agency is the designated department or agency as specified by statute or regulation.

**FIRE APPLIANCE** See Section 902.1.

**FIXED GUIDEWAY TRANSIT SYSTEMS.** (See California Building Code, Section 443.)

**FULL-TIME CARE** shall mean the establishment and routine care of persons on an hourly, daily, weekly, monthly, yearly or permanent basis, whether for 24-hours per day or less, and where sleeping accommodations are provided.

**HIGH-RISE BUILDING.** As used in this Code:

1. "Existing high-rise structure" means a high-rise structure, the construction of which is commenced or completed prior to July 1, 1974.
2. "High-rise structure" means every building of any type of construction or occupancy having floors used for human occupancy located more than 75 feet above the lowest floor level having building access (see California Building Code, Section 403.1.2), except buildings used as hospitals as defined in Health and Safety Code Section 1250.
3. "New high-rise structure" means a high-rise structure, the construction of which is commenced on or after July 1, 1974,

**HOLDING FACILITY** means a detention or correctional facility or area where inmates, staff and public are not housed but are restrained.

**HOUSING UNIT** is an area intended to lodge inmates on a 24-hour basis where accommodations are provided for sleeping.

**LABORATORY. [SFM]** A room, building or area where the use and storage of hazardous materials are utilized for testing, analysis, instruction, research or developmental activities.

**LISTED.** Equipment, materials, products or services included in a list published by an organization acceptable to the fire code official and concerned with evaluation of products or services that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services and whose listing states either that the

equipment, material, product or service meets identified standards or has been tested and found suitable for a specified purpose.

*For applications listed in Section 4441.11 regulated by the Office of the State Fire Marshal, "listed" shall also mean equipment or materials accepted by the state fire marshal as conforming to the provisions of the State Fire Marshal's regulations and which are included in a list published by the State Fire Marshal.*

**LABORATORY SUITE. [SFM]** See Section 443.2

**LODGING HOUSE** is any building or portion thereof containing not more than five guest rooms where rent is paid in money, goods, labor or otherwise.

**MENTALLY RETARDED PERSONS, PROFOUNDLY OR SEVERELY** shall mean any retarded person who is unable to evacuate a building unassisted during emergency conditions.

**Note:** The determination as to such incapacity shall be made by the Director of the State Department of Public Health or his or her designated representative pursuant to Health and Safety Code Section §13131.3.

**MODERNIZATION PROJECT** is any construction effort that has an estimated total cost in excess of \$200,000.00 that is intended to modify a permanent school building or structure and or the addition of a new school building or structure used to serve or house students from kindergarten through twelfth grade (K-12). Modernization efforts shall apply strictly to a public school that was established prior to July 1, 2002 and is funded pursuant to the Education Code, section 17074.56 and Education Code commencing with section 17070.10. Modernization projects that are to be completed in more than one phase, may defer the installation of the automatic fire detection and alarm systems until the final phase of the modernization project. Solely for the purposes of Education Code section 17074.20, routine maintenance and repair work shall not be considered a modernization project.

**NEW PUBLIC SCHOOL CAMPUS.** New public school campus is an educational institution established on or after July 1, 2002 that houses and or serves students from kindergarten through twelfth grade (K-12) and is funded pursuant to the Education Code, commencing with section 17070.10.

**NON-ACCESSIBLE AREA** is an enclosed area that creates a cavity by the application of any construction feature and or building materials. This area shall be recognized by the enforcing agency as a separation between the non-accessible space and any adjacent, occupied space of the building.

**NONAMBULATORY PERSONS,** are persons unable to leave a building unassisted under emergency conditions. It includes, but is not limited to, persons who depend on mechanical aids such as crutches, walkers and wheelchairs and any person who is unable to physically and mentally respond to a sensory signal approved by the state fire marshal or an oral instruction relating to fire danger.

The determination of ambulatory or non-ambulatory status of persons with developmental disabilities shall be made by the Director of Social Services or his or her designated representative, in consultation with the director of Developmental Services or his or her designated representative. The determination of ambulatory or nonambulatory status of all other disabled persons placed after January 1, 1984, who are not developmentally disabled shall be made by the Director of Social Services or his or her designated representative.

**NONCOMBUSTIBLE. [SFM]** Noncombustible as applied to building construction material means a material which, in the form in which it is used, is either one of the following:

1. Material of which no part will ignite and burn when subjected to fire. Any material passing ASTM E 136 shall be considered noncombustible.
2. Material having a structural base of noncombustible material as defined in Item 1 above, with a surfacing material not over  $\frac{1}{8}$  inch (3.2 mm) thick which has a flame-spread index of 50 or less.

"Noncombustible" does not apply to surface finish materials. Material required to be noncombustible for reduced clearances to flues, heating appliances or other sources of high temperature shall refer to material conforming to Item

1. No material shall be classed as noncombustible which is subject to increase in combustibility or flame-spread index, beyond the limits herein established, through the effects of age, moisture or other atmospheric condition

**PERMANENT PORTABLE BUILDING.** A portable building that is used to serve or house students and is certified as a permanent building on a new public school campus by the public school administration shall comply with the requirements of new campus buildings.

~~**[B] PERSONAL CARE SERVICE.** The care of residents who do not require chronic or convalescent medical or nursing care. Personal care involves responsibility for the safety of the resident while inside the building.~~

**RESIDENTIAL CARE FACILITY FOR THE CHRONICALLY ILL (RCF/CI),** as termed, means a housing arrangement with a maximum capacity of 25 residents that provides a range of services to residents who have chronic, life-threatening illnesses.

**RESIDENTIAL CARE FACILITY FOR THE ELDERLY (RCFE),** as defined in Health and Safety Code Section §1569.2, shall mean a facility with a housing arrangement chosen voluntarily by persons 60 years of age or over, or their authorized representative, where varying levels and intensities of care and supervision, protective supervision or personal care are provided, based on their varying needs, as determined in order to be admitted and to remain in the facility. Persons under 60 years of age with compatible needs, as determined by the Department of Social Services in regulations, may be allowed to be admitted or retained in a residential-care facility for the elderly.

Pursuant to Health and Safety Code Section §13133, regulations of the state fire marshal pertaining to Group R, Division 2 Occupancies classified as Residential Facilities (RF) and Residential-care Facilities for the Elderly (RCFE) shall apply uniformly throughout the state and no city, county, city and county, including a charter city or charter county, or fire protection district shall adopt or enforce any ordinance or local rule or regulation relating to fire and panic safety which is inconsistent with these regulations. A city, county, city and county, including a charter city or charter county may pursuant to Health and Safety Code Section §13143.5, or a fire protection district may pursuant to Health and Safety Code Section §13869.7, adopt standards more stringent than those adopted by the state fire marshal that are reasonably necessary to accommodate local climate, geological, or topographical conditions relating to roof coverings for Residential-care Facilities for the Elderly.

**RESIDENTIAL FACILITY (RF),** as defined in Section §1502 of the Health and Safety Code, shall mean any family home, group care facility, or similar facility determined by the director of Social Services, for 24-hour non-medical care of persons in need of personal services, supervision, or assistance essential for sustaining the activities of daily living or for the protection of the individual. Such facilities include small family homes and social rehabilitation facilities.

Pursuant to Health and Safety Code Section §13133, regulations of the state fire marshal pertaining to Group R, Division 2 Occupancies classified as Residential Facilities (RF) and Residential-care Facilities for the Elderly (RCFE) shall apply uniformly throughout the state and no city, county, city and county, including a charter city or charter county, or fire protection district shall adopt or enforce any ordinance or local rule or regulation relating to fire and panic safety which is inconsistent with these regulations. A city, county, city and county, including a charter city or charter county may pursuant to Health and Safety Code Section §13143.5, or a fire protection district may pursuant to Health and Safety Code Section §13869.7, adopt standards more stringent than those adopted by the state fire marshal that are reasonably necessary to accommodate local climate, geological, or topographical conditions relating to roof coverings for Residential-care Facilities for the Elderly.

**RESTRAINT.** Restraint shall mean the physical retention of a person within a room, cell or cell block by any means, or within the exterior walls of a building by means of locked doors inoperable by the person restrained. Restraint shall also mean the physical binding, strapping or similar restriction of any person in a chair, walker, bed or other contrivance for the purpose of deliberately restricting the free movement of ambulatory persons.

Restraint shall not be construed to include non-ambulatory persons nor shall it include the use of bandage material, strip sheeting or other fabrics or materials (soft ties) used to restrain persons in hospital-type beds or wheelchairs to prevent injury, provided an approved method of quick release is maintained. Facilities employing the use of soft ties, however, shall be classified as a building used to house non-ambulatory persons.

*Restraint shall not be practiced in licensed facilities classified as Group I-1, R-3 and R-4 occupancies unless constructed as a Group I-3 occupancy. For Group I-3 Occupancies see California Building Code Section ~~308-2308.4~~.*

**STATE-OWNED/LEASED BUILDING** is a building or portion of a building that is owned, leased or rented by the state. State-leased buildings shall include all required exits to a public way serving such leased area or space. Portions of state- leased buildings that are not leased or rented by the state shall not be included within the scope of this section unless such portions present an exposure hazard to the state-leased area or space.

**TERMINALLY ILL**, as termed for an individual, means the individual has a life expectancy of six months or less as stated in writing by his or her attending physician and surgeon.

**WINERY CAVES.** A subterranean space for winery facilities in natural or manmade caves shall be in accordance with this California Building Code, Section 436.

## CHAPTER 5 FIRE SERVICE FEATURES

**503.5.2 Fences and Gates.** School grounds may be fenced and gates therein may be equipped with locks, provided that safe dispersal areas based on 3 square feet (0.28 m<sup>2</sup>) per occupant are located between the school and the fence. Such required safe dispersal areas shall not be located less than 50 feet (15240 mm) from school buildings.

*Every public and private school shall conform with Section 32020 of the Education Code which states:*

*The governing board of every public school district, and the governing authority of every private school, which maintains any building used for the instruction or housing of school pupils on land entirely enclosed (except for building walls) by fences or walls, shall, through cooperation with the local law enforcement and fire-protection agencies having jurisdiction of the area, make provision for the erection of gates in such fences or walls. The gates shall be of sufficient size to permit the entrance of the ambulances, police equipment and fire-fighting apparatus used by the law enforcement and fire-protection agencies. There shall be no less than one such access gate and there shall be as many such gates as needed to assure access to all major buildings and ground areas. If such gates are to be equipped with locks, the locking devices shall be designed to permit ready entrance by the use of the chain or bolt-cutting devices with which the local law enforcement and fire-protection agencies may be equipped.*

**507.3 Fire flow.** Fire flow requirements for buildings or portions of buildings and facilities shall be determined by an approved method or Appendix B.

**507.5.3 Private fire service mains and water tanks.** Private fire service mains and water tanks shall be periodically inspected, tested and maintained in accordance with ~~NFPA 25 Title 19~~ California Code of Regulations, Title 19, Division 1, Chapter 5, at the following intervals:

- ~~1. Private fire hydrants (all types): Inspection annually and after each operation; flow test and maintenance annually.~~
- ~~2. Fire service main piping: Inspection of exposed, annually; flow test every 5 years.~~
- ~~3. Fire service main piping strainers: Inspection and maintenance after each use.~~

**508.1 General.** Where required by other sections of this code and in all buildings classified as high-rise buildings by the ~~International~~ California Building Code and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access, a fire command center for fire department operations shall be provided and shall comply with Sections 508.1.1 through 508.1.5.

**508.1.2 Separation.** The fire command center shall be separated from the remainder of the building by not less than a 1-hour fire barrier constructed in accordance with Section 707 of the ~~International~~ California Building Code or horizontal assembly constructed in accordance with Section 712 of the ~~International~~ California Building Code, or both.

**508.1.5 Required features.** The fire command center shall comply with NFPA 72 and shall contain the following features:

1. The emergency voice/alarm communication system control unit.
2. The fire department communications system.
3. Fire detection and alarm system annunciator.
4. Annunciator unit visually indicating the location of the elevators and whether they are operational.
5. Status indicators and controls for air distribution systems.
6. The fire-fighter's control panel required by Section 909.16 for smoke control systems installed in the building.
7. Controls for unlocking stairway doors simultaneously.
8. Sprinkler valve and water-flow detector display panels.
9. Emergency and standby power status indicators.
10. A telephone for fire department use with controlled access to the public telephone system.
11. Fire pump status indicators.
12. Schematic building plans indicating the typical floor plan and detailing the building core, means of egress, fire protection systems, fire-fighting equipment and fire department access and the location of fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions.
13. Work table.
14. Generator supervision devices, manual start and transfer features.
15. Public address system, where specifically required by other sections of this code.
16. Elevator fire recall switch in accordance with ASME A17.1.
17. Elevator emergency or standby power selector switch(es), where emergency or standby power is provided.

~~16—Fire Command Centers shall not be used for the housing of any boiler, heating unit, generator, combustible storage, or similar hazardous equipment or storage.~~

## CHAPTER 6 BUILDING SERVICES AND SYSTEMS

**603.1 Installation.** The installation of nonportable fuel gas appliances and systems shall comply with the ~~International Fuel Gas Code~~ *California Mechanical Code*. The installation of all other fuel-fired appliances, other than internal combustion engines, oil lamps and portable devices such as blow torches, melting pots and weed burners, shall comply with this section and the ~~International~~ *California Mechanical Code*.

**603.1.2 Approval.** The design, construction and installation of fuel-fired appliances shall be in accordance with the ~~International Fuel Gas Code~~ and the ~~International~~ *California Mechanical Code*.

**603.2 Chimneys.** Masonry chimneys shall be constructed in accordance with the ~~International~~ *California Building Code*. Factory-built chimneys shall be installed in accordance with the ~~International~~ *California Mechanical Code*. Metal chimneys shall be constructed and installed in accordance with NFPA 211.

**603.3 Fuel oil storage systems.** Fuel oil storage systems shall be installed in accordance with this code. Fuel oil piping systems shall be installed in accordance with the ~~International~~ *California Mechanical Code*.

**603.3.2.4 Installation.** Tanks and piping systems shall be installed and separated from other uses in accordance with Section 915 and Chapter 13 both of the ~~International~~ *California Mechanical Code*, as applicable.

**Exception:** Protected above-ground tanks complying with Section 3404.2.9.6 shall not be required to be separated from surrounding areas.

**603.5.2 Heating appliance installation and maintenance.** Heating appliances shall be installed and maintained in accordance with the manufacturer's instructions, the ~~International~~ *California Building Code*, the ~~International~~ *California Mechanical Code*, the ~~International Fuel Gas Code~~ and the ~~NEPA 70~~ *California Electrical Code*.

**603.6.1 Masonry chimneys.** Masonry chimneys that, upon inspection, are found to be without a flue liner and that have open mortar joints which will permit smoke or gases to bed as to be dangerous, shall be repaired or relined with a listed chimneys discharged into the building, or which are crackey liner system installed in accordance with the manufacturer's installation instructions or a flue lining system installed in accordance with the requirements of the ~~International~~ *California Building Code* and appropriate for the intended class of chimney service.

**603.8 Incinerators.** Commercial, industrial and residential-type incinerators and chimneys shall be constructed in accordance with the ~~International~~ *California Building Code*, the ~~International Fuel Gas Code~~ and the ~~International California Mechanical Code~~.

**604.1 Installation.** Emergency and standby power systems required by this code or the ~~International~~*California Building Code* shall be installed in accordance with this code, NFPA 110 and NFPA 111. Existing installations shall be maintained in accordance with the original approval.

**604.2.9 Membrane structures.** Emergency power shall be provided for exit signs in temporary tents and membrane structures in accordance with Section 2403.12.6.1. Standby power shall be provided for auxiliary inflation systems in permanent membrane structures in accordance with the ~~International~~ *California Building Code*.

**604.2.14 High-rise buildings and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access.** Standby power, light and emergency systems in high-rise buildings and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access shall comply with the requirements of Sections 604.2.14.1 through 604.2.14.3.

**604.2.14.1 Standby power.** A standby power system shall be provided. Where the standby system is a generator set inside a building, the system shall be located in a separate room enclosed with 2-hour fire barriers constructed in accordance with Section 707 of the ~~International~~*California Building Code* or horizontal assemblies constructed in accordance with Section 712 of the ~~International~~*California Building Code*, or both. System supervision with manual start and transfer features shall be provided at the fire command center.

**604.2.14.1.1 Fuel supply.** An on-premises fuel supply, sufficient for not less than ~~2-hour~~ 6-hour full-demand operation of the system, shall be provided. *Fire pumps shall be provided with an on-premises fuel supply, sufficient for not less than 8-hour full-demand operation of the rated pump capacity in addition to all other required supply demands in accordance with Section 913, NFPA 20 and this Section.*

**Exception:** When approved, the system shall be allowed to be supplied by natural gas pipelines.

**604.2.14.1.3 Connected facilities.** Power and lighting facilities for the *fire command center* and elevators specified in Sections 403.9 and 403.10 of the ~~International~~ *California Building Code*, as applicable, shall be transferable to the standby source. Standby power shall be provided for at least one elevator to serve all floors and be transferable to any elevator.

**604.2.15 Underground buildings.** Emergency and standby power systems in underground buildings covered in Chapter 4 of the ~~International~~ *California Building Code* shall comply with Sections 604.2.15.1 and 604.2.15.2.

**604.2.15.1 Standby power.** A standby power system complying with this section and ~~NFPA 70~~ *the California Electrical Code* shall be provided for standby power loads as specified in Section 604.2.15.1.1.

**604.2.15.1.1 Standby power loads.** The following loads are classified as standby power loads:

1. Smoke control system.
2. Ventilation and automatic fire detection equipment for smokeproof enclosures.
3. Fire pumps.
4. Standby power shall be provided for elevators in accordance with Section 3003 of the ~~International~~*California Building Code*.

**604.2.15.2 Emergency power.** An emergency power system complying with this code and ~~NFPA 70~~ *the California Electrical Code* shall be provided for emergency power loads as specified in Section 604.2.15.2.1.

**604.2.16 Group I-3 occupancies.** Power-operated sliding doors or power-operated locks for swinging doors in Group I-3 occupancies shall be operable by a manual release mechanism at the door, and either emergency power or a remote mechanical operating release shall be provided.

**Exception:** Emergency power is not required in facilities where provisions for remote locking and unlocking of occupied rooms in Occupancy Condition 4 are not required as set forth in the ~~International~~ *California Building Code*.

**605.3 Working space and clearance.** A working space of not less than 30 inches (762 mm) in width, 36 inches (914 mm) in depth and 78 inches (1981 mm) in height shall be provided in front of electrical service equipment. Where the electrical service equipment is wider than 30 inches (762 mm), the working space shall not be less than the width of the equipment. No storage of any materials shall be located within the designated working space.

**Exceptions:**

1. Where other dimensions are required or allowed by the ~~NFPA 70~~ *California Electrical Code*.
2. Access openings into attics or under-floor areas which provide a minimum clear opening of 22 inches (559 mm) by 30 inches (762 mm).

**605.4 Multiplug adapters.** Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with the ~~NFPA 70~~ *California Electrical Code* shall be prohibited.

**605.9 Temporary wiring.** Temporary wiring for electrical power and lighting installations is allowed for a period not to exceed 90 days. Temporary wiring methods shall meet the applicable provisions of the ~~NFPA 70~~ *California Electrical Code*.

**Exception:** Temporary wiring for electrical power and lighting installations is allowed during periods of construction, remodeling, repair or demolition of buildings, structures, equipment or similar activities.

**[M] 606.1 Scope.** Refrigeration systems shall be installed in accordance with the ~~International~~ *California Mechanical Code*.

**[M] 606.2 Refrigerants.** The use and purity of new, recovered, and reclaimed refrigerants shall be in accordance with the ~~International~~ *California Mechanical Code*.

**[M] 606.3 Refrigerant classification.** Refrigerants shall be classified in accordance with the ~~International~~ *California Mechanical Code*.

**[M] 606.4 Change in refrigerant type.** A change in the type of refrigerant in a refrigeration system shall be in accordance with the ~~International~~ *California Mechanical Code*.

**606.7 Emergency signs.** Refrigeration units or systems having a refrigerant circuit containing more than 220 pounds (100 kg) of Group A1 or 30 pounds (14 kg) of any other group refrigerant shall be provided with approved emergency signs, charts, and labels in accordance with NFPA704. Hazard signs shall be in accordance with the ~~International~~ *California Mechanical Code* for the classification of refrigerants listed therein.

**606.8 Refrigerant detector.** Machinery rooms shall contain a refrigerant detector with an audible and visual alarm. The detector, or a sampling tube that draws air to the detector, shall be located in an area where refrigerant from a leak will concentrate. The alarm shall be actuated at a value not greater than the corresponding TLV-TWA values shown in the ~~International~~ *California Mechanical Code* for the refrigerant classification. Detectors and alarms shall be placed in approved locations. The detector shall transmit a signal to an approved location.

**606.16 Electrical equipment.** Where refrigerants of Groups A2, A3, B2 and B3, as defined in the ~~International~~ *California Mechanical Code*, are used, refrigeration machinery rooms shall conform to the Class I, Division 2 hazardous location classification requirements of the ~~NFPA 70~~ *California Electrical Code*.

**Exception:** Ammonia machinery rooms that are provided with ventilation in accordance with ~~Section 1106.3~~ of the ~~International~~ *California Mechanical Code*.

~~607.4~~ **607.5 Shunt trip.** *Where elevator hoistways or elevator machine rooms containing elevator control equipment*

are protected with automatic sprinklers, a means installed in accordance with NFPA 72, Section 6.16.4, Elevator Shutdown, shall be provided to disconnect automatically the main line power supply to the affected elevator prior to the application of water. This means shall not be self-resetting. The activation of sprinklers outside the hoistway or machine room shall not disconnect the main line power supply.

~~607.4.1-607.5.1~~ Elevator power shunt-trip shall not activate prior to the completion of elevator Phase I emergency recall operation to the recall floor.

~~607.4.2-607.5.2~~ Elevator power shunt-trip capability shall be disabled during Phase II emergency in-car operation.

~~607.4.3-607.5.3~~ Audible and visual annunciation shall be provided at the fire alarm control unit indicating the disabling of elevator power shunt-trip capability under Phase II operation.

~~607.4.4-607.5.4~~ Audible and visual annunciation shall be provided at the fire alarm control unit indicating that the automatic sprinklers, smoke detectors, or heat detectors in the elevator hoistway or elevator machine room have activated.

~~607.4.5-607.5.5~~ Visual annunciation shall be provided inside all elevator cars indicating that the automatic sprinklers, smoke detectors, or heat detectors in the elevator hoistway or elevator machine room have activated.

**608.4 Room design and construction.** Enclosure of stationary battery systems shall comply with the ~~International~~ California Building Code. Battery systems shall be allowed to be in the same room with the equipment they support.

**608.6.1 Room ventilation.** Ventilation shall be provided in accordance with the ~~International~~ California Mechanical Code and the following:

1. For flooded lead acid, flooded nickel-cadmium, and VRLA batteries, the ventilation system shall be designed to limit the maximum concentration of hydrogen to 1 percent of the total volume of the room; or
2. Continuous ventilation shall be provided at a rate of not less than 1 cubic foot per minute per square foot [1ft<sup>3</sup>/min/ft<sup>2</sup> or 0.0051 m<sup>3</sup>/(s □ m<sup>2</sup>)] of floor area of the room.

**Exception:** Lithium-ion batteries shall not require ventilation.

**608.8 Seismic protection.** The battery systems shall be seismically braced in accordance with the ~~International~~ California Building Code.

**[M] 609.1 General.** Commercial kitchen exhaust hoods shall comply with the requirements of the ~~International~~ California Mechanical Code.

## CHAPTER 8 INTERIOR FINISHES

**803.1 General.** The provisions of this section shall limit the allowable flame spread and smoke development of interior wall and ceiling finishes and interior wall and ceiling trim in existing buildings based on location and occupancy classification. Interior wall and ceiling finishes shall be classified in accordance with Section 803 of the ~~International~~ California Building Code. Such materials shall be grouped in accordance with ASTM E 84, as indicated in Section 803.1.1, or in accordance with NFPA 286, as indicated in Section 803.1.2.

### Exceptions:

1. Materials having a thickness less than 0.036 inch (0.9mm) applied directly to the surface of walls and ceilings.
2. Exposed portions of structural members complying with the requirements of buildings of Type IV construction in accordance with the ~~International~~ California Building Code shall not be subject to interior finish requirements.

**803.7.2 Thermal barrier.** Foam plastic material shall be allowed if it is separated from the interior of the building by a

thermal barrier in accordance with Section 2603.4 of the ~~International~~ California Building Code.

**804.1 Interior trim.** Material, other than foam plastic used as interior trim, shall have a minimum *Class B flame spread and 450 smoke-developed index in Group I-3 and for all other occupancies Class C flame spread and smoke-developed index* when tested in accordance with ASTM E 84 or UL 723, as described in Section 803.1.1. Combustible trim, excluding handrails and guardrails, shall not exceed 10 percent of the specific wall or ceiling area in which it is attached.

**807.4.2.4 Motion Picture and Television Production Studio Sound Stages, Approved Production Facilities and Production Locations with live audiences.**

**807.4.2.4.1 Foam plastics, decorations, textile and film materials.** *Foam plastics, textile and film materials and other decorative materials and materials containing foam plastics shall be in accordance with the following:*

1. *Exhibit booth construction shall have a maximum heat-release rate of 100 kilowatts when tested in accordance with U.L. 1975.*
2. *Decorative objects, including but not limited to mannequins, murals and signs, shall have a maximum heat-release rate of 150 kilowatts when tested in accordance with U.L. 1975.*

**Exception:** *When the aggregate area of murals, signs or similar decorative objects occupies less than 10 percent of the floor or wall area, this requirement may be waived by the chief.*

3. *Theater, motion picture and television stage settings with or without horizontal projections and simulated caves or caverns shall have a maximum heat-release rate of 100 kilowatts when tested in accordance with U.L. 1975.*

**807.4.5 Group F-1 motion picture and television production studio sound stages, approved production facilities and production locations without live audiences.**

**807.4.5.1 Foam plastics, decorations, textile and film materials.** *Foam plastics, textile and film materials and other decorative materials and materials containing foam plastics shall be in accordance with the following:*

1. *Exhibit booth construction shall have a maximum heat-release rate of 100 kilowatts when tested in accordance with U.L. 1975.*
2. *Decorative objects, including but not limited to mannequins, murals and signs, shall have a maximum heat-release rate of 150 kilowatts when tested in accordance with U.L. 1975.*

**Exception:** *When the aggregate area of murals, signs or similar decorative objects occupies less than 10 percent of the floor or wall area, this requirement may be waived by the chief.*

3. *Theater, motion picture and television stage settings with or without horizontal projections and simulated caves or caverns shall have a maximum heat-release rate of 100 kilowatts when tested in accordance with U.L. 1975.*

## CHAPTER 9 FIRE PROTECTION SYSTEMS

**901.4.1 Required fire protection systems.** Fire protection systems required by this code or the ~~International~~ California Building Code shall be installed, repaired, operated, tested and maintained in accordance with this code.

**901.4.2 Nonrequired fire protection systems.** Any fire protection system or portion thereof not required by this code or the ~~International~~ California Building Code shall be allowed to be furnished for partial or complete protection provided such installed system meets the requirements of this code and the ~~International~~ California Building Code.

### Section 902.1 Definitions.

**FIRE APPLIANCE [SFM]** is apparatus or equipment provided or installed for use in the event of an emergency.

**903.2.1.2 Group A-2.** An automatic sprinkler system shall be provided for Group A-2 occupancies where one of the following conditions exists:

1. The fire area exceeds 5,000 square feet (464.5m<sup>2</sup>).
2. The fire area has an occupant load of 100 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.
4. *The structure exceeds 5,000 square feet (465 m<sup>2</sup>), contains more than one fire area containing a Group A-2 occupancy, and is separated into two or more buildings by fire walls of less than four hour fire resistance rating without openings.*

**903.2.1.3 Group A-3.** An automatic sprinkler system shall be provided for Group A-3 occupancies where one of the following conditions exists:

1. The fire area exceeds 12,000 square feet (1115 m<sup>2</sup>).
2. The fire area has an occupant load of 300 or more.
3. The fire area is located on a floor other than a level of exit discharge serving such occupancies.
4. *The structure exceeds 12,000 square feet (1155 m<sup>2</sup>), contains more than one fire area containing exhibition and display rooms, and is separated into two or more buildings by fire walls of less than four hour fire resistance rating without openings.*

~~903.2.2.1.2~~ **903.2.3.1.2 Permanent Portable Buildings.** *A portable building that is used to serve or house students and is certified, as a permanent building on a new public school campus by the public school administration shall comply with the requirements of section ~~903.2.2.1.4~~903.2.3.1.1.*

~~903.2.2.1.3~~ **903.2.3.1.3 Fire-Resistive Substitution for New Campus.** *A new public school campus as defined in Section 202 shall be entitled to include in the design and construction documents all of the applicable fire-resistive construction substitutions as permitted by this code.*

**903.2.4.1 Woodworking operations.** An automatic sprinkler system shall be provided throughout all Group F-1 occupancy fire areas that contain woodworking operations in excess of 2,500 square feet (232m<sup>2</sup>) in area which generate finely divided combustible waste or use finely divided combustible materials. [SFM] *A fire wall of less than four-hour fire-resistance rating without openings, or any fire wall with openings, shall not be used to establish separate fire areas.*

**903.2.5.2 Group H-5 occupancies.** An automatic sprinkler system shall be installed throughout buildings containing Group H-5 occupancies. The design of the sprinkler system shall not be less than that required under the ~~International~~California Building Code for the occupancy hazard classifications in accordance with Table 903.2.4.2. Where the design area of the sprinkler system consists of a corridor protected by one row of sprinklers, the maximum number of sprinklers required to be calculated is 13.

~~903.2.5.1~~ **903.2.6.2 Group I-3 .** *Every building, or portion thereof, where inmates are restrained shall be protected by an automatic sprinkler system conforming to NFPA 13. The main sprinkler control valve or valves and all other control valves in the system shall be locked in the open position and electrically supervised so that at least an audible and visual alarm will sound at a constantly attended location when valves are closed. The sprinkler branch piping serving cells may be embedded in the concrete construction.*

**Exception:** *Sprinklers are not required in cells housing two or fewer inmates and the building shall be considered sprinklered throughout when all the following criteria are met:*

1. *Automatic fire sprinklers shall be mounted outside the cell a minimum of 6 feet (1829 mm) on center and 12 inches (305 mm) from the wall with quick response sprinkler heads. Where spacing permits, the head shall be centered over the cell door opening.*
2. *The maximum amount of combustibles, excluding linen and clothing, shall be maintained at three pounds per*

*inmate.*

3. For local detention facilities, each individual housing cell shall be provided with a two-way inmate or sound-actuated audio monitoring system for communication directly to the control station serving the cell(s).
4. The provisions of the exception in Section 804.4.2 shall not apply.

**903.2.7 Group M.** An automatic sprinkler system shall be provided throughout buildings containing a Group M occupancy where one of the following conditions exists:

1. Where a Group M fire area exceeds 12,000 square feet (1115 m<sup>2</sup>);
2. Where a Group M fire area is located more than three stories above grade plane; or
3. Where the combined area of all Group M fire areas on all floors, including any mezzanines, exceeds 24,000 square feet (2230 m<sup>2</sup>).
4. Where a Group M occupancy is used for the display and sale of upholstered furniture.
- 4.5. [SFM] *The structure exceeds 24,000 square feet (465 m<sup>2</sup>), contains more than one fire area containing a Group M occupancies, and is separated into two or more buildings by fire walls of less than four hour fire resistance rating.*

**903.2.9.1 Repair garages.** An automatic sprinkler system shall be provided throughout all buildings used as repair garages in accordance with Section 406 of the ~~International~~ California Building Code, as follows:

1. Buildings having two or more stories above grade plane, including basements, with a fire area containing a repair garage exceeding 10,000 square feet (929 m<sup>2</sup>).
2. Buildings no more than one story above grade plane, with a fire area containing a repair garage exceeding 12,000 square feet (1115 m<sup>2</sup>).
3. Buildings with repair garages servicing vehicles parked in the basement.
4. A Group S-1 fire area used for the repair of commercial trucks or buses where the fire area exceeds 5,000 square feet (464 m<sup>2</sup>).

**903.2.11.4 Ducts conveying hazardous exhausts.** Where required by the ~~International~~ California Mechanical Code, automatic sprinklers shall be provided in ducts conveying hazardous exhaust, flammable or combustible materials.

**Exception:** Ducts where the largest cross-sectional diameter of the duct is less than 10 inches (254 mm).

**TABLE 903.2.11.6  
ADDITIONAL REQUIRED SUPPRESSION SYSTEMS**

<b>SECTION</b>	<b>SUBJECT</b>
914.2.1	Covered malls
914.3.1	High rise buildings <i>and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access</i>
914.4.1	Atriums
914.5.1	Underground structures
914.6.1	Stages
914.7.1	Special amusement buildings
914.8.2, 914.8.5	Aircraft hangars
914.9	Flammable finishes
914.10	Drying rooms
1025.6.2.3	Smoke-protected assembly seating
1208.2	Dry cleaning plants

1208.3	Dry cleaning machines
1504.2	Spray finishing in Group A, E, I or R
1504.4	Spray booths and spray rooms
1505.2	Dip-tank rooms in Group A, I or R
1505.4.1	Dip tanks
1505.9.4	Hardening and tempering tanks
1803.10	HPM facilities
1803.10.1.1	HPM work station exhaust
1803.10.2	HPM gas cabinets and exhausted enclosures
1803.10.3	HPM exit access corridor
1803.10.4	HPM exhaust ducts
1803.10.4.1	HPM noncombustible ducts
1803.10.4.2	HPM combustible ducts
1907.3	Lumber production conveyor enclosures
1908.7	Recycling facility conveyor enclosures
2106.1	Class A and B ovens
2106.2	Class C and D ovens
2209.3.2.6.2	Hydrogen motor fuel-dispensing area canopies
Table 2306.2	Storage fire protection
2306.4	Storage
2703.8.4.1	Gas rooms
2703.8.5.3	Exhausted enclosures
2704.5	Indoor storage of hazardous materials
2705.1.8	Indoor dispensing of hazardous materials
2804.4.1	Aerosol warehouses
2806.3.2	Aerosol display and merchandising areas
2904.5	Storage of more than 1,000 cubic feet of loose combustible fibers
3306.5.2.1	Storage of smokeless propellant
3306.5.2.3	Storage of small arms primers
3404.3.7.5.1	Flammable and combustible liquid storage rooms
3404.3.8.4	Flammable and combustible liquid storage warehouses
3405.3.7.3	Flammable and combustible liquid Group H-2 or H-3 areas
3704.1.2	Gas cabinets for highly toxic and toxic gas
3704.1.3	Exhausted enclosures for highly toxic and toxic gas
3704.2.2.6	Gas rooms for highly toxic and toxic gas

3704.3.3	Outdoor storage for highly toxic and toxic gas
4204.1.1	Pyroxylin plastic storage cabinets
4204.1.3	Pyroxylin plastic storage vaults
4204.2	Pyroxylin plastic storage and manufacturing
4603.4	Proxylin plastic storage in existing buildings
4603.4.2	Existing Group I-2 occupancies
California Building Code Section 430	Horse Racing Stables
California Building Code Section 431	Pet Kennels
California Building Code Section 439	Public Libraries

For SI: 1 cubic foot = 0.023 m<sup>3</sup>.

**903.2.14 Motion picture and television production studio sound stages, approved production facilities and production locations.**

**903.2.14.1 Existing Sound Stages and Approved Production Facilities.** All existing sound stages and approved production facilities equipped with an automatic fire sprinkler system shall be maintained in accordance with the provisions in this Chapter.

**903.2.14.2 New sound stages.** All new sound stages shall be equipped with an approved automatic fire sprinkler system. The system shall be installed in accordance with the provisions of the California Fire Code Chapter 9 and shall meet the minimum design requirements of an Extra Hazard, Group 2 system.

**903.2.15 Automatic sprinkler system – existing high-rise buildings.** Regardless of any other provisions of these regulations, every existing high-rise building of Type II-B, Type III-B or Type V-B construction shall be provided with an approved automatic sprinkler system conforming to NFPA 13.

**903.2.15.1 Existing R-1 and R-2 high-rise buildings fire-extinguishing systems.** Automatic fire-extinguishing systems installed in any existing high-rise structure in which a Group R-1 or a Group R-2 occupancy is, located shall have an approved flow indicator electrically interconnected to the required fire alarm system.

**903.2.16 Group L occupancies.** An automatic fire protection system shall be installed throughout buildings housing Group L Occupancies. Sprinkler system design for research laboratories and similar areas of a Group L Occupancy shall not be less than that required for Ordinary Hazard Group 2 with a design area of not less than 3,000 square feet (279 m<sup>2</sup>).

*In mixed occupancies, portions of floors or buildings not classified as Group L Occupancies shall be provided with sprinkler protection designed of not less than that required for Ordinary Hazard Group 1 with a design area of not less than 3,000 square feet (279 m<sup>2</sup>).*

**903.2.17 Fixed guideway transit systems.**

**903.2.17.1 Automatic sprinkler system.** An automatic sprinkler system shall be installed in all stations of fixed guideway transit systems.

**Exceptions:**

1. Guideways when the closest sprinkler heads to the guideway are within 3 feet (914mm) of the edge, over the

- platform, and spaced 6 feet (1829 mm) on center parallel to the guideway.*
2. *Station agent booths not exceeding 150 square feet (13.9 m<sup>2</sup>) in area, when provided with an approved smoke detector connected to the building fire alarm system.*
  3. *Power substations.*
  4. *Machinery rooms, electrical rooms and train control rooms protected by an approved automatic fixed fire-extinguishing system.*
  5. *Open stations.*
  6. *Station platform areas open to three or more sides.*

**903.2.17.2 Station guideway deluge system.** *Underground stations and stations in open cuts with walls 5 feet (1524 mm) above the top of the running rail and with a raised platform shall be provided with an under-vehicle guideway manually activated deluge sprinkler system. In open cut stations, such system shall be provided in guideways which are situated between a raised platform edge and a retaining wall.*

**903.2.17.2.1** *Systems shall be provided along the entire length of track at each station platform.*

**903.2.17.2.2** *Deluge nozzles with caps shall be located in the approximate center of track with spacing designed to completely wet the undersides of the vehicle at the applied density.*

**903.2.17.2.3** *System density shall be a minimum of 0.19 gallon per minute (gpm) per square foot (0.72 L/m per m<sup>2</sup>) for the design area. When more than one zone is provided, two adjacent zones are required to be considered operating for calculating purposes.*

**903.2.17.2.4** *Deluge systems shall be directly connected to a water supply capable of supplying the required flow rate for a minimum 30-minute duration.*

**903.2.17.2.5** *Controls or manually operable valves shall be in a location acceptable to the Fire Code Official. All deluge systems shall be monitored by the station fire alarm system.*

**903.2.17.2.6** *Each valve shall be monitored by a separate circuit. The alarm panel shall be located in an area normally occupied by station personnel or signals shall be transmitted to the operations control center (OCC).*

**903.3.5 Water supplies.** *Water supplies for automatic sprinkler systems shall comply with this section and the standards referenced in Section 903.3.1. The potable water supply shall be protected against backflow in accordance with the requirements of this section and the ~~International Plumbing Code~~. Health and Safety Code 13114.7.*

**903.4.2 Alarms.** *One exterior ~~Approved~~ approved audible devices shall be connected to every automatic sprinkler system in an approved location. Such sprinkler water-flow alarm devices shall be activated by water flow equivalent to the flow of a single sprinkler of the smallest orifice size installed in the system. ~~Alarm devices shall be provided on the exterior of the building in an approved location.~~ Where a building fire alarm system is installed, actuation of the automatic sprinkler system shall actuate the building fire alarm system. Visible alarm notification appliances shall not be required except when required by section 907.*

**903.4.3 Floor control valves.** *Approved supervised indicating control valves shall be provided at the point of connection to the riser on each floor in high-rise buildings and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access.*

**903.6 Existing buildings.** *The provisions of this section are intended to provide a reasonable degree of safety in existing structures not complying with the minimum requirements of the ~~International~~ California Building Code by requiring installation of an automatic fire-extinguishing system.*

**904.2.1 Commercial hood and duct systems.** *Each required commercial kitchen exhaust hood and duct system required by Section ~~640~~ 609 to have a Type I hood shall be protected with an approved automatic fire-extinguishing system installed in accordance with this code.*

**904.3.1 Electrical wiring.** *Electrical wiring shall be in accordance with this code or the ~~NEPA 70~~ California Electrical*

Code.

**904.5 Wet-chemical systems.** Wet-chemical extinguishing systems shall be installed, maintained, periodically inspected and tested in accordance with ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5~~ and NFPA 17A and their listing.

**904.6 Dry-chemical systems.** Dry-chemical extinguishing systems shall be installed, maintained, periodically inspected and tested in accordance with ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5~~ and NFPA 17 and their listing.

**904.7 Foam systems.** Foam-extinguishing systems shall be installed, maintained, periodically inspected and tested in accordance with ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5~~, NFPA 11 and NFPA 16 and their listing.

**904.7.1 System test.** Foam-extinguishing systems shall be inspected and tested at intervals in accordance with ~~NFPA 25 Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5~~.

**904.8 Carbon dioxide systems.** Carbon dioxide extinguishing systems shall be installed, maintained, periodically inspected and tested in accordance with ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5~~ and NFPA 12 and their listing.

**904.9 Halon systems.** Halogenated extinguishing systems shall be installed, maintained, periodically inspected and tested in accordance with ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5~~ and NFPA 12A and their listing.

**904.10 Clean-agent systems.** Clean-agent fire-extinguishing systems shall be installed, maintained, periodically inspected and tested in accordance with ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5~~ and NFPA 2001 and their listing.

**904.11.5 Portable fire extinguishers for commercial cooking equipment.** Portable fire extinguishers shall be provided ~~within a 30 foot (9144 mm) travel distance of commercial type cooking equipment. Cooking equipment involving solid fuels or vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher in accordance with Sections 904.11.5.1 or 904.11.5.2, as applicable and maintained in accordance with Title 19, California Code of Regulations, Title 19, Division 1, Chapter 3.~~

**904.11.5.2 Class K portable fire extinguishers for deep fat fryers.** When hazard areas include deep fat fryers, listed Class K portable fire extinguishers shall be provided *in accordance with Title 19, California Code of Regulations, Title 19, Division 1, Chapter 3 and as follows:*

1. For up to four fryers having a maximum cooking medium capacity of 80 pounds (36.3 kg) each: One Class K portable fire extinguisher of a minimum 1.5 gallon ( 6 L) capacity.
2. For every additional group of four fryers having a maximum cooking medium capacity of 80 pounds (36.3 kg) each: Additional Class K portable fire extinguishers of a minimum 1.5 gallon (6 L) capacity shall be provided.
3. For individual fryers exceeding 6 square feet (0.55 m<sup>2</sup>) in surface area: Class K portable fire extinguishers shall be installed in accordance with the extinguisher manufacturer's recommendations.

**904.11.6 Operations and maintenance.** Commercial cooking systems shall be operated and maintained in accordance with ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5~~ and this section.

**905.2 Installation standard.** Standpipe systems shall be installed in accordance with this section and NFPA 14 as amended in Chapter 47

**905.3 Required installations.** Standpipe systems shall be installed where required by Sections 905.3.1 through ~~905.3.710.1~~ 905.3.10.1 and in the locations indicated in Sections 905.4, 905.5 and 905.6. Standpipe systems are allowed to be combined with automatic sprinkler systems.

**Exception:** Standpipe systems are not required in Group R-3 occupancies.

**905.3.8 Smokeproof enclosures.** For smokeproof enclosures see California Building Code Section 909.20.

**905.3.9 Group I-3.** Housing units within cell complexes where 50 or more inmates are restrained, shall be provided with Class I wet standpipes. In addition, Class I wet standpipes shall be located so that it will not be necessary to extend hose lines through interlocking security doors and any doors in smoke-barrier walls, horizontal fire walls or fire barrier walls. Standpipes located in cell complexes may be placed in secured pipe chases.

**905.3.10 Fixed Guideway Transit Systems,** Underground stations shall be provided with a class III standpipe system designed to comply with the following:

1. Automatically supply 65 pounds per square inch (psi) for each outlet.
2. Supply a 250 gpm (946 L/m) flow to each of the two most remote 2½ inch (64 mm) outlets when pressurized through the fire department connection(s).

**905.3.10.1** All other stations shall be provided with a class I manual wet standpipe system; a manual dry class I standpipe system may be allowed in areas subject to freezing.

**Exception:** Open at-grade stations with unrestricted fire department access need not be provided with a standpipe system.

**905.5 Location of Class II standpipe hose connections.** Class II standpipe hose connections shall be accessible and shall be located so that all portions of the building are within 30 feet (9144 mm) of a listed variable stream fog nozzle attached to 100 feet (30 480mm) of hose.

~~**907.1.3-907.1.4 Fire-walls and Fire barrier walls.** For the purpose of Section 907 fire walls and fire barrier walls shall not define separate buildings.~~

**907.2.6 Group I.** A manual fire alarm system that activates the occupant notification system shall be installed in Group I occupancies. An automatic smoke detection system that activates the occupant notification system shall be provided in accordance with Sections 907.2.6.1, 907.2.6.2 and 907.2.6.3.3.

**Exceptions:**

1. ~~Manual fire alarm boxes in resident or patient sleeping areas of Group I-1 and I-2 occupancies shall not be required at exits if located at all nurses' control stations or other constantly attended staff locations, provided such stations are visible and continuously accessible and that travel distances required in Section 907.4.2 are not exceeded. Large family day care.~~
2. Occupant notification systems are not required to be activated where private mode signaling installed in accordance with NFPA 72 is approved by the fire code official.

**907.2.6.3.4 System annunciation** A staff alerting fire alarm shall sound at all staff control stations on the floor of activation and an audible and visual signal shall be indicated on an annunciator at the facility control center upon activation of any automatic extinguishing system, automatic detection system, or any smoke detector or manual actuating or initiating device. In addition, where there are staff-control stations on the floor, an audible, visual and manual alarm shall be located in each staff control station.

Fire and trouble signals of fire alarm systems and sprinkler water-flow and supervisory signals of extinguishing systems shall be annunciated in an area designated as the facility control center which shall be constantly attended by staff personnel. All such signals shall produce both an audible signal and visual display at the facility control center indicating the building, floor zone or other designated area from which the signal originated in accordance with Section ~~907-8907.7.3~~.

All local detention facilities within the scope of Section 6031.4 of the Penal Code shall have an automatic smoke detection system. A manual fire alarm-initiating device shall be installed in all guard control stations and shall be capable of alerting personnel in a central control point to the presence of fire or smoke within the facility.

**907.2.6.4 Large family day-care.** Every large family day-care home shall be provided with at least one manual device at a location approved by the enforcing agency. Such device shall actuate a fire alarm signal, which shall be audible throughout the facility at a minimum level of 15 db above ambient noise level. These devices need not be interconnected to any other fire alarm device, have a control panel or be electrically supervised or provided with emergency power. Such device or devices shall be attached to the structure and may be of any type acceptable to the enforcing agency, provided that such devices are distinctive in tone and are audible throughout the structure.

**907.2.7 Group M.** A manual fire alarm system that activates the occupant notification system in accordance with Section 907.6 shall be installed in Group M occupancies where one of the following conditions exists:

1. The combined Group M *occupant load* of all floors is 500 or more *persons*.
2. The Group M occupant load is more than 100 persons above or below the lowest level of exit discharge.

**Exceptions:**

1. A manual fire alarm system is not required in covered mall buildings complying with Section 402 of the ~~International~~ California Building Code.
2. Manual fire alarm boxes are not required where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 and the occupant notification appliances will automatically activate throughout the notification zones upon sprinkler water flow.

**907.2.11 Single- and multiple-station smoke alarms.** Listed single- and multiple-station smoke alarms complying with UL 217 shall be installed in accordance with Sections 907.2.11.1 through 907.2.11.4 and NFPA 72.

**Exception:** For Group R occupancies. A fire alarm system with smoke detectors located in accordance with this section may be installed in lieu of smoke alarms. Upon actuation of the detector, only those notification appliances in the dwelling unit or guest room where the detector is actuated shall activate.

**~~907.2.10.1.4~~ 907.2.11.2.1 Group I-4 Occupancies.** Large family day-care homes shall be equipped with State Fire Marshal approved and listed single station residential type smoke alarms. .

**~~907.2.10.1.5~~ 907.2.11.2.2 Group R-3.1** In all facilities housing a bedridden client, smoke alarms shall receive their primary power from the building wiring when such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms shall be electrically interconnected so as to cause all smoke alarms to sound a distinctive alarm signal upon actuation of any single smoke alarm. Such alarm signal shall be audible throughout the facility at a minimal level of 15 db above ambient noise level. These devices need not be interconnected to any other fire alarm device, have a control panel, or be electrically supervised or provided with emergency power.

**907.2.11.3 Interconnection.** Where more than one smoke alarm is required to be installed within an individual dwelling unit in Group R-2, R-3, R-3.1, or R-4, or within an individual dwelling unit or sleeping unit in Group R-1, the smoke alarms shall be interconnected in such a manner that the activation of one alarm will activate all of the alarms in the individual unit. The alarm shall be clearly audible in all bedrooms over background noise levels with all intervening doors closed.

**907.2.11.4 Power source.** In new construction and in newly classified Group R-3.1 Occupancies, required smoke alarms shall receive their primary power from the building wiring where such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms shall emit a signal when the batteries are low. Wiring shall be permanent and without a disconnecting switch other than as required for overcurrent protection.

**Exception:** Smoke alarms are not required to be equipped with battery backup in Group R-1 where they are connected to an emergency electrical system.

**907.2.18 Underground buildings with smoke exhaust systems.** Where a smoke exhaust system is installed in an underground building in accordance with the ~~International~~ California Building Code, automatic fire detectors shall be provided in accordance with Section 907.2.18.1.

**907.2.21 Residential aircraft hangars.** A minimum of one listed smoke alarm shall be installed within a residential aircraft hangar as defined in the ~~International~~California Building Code and shall be interconnected into the residential smoke alarm or other sounding device to provide an alarm which will be audible in all sleeping areas of the dwelling.

**907.2.24 Motion Picture and Television Production Studio Sound Stages and Approved Production Facilities**

**907.2.25 Group C Occupancies (Organized Camps).**

**907.2.25.1 General.** Every building and structure used or intended for sleeping purposes shall be provided with an automatic smoke-detection system.

**Exception:**

1. Buildings and structures in existence and in operation prior to January 1, 1985.
2. Tents, tent structures and buildings and structures that do not exceed 25 ft (7620mm) in any lateral dimensions and where such building or structure is not more than one story.

**907.2.27 Winery Caves.** An approved manual fire alarm system conforming to the provisions of Section 907.2-4 shall be provided in all Type 3 winery caves.

**907.4 Fire safety functions.** Automatic fire detectors utilized for the purpose of performing fire safety functions shall be connected to the building's fire alarm control unit where a fire alarm system is ~~required by Section 907.2~~ installed. Detectors shall, upon actuation, perform the intended function and activate the alarm notification appliances or a visible and audible supervisory signal at a constantly attended location. In buildings not required to be equipped with a fire alarm system, the automatic fire detector shall be powered by normal electrical service and, upon actuation, perform the intended function. The detectors shall be located in accordance with NFPA 72.

**907.4.2 Delayed egress locks.** Where delayed egress locks or devices are installed on means of egress doors in accordance with Section 1008.1.9.7, an automatic smoke ~~or heat~~ detection system shall be installed as required by ~~that~~ this Section ~~and Section 1008.1.8.6~~ 1008.1.9.7.

**907.5.2.1 Location.** Manual fire alarm boxes shall be located not more than 5 feet (1524 mm) from the entrance to each exit. Additional manual fire alarm boxes shall be located so that travel distance to the nearest box does not exceed 200 feet (60 960 mm).

**Exception:** When individual dwelling units are served by a single exit stairway, additional boxes at other than the ground floor may be omitted.

**907.6.2.1 Audible alarms.** Audible alarm notification appliances shall be provided and emit a distinctive sound that is not to be used for any purpose other than that of a fire alarm.

*In ~~g~~Group I-2 occupancies, audible appliances ~~placed~~ located in patient areas shall be only chimes or similar sounding ~~devices~~ appliances for alerting staff. See Section 907.7.5.*

**Exception:** Visible alarm notification appliances shall be allowed in lieu of audible alarm notification appliances in ~~critical care~~ areas of Group I-2 occupancies.

**907.6.2.3.1 Public and common use areas.** Visible alarm notification appliances shall be provided in public use areas and common use areas, including but not limited to:

1. Sanitary facilities including restrooms, bathrooms and shower rooms
2. Corridors
3. Music practice rooms
4. Band rooms
5. Gymnasiums
6. Multipurpose rooms
7. Occupational shops

- 8. Occupied rooms where ambient noise impairs hearing of the fire alarm
- 9. Lobbies
- 10. Meeting rooms
- 11. Classrooms

**TABLE 907.6.2.3.3  
VISIBLE AND AUDIBLE ALARMS**

NUMBER OF SLEEPING UNITS	SLEEPING ACCOMODATIONS WITH VISIBLE ALARMS
6 to 25	2
26 to 50	4
51 to 75	7
76 to 100	9
101 to 150	12
151 to 200	14
201 to 300	17
301 to 400	20
401 to 500	22
501 to 1,000	5% of total
1,001 and over	50 plus 3 for each 100 over 1,000

[SFM] Also see Chapter 11B Section 1111B.4.5, Table 11B-3, and Table 11B-4 of the California Building Code.

**907.7.1 Wiring.** Wiring shall comply with the requirements of this code or the ~~NFPA 70~~-California Electrical Code and NFPA 72. Wireless protection systems utilizing radio-frequency transmitting devices shall comply with the special requirements for supervision of low-power wireless systems in NFPA 72.

~~907.9.1~~ **907.7.3.1 Annunciation.** Alarm, supervisory and trouble signals shall be annunciated in the main control unit by means of an audible signal and a visual display in accordance with NFPA 72. Identification of the type of alarm and supervisory initiating devices, such as manual, automatic, sprinkler waterflow, sprinkler valve supervisory, fire-pump supervisory, etc., shall be separately indicated.

**Exception:** Group R-3 Occupancies.

**907.7.3.2 High-rise buildings.** In high-rise buildings with a floor used for human occupancy that is located more than 75 feet (22 860 mm) above the lowest level of fire department vehicle building access and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access, a separate zone by floor shall be provided for all of the following types of alarm-initiating devices where provided:

1. Smoke detectors.
2. Sprinkler water-flow devices.
3. Manual fire alarm boxes.
4. Other approved types of automatic fire detection devices or suppression systems.

**909.1 Scope and purpose.** This section applies to mechanical or passive smoke control systems when they are required for new buildings or portions thereof by provisions of the ~~International~~ California Building Code or this code. The purpose of this section is to establish minimum requirements for the design, installation and acceptance testing of smoke control systems that are intended to provide a tenable environment for the evacuation or relocation of occupants. These provisions are not intended for the preservation of contents, the timely restoration of operations, or for assistance in fire suppression or overhaul activities. Smoke control systems regulated by this section serve a different purpose than the smoke- and heat-venting provisions found in Section 910. Mechanical smoke control

systems shall not be considered exhaust systems under Chapter 5 of the ~~International~~California Mechanical Code.

**909.2 General design requirements.** Buildings, structures, or parts thereof required by the ~~International~~California Building Code or this code to have a smoke control system or systems shall have such systems designed in accordance with the applicable requirements of Section 909 and the generally accepted and well-established principles of engineering relevant to the design. The construction documents shall include sufficient information and detail to describe adequately the elements of the design necessary for the proper implementation of the smoke control systems. These documents shall be accompanied with sufficient information and analysis to demonstrate compliance with these provisions.

**909.3 Special inspection and test requirements.** In addition to the ordinary inspection and test requirements to which buildings, structures and parts thereof are required to undergo, smoke control systems subject to the provisions of Section 909 shall undergo special inspections and tests sufficient to verify the proper commissioning of the smoke control design in its final installed condition. The design submission accompanying the construction documents shall clearly detail procedures and methods to be used and the items subject to such inspections and tests. Such commissioning shall be in accordance with generally accepted engineering practice and, where possible, based on published standards for the particular testing involved. The special inspections and tests required by this section shall be conducted under the same terms as in Section 1704 of the ~~International~~California Building Code.

**909.4.3 Wind effect.** The design shall consider the adverse effects of wind. Such consideration shall be consistent with the wind-loading provisions of the ~~International~~California Building Code.

**909.5 Smoke barrier construction.** Smoke barriers shall comply with the ~~International~~California Building Code. Smoke barriers shall be constructed and sealed to limit leakage areas exclusive of protected openings. The maximum allowable leakage area shall be the aggregate area calculated using the following leakage area ratios:

**909.5.2 Opening protection.** Openings in smoke barriers shall be protected by *self-closing devices* or automatic-closing devices actuated by the required controls for the mechanical smoke control system. Door openings shall be protected by fire door assemblies complying with Section 715.4.3 ~~International~~ California Building Code.

**Exceptions:**

1. Passive smoke control systems with automatic-closing devices actuated by spot-type smoke detectors listed for releasing service installed in accordance with Section 907.4. *When used in a Group I-2, such detectors shall activate the building fire alarm system and shall close all the smoke barrier doors within the effected zone.*
2. Fixed openings between smoke zones that are protected utilizing the airflow method *in other than Group I-2.*
3. In Group I-2, where doors are installed across corridors, a pair of opposite-swinging doors without a center mullion or horizontal sliding doors that comply with Section ~~1008.1.3-31008.1.4.3~~. ~~Shall be installed having vision panels with fire protection-rated glazing materials in fire protection-rated frames, the area of which shall not exceed that tested.~~ *Vision panels consisting of fire-rated glazing in approved frames shall be provided in each cross-corridor swinging door and at each cross-corridor horizontal-sliding door in a smoke barrier. The doors shall be close fitting within operational tolerances, and shall not have undercuts, louvers or grilles. The Swinging doors shall have head and jamb stops, and astragals or rabbets at meeting edges. and Doors installed across corridors shall be automatic closing by smoke detection in accordance with Section 715.4.7.3715.4.8.3 of the ~~International~~ California Building Code. Positive-latching devices are not required. Doors installed across corridors shall comply with Section 1008.1.1.*
4. Group I-3.
5. Openings between smoke zones with clear ceiling heights of 14 feet (4267 mm) or greater and bank-down capacity of greater than 20 minutes as determined by the design fire size.
6. *In Group I-2, smoke damper activation may be accomplished by a fire alarm control unit provided that an open area smoke detection system is provided within all areas served by an HVAC system.*

**909.5.2.1 Ducts and air transfer openings.** Ducts and air transfer openings are required to be protected with a minimum Class II, 250°F (121°C) smoke damper complying with Section 716 of the ~~International~~California Building Code.

**909.10.2 Ducts.** Duct materials and joints shall be capable of withstanding the probable temperatures and pressures to which they are exposed as determined in accordance with Section 909.10.1. Ducts shall be constructed and supported in accordance with the ~~International~~*California Mechanical Code*. Ducts shall be leak tested to 1.5 times the maximum design pressure in accordance with nationally accepted practices. Measured leakage shall not exceed 5 percent of design flow. Results of such testing shall be a part of the documentation procedure. Ducts shall be supported directly from fire-resistance-rated structural elements of the building by substantial, noncombustible supports.

**Exception:** Flexible connections (for the purpose of vibration isolation) complying with the ~~International~~*California Mechanical Code* and which are constructed of approved fire-resistance-rated materials.

**909.10.5 Fans.** In addition to other requirements, belt-driven fans shall have 1.5 times the number of belts required for the design duty with the minimum number of belts being two. Fans shall be selected for stable performance based on normal temperature and, where applicable, elevated temperature. Calculations and manufacturer's fan curves shall be part of the documentation procedures. Fans shall be supported and restrained by noncombustible devices in accordance with the structural design requirements of Chapter 16 of the ~~International~~*California Building Code*. Motors driving fans shall not be operated beyond their nameplate horsepower (kilowatts) as determined from measurement of actual current draw and shall have a minimum service factor of 1.15.

**909.11 Power systems.** The smoke control system shall be supplied with two sources of power. Primary power shall be from the normal building power systems. Secondary power shall be from an approved standby source complying with Section 604 and ~~NEPA 70~~*California Electrical Code*. The standby power source and its transfer switches shall be in a room separate from the normal power transformers and switch gears and ventilated directly to and from the exterior. The room shall be enclosed with not less than 1-hour fire barriers constructed in accordance with Section 707 of the ~~International~~*California Building Code* or horizontal assemblies constructed in accordance with Section 712 of the ~~International~~*California Building Code*, or both.

**909.12.1 Wiring.** In addition to meeting requirements of this code or the ~~NEPA 70~~*California Electrical Code*, all wiring, regardless of voltage, shall be fully enclosed within continuous raceways.

**909.16 Fire-fighter's smoke control panel.** A fire-fighter's smoke control panel for fire department emergency response purposes only shall be provided and shall include manual control or override of automatic control for mechanical smoke control systems. The panel shall be located in a fire command center complying with Section 509 in high-rise buildings, *Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access* or buildings with smoke-protected assembly seating. In all other buildings, the fire-fighter's smoke control panel shall be installed in an approved location adjacent to the fire alarm control panel. The fire-fighter's smoke control panel shall comply with Sections 909.16.1 through 909.16.3.

**909.16.1 Smoke control systems.** *Fans within the building shall be shown on the fire-fighter's control panel. A clear indication of the direction of airflow and the relationship of components shall be displayed. Status indicators shall be provided for all smoke control equipment, annunciated by fan and zone, and by approved indicators as follows:*

1. *Fans, dampers and other operating equipment in their normal status—WHITE.*
2. *Fans, dampers and other operating equipment in their off or closed status—RED.*
3. *Fans, dampers and other operating equipment in their on or open status—GREEN.*
4. *Fans, dampers and other operating equipment in a fault status—YELLOW/AMBER.*

**909.16.3 Control action and priorities.** The fire-fighter's control panel actions shall be as follows:

1. ON-OFF and OPEN-CLOSE control actions shall have the highest priority of any control point within the building. Once issued from the fire-fighter's control panel, no automatic or manual control from any other control point within the building shall contradict the control action. Where automatic means are provided to interrupt normal, nonemergency equipment operation or produce a specific result to safeguard the building or equipment (i.e., duct freeze stats, duct smoke detectors, high-temperature cutouts, temperature-actuated linkage and similar devices), such means shall be capable of being overridden by the fire-fighter's control panel. The last control action as indicated by each fire-fighter's control panel switch position shall prevail. In no case shall control actions require the smoke control system to assume more than one configuration at any one time.

**Exception:** Power disconnects required by this code or the ~~NEPA 70~~ *California Electrical Code*.

2. Only the AUTO position of each three-position fire-fighter's control panel switch shall allow automatic or manual control action from other control points within the building. The AUTO position shall be the NORMAL, nonemergency, building control position. Where a fire-fighter's control panel is in the AUTO position, the actual status of the device (on, off, open, closed) shall continue to be indicated by the status indicator described above. When directed by an automatic signal to assume an emergency condition, the NORMAL position shall become the emergency condition for that device or group of devices within the zone. In no case shall control actions require the smoke control system to assume more than one configuration at any one time.

**910.1 General.** Where required by this code or otherwise installed, smoke and heat vents or mechanical smoke exhaust systems and draft curtains shall conform to the requirements of this section.

**Exceptions:**

1. Frozen food warehouses used solely for storage of Class I and II commodities where protected by an approved automatic sprinkler system.
2. Where areas of buildings are equipped with early suppression fast-response (ESFR) sprinklers, automatic smoke and heat vents shall not be required within these areas. *This exception shall not apply to any state institution or other state-owned or state-occupied buildings and other applications listed in Section 444.11 regulated by the Office of the State Fire Marshal.*

**910.3.1 Design.** Smoke and heat vents shall be listed and labeled to indicate compliance with *FM 4430, ICC ES AC 331, or UL 793*.

**911.2 Required deflagration venting.** Areas that are required to be provided with deflagration venting shall comply with the following:

1. Walls, ceilings and roofs exposing surrounding areas shall be designed to resist a minimum internal pressure of 100 pounds per square foot (psf) (4788 Pa). The minimum internal design pressure shall not be less than five times the maximum internal relief pressure specified in Section 911.2, Item 5.
2. Deflagration venting shall be provided only in exterior walls and roofs.

**Exception:** Where sufficient exterior wall and roof venting cannot be provided because of inadequate exterior wall or roof area, deflagration venting shall be allowed by specially designed shafts vented to the exterior of the building.

3. Deflagration venting shall be designed to prevent unacceptable structural damage. Where relieving a deflagration, vent closures shall not produce projectiles of sufficient velocity and mass to cause life threatening injuries to the occupants or other persons on the property or adjacent public ways.
4. The aggregate clear area of vents and venting devices shall be governed by the pressure resistance of the construction assemblies specified in Item 1 of this section and the maximum internal pressure allowed by Item 5 of this section.
5. Vents shall be designed to withstand loads in accordance with the ~~International~~*California Building Code*. Vents shall consist of any one or any combination of the following to relieve at a maximum internal pressure of 20 pounds per square foot (958 Pa), but not less than the loads required by the ~~International~~*California Building Code*:
  - 5.1. Exterior walls designed to release outward.
  - 5.2. Hatch covers.
  - 5.3. Outward swinging doors.
  - 5.4. Roofs designed to uplift.
  - 5.5. Venting devices listed for the purpose.
6. Vents designed to release from the exterior walls or roofs of the building when venting a deflagration shall discharge directly to the exterior of the building where an unoccupied space not less than 50 feet (15 240 mm) in width is provided between the exterior walls of the building and the property line.

**Exception:** Vents complying with Item 7 of this section.

7. Vents designed to remain attached to the building when venting a deflagration shall be so located that the discharge opening shall not be less than 10 feet (3048 mm) vertically from window openings and exits in the building and 20 feet (6096 mm) horizontally from exits in the building, from window openings and exits in adjacent buildings on the same property, and from the property line.
8. Discharge from vents shall not be into the interior of the building.

**912.3 Access.** Immediate access to fire department connections shall be maintained at all times and without obstruction by fences, bushes, trees, walls or any other fixed or moveable object. Access to fire department connections shall be approved by the fire chief.

**Exceptions:**

1. Fences, where provided with an access gate equipped with a sign complying with the legend requirements of Section 912.4 and a means of emergency operation. The gate and the means of emergency operation shall be approved by the fire chief and maintained operational at all times.

**Exception:** 2. *When acceptable to the fire enforcing agency, fire department connections for Group I-3 detention facilities may be located inside all security walls or fences on the property.*

**912.5 Backflow protection.** The potable water supply to automatic sprinkler and standpipe systems shall be protected against backflow as required by the ~~International Plumbing Code~~ *Health and Safety Code 13114.7.*

**912.6 Inspection, testing and maintenance.** All fire department connections shall be periodically inspected, tested and maintained in accordance with ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5.~~

**913.5 Testing and maintenance.** Fire pumps shall be inspected, tested and maintained in accordance with the requirements of this section and ~~Title 19, California Code of Regulations, Title 19, Division 1, Chapter 5.~~

**914.1 General.** This section shall specify where fire protection systems are required based on the detailed requirements of use and occupancy of the ~~International~~ *California Building Code.*

**914.2.1 Automatic sprinkler system.** The covered mall building and buildings connected shall be equipped throughout with an automatic sprinkler system in accordance with Section 903.1.1, which shall comply with the following:

1. The automatic sprinkler system shall be complete and operative throughout occupied space in the covered mall building prior to occupancy of any of the tenant spaces. Unoccupied tenant spaces shall be similarly protected unless provided with approved alternate protection.
2. Sprinkler protection for the mall shall be independent from that provided for tenant spaces or anchors. Where tenant spaces are supplied by the same system, they shall be independently controlled.

**Exception:** An automatic sprinkler system shall not be required in space or areas of open parking garages constructed in accordance with Section 406.2 of the ~~International~~ *California Building Code.*

**914.3 High-rise buildings.** High-rise buildings *and Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access* shall comply with Sections 914.3.1 through 914.3.56.

**~~914.3.6~~ 914.3.7 Smoke control.**

**~~914.3.6.1~~ 914.3.7.1 Smoke Control System.** *All portions of high-rise buildings shall be provided with a smoke control system in accordance with California Building Code, Section 909.*

**~~914.3.6.2~~ 914.3.7.2 Smokeproof exit enclosures.** *Every exit enclosure in high-rise buildings shall comply with California Building Code, Sections 909.20 and ~~4020.1.7-1022.9.~~ Every required stairway in Group I-2 occupancies serving floors more than 75 feet (22 860 mm) above the lowest level of fire department vehicle access shall comply with Section 909.20 and ~~4020.1.7-1022.9.~~*

**914.5.3 Compartment smoke control system.** Where compartmentation is required by Section 405.4 of the ~~International~~*California Building Code*, each compartment shall have an independent smoke-control system. The system shall be automatically activated and capable of manual operation in accordance with Section 907.2.18.

**914.10 Drying rooms.** Drying rooms designed for high-hazard materials and processes, including special occupancies as provided for in Chapter 4 of the ~~International~~*California Building Code*, shall be protected by an approved automatic fire-extinguishing system complying with the provisions of Chapter 9.

## CHAPTER 14 FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION

**1403.1 Listed.** Temporary heating devices shall be listed and labeled in accordance with the ~~International~~*California Mechanical Code* or the ~~International Fuel Gas Mechanical Code~~. Installation, maintenance and use of temporary heating devices shall be in accordance with the terms of the listing.

**1403.3 LP-gas heaters.** Fuel supplies for liquefied-petroleum gas-fired heaters shall comply with Chapter 38 and the ~~International Fuel Gas~~ *California Mechanical Code*.

**1404.7 Electrical.** Temporary wiring for electrical power and lighting installations used in connection with the construction, alteration or demolition of buildings, structures, equipment or similar activities shall comply with the ~~NFPA 70~~ *California Electrical Code*.

**1414.1 Completion before occupancy.** In buildings where an automatic sprinkler system is required by this code or the ~~International~~ *California Building Code*, it shall be unlawful to occupy any portion of a building or structure until the automatic sprinkler system installation has been tested and approved, except as provided in Section 105.3.4.

## CHAPTER 15 FLAMMABLE FINISHES

### SECTION 1502 DEFINITIONS

**SPRAY ROOM.** A room designed to accommodate spraying operations constructed in accordance with the ~~International~~ *California Building Code* and separated from the remainder of the building by a minimum 1-hour fire barrier.

**1503.2.1 Electrical wiring and equipment.** Electrical wiring and equipment shall comply with this chapter and the ~~NFPA 70~~ *California Electrical Code*.

**1503.2.1.1 Flammable vapor areas.** Electrical wiring and equipment in flammable vapor areas shall be of an explosion proof type approved for use in such hazardous locations. Such areas shall be considered to be Class I, Division 1 or Class II, Division 1 hazardous locations in accordance with the ~~NFPA 70~~ *California Electrical Code*.

**1503.2.1.4 Areas subject to overspray deposits.** Electrical equipment in flammable vapor areas located such that deposits of combustible residues could readily accumulate thereon shall be specifically approved for locations containing deposits of readily ignitable residue and explosive vapors in accordance with the ~~NFPA 70~~ *California Electrical Code*.

#### **Exceptions:**

1. Wiring in rigid conduit.
2. Boxes or fittings not containing taps, splices or terminal connections.
3. Equipment allowed by Sections 1504 and 1507 and Chapter 21.

**1503.2.5 Grounding.** Metal parts of spray booths, exhaust ducts and piping systems conveying Class I or II liquids shall be electrically grounded in accordance with the ~~NFPA 70~~ *California Electrical Code*. Metallic parts located in resin application areas, including but not limited to exhaust ducts, ventilation fans, spray application equipment,

workpieces and piping, shall be electrically grounded.

**1504.2 Location of spray-finishing operations.** Spray finishing operations conducted in buildings used for Group A, E, I or R occupancies shall be located in a spray room protected with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 and separated vertically and horizontally from other areas in accordance with the ~~International~~ *California Building Code*. In other occupancies, spray-finishing operations shall be conducted in a spray room, spray booth or spraying space approved for such use.

**Exceptions:**

1. Automobile undercoating spray operations and spray-on automotive lining operations conducted in areas with approved natural or mechanical ventilation shall be exempt from the provisions of Section 1504 when approved and where utilizing Class IIIA or IIIB combustible liquids.
2. In buildings other than Group A, E, I or R occupancies, approved limited spraying space in accordance with Section 1504.9.
3. Resin application areas used for manufacturing of reinforced plastics complying with Section 1509 shall not be required to be located in a spray room, spray booth or spraying space.

**1504.3.1 Spray rooms.** Spray rooms shall be constructed and designed in accordance with this section and the ~~International~~ *California Building Code*, and shall comply with Sections 1504.4 through 1504.8.

**1504.3.2.6 Size.** The aggregate area of spray booths in a building shall not exceed the lesser of 10 percent of the area of any floor of a building or the basic area allowed for a Group H-2 occupancy without area increases, as set forth in the ~~International~~ *California Building Code*. The area of an individual spray booth in a building shall not exceed the lesser of the aggregate size limit or 1,500 square feet (139 m<sup>2</sup>).

**Exception:** One individual booth not exceeding 500 square feet (46 m<sup>2</sup>).

**1504.3.3 Spraying spaces.** Spraying spaces shall be designed and constructed in accordance with the ~~International~~ *California Building Code* and Sections 1504.3.3.1 and 1504.4 and through 1504.8 of this code.

**1504.6.1.2.2 Portable infrared apparatus.** When a portable infrared drying apparatus is used, electrical wiring and portable infrared drying equipment shall comply with the ~~NEPA-70~~ *California Electrical Code*. Electrical equipment located within 18 inches (457 mm) of floor level shall be approved for Class I, Division 2 hazardous locations. Metallic parts of drying apparatus shall be electrically bonded and grounded. During spraying operations, portable drying apparatus and electrical connections and wiring thereto shall not be located within spray booths, spray rooms or other areas where spray residue would be deposited thereon.

**1504.7 Ventilation.** Mechanical ventilation of flammable vapor areas shall be provided in accordance with ~~Section 540~~ 505 of the ~~International~~ *California Mechanical Code*.

**1504.7.2 Recirculation.** Air exhausted from spraying operations shall not be recirculated.

**Exceptions:**

1. Air exhausted from spraying operations is allowed to be recirculated as makeup air for unmanned spray operations, provided that:
  - 1.1. The solid particulate has been removed.
  - 1.2. The vapor concentration is less than 25 percent of the LFL.
  - 1.3. Approved equipment is used to monitor the vapor concentration.
  - 1.4. When the vapor concentration exceeds 25 percent of the LFL, the following shall occur:
    - a. An alarm shall sound; and
    - b. Spray operations shall automatically shut down.
  - 1.5. In the event of shutdown of the vapor concentration monitor, 100 percent of the air volume specified in ~~Section 540~~ of the *California Mechanical Code* is automatically exhausted.

2. Air exhausted from spraying operations is allowed to be recirculated as makeup air to manned spraying operations where all of the conditions provided in Exception 1 are included in the installation and documents have been prepared to show that the installation does not pose a life safety hazard to personnel inside the spray booth, spraying space or spray room.

**1504.9.4 Electrical wiring.** Electrical wiring within 10 feet (3048 mm) of the floor and 20 feet (6096 mm) horizontally of the limited spraying space shall be designed for Class I, Division 2 locations in accordance with the ~~NEPA-70~~ *California Electrical Code*.

**1505.2 Location of dip-tank operations.** Dip-tank operations conducted in buildings used for Group A, I or R occupancies shall be located in a room designed for that purpose, equipped with an approved automatic sprinkler system and separated vertically and horizontally from other areas in accordance with the ~~International~~ *California Building Code*.

## CHAPTER 18 SEMICONDUCTOR FABRICATION FACILITIES

**1801.1 Scope.** Semiconductor fabrication facilities and comparable research and development areas classified as Group H-5 shall comply with this chapter and the ~~International~~ *California Building Code*. The use, storage and handling of hazardous materials in Group H-5 shall comply with this chapter, other applicable provisions of this code and the ~~International~~ *California Building Code*.

**1801.4 Existing buildings and existing fabrication areas.** Existing buildings and existing fabrication areas shall comply with this chapter, except that transportation and handling of HPM in exit access corridors and exit enclosures shall be allowed when in compliance with Section 1805.3.2 and the ~~International~~ *California Building Code*.

**1803.2.2 General requirements.** In addition to the requirements in Section 1803.2, systems, equipment and processes shall also comply with Section 2703.2, other applicable provisions of this code, the ~~International~~ *California Building Code* and the ~~International~~ *California Mechanical Code*.

**1803.3.1 Fabrication areas.** Construction and location of fabrication areas shall comply with the ~~International~~ *California Building Code*.

**1803.3.2 Pass-throughs in exit access corridors.** Pass-throughs in exit access corridors shall be constructed in accordance with the ~~International~~ *California Building Code*.

**1803.3.3 Liquid storage rooms.** Liquid storage rooms shall comply with Chapter 34 and the ~~International~~ *California Building Code*.

**1803.3.4 HPM rooms.** HPM rooms shall comply with the ~~International~~ *California Building Code*.

**1803.3.8 Service corridors.** Service corridors shall comply with Section 1805.3 and the ~~International~~ *Building Code*.

**1803.7.1 Fabrication areas.** Electrical wiring and equipment in fabrication areas shall comply with the ~~NEPA-70~~ *California Electrical Code*.

**1803.7.2 Workstations.** Electrical equipment and devices within 5 feet (1524 mm) of workstations in which flammable or pyrophoric gases or flammable liquids are used shall comply with the ~~NEPA-70~~ *California Electrical Code* for Class I, Division 2 hazardous locations. Workstations shall not be energized without adequate exhaust ventilation in accordance with Section 1803.14.

**Exception:** Class I, Division 2 hazardous electrical equipment is not required when the air removal from the workstation or dilution will prevent the accumulation of flammable vapors and fumes on a continuous basis.

**1803.7.3 Hazardous production material (HPM) rooms, gas rooms and liquid storage rooms.** Electrical wiring

and equipment in HPM rooms, gas rooms and liquid storage rooms shall comply with the ~~NFPA 70~~ *California Electrical Code*.

**1803.10.4 Exhaust ducts for HPM.** An approved automatic sprinkler system shall be provided in exhaust ducts conveying gases, vapors, fumes, mists or dusts generated from HPM in accordance with this section and the ~~International~~ *California Mechanical Code*.

**1803.14 Exhaust ventilation systems for HPM.** Exhaust ventilation systems and materials for exhaust ducts utilized for the exhaust of HPM shall comply with Sections 1803.14.1 through 1803.14.3, other applicable provisions of this code, the ~~International~~ *California Building Code* and the ~~International~~ *California Mechanical Code*.

**1803.14.1 Where required.** Exhaust ventilation systems shall be provided in the following locations in accordance with the requirements of this section and the ~~International~~ *California Building Code*:

1. Fabrication areas: Exhaust ventilation for fabrication areas shall comply with the ~~International~~ *California Building Code*. The fire code official is authorized to require additional manual control switches.
2. Workstations: A ventilation system shall be provided to capture and exhaust gases, fumes and vapors at workstations.
3. Liquid storage rooms: Exhaust ventilation for liquid storage rooms shall comply with Section 2704.3.1 and the ~~International~~ *California Building Code*.
4. HPM rooms: Exhaust ventilation for HPM rooms shall comply with Section 2704.3.1 and the ~~International~~ *California Building Code*.
5. Gas cabinets: Exhaust ventilation for gas cabinets shall comply with Section 2703.8.6.2. The gas cabinet ventilation system is allowed to connect to a workstation ventilation system. Exhaust ventilation for gas cabinets containing highly toxic or toxic gases shall also comply with Chapter 37.
6. Exhausted enclosures: Exhaust ventilation for exhausted enclosures shall comply with Section 2703.8.5.2. Exhaust ventilation for exhausted enclosures containing highly toxic or toxic gases shall also comply with Chapter 37.
7. Gas rooms: Exhaust ventilation for gas rooms shall comply with Section 2703.8.4.2. Exhaust ventilation for gas cabinets containing highly toxic or toxic gases shall also comply with Chapter 37.
8. Cabinets containing pyrophoric liquids or Class 3 water-reactive liquids: Exhaust ventilation for cabinets in fabrication areas containing pyrophoric liquids or Class 3 water-reactive liquids shall be as required in Section 1805.2.3.4.

**1803.15.1 Required electrical systems.** Emergency power shall be provided for electrically operated equipment and connected control circuits for the following systems:

1. HPM exhaust ventilation systems.
2. HPM gas cabinet ventilation systems.
3. HPM exhausted enclosure ventilation systems.
4. HPM gas room ventilation systems.
5. HPM gas detection systems.
6. Emergency alarm systems.
7. Manual fire alarm systems.
8. Automatic sprinkler system monitoring and alarm systems.
9. Automatic alarm and detection systems for pyrophoric liquids and Class 3 water-reactive liquids required in Section 1805.2.3.5.
10. Flow alarm switches for pyrophoric liquids and Class 3 water-reactive liquids cabinet exhaust ventilation systems required in Section 1805.2.3.4.
11. Electrically operated systems required elsewhere in this code or in the ~~International~~ *California Building Code* applicable to the use, storage or handling of HPM.

**1804.3.1 HPM storage.** The indoor storage of HPM in quantities greater than those listed in Section 2703.1.1 and 3404.3.4 shall be in a room complying with the requirements of the ~~International~~ *California Building Code* and this code for a liquid storage room, HPM room or gas room as appropriate for the materials stored.

**1805.2.3.2 Protection of vessels.** Vessels containing hazardous materials located in or connected to a workstation shall be protected as follows:

1. HPM: Vessels containing HPM shall be protected from physical damage and shall not project from the workstation.
2. Hazardous cryogenic fluids, gases and liquids:  
Hazardous cryogenic fluid, gas and liquid vessels located within a workstation shall be protected from seismic forces in an approved manner in accordance with the ~~International~~ *California Building Code*.
3. Compressed gases: Protection for compressed gas vessels shall also comply with Section 3003.5.
4. Cryogenic fluids: Protection for cryogenic fluid vessels shall also comply with Section 3203.3.

**1805.3.1 Exit corridors access and exit enclosures.** Exit access corridors and exit enclosures in new buildings or serving new fabrication areas shall not contain HPM except as permitted for exit access corridors by Section 415.8.6.3 of the ~~International~~ *California Building Code*.

**1805.3.2 Transport in existing exit access corridors.** When existing fabrication areas are altered or modified in existing buildings, HPM is allowed to be transported in existing exit access corridors when such exit access corridors comply with the ~~International~~ *California Building Code*. Transportation in exit access corridors shall comply with Section 2703.10.

**1805.3.3 Service corridors.** When a new fabrication area is constructed, a service corridor shall be provided where it is necessary to transport HPM from a liquid storage room, HPM room, gas room or from the outside of a building to the perimeter wall of a fabrication area. Service corridors shall be designed and constructed in accordance with the ~~International~~ *California Building Code*.

## CHAPTER 19 LUMBER YARDS AND WOODWORKING FACILITIES

**1903.1 Open yards.** Open yards required by the ~~International~~ *California Building Code* shall be maintained around structures.

**1903.2 Dust control.** Equipment or machinery located inside buildings which generates or emits combustible dust shall be provided with an approved dust collection and exhaust system installed in accordance with Chapter 13 and the ~~International~~ *California Mechanical Code*. Equipment or systems that are used to collect, process or convey combustible dusts shall be provided with an approved explosion control system.

**1903.3 Waste removal.** Sawmills, planing mills and other woodworking plants shall be equipped with a waste removal system that will collect and remove sawdust and shavings. Such systems shall be installed in accordance with Chapter 13 and the ~~International~~ *California Mechanical Code*.

**Exception:** Manual waste removal when approved.

**1903.4 Electrical equipment.** Electrical wiring and equipment shall comply with the ~~NEPA-70~~ *California Electrical Code*.

## CHAPTER 20 MANUFACTURE OF ORGANIC COATINGS

**2004.1 Wiring and equipment.** Electrical wiring and equipment shall comply with this chapter and shall be installed in accordance with the ~~NEPA-70~~ *California Electrical Code*.

**2005.1 Design.** Process structures shall be designed and constructed in accordance with the ~~International~~ *California Building Code*.

**2009.2 Tank storage.** Tank storage for flammable and combustible liquids located inside of structures shall be limited to storage areas at or above grade which are separated from the processing area in accordance with the ~~International~~

*California Building Code*. Processing equipment containing flammable and combustible liquids and storage in quantities essential to the continuity of the operations shall not be prohibited in the processing area.

**2009.4 Nitrocellulose storage.** Nitrocellulose storage shall be located on a detached pad or in a separate structure or a room enclosed in accordance with the ~~International~~ *California Building Code*. The nitrocellulose storage area shall not be utilized for any other purpose. Electrical wiring and equipment installed in storage areas adjacent to process areas shall comply with Section 2004.2.

**2009.6 Finished products.** Finished products that are flammable or combustible liquids shall be stored outside of structures, in a separate structure, or in a room separated from the processing area in accordance with the ~~International~~ *California Building Code*. The storage of finished products shall be in tanks or closed containers in accordance with Chapter 34.

## CHAPTER 21 INDUSTRIAL OVENS

**2101.1 Scope.** This chapter shall apply to the installation and operation of industrial ovens and furnaces. Industrial ovens and furnaces shall comply with the applicable provisions of NFPA 86, ~~the International Fuel Gas Code,~~ ~~International~~ *California Mechanical Code* and this chapter. The terms “ovens” and “furnaces” are used interchangeably in this chapter.

**2103.1 Ventilation.** Enclosed rooms or basements containing industrial ovens or furnaces shall be provided with combustion air in accordance with the ~~International~~ *California Mechanical Code* and the ~~International Fuel Gas Code,~~ and with ventilation air in accordance with the ~~International~~ *California Mechanical Code*.

**2104.1 Fuel-gas piping.** Fuel-gas piping serving industrial ovens shall comply with the ~~International Fuel Gas~~ *California Mechanical Code*. Piping for other fuel sources shall comply with this section.

**2104.2 Shutoff valves.** Each industrial oven or furnace shall be provided with an approved manual fuel shutoff valve in accordance with the ~~International~~ *California Mechanical Code* or the ~~International Fuel Gas Code~~.

**2106.3 Fire extinguishers.** Portable fire extinguishers complying with Section 906 shall be provided not closer than 15 feet (4572 mm) or a maximum of 50 feet (15 240 mm) ~~or in accordance with NFPA 10~~. This shall apply to the oven and related equipment.

## CHAPTER 22 MOTOR FUEL-DISPENSING FACILITIES AND REPAIR GARAGES

**2201.1 Scope.** Automotive motor fuel-dispensing facilities, marine motor fuel-dispensing facilities, fleet vehicle motor fuel-dispensing facilities, aircraft motor-vehicle fuel-dispensing facilities and repair garages shall be in accordance with this chapter and ~~International~~ *California Building Code*, ~~International Fuel Gas Code~~ *California Plumbing Code* and the ~~International~~ *California Mechanical Code*. Such operations shall include both those that are accessible to the public and private operations.

**2201.4 Indoor motor fuel-dispensing facilities.** Motor fuel-dispensing facilities located inside buildings shall comply with the ~~International~~ *California Building Code* and NFPA 30A.

**2201.5 Electrical.** Electrical wiring and equipment shall be suitable for the locations in which they are installed and shall comply with Section 605, NFPA 30A and ~~NFPA 70~~ *California Electrical Code*.

**2201.6 Heat-producing appliances.** Heat-producing appliances shall be suitable for the locations in which they are installed and shall comply with NFPA 30A and the ~~International Fuel Gas Code~~ *California Plumbing Code* or the ~~International~~ *California Mechanical Code*.

**2203.1 Location of dispensing devices.** Dispensing devices shall be located as follows:

1. Ten feet (3048 mm) or more from lot lines.
2. Ten feet (3048 mm) or more from buildings having combustible exterior wall surfaces or buildings having noncombustible exterior wall surfaces that are not part of a 1-hour fire-resistance-rated assembly or buildings having combustible overhangs.

**Exception:** Canopies constructed in accordance with the ~~International~~ California Building Code providing weather protection for the fuel islands.

3. Such that all portions of the vehicle being fueled will be on the premises of the motor fuel-dispensing facility.
4. Such that the nozzle, when the hose is fully extended, will not reach within 5 feet (1524 mm) of building openings.
5. Twenty feet (6096 mm) or more from fixed sources of ignition.

**2203.1.1 Protection of dispensing devices** of Where dispensing devices are mounted at grade, they shall be protected at each end with a minimum of two concrete filled steel posts, 6 inches (152mm) in diameter, having a minimum 3 feet (914 mm) deep footing not less than 15 inches (381 mm) in diameter and projecting above grade at a minimum of 3 feet (914 mm) and be located not less than 4 feet (1219 mm) nor more than 5 feet (1524 mm) from fuel dispensers or point-of-sale devices, or equivalent means approved by the chief.

**2205.4 Sources of ignition.** Smoking and open flames shall be prohibited in areas where fuel is dispensed. The engines of vehicles being fueled shall be shut off during fueling. Electrical equipment shall be in accordance with the ~~NFPA 70~~ California Electrical Code.

**2206.7.6 Fuel delivery nozzles.** A listed automatic-closing-type hose nozzle valve with ~~or without~~ a latch-open device shall be provided on island-type dispensers used for dispensing Class I, II or IIIA liquids.

Overhead-type dispensing units shall be provided with a listed automatic-closing-type hose nozzle valve ~~without~~ a latch-open device. *The design of the system shall be such that the hose nozzle valve will close automatically in the event the valve is released from a fill opening or upon impact with a driveway.*

~~**Exception:** A listed automatic closing type hose nozzle valve with latch open device is allowed to be used on overhead type dispensing units where the design of the system is such that the hose nozzle valve will close automatically in the event the valve is released from a fill opening or upon impact with a driveway.~~

*Any latch-open device determined to be inoperative by the fire code official shall be repaired or replaced, within 48 hours after notification.*

**2208.3 Location of dispensing operations and equipment.** Compression, storage and dispensing equipment shall be located above ground, outside.

**Exceptions:**

1. Compression, storage or dispensing equipment shall be allowed in buildings of noncombustible construction, as set forth in the ~~International~~ California Building Code, which are unenclosed for three quarters or more of the perimeter.
2. Compression, storage and dispensing equipment shall be allowed indoors or in vaults in accordance with Chapter 30.

**2208.3.1 Location on property.** In addition to the requirements of Section 2203.1, compression, storage and dispensing equipment not located in vaults complying with Chapter 30 shall be installed as follows:

1. Not beneath power lines.
2. Ten feet (3048 mm) or more from the nearest building or lot line that could be built on, public street, sidewalk or source of ignition.

**Exception:** Dispensing equipment need not be separated from canopies that are constructed in accordance with the ~~International~~ California Building Code and that provide weather protection for the dispensing equipment.

3. Twenty-five feet (7620 mm) or more from the nearest rail of any railroad track and 50 feet (15 240 mm) or more from the nearest rail of any railroad main track or any railroad or transit line where power for train propulsion is provided by an outside electrical source, such as third rail or overhead catenary.
4. Fifty feet (15 240 mm) or more from the vertical plane below the nearest overhead wire of a trolley bus line.

**2208.8.1.2.4 Grounding and bonding.** The structure or appurtenance used for supporting the cylinder shall be grounded in accordance with the ~~NFPA 70~~ *California Electrical Code*. The cylinder valve shall be bonded prior to the commencement of venting operations.

**2209.2.3 Electrical equipment.** Electrical installations shall be in accordance with the ~~NFPA 70~~ *California Electrical Code*.

**TABLE 2209.3.1** (footnotes)

For SI: 1 foot = 304.8 mm. 1 cubic foot = 0.02832m<sup>3</sup>.

- a. The applicability of tabular distance is in terms of a radius that defines a hemisphere from the source when not interrupted by an intervening fire barrier without through penetrations.
- b. See Section 2209.3.1.1.
- c. The dispenser and point of transfer for dispensing need not be separated from canopies constructed in accordance with Section 406.5 of the ~~International~~ *California Building Code* and constructed in a manner that prevents the accumulation of hydrogen gas.
- d. Measured along the natural and unobstructed line of travel (e.g., around protective walls, around corners of buildings).
- e. Ignition sources include appliance burner igniters, hotwork and hot surfaces capable of igniting flammable vapors.

**2209.3.2.3 Indoors.** Generation, compression, storage and dispensing equipment shall be located in indoor rooms or areas constructed in accordance with the requirements of the ~~International~~ *California Building Code*, the ~~International Fuel Gas Code~~ and the ~~International~~ *California Mechanical Code* and one of the following:

1. Inside a building in a hydrogen cutoff room designed and constructed in accordance with Section 420 of the ~~International~~ *California Building Code*.
2. Inside a building not in a hydrogen cutoff room where the gaseous hydrogen system is listed and labeled for indoor installation and installed in accordance with the manufacturer's installation instructions.
3. Inside a building in a dedicated hydrogen fuel dispensing area having an aggregate hydrogen delivery capacity no greater than 12 standard cubic feet per minute (SCFM) and designed and constructed in accordance with Section 703.1 of the ~~International Fuel Gas Code~~ *California Mechanical Code*.

**2209.3.2.6 Canopy tops.** Gaseous hydrogen compression and storage equipment located on top of motorfuel-dispensing facility canopies shall be in accordance with Sections 2209.3.2.6.1 through 2209.3.2.6.3, Chapters 30 and 35 and the ~~International Fuel Gas Code~~ *California Mechanical Code*.

**2209.3.2.6.1 Construction.** Canopies shall be constructed in accordance with the motor fuel-dispensing facility canopy requirements of Section 406 of the ~~International~~ *California Building Code*.

**2209.3.3 Canopies.** Dispensing equipment need not be separated from canopies of Type I or II construction that are constructed in a manner that prevents the accumulation of hydrogen gas and in accordance with Section 406.5 of the ~~International~~ *California Building Code*.

**2210.1 General.** The construction of marine motor fuel-dispensing facilities shall be in accordance with the ~~International~~ *Building Code* and NFPA30A. The storage of Class I, II or IIIA liquids at marine motor fuel-dispensing facilities shall be in accordance with this chapter and Chapter 34.

**2211.1 General.** Repair garages shall comply with this section and the ~~International~~ *California Building Code*. Repair garages for vehicles that use more than one type of fuel shall comply with the applicable provisions of this section for each type of fuel used. Where a repair garage also includes a motor fuel-dispensing facility, the fuel-dispensing operation shall comply with the requirements of this chapter for motor fuel-dispensing facilities.

**2211.2.3 Drainage and disposal of liquids and oil-soaked waste.** Garage floor drains, where provided, shall drain to approved oil separators or traps discharging to a sewer in accordance with the *International California Plumbing Code*. Contents of oil separators, traps and floor drainage systems shall be collected at sufficiently frequent intervals and removed from the premises to prevent oil from being carried into the sewers

**2211.3.1 Equipment.** Appliances and equipment installed in a repair garage shall comply with the provisions of the *International California Building Code*, the *International California Mechanical Code* and the *NFPA 70-California Electrical Code*.

**2211.4.1 Construction.** Pits and below-grade work areas shall be constructed in accordance with the *International Building Code*.

**2211.4.3 Ventilation.** Where Class I liquids or LP-gas are stored or used within a building having a basement or pit wherein flammable vapors could accumulate, the basement or pit shall be provided with mechanical ventilation in accordance with the *International California Mechanical Code*, at a minimum rate of 1.5 cubic feet per minute per square foot (cfm/ft<sup>2</sup>) [0.008 m<sup>3</sup>/(s ⊕ m<sup>2</sup>)] to prevent the accumulation of flammable vapors.

**2211.7.1 Ventilation.** Repair garages used for the repair of natural gas- or hydrogen-fueled vehicles shall be provided with an approved mechanical ventilation system. The mechanical ventilation system shall be in accordance with the *International California Mechanical Code* and Sections 2211.7.1.1 and 2211.7.1.2.

**Exception:** Repair garages with natural ventilation when approved.

**2211.8.1.2.3 Stability of cylinders, containers and tanks.** A method of rigidly supporting cylinders, containers or tanks used during the closed transfer system discharge or defueling of hydrogen shall be provided. The method shall provide not less than two points of support and shall be designed to resist lateral movement of the receiving cylinder, container or tank. The system shall be designed to resist movement of the receiver based on the highest gas-release velocity through valve orifices at the receiver's rated service pressure and volume. Supporting structure or appurtenance used to support receivers shall be constructed of noncombustible materials in accordance with the *International California Building Code*.

**2211.8.1.2.4 Grounding and bonding.** Cylinders, containers or tanks and piping systems used for defueling shall be bonded and grounded. Structures or appurtenances used for supporting the cylinders, containers or tanks shall be grounded in accordance with the *NFPA 70-California Electrical Code*. The valve of the vehicle storage tank shall be bonded with the defueling system prior to the commencement of discharge or defueling operations.

## CHAPTER 23 HIGH-PILED COMBUSTIBLE STORAGE

**2301.3 Construction documents.** At the time of building permit application for new structures designed to accommodate high-piled storage or for requesting a change of occupancy/use, and at the time of application for a storage permit, plans and specifications shall be submitted for review and approval. In addition to the information required by the *International California Building Code*, the storage permit submittal shall include the information specified in this section. Following approval of the plans, a copy of the approved plans shall be maintained on the premises in an approved location. The plans shall include the following:

1. Floor plan of the building showing locations and dimensions of high-piled storage areas.
2. Usable storage height for each storage area.
3. Number of tiers within each rack, if applicable.
4. Commodity clearance between top of storage and the sprinkler deflector for each storage arrangement.
5. Aisle dimensions between each storage array.
6. Maximum pile volume for each storage array.
7. Location and classification of commodities in accordance with Section 2303.
8. Location of commodities which are banded or encapsulated.
9. Location of required fire department access doors.

10. Type of fire suppression and fire detection systems.
11. Location of valves controlling the water supply of ceiling and in-rack sprinklers.
12. Type, location and specifications of smoke removal and curtain board systems
13. Dimension and location of transverse and longitudinal flue spaces.
14. Additional information regarding required design features, commodities, storage arrangement and fire protection features within the high-piled storage area shall be provided at the time of permit, when required by the fire code official.

**TABLE 2306.2** (footnotes)

For SI: 1 foot = 304.8 mm, 1 cubic foot = 0.02832m<sup>3</sup>, 1 square foot = 0.0929m<sup>2</sup>.

- a. When automatic sprinklers are required for reasons other than those in Chapter 23, the portion of the sprinkler system protecting the high-piled storage area shall be designed and installed in accordance with Sections 2307 and 2308.
- b. For aisles, see Section 2306.9.
- c. Piles shall be separated by aisles complying with Section 2306.9.
- d. For storage in excess of the height indicated, special fire protection shall be provided in accordance with Note g when required by the fire code official. See also Chapters 28 and 34 for special limitations for aerosols and flammable and combustible liquids, respectively.
- e. Section 503 shall apply for fire apparatus access.
- f. For storage exceeding 30 feet in height, Option 1 shall be used.
- g. Special fire protection provisions including, but not limited to, fire protection of exposed steel columns; increased sprinkler density; additional in-rack sprinklers, without associated reductions in ceiling sprinkler density; or additional fire department hose connections shall be provided when required by the fire code official.
- h. High-piled storage areas shall not exceed 500,000 square feet. A 2-hour fire wall constructed in accordance with the ~~International~~ *California Building Code* shall be used to divide high-piled storage exceeding 500,000 square feet in area.
- i. Not required when an automatic fire-extinguishing system is designed and installed to protect the high-piled storage area in accordance with Sections 2308 and 2308.
- j. Not required when storage areas are protected by early suppression fast response (ESFR) sprinkler systems installed in accordance with NFPA 13. *This footnote shall not apply to any state institution or other state-owned or state-occupied buildings or other applications listed in Section 441.11 regulated by the Office of the State Fire Marshal.*

**2306.3.1 Separation from other uses.** Mixed occupancies shall be separated in accordance with the ~~International~~ *California Building Code*.

**2306.3.2.1 Aggregate area.** The aggregate of all high-piled storage areas within a building shall be used for the application of Table 2306.2 unless such areas are separated from each other by 1-hour fire barrier walls constructed in accordance with the ~~International~~ *California Building Code*. Openings in such walls shall be protected by opening protective assemblies having a 1-hour fire protection rating.

**2306.3.2.2 Multiclass high-piled storage areas.** High-piled storage areas classified as Class I through IV not separated from high-piled storage areas classified as high hazard shall utilize the aggregate of all high-piled storage areas as high hazard for the purposes of the application of Table 2306.2. To be considered as separated, 1-hour fire barrier walls shall be constructed in accordance with the ~~International~~ *California Building Code*. Openings in such walls shall be protected by opening protective assemblies having a 1-hour fire protection rating.

**Exception:** As provided for in Section 2304.2.

**2306.8 Fire department hose connections.** Where exit passageways are required by the ~~International~~ *California Building Code* for egress, a Class I standpipe system shall be provided in accordance with Section 905.

**2307.2 Fire protection.** Where automatic sprinklers are required by Table 2306.2, an approved automatic sprinkler system shall be installed throughout the building or to 1-hour fire barrier walls constructed in accordance with the

~~International~~ California Building Code. Openings in such walls shall be protected by opening protective assemblies having 1-hour fire protection ratings. The design and installation of the automatic sprinkler system and other applicable fire protection shall be in accordance with the ~~International~~ California Building Code and NFPA 13.

**2308.2 Fire protection.** Where automatic sprinklers are required by Table 2306.2, an approved automatic sprinkler system shall be installed throughout the building or to 1-hour fire barrier walls constructed in accordance with the ~~International~~ California Building Code. Openings in such walls shall be protected by opening protective assemblies having 1-hour fire protection ratings. The design and installation of the automatic sprinkler system and other applicable fire protection shall be in accordance with Section 903.3.1.1 and the ~~International~~ California Building Code.

## CHAPTER 24 TENTS, CANOPIES AND OTHER MEMBRANE STRUCTURES

**2403.12.6.1 Exit sign illumination.** Exit signs shall be of an approved self-luminous type or shall be internally or externally illuminated by luminaires supplied in the following manner:

1. Two separate circuits, one of which shall be separate from all other circuits, for occupant loads of 300 or less; or
2. Two separate sources of power, one of which shall be an approved emergency system, shall be provided when the occupant load exceeds 300. Emergency systems shall be supplied from storage batteries or from the on-site generator set, and the system shall be installed in accordance with the ~~NFPA 70-California~~ Electrical Code.

**2404.1 General.** All tents, canopies and membrane structures, both temporary and permanent, shall be in accordance with this section. Permanent tents, canopies and membrane structures shall also comply with the ~~International~~ California Building Code.

**2404.15.1 Installation.** Heating or cooking equipment, tanks, piping, hoses, fittings, valves, tubing and other related components shall be installed as specified in the ~~International~~ California Mechanical Code and the ~~International Fuel Gas Code~~, and shall be approved by the fire code official.

**2404.15.2 Venting.** Gas, liquid and solid fuel-burning equipment designed to be vented shall be vented to the outside air as specified in the ~~International Fuel Gas Code~~ and the ~~International~~ California Mechanical Code. Such vents shall be equipped with approved spark arresters when required. Where vents or flues are used, all portions of the tent, canopy or membrane structure shall be not less than 12 inches (305 mm) from the flue or vent.

**2404.15.7 Electrical heating and cooking equipment.** Electrical cooking and heating equipment shall comply with the ~~NFPA 70-California~~ Electrical Code.

**2404.16.1 General.** LP-gas equipment such as tanks, piping, hoses, fittings, valves, tubing and other related components shall be approved and in accordance with Chapter 38 and with the ~~International Fuel Gas~~ California Mechanical Code.

**2404.23 Obstructions.** Exits, aisles and passageways shall not be blocked or have their minimum clear width obstructed in any manner by ticket offices, turnstiles, concessions, chairs, equipment, animal chutes, poles or guy ropes, or anything whatsoever, nor shall they be blocked by persons for whom no seats are available.

*In occupancies having fixed seating, and on request of the owner or manager, the enforcing agency may permit modifications from the provisions of this code to accommodate seating for handicapped persons using mechanical aids such as, but not limited to, walkers and wheelchairs.*

## CHAPTER 26 WELDING AND OTHER HOT WORK

**2606.4 Emergency disconnect.** A switch or circuit breaker shall be provided so that fixed electric welders and control equipment can be disconnected from the supply circuit. The disconnect shall be installed in accordance with

the ~~NEPA 70~~ California Electrical Code.

## CHAPTER 27 HAZARDOUS MATERIALS—GENERAL PROVISIONS

### Table 2703.1.1(1) footnote d:

Revise Footnote d to Table 2703.1.1(1) as follows:

#### Table 2703.1.1(1) (footnotes)

For SI: 1 cubic foot = 0.02832 m<sup>3</sup>, 1 pound = 0.454 kg, 1 gallon = 3.785 L.

- a. For use of control areas, see Section 2703.8.3.
- b. The aggregate quantity in use and storage shall not exceed the quantity listed for storage.
- c. The quantities of alcoholic beverages in retail and wholesale sales occupancies shall not be limited providing the liquids are packaged in individual containers not exceeding 1.3 gallons. In retail and wholesale sales occupancies, the quantities of medicines, foodstuffs, consumer or industrial products, and cosmetics containing not more than 50 percent by volume of water-miscible liquids with the remainder of the solutions not being flammable shall not be limited, provided that such materials are packaged in individual containers not exceeding 1.3 gallons.
- d. Maximum allowable quantities shall be increased 100 percent in buildings equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1. Where Note e also applies, the increase for both notes shall be applied accumulatively.
- e. Maximum allowable quantities shall be increased 100 percent when stored in approved storage cabinets, day boxes, gas cabinets, exhausted enclosures, or listed safety cans. Listed safety cans shall be in accordance with Section 2703.9.10. Where Note d also applies, the increase for both notes shall be applied accumulatively.
- f. Quantities shall not be limited in a building equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1.
- g. Allowed only in buildings equipped throughout with an approved automatic sprinkler system.
- h. Containing not more than the maximum allowable quantity per control area of Class IA, Class IB or Class IC flammable liquids.
- i. The maximum allowable quantity shall not apply to fuel oil storage complying with Section 603.3.2.
- j. Quantities in parenthesis indicate quantity units in parenthesis at the head of each column.
- k. A maximum quantity of 200 pounds of solid or 20 gallons of liquid Class 3 oxidizers is allowed when such materials are necessary for maintenance purposes, operation or sanitation of equipment when the storage containers and the manner of storage are approved.
- l. Net weight of pyrotechnic composition of the fireworks. Where the net weight of the pyrotechnic composition of the fireworks is not known, 25 percent of the gross weight of the fireworks including packaging shall be used.
- m. For gallons of liquids, divide the amount in pounds by 10 in accordance with Section 2703.1.2.
- n. For storage and display quantities in Group M and storage quantities in Group S occupancies complying with Section 2703.11, see Table 2703.11.1.
- o. Densely-packed baled cotton that complies with the packing requirements of ISO 8115 shall not be included in this material class.
- p. The following shall not be included in determining the maximum allowable quantities:
  1. Liquid or gaseous fuel in fuel tanks on vehicles.
  2. Liquid or gaseous fuel in fuel tanks on motorized equipment operated in accordance with this code.
  3. Gaseous fuels in piping systems and fixed appliances regulated by the ~~International Fuel Gas California Mechanical Code~~.
  4. Liquid fuels in piping systems and fixed appliances, regulated by the ~~International Fuel Gas California Mechanical Code~~.

### TABLE 2703.1.1(2) footnote e:

Revise Footnote e to Table 2703.1.1(2) as follows:

#### Table 2703.1.1(2) (footnotes)

For SI: 1 cubic foot = 0.02832 m<sup>3</sup>, 1 pound = 0.454 kg, 1 gallon = 3.785 L.

- a. For use of control areas, see Section 2703.8.3.

- b. In retail and wholesale sales occupancies, the quantities of medicines, foodstuffs, consumer or industrial products, and cosmetics, containing not more than 50 percent by volume of water-miscible liquids and with the remainder of the solutions not being flammable, shall not be limited, provided that such materials are packaged in individual containers not exceeding 1.3 gallons.
- c. For storage and display quantities in Group M and storage quantities in Group S occupancies complying with Section 2703.11, see Table 2703.11.1.
- d. The aggregate quantity in use and storage shall not exceed the quantity listed for storage.
- e. Maximum allowable quantities shall be increased 100 percent in buildings equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1. Where Note f also applies, the increase for both notes shall be applied accumulatively. *This footnote shall not be applicable to Group L Occupancies.*
- f. Maximum allowable quantities shall be increased 100 percent when stored in approved storage cabinets, gas cabinets or exhausted enclosures. Where Note e also applies, the increase for both notes shall be applied accumulatively.
- g. Allowed only when stored in approved exhausted gas cabinets or exhausted enclosures.
- h. Quantities in parentheses indicate quantity units in parentheses at the head of each column.
- i. For gallons of liquids, divide the amount in pounds by 10 in accordance with Section 2703.1.2.

**2703.2.2.2 Additional regulations for supply piping for health-hazard materials.** Supply piping and tubing for gases and liquids having a health-hazard ranking of 3 or 4 in accordance with NFPA704 shall be in accordance with ASME B31.3 and the following:

1. Piping and tubing utilized for the transmission of highly toxic, toxic or highly volatile corrosive liquids and gases shall have welded, threaded or flanged connections throughout except for connections located within a ventilated enclosure if the material is a gas, or an approved method of drainage or containment is provided for connections if the material is a liquid.
2. Piping and tubing shall not be located within corridors, within any portion of a means of egress required to be enclosed in fire-resistance-rated construction or in concealed spaces in areas not classified as Group H occupancies.

**Exception:** Piping and tubing within the space defined by the walls of corridors and the floor or roof above or in concealed spaces above other occupancies when installed in accordance with Section 415.8.6.3 of the ~~International~~ California Building Code for Group H-5 occupancies.

**2703.2.8 Seismic protection.** Machinery and equipment utilizing hazardous materials shall be braced and anchored in accordance with the seismic design requirements of the ~~International~~ California Building Code for the seismic design category in which the machinery or equipment is classified.

**2703.7.3 Industrial trucks.** Powered industrial trucks used in areas designated as hazardous (classified) locations in accordance with the ~~NFPA-70~~ California Electrical Code shall be listed and labeled for use in the environment intended in accordance with NFPA 505.

**2703.8.1 Buildings.** Buildings, or portions thereof, in which hazardous materials are stored, handled or used shall be constructed in accordance with the ~~International~~ California Building Code.

**Table 2703.8.2** (footnotes)

For SI: 1 pound = 0.454 kg, 1 cubic foot = 0.02832m<sup>3</sup>, 1 ton = 2000 lbs. = 907.2 kg.

- a. For materials which are detonable, the distance to other buildings or lot lines shall be as specified in the ~~International~~ California Building Code. For materials classified as explosives, the required separation distances shall be as specified in Chapter 33.
- b. "Maximum Allowable Quantity" means the maximum allowable quantity per control area set forth in Table 2703.1.1(1).
- c. Limited to Division 1.4 materials and articles, including articles packaged for shipment, that are not regulated as an explosive under Bureau of Alcohol, Tobacco and Firearms regulations, or unpackaged articles used in process operations that do not propagate a detonation or deflagration between articles, providing the net explosive weight of individual articles does not exceed 1 pound.

**2703.8.3.1 Construction requirements.** Control areas shall be separated from each other by fire barriers constructed in accordance with Section 707 of the ~~International~~ *California Building Code* or horizontal assemblies constructed in accordance with Section 712 of the ~~International~~ *California Building Code*, or both.

**2703.8.4.1 Construction.** Gas rooms shall be protected with an automatic sprinkler system. Gas rooms shall be separated from the remainder of the building in accordance with the requirements of the ~~International~~ *California Building Code* based on the occupancy group into which it has been classified.

**2703.8.4.2 Ventilation system.** The ventilation system for gas rooms shall be designed to operate at a negative pressure in relation to the surrounding area. Highly toxic and toxic gases shall also comply with Section 3704.2.2.6. The ventilation system shall be installed in accordance with the ~~International~~ *California Mechanical Code*.

**2703.8.5.2 Ventilation.** The ventilation system for exhausted enclosures shall be designed to operate at a negative pressure in relation to the surrounding area. Ventilation systems used for highly toxic and toxic gases shall also comply with Items 1, 2 and 3 of Section 3704.1.2. The ventilation system shall be installed in accordance with the ~~International~~ *California Mechanical Code*.

**2703.8.6.2 Ventilation.** The ventilation system for gas cabinets shall be designed to operate at a negative pressure in relation to the surrounding area. Ventilation systems used for highly toxic and toxic gases shall also comply with Items 1, 2 and 3 of Section 3704.1.2. The ventilation system shall be installed in accordance with the ~~International~~ *California Mechanical Code*.

**2703.8.7.1 Construction.** The interior of cabinets shall be treated, coated or constructed of materials that are nonreactive with the hazardous material stored. Such treatment, coating or construction shall include the entire interior of the cabinet. Cabinets shall either be listed in accordance with UL 1275 as suitable for the intended storage or constructed in accordance with the following:

1. Cabinets shall be of steel having a thickness of not less than 0.0478 inch (1.2 mm) (No. 18 gage). The cabinet, including the door, shall be double walled with a 1.5-inch (38 mm) airspace between the walls. Joints shall be riveted or welded and shall be tight fitting. Doors shall be well fitted, self-closing and equipped with a self-latching device.
2. The bottoms of cabinets utilized for the storage of liquids shall be liquid tight to a minimum height of 2 inches (51 mm).

Electrical equipment and devices within cabinets used for the storage of hazardous gases or liquids shall be in accordance with the ~~NEPA-70~~ *California Electrical Code*.

**2703.9.4 Electrical wiring and equipment.** Electrical wiring and equipment shall be installed and maintained in accordance with the ~~NEPA-70~~ *California Electrical Code*.

**2703.9.9 Shelf storage.** Shelving shall be of substantial construction, and shall be braced and anchored in accordance with the seismic design requirements of the ~~International~~ *California Building Code* for the seismic zone in which the material is located. Shelving shall be treated, coated or constructed of materials that are compatible with the hazardous materials stored. Shelves shall be provided with a lip or guard when used for the storage of individual containers.

**Exceptions:**

1. Storage in hazardous material storage cabinets or laboratory furniture specifically designed for such use.
2. Storage of hazardous materials in amounts not requiring a permit in accordance with Section 2701.5.

Shelf storage of hazardous materials shall be maintained in an orderly manner.

**2704.2.2.6 Drainage system design.** Drainage systems shall be in accordance with the ~~International~~ *California Plumbing Code* and all of the following:

1. The slope of floors to drains in indoor locations, or similar areas in outdoor locations shall not be less than 1

- percent.
2. Drains from indoor storage areas shall be sized to carry the volume of the fire protection water as determined by the design density discharged from the automatic fire-extinguishing system over the minimum required system design area or area of the room or area in which the storage is located, whichever is smaller.
  3. Drains from outdoor storage areas shall be sized to carry the volume of the fire flow and the volume of a 24-hour rainfall as determined by a 25-year storm.
  4. Materials of construction for drainage systems shall be compatible with the materials stored.
  5. Incompatible materials used in open systems shall be separated from each other in the drainage system.
  6. Drains shall terminate in an approved location away from buildings, valves, means of egress, fire access roadways, adjoining property and storm drains.

**2704.3.1 System Requirements.** Exhaust ventilation systems shall comply with all of the following:

1. Installation shall be in accordance with the ~~International~~ *California Mechanical Code*.
2. Mechanical ventilation shall be at a rate of not less than 1 cubic foot per minute per square foot [0.00508 m<sup>3</sup>/(sm<sup>2</sup>)] of floor area over the storage area.
3. Systems shall operate continuously unless alternative designs are approved.
4. A manual shutoff control shall be provided outside of the room in a position adjacent to the access door to the room or in an approved location. The switch shall be a break-glass or other approved type and shall be labeled "VENTILATION SYSTEM EMERGENCY SHUTOFF".

**Exception:** *[For SFM] When exhaust systems containing explosive, corrosive, combustible, flammable or highly toxic dusts, mists, fumes, vapors, or gases are 100 percent exhausted to the outside, an emergency ventilation system shutoff is not required.*

5. Exhaust ventilation shall be designed to consider the density of the potential fumes or vapors released. For fumes or vapors that are heavier than air, exhaust shall be taken from a point within 12 inches (305 mm) of the floor. For fumes or vapors that are lighter than air, exhaust shall be taken from a point within 12 inches (305 mm) of the highest point of the room.
6. The location of both the exhaust and inlet air openings shall be designed to provide air movement across all portions of the floor or room to prevent the accumulation of vapors.
7. Exhaust air shall not be recirculated to occupied areas if the materials stored are capable of emitting hazardous vapors and contaminants have not been removed. Air-contaminated with explosive or flammable vapors, fumes, or dusts; flammable, highly toxic or toxic gases; or radioactive materials shall not be recirculated.

**2704.7 Standby or emergency power.** Where mechanical ventilation, treatment systems, temperature control, alarm, detection or other electrically operated systems are required, such systems shall be provided with an emergency or standby power system in accordance with the ~~NFPA-70~~ *California Electrical Code* and Section 604.

**Exceptions:**

1. Storage areas for Class 1 and 2 oxidizers.
2. Storage areas for Class III, IV and V organic peroxides.
3. For storage areas for highly toxic or toxic materials, see Sections 3704.2.2.8 and 3704.3.2.4.
4. Standby power for mechanical ventilation, treatment systems and temperature control systems shall not be required where an approved fail-safe engineered system is installed.

**2704.13 Weather protection.** Where overhead noncombustible construction is provided for sheltering outdoor hazardous material storage areas, such storage shall not be considered indoor storage when the area is constructed in accordance with the requirements for weather protection as required by the ~~International~~ *California Building Code*.

**Exception:** Storage of explosive materials shall be considered as indoor storage.

**2705.1.5 Standby or emergency power.** Where mechanical ventilation, treatment systems, temperature control, manual alarm, detection or other electrically operated systems are required, such systems shall be provided with an

emergency or standby power system in accordance with the ~~NFPA-70~~ *California Electrical Code* and Section 604.

**Exceptions:**

1. Standby power for mechanical ventilation, treatment systems and temperature control systems shall not be required where an approved fail-safe engineered system is installed.
2. Systems for highly toxic or toxic gases shall be provided with emergency power in accordance with Sections 3704.2.2.8 and 3704.3.4.2.

**2705.2 Indoor dispensing and use.** Indoor dispensing and use of hazardous materials shall be in buildings complying with the ~~International~~ *California Building Code* and in accordance with Section 2705.1 and Sections 2705.2.1 through 2705.2.2.4.

**2705.3.9 Weather protection.** Where overhead noncombustible construction is provided for sheltering outdoor hazardous material use areas, such use shall not be considered indoor use when the area is constructed in accordance with the requirements for weather protection as required in the ~~International~~ *California Building Code*.

**Exception:** Use of explosive materials shall be considered as indoor use.

## CHAPTER 28 AEROSOLS

**2801.1 Scope.** The provisions of this chapter, the ~~International~~ *California Building Code* and NFPA 30B shall apply to the manufacturing, storage and display of aerosol products. Manufacturing of aerosol products using hazardous materials shall also comply with Chapter 27.

## CHAPTER 29 COMBUSTIBLE FIBERS

**2903.5 Dust collection.** Where located within a building, equipment or machinery which generates or emits combustible fibers shall be provided with an approved dust-collecting and exhaust system. Such systems shall comply with ~~Chapter 13 and Section 511 of the~~ *International California Mechanical Code*.

**2904.3 Storage of more than 100 cubic feet to 500 cubic feet.** Loose combustible fibers in quantities exceeding 100 cubic feet (3 m<sup>3</sup>) but not exceeding 500 cubic feet (14 m<sup>3</sup>) shall be stored in rooms enclosed with 1-hour fire-resistance-rated fire barriers, with openings protected by an approved opening protective assembly having a fire protection rating of 3/4 hour, constructed in accordance with the ~~International~~ *California Building Code*.

**2904.4 Storage of more than 500 cubic feet to 1,000 cubic feet.** Loose combustible fibers in quantities exceeding 500 cubic feet (14 m<sup>3</sup>) but not exceeding 1,000 cubic feet (28 m<sup>3</sup>) shall be stored in rooms enclosed with 2-hour fire-resistance-rated fire barriers, with openings protected by an approved opening protective assembly having a fire protection rating of 1 1/2 hours, and constructed in accordance with the ~~International~~ *California Building Code*.

**2904.5 Storage of more than 1,000 cubic feet.** Loose combustible fibers in quantities exceeding 1,000 cubic feet (28 m<sup>3</sup>) shall be stored in rooms enclosed with 2-hour fire-resistance-rated fire barriers, with openings protected by an approved opening protective assembly having a fire protection rating of 1 1/2 hours, and constructed in accordance with the ~~International~~ *California Building Code*. The storage room shall be protected by an automatic sprinkler system installed in accordance with Section 903.3.1.1.

## CHAPTER 30 COMPRESSED GASES

**3001.1 Scope.** Storage, use and handling of compressed gases in compressed gas containers, cylinders, tanks and systems shall comply with this chapter, including those gases regulated elsewhere in this code. Partially full compressed gas containers, cylinders or tanks containing residual gases shall be considered as full for the purposes

of the controls required.

**Exceptions:**

1. Gases used as refrigerants in refrigeration systems (see Section 606).
2. Compressed natural gas (CNG) for use as a vehicular fuel shall comply with Chapter 22, NFPA 52 and the ~~International Fuel Gas~~ *California Mechanical Code*.

Cutting and welding gases shall also comply with Chapter 26.

Cryogenic fluids shall also comply with Chapter 32. Liquefied natural gas for use as a vehicular fuel shall also comply with NFPA 57 and NFPA 59A.

Compressed gases classified as hazardous materials shall also comply with Chapter 27 for general requirements and chapters addressing specific hazards, including Chapters 35 (Flammable Gases), 37 (Highly Toxic and Toxic Materials), 40 (Oxidizers) and 41 (Pyrophoric).

LP-gas shall also comply with Chapter 38 and the ~~International Fuel Gas~~ *California Mechanical Code*.

**3003.7.6 Heating.** Compressed gas containers, cylinders and tanks, whether full or partially full, shall not be heated by devices which could raise the surface temperature of the container, cylinder or tank to above 125°F (52°C). Heating devices shall comply with the ~~International~~ *California Mechanical Code* and the ~~NFPA-70~~ *California Electrical Code*. Approved heating methods involving temperatures of less than 125°F (52°C) are allowed to be used by trained personnel. Devices designed to maintain individual compressed gas containers, cylinders or tanks at constant temperature shall be approved and shall be designed to be fail safe.

**3003.8 Wiring and equipment.** Electrical wiring and equipment shall comply with the ~~NFPA-70~~ *California Electrical Code*. Compressed gas containers, cylinders, tanks and systems shall not be located where they could become part of an electrical circuit. Compressed gas containers, cylinders, tanks and systems shall not be used for electrical grounding.

**3003.16.1 Listing required.** Vaults shall be listed by a nationally recognized testing laboratory.

**Exception:** Where approved by the fire code official, below-grade vaults are allowed to be constructed on site, provided that the design is in accordance with the ~~International~~ *California Building Code* and that special inspections are conducted to verify structural strength and compliance of the installation with the approved design in accordance with Section 1707 of the ~~International~~ *California Building Code*. Installation plans for below-grade vaults that are constructed on site shall be prepared by, and the design shall bear the stamp of, a professional engineer. Consideration shall be given to soil and hydrostatic loading on the floors, walls and lid; anticipated seismic forces; uplifting by ground water or flooding; and to loads imposed from above, such as traffic and equipment loading on the vault lid.

**3003.16.2 Design and construction.** The vault shall completely enclose generation, compression, storage or dispensing equipment located in the vault. There shall be no openings in the vault enclosure except those necessary for vault ventilation and access, inspection, filling, emptying or venting of equipment in the vault. The walls and floor of the vault shall be constructed of reinforced concrete at least 6 inches (152 mm) thick. The top of an above-grade vault shall be constructed of noncombustible material and shall be designed to be weaker than the walls of the vault to ensure that the thrust of any explosion occurring inside the vault is directed upward.

The top of an at- or below-grade vault shall be designed to relieve safely or contain the force of an explosion occurring inside the vault. The top and floor of the vault and the tank foundation shall be designed to withstand the anticipated loading, including loading from vehicular traffic, where applicable. The walls and floor of a vault installed below grade shall be designed to withstand anticipated soil and hydrostatic loading. Vaults shall be designed to be wind and earthquake resistant, in accordance with the ~~International~~ *California Building Code*.

**3003.16.9 Ventilation.** Vaults shall be provided with an exhaust ventilation system installed in accordance with Section 2704.3. The ventilation system shall operate continuously or be designed to operate upon activation of the

vapor or liquid detection system. The system shall provide ventilation at a rate of not less than 1 cubic foot per minute (cfm) per square foot of floor area [0.00508 m<sup>3</sup>/(s ⊕ m<sup>2</sup>)], but not less than 150 cfm [0.071 m<sup>3</sup>/(s ⊕ m<sup>2</sup>)]. The exhaust system shall be designed to provide air movement across all parts of the vault floor for gases having a density greater than air and across all parts of the vault ceiling for gases having a density less than air. Supply ducts shall extend to within 3 inches (76 mm), but not more than 12 inches (305 mm), of the floor. Exhaust ducts shall extend to within 3 inches (76 mm), but not more than 12 inches (305 mm) of the floor or ceiling, for heavier-than-air or lighter-than-air gases, respectively. The exhaust system shall be installed in accordance with the ~~International~~ *California Mechanical Code*.

**3003.16.11 Liquid removal.** Means shall be provided to recover liquid from the vault. Where a pump is used to meet this requirement, it shall not be permanently installed in the vault. Electric-powered portable pumps shall be suitable for use in Class I, Division 1 locations, as defined in the ~~NFPA-70~~ *California Electrical Code*.

**3003.16.14 Classified area.** The interior of a vault containing a flammable gas shall be designated a Class I, Division 1 location, as defined in the ~~NFPA-70~~ *California Electrical Code*.

**3005.5 Venting.** Venting of gases shall be directed to an approved location. Venting shall comply with the ~~International~~ *California Mechanical Code*.

**3006.2.2 One-hour interior room.** When an exterior wall cannot be provided for the room, automatic sprinklers shall be installed within the room. The room shall be exhausted through a duct to the exterior. Supply and exhaust ducts shall be enclosed in a 1-hour-rated shaft enclosure from the room to the exterior. Approved mechanical ventilation shall comply with the ~~International~~ *California Mechanical Code* and be provided at a minimum rate of 1 cubic foot per minute per square foot [0.00508 m<sup>3</sup>/(s ⊕ m<sup>2</sup>)] of the area of the room.

## CHAPTER 31 CORROSIVE MATERIALS

**3104.2.1 Above-ground outside storage tanks.** ~~When required by Section 2704.2.2 above-ground outside storage tanks exceeding an aggregate quantity of 1,000 gallons (3785 L) of corrosive liquids shall be provided with secondary containment in accordance with Section 2704.2.2.~~

## CHAPTER 32 CRYOGENIC FLUIDS

**3203.1.2 Concrete containers.** Concrete containers shall be built in accordance with the ~~International~~ *California Building Code*. Barrier materials and membranes used in connection with concrete, but not functioning structurally, shall be compatible with the materials contained.

**3203.5.2 Securing of containers.** Stationary containers shall be secured to foundations in accordance with the ~~International~~ *California Building Code*. Portable containers subject to shifting or upset shall be secured. Nesting shall be an acceptable means of securing containers.

**3203.7 Electrical wiring and equipment.** Electrical wiring and equipment shall comply with the ~~NFPA-70~~ *California Electrical Code* and Sections 3203.7.1 and 3203.7.2.

**3203.7.2 Electrical grounding and bonding.** Containers and systems shall not be used for electrical grounding. When electrical grounding and bonding is required, the system shall comply with the ~~NFPA-70~~ *California Electrical Code*. The grounding system shall be protected against corrosion, including corrosion caused by stray electric currents.

**3204.2.1.2 Construction of indoor areas.** Cryogenic fluids in stationary containers stored indoors shall be located in buildings, rooms or areas constructed in accordance with the ~~International~~ *California Building Code*.

**3204.2.1.3 Ventilation.** Storage areas for stationary containers shall be ventilated in accordance with the ~~International~~ *California Mechanical Code*.

**3204.2.2.2 Construction of indoor areas.** Cryogenic fluids in portable containers stored indoors shall be stored in buildings, rooms or areas constructed in accordance with the ~~International~~ *California Building Code*.

**3204.2.2.3 Ventilation.** Storage areas shall be ventilated in accordance with the ~~International~~ *California Mechanical Code*.

**3205.4.1 Dispensing areas.** Dispensing of cryogenic fluids with physical or health hazards shall be conducted in approved locations. Dispensing indoors shall be conducted in areas constructed in accordance with the ~~International~~ *California Building Code*.

**3205.4.1.1 Ventilation.** Indoor areas where cryogenic fluids are dispensed shall be ventilated in accordance with the requirements of the ~~International~~ *California Mechanical Code* in a manner that captures any vapor at the point of generation.

**Exception:** Cryogenic fluids that can be demonstrated not to create harmful vapors.

## CHAPTER 33 EXPLOSIVES AND FIREWORKS

### SECTION 3301 GENERAL

**3301.1 Scope.** ~~The provisions of this chapter shall govern the possession, manufacture, storage, handling, sale and use of explosives, explosive materials, fireworks and small arms ammunition. For explosives requirements see Title 19 California Code of Regulations, Title 19, Division 1, Chapter 10. For fireworks requirements see Title 19 California Code of Regulations, Title 19, Division 1, Chapter 6.~~

**Exceptions:**

1. The Armed Forces of the United States, Coast Guard or National Guard.
2. Explosives in forms prescribed by the official United States Pharmacopoeia.
3. The possession, storage and use of small arms ammunition when packaged in accordance with DOTn packaging requirements.
4. ~~The possession, storage, and use of not more than 1 pound (0.454 kg) of commercially manufactured sporting black powder, 20 pounds (9 kg) of smokeless powder and 10,000 small arms primers for hand loading of small arms ammunition for personal consumption.~~
- 5 4. The use of explosive materials by federal, state and local regulatory, law enforcement and fire agencies acting in their official capacities.
6. ~~Special industrial explosive devices which in the aggregate contain less than 50 pounds (23 kg) of explosive materials.~~
7. ~~The possession, storage and use of blank industrial power load cartridges when packaged in accordance with DOTn packaging regulations.~~
8. ~~Transportation in accordance with DOTn 49 CFR Parts 100-178.~~
- 9 5. Items preempted by federal regulations.

**3301.1.1 Explosive material standard.** ~~In addition to the requirements of this chapter, NFPA 495 shall govern the manufacture, transportation, storage, sale, handling and use of explosive materials.~~

**3301.1.2 Explosive material terminals.** ~~In addition to the requirements of this chapter, the operation of explosive material terminals shall conform to the provisions of NFPA 498.~~

**3301.1.3 Fireworks.** ~~The possession, manufacture, storage, sale, handling and use of fireworks are prohibited.~~

**Exceptions:**

1. ~~Storage and handling of fireworks as allowed in Section 3304.~~
2. ~~Manufacture, assembly and testing of fireworks as allowed in Section 3305.~~

~~3. The use of fireworks for display as allowed in Section 3308.~~

~~4. The possession, storage, sale, handling and use of specific types of Division 1.4G fireworks where allowed by applicable laws, ordinances and regulations, provided such fireworks comply with, CPSC 16 CFR, Parts 1500 and 1507, and DOTn 49 CFR, Parts 100-178, for consumer fireworks.~~

~~**3301.1.4 Rocketry.** The storage, handling and use of model and high-power rockets shall comply with the requirements of NFPA 1122, NFPA 1125, and NFPA 1127.~~

~~**3301.1.5 Ammonium nitrate.** The storage and handling of ammonium nitrate shall comply with the requirements of NFPA 490 and Chapter 40.~~

~~**Exception:** Storage of ammonium nitrate in magazines with blasting agents shall comply with the requirements of NFPA 495.~~

~~**3301.2 Permit required.** Permits shall be required as set forth in Section 105.6 and regulated in accordance with this section.~~

~~**3301.2.1 Residential uses.** No person shall keep or store, nor shall any permit be issued to keep or store, any explosives at any place of habitation, or within 100 feet (30 480 mm) thereof.~~

~~**Exception:** Storage of smokeless propellant, black powder, and small arms primers for personal use and not for resale in accordance with Section 3306.~~

~~**3301.2.2 Sale and retail display.** No person shall construct a retail display nor offer for sale explosives, explosive materials, or fireworks upon highways, sidewalks, public property, or in Group A or E occupancies.~~

~~**3301.2.3 Permit restrictions.** The fire code official is authorized to limit the quantity of explosives, explosive materials, or fireworks permitted at a given location. No person, possessing a permit for storage of explosives at any place, shall keep or store an amount greater than authorized in such permit. Only the kind of explosive specified in such a permit shall be kept or stored.~~

~~**3301.2.4 Financial responsibility.** Before a permit is issued, as required by Section 3301.2, the applicant shall file with the jurisdiction a corporate surety bond in the principal sum of \$100,000 or a public liability insurance policy for the same amount, for the purpose of the payment of all damages to persons or property which arise from, or are caused by, the conduct of any act authorized by the permit upon which any judicial judgment results. The fire code official is authorized to specify a greater or lesser amount when, in his or her opinion, conditions at the location of use indicate a greater or lesser amount is required. Government entities shall be exempt from this bond requirement.~~

~~**3301.2.4.1 Blasting.** Before approval to do blasting is issued, the applicant for approval shall file a bond or submit a certificate of insurance in such form, amount and coverage as determined by the legal department of the jurisdiction to be adequate in each case to indemnify the jurisdiction against any and all damages arising from permitted blasting.~~

~~**3301.2.4.2 Fireworks display.** The permit holder shall furnish a bond or certificate of insurance in an amount deemed adequate by the fire code official for the payment of all potential damages to a person or persons or to property by reason of the permitted display, and arising from any acts of the permit holder, the agent, employees or subcontractors.~~

~~**3301.3 Prohibited explosives.** Permits shall not be issued or renewed for possession, manufacture, storage, handling, sale or use of the following materials and such materials currently in storage or use shall be disposed of in an approved manner:~~

~~1. Liquid nitroglycerin.~~

~~2. Dynamite containing more than 60 percent liquid explosive ingredient.~~

~~3. Dynamite having an unsatisfactory absorbent or one that permits leakage of a liquid explosive ingredient under any conditions liable to exist during storage.~~

~~4. Nitrocellulose in a dry and uncompressed condition in a quantity greater than 10 pounds (4.54 kg) of net weight in one package.~~

- ~~5. Fulminate of mercury in a dry condition and fulminate of all other metals in any condition except as a component of manufactured articles not hereinafter forbidden.~~
  - ~~6. Explosive compositions that ignite spontaneously or undergo marked decomposition, rendering the products of their use more hazardous, when subjected for 48 consecutive hours or less to a temperature of 167°F (75°C).~~
  - ~~7. New explosive materials until approved by DOTn, except that permits are allowed to be issued to educational, governmental or industrial laboratories for instructional or research purposes.~~
  - ~~8. Explosive materials condemned by DOTn.~~
  - ~~9. Explosive materials containing an ammonium salt and a chlorate.~~
  - ~~10. Explosives not packed or marked as required by DOTn~~
- ~~49 CFR, Parts 100-178.~~

~~**Exception:** Gelatin dynamite.~~

~~**3301.4 Qualifications.** Persons in charge of magazines, blasting, fireworks display, or pyrotechnic special effect operations shall not be under the influence of alcohol or drugs which impair sensory or motor skills, shall be at least 21 years of age, and shall demonstrate knowledge of all safety precautions related to the storage, handling or use of explosives, explosive materials or fireworks.~~

~~**3301.5 Supervision.** The fire code official is authorized to require operations permitted under the provisions of Section 3301.2 to be supervised at any time by the fire code official in order to determine compliance with all safety and fire regulations.~~

~~**3301.6 Notification.** Whenever a new explosive material storage or manufacturing site is established, including a temporary job site, the local lawenforcement agency, fire department, and local emergency planning committee shall be notified 48 hours in advance, not including Saturdays, Sundays and holidays, of the type, quantity and location of explosive materials at the site.~~

~~**3301.7 Seizure.** The fire code official is authorized to remove or cause to be removed or disposed of in an approved manner, at the expense of the owner, explosives, explosive materials or fireworks offered or exposed for sale, stored, possessed or used in violation of this chapter.~~

~~**3301.8 Establishment of quantity of explosives and distances.** The quantity of explosives and distances shall be in accordance with Sections 3301.8.1 and 3301.8.1.1.~~

~~**3301.8.1 Quantity of explosives.** The quantity distance (Q-D) tables in Sections 3304.5 and 3305.3 shall be used to provide the minimum separation distances from potential explosion sites as set forth in Tables 3301.8.1(1) through 3301.8.1(3). The classification and the weight of the explosives are primary characteristics governing the use of these tables. The net explosive weight shall be determined in accordance with Sections 3301.8.1.1 through 3301.8.1.4.~~

~~**3301.8.1.1 Mass-detonating explosives.** The total net explosive weight of Division 1.1, 1.2 or 1.5 explosives shall be used. See Table 3304.5.2(2) or Table 3305.3 as appropriate.~~

~~**Exception:** When the TNT equivalence of the explosive material has been determined, the equivalence is allowed to be used to establish the net explosive weight.~~

~~**3301.8.1.2 Nonmass-detonating explosives (excluding Division 1.4).** Nonmass-detonating explosives shall be as follows:~~

- ~~1. Division 1.3 propellants. The total weight of the propellants alone shall be the net explosive weight. The net weight of propellant shall be used. See Table 3304.5.2(3).~~
- ~~2. Combinations of bulk metal powder and pyrotechnic compositions. The sum of the net weights of metal powders and pyrotechnic compositions in the containers shall be the net explosive weight. See Table 3304.5.2(3).~~

~~**TABLE 3301.8.1(1)**~~

~~**TABLE 3301.8.1(2)**~~

### TABLE 3301.8.1(3)

#### ~~3301.8.1.3 Combinations of mass detonating and nonmass detonating explosives (excluding Division~~

~~1.4). Combination of mass detonating and nonmass detonating explosives shall be as follows:~~

~~1. When Division 1.1 and 1.2 explosives are located in the same site, determine the distance for the total quantity considered first as 1.1 and then as 1.2. The required distance is the greater of the two. When the Division 1.1 requirements are controlling and the TNT equivalence of the 1.2 is known, the TNT equivalent weight of the 1.2 items shall be allowed to be added to the total explosive weight of Division 1.1 items to determine the net explosive weight for Division 1.1 distance determination. See Table 3304.5.2(3) or Table 3305.3 as appropriate.~~

~~2. When Division 1.1 and 1.3 explosives are located in the same site, determine the distances for the total quantity considered first as 1.1 and then as 1.3. The required distance is the greater of the two. When the Division 1.1 requirements are controlling and the TNT equivalence of the 1.3 is known, the TNT equivalent weight of the 1.3 items shall be allowed to be added to the total explosive weight of Division 1.1 items to determine the net explosive weight for Division 1.1 distance determination. See Table 3304.5.2(2), 3304.5.2(3) or 3305.3, as appropriate.~~

~~3. When Division 1.1, 1.2 and 1.3 explosives are located in the same site, determine the distances for the total quantity considered first as 1.1, next as 1.2 and finally as 1.3. The required distance is the greatest of the three. As allowed by paragraphs 1 and 2 above, TNT equivalent weights for 1.2 and 1.3 items are allowed to be used to determine the net weight of explosives for Division 1.1 distance determination. Table 3304.5.2(2) or 3305.3 shall be used when TNT equivalency is used to establish the net explosive weight.~~

~~4. For composite pyrotechnic items Division 1.1 and Division 1.3, the sum of the net weights of the pyrotechnic composition and the explosives involved shall be used. See Tables 3304.5.2(2) and 3304.5.2(3).~~

~~3301.8.1.4 Moderate fire—no blast hazards.~~ Division 1.4 explosives. The total weight of the explosive material alone is the net weight. The net weight of the explosive material shall be used.

### SECTION 3302

#### DEFINITIONS

~~3302.1 Definitions.~~ The following words and terms shall, for the purposes of this chapter and as used elsewhere in this code, have the meanings shown herein.

**AMMONIUM NITRATE.** A chemical compound represented by the formula  $NH_4NO_3$ .

**BARRICADE.** A structure that consists of a combination of walls, floor and roof, which is designed to withstand the rapid release of energy in an explosion and which is fully confined, partially vented or fully vented; or other effective method of shielding from explosive materials by a natural or artificial barrier.

**Artificial barricade.** An artificial mound or revetment a minimum thickness of 3 feet (914 mm).

**Natural barricade.** Natural features of the ground, such as hills, or timber of sufficient density that the surrounding exposures that require protection cannot be seen from the magazine or building containing explosives when the trees are bare of leaves.

**BARRICADED.** The effective screening of a building containing explosive materials from the magazine or other building, railway, or highway by a natural or an artificial barrier. A straight line from the top of any sidewall of the building containing explosive materials to the eave line of any magazine or other building or to a point 12 feet (3658 mm) above the center of a railway or highway shall pass through such barrier.

**BLAST AREA.** The area including the blast site and the immediate adjacent area within the influence of flying rock, missiles and concussion.

**BLASTSITE.** The area in which explosive materials are being or have been loaded and which includes all holes loaded or to be loaded for the same blast and a distance of 50 feet (15 240 mm) in all directions.

**BLASTER.** A person qualified in accordance with Section 3301.4 to be in charge of and responsible for the loading and firing of a blast.

**BLASTING AGENT.** A material or mixture consisting of fuel and oxidizer, intended for blasting provided that the finished product, as mixed for use or shipment, cannot be detonated by means of a No. 8 test detonator when unconfined. Blasting agents are labeled and placarded as Class 1.5 material by US DOTn.

**BULLET RESISTANT.** Constructed so as to resist penetration of a bullet of 150-grain M2ball ammunition having a nominal muzzle velocity of 2,700 feet per second (fps) (824 mps) when fired from a 30-caliber rifle at a distance of 100 feet (30.480 mm), measured perpendicular to the target.

**DETONATING CORD.** A flexible cord containing a center core of high explosive used to initiate other explosives.

**DETONATION.** An exothermic reaction characterized by the presence of a shock wave in the material which establishes and maintains the reaction. The reaction zone progresses through the material at a rate greater than the velocity of sound. The principal heating mechanism is one of shock compression. Detonations have an explosive effect.

**DETONATOR.** A device containing any initiating or primary explosive that is used for initiating detonation. A detonator shall not contain more than 154.32 grains (10 grams) of total explosives by weight, excluding ignition or delay charges. The term includes, but is not limited to, electric blasting caps of instantaneous and delay types, blasting caps for use with safety fuses, detonating cord delay connectors, and noninstantaneous and delay blasting caps which use detonating cord, shock tube or any other replacement for electric leg wires. All types of detonators in strengths through No. 8 cap should be rated at 1.5 pounds (0.68 kg) of explosives per 1,000 caps. For strengths higher than No. 8 cap, consult the manufacturer.

**DISCHARGE SITE.** The immediate area surrounding the fireworks mortars used for an outdoor fireworks display.

**DISPLAY SITE.** The immediate area where a fireworks display is conducted. The display area includes the discharge site, the fallout area, and the required separation distance from the mortars to spectator viewing areas. The display area does not include spectator viewing areas or vehicle parking areas.

**EXPLOSIVE.** A chemical compound, mixture or device, the primary or common purpose of which is to function by explosion. The term includes, but is not limited to, dynamite, black powder, pellet powder, initiating explosives, detonators, safety fuses, squibs, detonating cord, igniter cord, igniters and display fireworks, 1.3G (Class B, Special). The term "explosive" includes any material determined to be within the scope of USC Title 18: Chapter 40 and also includes any material classified as an explosive other than consumer fireworks, 1.4G (Class C, Common) by the hazardous materials regulations of DOTn 49 CFR.

**High explosive.** Explosive material, such as dynamite, which can be caused to detonate by means of a No. 8 test blasting cap when unconfined.

**Low explosive.** Explosive material that will burn or deflagrate when ignited. It is characterized by a rate of reaction that is less than the speed of sound. Examples of low explosives include, but are not limited to, black powder, safety fuse, igniters, igniter cord, fuse lighters, fireworks, 1.3G (Class B special) and propellants, 1.3C.

**Mass-detonating explosives.** Division 1.1, 1.2 and 1.5 explosives alone or in combination, or loaded into various types of ammunition or containers, most of which can be expected to explode virtually instantaneously when a small portion is subjected to fire, severe concussion, impact, the impulse of an initiating agent, or the effect of a considerable discharge of energy from without. Materials that react in this manner represent a mass explosion hazard. Such an explosive will normally cause severe structural damage to adjacent objects. Explosive propagation could occur immediately to other items of ammunition and explosives stored sufficiently close to and not adequately protected from the initially exploding pile with a time interval short enough so that two or more quantities must be considered as one for quantity distance purposes.

**UN/DOTn Class 1 explosives.** The former classification system used by DOTn included the terms "high" and "low"

~~explosives as defined herein. The following terms further define explosives under the current system applied by DOTn for all explosive materials defined as hazard Class 1 materials. Compatibility group letters are used in concert with the Division to specify further limitations on each division noted, (i.e., the letter G identifies the material as a pyrotechnic substance or article containing a pyrotechnic substance and similar materials).~~

~~**Division 1.1.** Explosives that have a mass explosion hazard. A mass explosion is one which affects almost the entire load instantaneously.~~

~~**Division 1.2.** Explosives that have a projection hazard but not a mass explosion hazard.~~

~~**Division 1.3.** Explosives that have a fire hazard and either a minor blast hazard or a minor projection hazard or both, but not a mass explosion hazard.~~

~~**Division 1.4.** Explosives that pose a minor explosion hazard. The explosive effects are largely confined to the package and no projection of fragments of appreciable size or range is to be expected. An external fire must not cause virtually instantaneous explosion of almost the entire contents of the package.~~

~~**Division 1.5.** Very insensitive explosives. This division is comprised of substances that have a mass explosion hazard but which are so insensitive that there is very little probability of initiation or of transition from burning to detonation under normal conditions of transport.~~

~~**Division 1.6.** Extremely insensitive articles which do not have a mass explosion hazard. This division is comprised of articles that contain only extremely insensitive detonating substances and which demonstrate a negligible probability of accidental initiation or propagation.~~

~~**EXPLOSIVE MATERIAL.** The term "explosive" material means explosives, blasting agents, and detonators.~~

~~**FALLOUT AREA.** The area over which aerial shells are fired. The shells burst over the area, and unsafe debris and malfunctioning aerial shells fall into this area. The fallout area is the location where a typical aerial shell dud falls to the ground depending on the wind and the angle of mortar placement.~~

~~**FIREWORKS.** Any composition or device for the purpose of producing a visible or an audible effect for entertainment purposes by combustion, deflagration or detonation that meets the definition of 1.4G fireworks or 1.3G fireworks as set forth herein.~~

~~**Fireworks, 1.4G.** (Formerly known as Class C, Common Fireworks.) Small fireworks devices containing restricted amounts of pyrotechnic composition designed primarily to produce visible or audible effects by combustion. Such 1.4G fireworks which comply with the construction, chemical composition and labeling regulations of the DOTn for Fireworks, UN 0336, and the U.S. Consumer Product Safety Commission as set forth in CPSC 16 CFR: Parts 1500 and 1507, are not explosive materials for the purpose of this code.~~

~~**Fireworks, 1.3G.** (Formerly Class B, Special Fireworks.) Large fireworks devices, which are explosive materials, intended for use in fireworks displays and designed to produce audible or visible effects by combustion, deflagration or detonation. Such 1.3G fireworks include, but are not limited to, firecrackers containing more than 130 milligrams (2 grains) of explosive composition, aerial shells containing more than 40 grams of pyrotechnic composition, and other display pieces which exceed the limits for classification as 1.4G fireworks. Such 1.3G fireworks, are also described as Fireworks, UN0335 by the DOTn.~~

~~**FIREWORKS DISPLAY.** A presentation of fireworks for a public or private gathering.~~

~~**HIGHWAY.** A public street, public alley or public road.~~

~~**INHABITED BUILDING.** A building regularly occupied in whole or in part as a habitation for people, or any place of religious worship, schoolhouse, railroad station, store or other structure where people are accustomed to assemble, except any building or structure occupied in connection with the manufacture, transportation, storage or use of explosive materials.~~

~~**MAGAZINE.** A building, structure or container, other than an operating building, approved for storage of explosive~~

materials.

**Indoor.** A portable structure, such as a box, bin or other container, constructed as required for Type 2, 4 or 5 magazines in accordance with NFPA 495, NFPA 1124 or DOTy 27 CFR Part 55 so as to be fire resistant and theft resistant.

**Type 1.** A permanent structure, such as a building or igloo, that is bullet resistant, fire resistant, theft resistant, weather resistant and ventilated in accordance with the requirements of NFPA 495, NFPA 1124, or DOTy 27 CFR Part 55.

**Type 2.** A portable or mobile structure, such as a box, skid magazine, trailer or semitrailer, constructed in accordance with the requirements of NFPA 495, NFPA 1124 or DOTy 27 CFR, Part 55 that is fire resistant, theft resistant, weather resistant and ventilated. If used outdoors, a Type 2 magazine is also bullet resistant.

**Type 3.** A fire resistant, theft resistant and weather resistant "day box" or portable structure constructed in accordance with NFPA 495, NFPA 1124, or DOTy 27 CFR Part 55 used for the temporary storage of explosive materials.

**Type 4.** A permanent, portable or mobile structure such as a building, igloo, box, semitrailer or other mobile container that is fire resistant, theft resistant and weather resistant and constructed in accordance with NFPA 495, NFPA 1124, or DOTy 27 CFR, Part 55.

**Type 5.** A permanent, portable or mobile structure such as a building, igloo, box, bin, tank, semitrailer, bulk trailer, tank trailer, bulk truck, tank truck or other mobile container that is theft resistant, which is constructed in accordance with NFPA 495, NFPA 1124, or DOTy 27 CFR, Part 55.

**MORTAR.** A tube from which fireworks shells are fired into the air.

**NET EXPLOSIVE WEIGHT (net weight).** The weight of explosive material expressed in pounds. The net explosive weight is the aggregate amount of explosive material contained within buildings, magazines, structures or portions thereof, used to establish quantity-distance relationships.

**OPERATING BUILDING.** A building occupied in conjunction with the manufacture, transportation, or use of explosive materials. Operating buildings are separated from one another with the use of intraplant or intraline distances.

**OPERATING LINE.** A group of buildings, facilities or workstations so arranged as to permit performance of the steps in the manufacture of an explosive or in the loading, assembly, modification and maintenance of ammunition or devices containing explosive materials.

**PLOSOPHORIC MATERIAL.** Two or more unmixed, commercially manufactured, prepackaged chemical substances including oxidizers, flammable liquids or solids, or similar substances that are not independently classified as explosives but which, when mixed or combined, form an explosive that is intended for blasting.

**PROXIMATE AUDIENCE.** An audience closer to pyrotechnic devices than allowed by NFPA 1123.

**PUBLIC TRAFFIC ROUTE (PTR).** Any public street, road, highway, navigable stream or passenger railroad that is used for through traffic by the general public.

**PYROTECHNIC COMPOSITION.** A chemical mixture that produces visible light displays or sounds through a self-propagating, heat releasing chemical reaction which is initiated by ignition.

**PYROTECHNIC SPECIAL EFFECT.** A visible or audible effect for entertainment created through the use of pyrotechnic materials and devices.

**PYROTECHNIC SPECIAL-EFFECT MATERIAL.** A chemical mixture used in the entertainment industry, to produce visible or audible effects by combustion, deflagration or detonation. Such a chemical mixture predominantly consists of solids capable of producing a controlled, self-sustaining and self-contained exothermic chemical reaction that

results in heat, gas, sound, light or a combination of these effects. The chemical reaction functions without external oxygen.

**QUANTITY-DISTANCE (Q-D).** The quantity of explosive material and separation distance relationships providing protection. These relationships are based on levels of risk considered acceptable for the stipulated exposures and are tabulated in the appropriate Q-D tables. The separation distances specified afford less than absolute safety.

**Minimum separation distance (Do).** The minimum separation distance between adjacent buildings occupied in conjunction with the manufacture, transportation, storage or use of explosive materials where one of the buildings contains explosive materials and the other building does not.

**Intraline distance (ILD) or Intraplant distance (IPD).** The distance to be maintained between any two operating buildings on an explosives manufacturing site when at least one contains or is designed to contain explosives, or the distance between a magazine and an operating building.

**Inhabited building distance (IBD).** The minimum separation distance between an operating building or magazine containing explosive materials and an inhabited building or site boundary.

**Intermagazine distance (IMD).** The minimum separation distance between magazines.

**RAILWAY.** A steam, electric or other railroad or railway that carries passengers for hire.

**READY BOX.** A weather resistant container with a self closing or automatic closing cover that protects fireworks shells from burning debris. Tarpaulins shall not be considered as ready boxes.

**SMALL ARMS AMMUNITION.** A shotgun, rifle or pistol cartridge and any cartridge for propellant actuated devices. This definition does not include military ammunition containing bursting charges or incendiary, trace, spotting or pyrotechnic projectiles.

**SMALL ARMS PRIMERS.** Small percussion sensitive explosive charges, encased in a cap, used to ignite propellant powder.

**SMOKELESS PROPELLANTS.** Solid propellants, commonly referred to as smokeless powders, used in small arms ammunition, cannons, rockets, propellant actuated devices and similar articles.

**SPECIAL INDUSTRIAL EXPLOSIVE DEVICE.** An explosive power pack containing an explosive charge in the form of a cartridge or construction device. The term includes but is not limited to explosive rivets, explosive bolts, explosive charges for driving pins or studs, cartridges for explosive actuated power tools and charges of explosives used in automotive air bag inflators, jet tapping of open hearth furnaces and jet perforation of oil well casings.

**THEFT RESISTANT.** Construction designed to deter illegal entry into facilities for the storage of explosive materials.

## **SECTION 3303**

### **RECORD KEEPING AND REPORTING**

**3303.1 General.** Records of the receipt, handling, use or disposal of explosive materials, and reports of any accidents, thefts, or unauthorized activities involving explosive materials shall conform to the requirements of this section.

**3303.2 Transaction record.** The permittee shall maintain a record of all transactions involving receipt, removal, use or disposal of explosive materials. Such a record shall be maintained for a period of five years, and shall be furnished to the fire code official for inspection upon request.

**Exception:** Where only Division 1.4G (consumer fireworks) are handled, records need only be maintained for a period of three years.

~~**3303.3 Loss, theft or unauthorized removal.** The loss, theft or unauthorized removal of explosive materials from a magazine or permitted facility shall be reported to the fire code official, local law enforcement authorities, and the U.S. Department of Treasury, Bureau of Alcohol, Tobacco and Firearms within 24 hours.~~

~~**Exception:** Loss of Division 1.4G (consumer fireworks) need not be reported to the Bureau of Alcohol, Tobacco and Firearms.~~

~~**3303.4 Accidents.** Accidents involving the use of explosives, explosive materials and fireworks, which result in injuries or property damage, shall be reported to the fire code official immediately.~~

~~**3303.5 Misfires.** The pyrotechnic display operator or blaster in charge shall keep a record of all aerial shells that fail to fire or charges that fail to detonate.~~

~~**3303.6 Hazard communication.** Manufacturers of explosive materials and fireworks shall maintain records of chemicals, chemical compounds and mixtures required by DOL 29 CFR, Part 1910.1200, and Section 407.~~

~~**3303.7 Safety rules.** Current safety rules covering the operation of magazines, as described in Section 3304.7, shall be posted on the interior of the magazine in a visible location.~~

## **SECTION 3304 EXPLOSIVE MATERIALS STORAGE AND HANDLING**

~~**3304.1 General.** Storage of explosives and explosive materials, small arms ammunition, small arms primers, propellant actuated cartridges and smokeless propellants in magazines, shall comply with the provisions of this section.~~

~~**3304.2 Magazine required.** Explosives and explosive materials, and Division 1.3G fireworks shall be stored in magazines constructed, located, operated and maintained in accordance with the provisions of Section 3304 and NFPA 495 or NFPA 1124.~~

### **Exceptions:**

- ~~1. Storage of fireworks at display sites in accordance with Section 3308.5 and NFPA 1123 or NFPA 1126.~~
- ~~2. Portable or mobile magazines not exceeding 120 square feet (11 m<sup>2</sup>) in area shall not be required to comply with the requirements of the *International Building Code*.~~

### **TABLE 3304.3**

~~**3304.3 Magazines.** The storage of explosives and explosive materials in magazines shall comply with Table 3304.3.~~

~~**3304.3.1 High explosives.** Explosive materials classified as Division 1.1 or 1.2 or formerly classified as Class A by the U.S. Department of Transportation shall be stored in Type 1, 2 or 3 magazines.~~

### **Exceptions:**

- ~~1. Black powder shall be stored in a Type 1, 2, 3 or 4 magazine.~~
- ~~2. Cap sensitive explosive material that is demonstrated not to be bullet sensitive, shall be stored in a Type 1, 2, 3, 4 or 5 magazine.~~

~~**3304.3.2 Low explosives.** Explosive materials that are not cap sensitive shall be stored in a Type 1, 2, 3, 4 or 5 magazine.~~

~~**3304.3.3 Detonating cord.** For quantity and distance purposes, detonating cord of 50 grains per foot shall be calculated as equivalent to 8 pounds (4 kg) of high explosives per 1,000 feet (305 m). Heavier or lighter core loads shall be rated proportionally.~~

~~**3304.4 Prohibited storage.** Detonators shall be stored in a~~

separate magazine for blasting supplies and shall not be stored in a magazine with other explosive materials.

**3304.5 Location.** The use of magazines for storage of explosives and explosive materials shall comply with Sections 3304.5.1 through 3304.5.3.3.

**3304.5.1 Indoor magazines.** The use of indoor magazines for storage of explosives and explosive materials shall comply with the requirements of this section.

**3304.5.1.1 Use.** The use of indoor magazines for storage of explosives and explosive materials shall be limited to occupancies of Group F, H, M or S, and research and development laboratories.

**3304.5.1.2 Construction.** Indoor magazines shall comply with the following construction requirements:

1. Construction shall be fire resistant and theft resistant.
2. Exterior shall be painted red.
3. Base shall be fitted with wheels, casters or rollers to facilitate removal from the building in an emergency.
4. Lid or door shall be marked with conspicuous white lettering not less than 3 inches (76 mm) high and minimum 1/2 inch (12.7 mm) stroke, reading

EXPLOSIVES — KEEP FIRE AWAY.

5. The least horizontal dimension shall not exceed the clear width of the entrance door.

**3304.5.1.3 Quantity limit.** Not more than 50 pounds (23 kg) of explosives or explosive materials shall be stored within an indoor magazine.

**Exception:** Day boxes used for the storage of in process material in accordance with Section 3305.6.4.1.

**3304.5.1.4 Prohibited use.** Indoor magazines shall not be used within buildings containing Group R occupancies.

**3304.5.1.5 Location.** Indoor magazines shall be located within 10 feet (3048 mm) of an entrance and only on floors at or having ramp access to the exterior grade level.

**3304.5.1.6 Number.** Not more than two indoor magazines shall be located in the same building. Where two such magazines are located in the same building, one magazine shall be used solely for the storage of not more than 5,000 detonators.

**3304.5.1.7 Separation distance.** When two magazines are located in the same building, they shall be separated by a distance of not less than 10 feet (3048 mm).

**3304.5.2 Outdoor magazines.** All outdoor magazines other than Type 3 shall be located so as to comply with Table 3304.5.2(2) or Table 3304.5.2(3) as set forth in Tables 3301.8.1(1) through 3301.8.1(3). Where a magazine or group of magazines, as described in Section 3304.5.2.2, contains different classes of explosive materials, and Division 1.1 materials are present, the required separations for the magazine or magazine group as a whole shall comply with Table 3304.5.2(2).

**TABLE 3304.5.2(1)**

**TABLE 3304.5.2(2)**

**TABLE 3304.5.2(3)**

**3304.5.2.1 Separation.** Where two or more storage magazines are located on the same property, each magazine shall comply with the minimum distances specified from inhabited buildings, public transportation routes and operating buildings. Magazines shall be separated from each other by not less than the intermagazine distances (IMD) shown for the separation of magazines.

~~**3304.5.2.2 Grouped magazines.** Where two or more magazines are separated from each other by less than the intermagazine distances (IMD), such magazines as a group shall be considered as one magazine and the total quantity of explosive materials stored in the group shall be treated as if stored in a single magazine. The location of the group of magazines shall comply with the intermagazine distances (IMD) specified from other magazines or magazine groups, inhabited buildings (IBD), public transportation routes (PTR) and operating buildings (ILD or IPD) as required.~~

~~**3304.5.3 Special requirements for Type 3 magazines.** Type 3 magazines shall comply with Sections 3304.5.3.1 through 3304.5.3.3.~~

~~**3304.5.3.1 Location.** Wherever practicable, Type 3 magazines shall be located away from neighboring inhabited buildings, railways, highways, and other magazines in accordance with Table 3304.5.2(2) or 3304.5.2(3) as applicable.~~

~~**3304.5.3.2 Supervision.** Type 3 magazines shall be attended when explosive materials are stored within. Explosive materials shall be removed to appropriate storage magazines for unattended storage at the end of the work day.~~

~~**3304.5.3.3 Use.** Not more than two Type 3 magazines shall be located at the same blasting site. Where two Type 3 magazines are located at the same blasting site, one magazine shall used solely for the storage of detonators.~~

~~**3304.6 Construction.** Magazines shall be constructed in accordance with Sections 3304.6.1 through 3304.6.5.2.~~

~~**3304.6.1 Drainage.** The ground around a magazine shall be graded so that water drains away from the magazine.~~

~~**3304.6.2 Heating.** Magazines requiring heat shall be heated as prescribed in NFPA 495 by either hot water radiant heating within the magazine or by indirect warm air heating.~~

~~**3304.6.3 Lighting.** When lighting is necessary within a magazine, electric safety flashlights or electric safety lanterns shall be used, except as provided in NFPA 495.~~

~~**3304.6.4 Nonsparking materials.** In other than Type 5 magazines, there shall be no exposed ferrous metal on the interior of a magazine containing packages of explosives.~~

~~**3304.6.5 Signs and placards.** Property upon which Type 1 magazines and outdoor magazines of Types 2, 4 and 5 are located shall be posted with signs stating:  
EXPLOSIVES — KEEP OFF.~~

~~These signs shall be of contrasting colors with a minimum letter height of 3 inches (76 mm) with a minimum brush stroke of 0.5 inch (12.7 mm). The signs shall be located to minimize the possibility of a bullet shot at the sign hitting the magazine.~~

~~**3304.6.5.1 Access road signs.** At the entrance to explosive material manufacturing and storage sites, all access roads shall be posted with the following warning sign or other approved sign:~~

~~DANGER!  
NEVER FIGHT EXPLOSIVE FIRES.  
EXPLOSIVES ARE STORED ON THIS SITE  
CALL \_\_\_\_\_.~~

~~The sign shall be weather resistant with a reflective surface and have lettering at least 2 inches (51 mm) high.~~

~~**3304.6.5.2 Placards.** Type 5 magazines containing Division 1.5 blasting agents shall be prominently placarded as required during transportation by DOTn 49 CFR, Part 172 and DOTy 27 CFR, Part 55.~~

~~**3304.7 Operation.** Magazines shall be operated in accordance with Sections 3304.7.1 through 3304.7.9.~~

~~**3304.7.1 Security.** Magazines shall be kept locked in the manner prescribed in NFPA 495 at all times except during~~

placement or removal of explosives or inspection.

**3304.7.2 Open flames and lights.** Smoking, matches, flame producing devices, open flames, firearms and firearms cartridges shall not be allowed inside of or within 50 feet (15 240 mm) of magazines.

**3304.7.3 Brush.** The area located around a magazine shall be kept clear of brush, dried grass, leaves, trash, debris, and similar combustible materials for a distance of 25 feet (7620 mm).

**3304.7.4 Combustible storage.** Combustible materials shall not be stored within 50 feet (15 240 mm) of magazines.

**3304.7.5 Unpacking and repacking explosive materials.** Containers of explosive materials, except fiberboard containers, and packages of damaged or deteriorated explosive materials or fireworks shall not be unpacked or repacked inside or within 50 feet (15 240 mm) of a magazine or in close proximity to other explosive materials.

**3304.7.5.1 Storage of opened packages.** Packages of explosive materials that have been opened shall be closed before being placed in a magazine.

**3304.7.5.2 Nonsparking tools.** Tools used for the opening and closing of packages of explosive materials, other than metal slitters for opening paper, plastic or fiberboard containers, shall be made of nonsparking materials.

**3304.7.5.3 Disposal of packaging.** Empty containers and paper and fiber packaging materials that previously contained explosive materials shall be disposed of or reused in a approved manner.

**3304.7.6 Tools and equipment.** Metal tools, other than nonferrous transfer conveyors and ferrous metal conveyor stands protected by a coat of paint, shall not be stored in a magazine containing explosive materials or detonators.

**3304.7.7 Contents.** Magazines shall be used exclusively for the storage of explosive materials, blasting materials and blasting accessories.

**3304.7.8 Compatibility.** Corresponding grades and brands of explosive materials shall be stored together and in such a manner that the grade and brand marks are visible. Stocks shall be stored so as to be easily counted and checked. Packages of explosive materials shall be stacked in a stable manner not exceeding 8 feet (2438 mm) in height.

**3304.7.9 Stock rotation.** When explosive material is removed from a magazine for use, the oldest usable stocks shall be removed first.

**3304.8 Maintenance.** Maintenance of magazines shall comply with Sections 3304.8.1 through 3304.8.3.

**3304.8.1 Housekeeping.** Magazine floors shall be regularly swept and be kept clean, dry and free of grit, paper, empty packages and rubbish. Brooms and other cleaning utensils shall not have any spark producing metal parts. Sweepings from magazine floors shall be disposed of in accordance with the manufacturers' approved instructions.

**3304.8.2 Repairs.** Explosive materials shall be removed from the magazine before making repairs to the interior of a magazine. Explosive materials shall be removed from the magazine before making repairs to the exterior of the magazine where there is a possibility of causing a fire. Explosive materials removed from a magazine under repair shall either be placed in another magazine or placed a safe distance from the magazine, where they shall be properly guarded and protected until repairs have been completed. Upon completion of repairs, the explosive materials shall be promptly returned to the magazine. Floors shall be cleaned before and after repairs.

**3304.8.3 Floors.** Magazine floors stained with liquid shall be dealt with according to instructions obtained from the manufacturer of the explosive material stored in the magazine.

**3304.9 Inspection.** Magazines containing explosive materials shall be opened and inspected at maximum seven day intervals. The inspection shall determine whether there has been an unauthorized or attempted entry into a magazine or an unauthorized removal of a magazine or its contents.

~~**3304.10 Disposal of explosive materials.** Explosive materials shall be disposed of in accordance with Sections 3304.10.1 through 3304.10.7.~~

~~**3304.10.1 Notification.** The fire code official shall be notified immediately when deteriorated or leaking explosive materials are determined to be dangerous or unstable and in need of disposal.~~

~~**3304.10.2 Deteriorated materials.** When an explosive material has deteriorated to an extent that it is in an unstable or dangerous condition, or when a liquid has leaked from an explosive material, the person in possession of such material shall immediately contact the material's manufacturer to obtain disposal and handling instructions.~~

~~**3304.10.3 Qualified person.** The work of destroying explosive materials shall be directed by persons experienced in the destruction of explosive materials.~~

~~**3304.10.4 Storage of misfires.** Explosive materials and fireworks recovered from blasting or display misfires shall be placed in a magazine until an experienced person has determined the proper method for disposal.~~

~~**3304.10.5 Disposal sites.** Sites for the destruction of explosive materials and fireworks shall be approved and located at the maximum practicable safe distance from inhabited buildings, public highways, operating buildings, and all other exposures to ensure keeping air blast and ground vibration to a minimum. The location of disposal sites shall be no closer to magazines, inhabited buildings, railways, highways and other rights of way than is allowed by Tables 3304.5.2(1), 3304.5.2(2) and 3304.5.2(3). When possible, barricades shall be utilized between the destruction site and inhabited buildings. Areas where explosives are detonated or burned shall be posted with adequate warning signs.~~

~~**3304.10.6 Reuse of site.** Unless an approved burning site has been thoroughly saturated with water and has passed a safety inspection, 48 hours shall elapse between the completion of a burn and the placement of scrap explosive materials for a subsequent burn.~~

~~**3304.10.7 Personnel safeguards.** Once an explosive burn operation has been started, personnel shall relocate to a safe location where adequate protection from air blast and flying debris is provided. Personnel shall not return to the burn area until the person in charge has inspected the burn site and determined that it is safe for personnel to return.~~

## ~~**SECTION 3305 MANUFACTURE, ASSEMBLY AND TESTING OF EXPLOSIVES, EXPLOSIVE MATERIALS AND FIREWORKS**~~

~~**3305.1 General.** The manufacture, assembly and testing of explosives, ammunition, blasting agents and fireworks shall comply with the requirements of this section and NFPA 495 or NFPA 1124.~~

### ~~**Exceptions:**~~

- ~~1. The hand loading of small arms ammunition prepared for personal use and not offered for resale.~~
- ~~2. The mixing and loading of blasting agents at blasting sites in accordance with NFPA 495.~~
- ~~3. The use of binary explosives or phosphoric materials in blasting or pyrotechnic special effects applications in accordance with NFPA 495 or NFPA 1126.~~

~~**3305.2 Emergency planning and preparedness.** Emergency plans, emergency drills, employee training and hazard communication shall conform to the provisions of this section and Sections 404, 405, 406 and 407.~~

~~**3305.2.1 Hazardous Materials Management Plans and Inventory Statements required.** Detailed Hazardous Materials Management Plans (HMMP) and Hazardous Materials Inventory Statements (HMIS) complying with the requirements of Section 407 shall be prepared and submitted to the local emergency planning committee, the fire code official, and the local fire department.~~

~~**3305.2.2 Maintenance of plans.** A copy of the required HMMP and HMIS shall be maintained on site and furnished to the fire code official on request.~~

~~**3305.2.3 Employee training.** Workers who handle explosives or explosive charges or dispose of explosives shall be trained in the hazards of the materials and processes in which they are to be engaged and with the safety rules governing such materials and processes.~~

~~**3305.2.4 Emergency procedures.** Approved emergency procedures shall be formulated for each plant which will include personal instruction in any emergency that may be anticipated. All personnel shall be made aware of an emergency warning signal.~~

~~**3305.3 Intraplant separation of operating buildings.** Explosives manufacturing buildings and fireworks manufacturing buildings, including those where explosive charges are assembled, manufactured, prepared or loaded utilizing Division 1.1, 1.2, 1.3, 1.4 or 1.5 explosives, shall be separated from all other buildings, including magazines, within the confines of the manufacturing plant, at a distance not less than those shown in Table 3305.3 or 3304.5.2(3), as appropriate.~~

~~**Exception:** Fireworks manufacturing buildings separated in accordance with NFPA 1124. The quantity of explosives in an operating building shall be the net weight of all explosives contained therein. Distances shall be based on the hazard division requiring the greatest separation, unless the aggregate explosive weight is divided by approved walls or shields designed for that purpose. When dividing a quantity of explosives into smaller stacks, a suitable barrier or adequate separation distance shall be provided to prevent propagation from one stack to another. When distance is used as the sole means of separation within a building, such distance shall be established by testing. Testing shall demonstrate that propagation between stacks will not result. Barriers provided to protect against explosive effects shall be designed and installed in accordance with approved standards.~~

~~**3305.4 Separation of manufacturing operating buildings from inhabited buildings, public traffic routes and magazines.** When an operating building on an explosive materials plant site is designed to contain explosive materials, such a building shall be located away from inhabited buildings, public traffic routes and magazines in accordance with Table 3304.5.2(2) or 3304.5.2(3) as appropriate, based on the maximum quantity of explosive materials permitted to be in the building at one time (see Section 3301.8).~~

~~**Exception:** Fireworks manufacturing buildings constructed and operated in accordance with NFPA 1124.~~

~~**3305.4.1 Determination of net explosive weight for operating buildings.** In addition to the requirements of Section 3301.8 to determine the net explosive weight for materials stored or used in operating buildings, quantities of explosive materials stored in magazines located at distances less than intraline distances from the operating building shall be added to the contents of the operating building to determine the net explosive weight for the operating building.~~

~~**3305.4.1.1 Indoor magazines.** The storage of explosive materials located in indoor magazines in operating buildings shall be limited to a net explosive weight not to exceed 50 pounds (23 kg).~~

~~**3305.4.1.2 Outdoor magazines with a net explosive weight less than 50 pounds.** The storage of explosive materials in outdoor magazines located at less than intraline distances from operating buildings shall be limited to a net explosive weight not to exceed 50 pounds (23 kg).~~

~~**3305.4.1.3 Outdoor magazines with a net explosive weight greater than 50 pounds.** The storage of explosive materials in outdoor magazines in quantities exceeding 50 pounds (23 kg) net explosive weight shall be limited to storage in outdoor magazines located not less than intraline distances from the operating building in accordance with Section 3304.5.2.~~

~~**3305.4.1.4 Net explosive weight of materials stored in combination indoor and outdoor magazines.** The aggregate quantity of explosive materials stored in any combination of indoor magazines or outdoor magazines located at less than the intraline distances from an operating building shall not exceed 50 pounds (23 kg).~~

~~**3305.5 Buildings and equipment.** Buildings or rooms that exceed the maximum allowable quantity per control area of explosive materials shall be operated in accordance with this section and constructed in accordance with the requirements of the *International Building Code* for Group H occupancies.~~

**Exception:** Fireworks manufacturing buildings constructed and operated in accordance with NFPA 1124.

**3305.5.1 Explosives dust.** Explosives dust shall not be exhausted to the atmosphere.

**3305.5.1.1 Wet collector.** When collecting explosives dust, a wet collector system shall be used. Wetting agents shall be compatible with the explosives. Collector systems shall be interlocked with process power supplies so that the process cannot continue without the collector systems also operating.

**3305.5.1.2 Waste disposal and maintenance.** Explosives dust shall be removed from the collection chamber as often as necessary to prevent overloading. The entire system shall be cleaned at a frequency that will eliminate hazardous concentrations of explosives dust in pipes, tubing and ducts.

**3305.5.2 Exhaust fans.** Squirrel-cage blowers shall not be used for exhausting hazardous fumes, vapors or gases. Only nonferrous fan blades shall be used for fans located within the ductwork and through which hazardous materials are exhausted. Motors shall be located outside the duct.

### **TABLE 3305.3**

**3305.5.3 Work stations.** Work stations shall be separated by distance, barrier or other approved alternatives so that fire in one station will not ignite material in another work station. Where necessary, the operator shall be protected by a personnel shield located between the operator and the explosive device or explosive material being processed. This shield and its support shall be capable of withstanding a blast from the maximum amount of explosives allowed behind it.

**3305.6 Operations.** Operations involving explosives shall comply with Sections 3305.6.1 through 3305.6.10.

**3305.6.1 Isolation of operations.** When the type of material and processing warrants, mechanical operations involving explosives in excess of 1 pound (0.454 kg) shall be carried on at isolated stations or at intraplant distances, and machinery shall be controlled from remote locations behind barricades or at separations so that workers will be at a safe distance while machinery is operating.

**3305.6.2 Static controls.** The work area where the screening, grinding, blending and other processing of static-sensitive explosives or pyrotechnic materials is done shall be provided with approved static controls.

**3305.6.3 Approved containers.** Bulk explosives shall be kept in approved, nonsparking containers when not being used or processed. Explosives shall not be stored or transported in open containers.

**3305.6.4 Quantity limits.** The quantity of explosives at any particular work station shall be limited to that posted on the load limit signs for the individual work station. The total quantity of explosives for multiple workstations shall not exceed that established by the intraplant distances in Table 3305.3 or 3304.5.2(3), as appropriate.

**3305.6.4.1 Magazines.** Magazines used for storage in processing areas shall be in accordance with the requirements of Section 3304.5.1. All explosive materials shall be removed to appropriate storage magazines for unattended storage at the end of the work day. The contents of indoor magazines shall be added to the quantity of explosives contained at individual workstations and the total quantity of material stored, processed or used shall be utilized to establish the intraplant separation distances indicated by Table 3305.3 or 3304.5.2(3), as appropriate.

**3305.6.5 Waste disposal.** Approved receptacles with covers shall be provided for each location for disposing of waste material and debris. These waste receptacles shall be emptied and cleaned as often as necessary but not less than once each day or at the end of each shift.

**3305.6.6 Safety rules.** General safety rules and operating instructions governing the particular operation or process conducted at that location shall be available at each location.

**3305.6.7 Personnel limits.** The number of occupants in each process building and in each magazine shall not

exceed the number necessary for proper conduct of production operations.

~~**3305.6.8 Pyrotechnic and explosive composition quantity limits.** Not more than 500 pounds (227 kg) of pyrotechnic or explosive composition, including not more than 10 pounds (5 kg) of salute powder shall be allowed at one time in any process building or area. All compositions not in current use shall be kept in covered nonferrous containers.~~

~~**Exception:** Composition that has been loaded or pressed into tubes or other containers as consumer fireworks.~~

~~**3305.6.9 Posting limits.** The maximum number of occupants and maximum weight of pyrotechnic and explosive composition permitted in each process building shall be posted in a conspicuous location in each process building or magazine.~~

~~**3305.6.10 Heat sources.** Fireworks, explosives or explosive charges in explosive materials manufacturing, assembly or testing shall not be stored near any source of heat.~~

~~**Exception:** Approved drying or curing operations.~~

~~**3305.7 Maintenance.** Maintenance and repair of explosives manufacturing facilities and areas shall comply with Section 3304.8.~~

~~**3305.8 Explosive materials testing sites.** Detonation of explosive materials or ignition of fireworks for testing purposes shall be done only in isolated areas at sites where distance, protection from missiles, shrapnel or flyrock, and other safeguards provides protection against injury to personnel or damage to property.~~

~~**3305.8.1 Protective clothing and equipment.** Protective clothing and equipment shall be provided to protect persons engaged in the testing, ignition or detonation of explosive materials.~~

~~**3305.8.2 Site security.** When tests are being conducted or explosives are being detonated, only authorized persons shall be present. Areas where explosives are regularly or frequently detonated or burned shall be approved and posted with adequate warning signs. Warning devices shall be activated before burning or detonating explosives to alert persons approaching from any direction that they are approaching a danger zone.~~

~~**3305.9 Waste disposal.** Disposal of explosive materials waste from manufacturing, assembly or testing operations shall be in accordance with Section 3304.10.~~

## **SECTION 3306 SMALL ARMS AMMUNITION**

~~**3306.1 General.** Indoor storage and display of black powder, smokeless propellants and small arms ammunition shall comply with this section and NFPA 495.~~

~~**3306.2 Prohibited storage.** Small arms ammunition shall not be stored together with Division 1.1, Division 1.2 or Division 1.3 explosives unless the storage facility is suitable for the storage of explosive materials.~~

~~**3306.3 Packages.** Smokeless propellants shall be stored in approved shipping containers conforming to DOTn 49 CFR, Part 173.~~

~~**3306.3.1 Repackaging.** The bulk repackaging of smokeless propellants, black powder, and small arms primers shall not be performed in retail establishments.~~

~~**3306.3.2 Damaged packages.** Damaged containers shall not be repackaged.~~

~~**Exception:** Approved repackaging of damaged containers of smokeless propellant into containers of the same type and size as the original container.~~

~~**3306.4 Storage in Group R occupancies.** The storage of small arms ammunition in Group R occupancies shall comply with Sections 3306.4.1 and 3306.4.2.~~

~~**3306.4.1 Black powder and smokeless propellants.** Propellants for personal use in quantities not exceeding 20 pounds (9 kg) of black powder or 20 pounds (9 kg) of smokeless powder shall be stored in original containers in occupancies limited to Group R-3. Smokeless powder in quantities exceeding 20 pounds (9 kg) but not exceeding 50 pounds (23 kg) kept in a wooden box or cabinet having walls of at least 1 inch (25 mm) nominal thickness shall be allowed to be stored in occupancies limited to Group R-3. Quantities exceeding these amounts shall not be stored in any Group R occupancy.~~

~~**3306.4.2 Small arms primers.** No more than 10,000 small arms primers shall be stored in occupancies limited to Group R-3.~~

~~**3306.5 Display and storage in Group M occupancies.** The display and storage of small arms ammunition in Group M occupancies shall comply with this section.~~

~~**3306.5.1 Display.** Display of small arms ammunition in Group M occupancies shall comply with Sections 3306.5.1.1 through 3306.5.1.3.~~

~~**3306.5.1.1 Smokeless propellant.** No more than 20 pounds (9 kg) of smokeless propellants, each in containers of 1 pound (0.454 kg) or less capacity, shall be displayed in Group M occupancies.~~

~~**3306.5.1.2 Black powder.** No more than 1 pound (0.454 kg) of black powder shall be displayed in Group M occupancies.~~

~~**3306.5.1.3 Small arms primers.** No more than 10,000 small arms primers shall be displayed in Group M occupancies.~~

~~**3306.5.2 Storage.** Storage of small arms ammunition shall comply with Sections 3306.5.2.1 through 3306.5.2.3.~~

~~**3306.5.2.1 Smokeless propellant.** Commercial stocks of smokeless propellants shall be stored as follows:~~

~~1. Quantities exceeding 20 pounds (9 kg), but not exceeding 100 pounds (45 kg) shall be stored in portable wooden boxes having walls of at least 1 inch (25 mm) nominal thickness~~

~~2. Quantities exceeding 100 pounds (45 kg), but not exceeding 800 pounds (363 kg), shall be stored in nonportable storage cabinets having walls at least 1 inch (25 mm) nominal thickness. Not more than 400 pounds (182 kg) shall be stored in any one cabinet, and cabinets shall be separated by a distance of at least 25 feet (7620 mm) or by a fire partition having a fire resistance rating of at least 1 hour.~~

~~3. Storage of quantities exceeding 800 pounds (363 kg), but not exceeding 5,000 pounds (2270 kg) in a building shall comply with all of the following:~~

~~3.1. The warehouse or storage room is unaccessible to unauthorized personnel.~~

~~3.2. Smokeless propellant shall be stored in nonportable storage cabinets having wood walls at least 1 inch (25 mm) nominal thickness and having shelves with no more than 3 feet (914 mm) of separation between shelves.~~

~~3.3. No more than 400 pounds (182 kg) is stored in any one cabinet.~~

~~3.4. Cabinets shall be located against walls of the storage room or warehouse with at least 40 feet (12 192 mm) between cabinets.~~

~~3.5. The minimum required separation between cabinets shall be 20 feet (6096 mm) provided that barricades twice the height of the cabinets are attached to the wall, midway between each cabinet. The barricades must extend a minimum of 10 feet (3048 mm) outward, be firmly attached to the wall, and be constructed of steel not less than 0.25 inch thick (6.4 mm), 2 inch (51 mm) nominal thickness wood, brick, or concrete block.~~

~~3.6. Smokeless propellant shall be separated from materials classified as combustible liquids, flammable liquids, flammable solids, or oxidizing materials by a distance of 25 feet (7620 mm) or by a fire partition having a fire resistance rating of 1 hour.~~

~~3.7. The building shall be equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1.~~

~~4. Smokeless propellants not stored according to Item 1, 2, or 3 above shall be stored in a Type 2 or 4 magazine in accordance with Section 3304 and NFPA 495.~~

**3306.5.2.2 Black powder.** Commercial stocks of black powder in quantities less than 50 pounds (23 kg) shall be allowed to be stored in Type 2 or 4 indoor or outdoor magazines. Quantities greater than 50 pounds (23 kg) shall be stored in outdoor Type 2 or 4 magazines. When black powder and smokeless propellants are stored together in the same magazine, the total quantity shall not exceed that permitted for black powder.

**3306.5.2.3 Small arms primers.** Commercial stocks of small arms primers shall be stored as follows:

1. Quantities exceeding 20 pounds (9 kg), but not exceeding 100 pounds (45 kg) shall be stored in portable wooden boxes having walls of at least 1 inch (25 mm) nominal thickness.
2. Quantities exceeding 750,000 small arms primers stored in a building shall comply with all of the following:
  - 2.1. The warehouse or storage building shall not be accessible to unauthorized personnel.
  - 2.2. Small arms primers shall be stored in cabinets. No more than 200,000 small arms primers shall be stored in any one cabinet.
  - 2.3. Shelves in cabinets shall have vertical separation of at least 2 feet (610 mm).
  - 2.4. Cabinets shall be located against walls of the warehouse or storage room with at least 40 feet (12 192 mm) between cabinets. The minimum required separation between cabinets shall be allowed to be reduced to 20 feet (6096 mm) provided that barricades twice the height of the cabinets are attached to the wall, midway between each cabinet. The barricades shall be firmly attached to the wall and shall be constructed of steel not less than 1/4 inch thick (6.4 mm), 2-inch (51 mm) nominal thickness wood, brick or concrete block.
  - 2.5. Small arms primers shall be separated from materials classified as combustible liquids, flammable liquids, flammable solids or oxidizing materials by a distance of 25 feet (7620 mm) by a fire partition having a fire resistance rating of 1 hour.
  - 2.6. The building shall be protected throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1.
3. Small arms primers not stored in accordance with Item 1 or 2 of this section shall be stored in a magazine meeting the requirements of Section 3304 and NFPA 495.

## **SECTION 3307 BLASTING**

**3307.1 General.** Blasting operations shall be conducted only by approved, competent operators familiar with the required safety precautions and the hazards involved and in accordance with the provisions of NFPA 495.

**3307.2 Manufacturer's instructions.** Blasting operations shall be performed in accordance with the instructions of the manufacturer of the explosive materials being used.

**3307.3 Blasting in congested areas.** When blasting is done in a congested area or in close proximity to a structure, railway or highway, or any other installation, precautions shall be taken to minimize earth vibrations and air blast effects. Blasting mats or other protective means shall be used to prevent fragments from being thrown.

**3307.4 Restricted hours.** Surface blasting operations shall only be conducted during daylight hours. Other blasting shall be performed during daylight hours unless otherwise approved by the fire code official.

**3307.5 Utility notification.** Whenever blasting is being conducted in the vicinity of utility lines or rights of way, the blaster shall notify the appropriate representatives of the utilities at least 24 hours in advance of blasting, specifying the location and intended time of such blasting. Verbal notices shall be confirmed with written notice.

**Exception:** In an emergency situation, the time limit shall not apply when approved.

**3307.6 Electric detonator precautions.** Precautions shall be taken to prevent accidental discharge of electric detonators from currents induced by radar and radio transmitters, lightning, adjacent power lines, dust and snow storms, or other sources of extraneous electricity.

**3307.7 Nonelectric detonator precautions.** Precautions shall be taken to prevent accidental initiation of nonelectric detonators from stray currents induced by lightning or static electricity.

~~**3307.8 Blasting area security.** During the time that holes are being loaded or are loaded with explosive materials, blasting agents or detonators, only authorized persons engaged in drilling and loading operations or otherwise authorized to enter the site shall be allowed at the blast site. The blast site shall be guarded or barricaded and posted. Blast site security shall be maintained until after the post blast inspection has been completed.~~

~~**3307.9 Drill holes.** Holes drilled for the loading of explosive charges shall be made and loaded in accordance with NFPA 495.~~

~~**3307.10 Removal of excess explosive materials.** After loading for a blast is completed and before firing, excess explosive materials shall be removed from the area and returned to the proper storage facilities.~~

~~**3307.11 Initiation means.** The initiation of blasts shall be by means conforming to the provisions of NFPA 495.~~

~~**3307.12 Connections.** The blaster shall supervise the connecting of the blastholes and the connection of the loadline to the power source or initiation point. Connections shall be made progressively from the blasthole back to the initiation point. Blasting lead lines shall remain shunted (shorted) and shall not be connected to the blasting machine or other source of current until the blast is to be fired.~~

~~**3307.13 Firing control.** No blast shall be fired until the blaster has made certain that all surplus explosive materials are in a safe place in accordance with Section 3307.10, all persons and equipment are at a safe distance or under sufficient cover, and that an adequate warning signal has been given.~~

~~**3307.14 Post blast procedures.** After the blast, the following procedures shall be observed.~~

- ~~1. No person shall return to the blast area until allowed to do so by the blaster in charge.~~
- ~~2. The blaster shall allow sufficient time for smoke and fumes to dissipate and for dust to settle before returning to or approaching the blast area.~~
- ~~3. The blaster shall inspect the entire blast site for misfires before allowing other personnel to return to the blast area.~~

~~**3307.15 Misfires.** Where a misfire is suspected, all initiating circuits shall be traced and a search made for unexploded charges. Where a misfire is found, the blaster shall provide proper safeguards for excluding all personnel from the blast area. Misfires shall be reported to the blasting supervisor immediately. Misfires shall be handled under the direction of the person in charge of the blasting operation in accordance with NFPA 495.~~

## **SECTION 3308 FIREWORKS DISPLAY**

~~**3308.1 General.** Outdoor fireworks displays, use of pyrotechnics before a proximate audience and pyrotechnic special effects in motion picture, television, theatrical and group entertainment productions shall comply with Sections 3308.2 through 3308.10 and NFPA 1123 or NFPA 1126 Title 19 California Code of Regulations, Title 19, Division 1, Chapter 6 - Fireworks.~~

~~**3308.1.1 Scope.** *Fireworks and temporary storage, use, and handling of pyrotechnic special effects material used in motion pictures, television, and theatrical and group entertainment productions shall be in accordance with Title 19 California Code of Regulations, Title 19, Division 1, Chapter 6 – Fireworks.*~~

~~**3308.2 Permit application.** Prior to issuing permits for a fireworks display, plans for the display, inspections of the display site and demonstrations of the display operations shall be approved. A plan establishing procedures to follow and actions to be taken in the event that a shell fails to ignite in, or discharge from, a mortar or fails to function over the fallout area or other malfunctions shall be provided to the fire code official.~~

~~**3308.2.1 Outdoor displays.** In addition to the requirements of Section 403, permit applications for outdoor fireworks displays using Division 1.3G fireworks shall include a diagram of the location at which the display will be conducted, including the site from which fireworks will be discharged; the location of buildings, highways, overhead obstructions and utilities; and the lines behind which the audience will be restrained.~~

~~**3308.2.2 Proximate audience displays.** Where the separation distances required by Section 3308.4 and NFPA~~

~~1123 are unavailable or cannot be secured, only proximate audience displays conducted in accordance with NFPA 1126 shall be allowed. Applications for proximate audience displays shall include plans indicating the required clearances for spectators and combustibles, crowd control measures, smoke control measures, and requirements for standby personnel and equipment when provision of such personnel or equipment is required by the fire code official.~~

~~**3308.3 Approved displays.** Approved displays shall include only the approved Division 1.3G, Division 1.4G, and Division 1.4S fireworks, shall be handled by an approved competent operator, and the fireworks shall be arranged, located, ischarged and fired in a manner that will not pose a hazard to property or endanger any person.~~

~~**3308.4 Clearance.** Spectators, spectator parking areas, and dwellings, buildings or structures shall not be located within the display site.~~

**Exceptions:**

- ~~1. This provision shall not apply to pyrotechnic special effects and displays using Division 1.4G materials before a proximate audience in accordance with NFPA 1126.~~
- ~~2. This provision shall not apply to unoccupied dwellings, buildings and structures with the approval of the building owner and the fire code official.~~

~~**3308.5 Storage of fireworks at display site.** The storage of fireworks at the display site shall comply with the requirements of this section and NFPA 1123 or NFPA 1126.~~

~~**3308.5.1 Supervision and weather protection.** Beginning as soon as fireworks have been delivered to the display site, they shall not be left unattended.~~

~~**3308.5.2 Weather protection.** Fireworks shall be kept dry after delivery to the display site.~~

~~**3308.5.3 Inspection.** Shells shall be inspected by the operator or assistants after delivery to the display site. Shells having tears, leaks, broken fuses or signs of having been wet shall be set aside and shall not be fired. Aerial shells shall be checked for proper fit in mortars prior to discharge. Aerial shells that do not fit properly shall not be fired. After the display, damaged, deteriorated or dud shells shall either be returned to the supplier or destroyed in accordance with the supplier's instructions and Section 3304.10.~~

~~**Exception:** Minor repairs to fuses shall be allowed. For electrically ignited displays, attachment of electric matches and similar tasks shall be allowed.~~

~~**3308.5.4 Sorting and separation.** After delivery to the display site and prior to the display, all shells shall be separated according to size and their designation as salutes.~~

~~**Exception:** For electrically fired displays, or displays where all shells are loaded into mortars prior to the show, there is no requirement for separation of shells according to size or their designation as salutes.~~

~~**3308.5.5 Ready boxes.** Display fireworks (Division 1.3G) that will be temporarily stored at the site during the fireworks display shall be stored in ready boxes located upwind and at least 25 feet (7620 mm) from the mortar placement and separated according to size and their designation as salutes.~~

~~**Exception:** For electrically fired displays, or displays where all shells are loaded into mortars prior to the show, there is no requirement for separation of shells according to size, their designation as salutes, or for the use of ready boxes.~~

~~**3308.6 Installation of mortars.** Mortars for firing fireworks shells shall be installed in accordance with NFPA 1123 and shall be positioned so that shells are propelled away from spectators and over the fallout area. Under no circumstances shall mortars be angled toward the spectator viewing area. Prior to placement, mortars shall be inspected for defects, such as dents, bent ends, damaged interiors and damaged plugs. Defective mortars shall not be used.~~

~~**3308.7 Handling.** Aerial shells shall be carried to mortars by the shell body. For the purpose of loading mortars, aerial shells shall be held by the thick portion of the fuse and carefully loaded into mortars.~~

~~**3308.8 Display supervision.** Whenever in the opinion of the fire code official or the operator a hazardous condition exists, the fireworks display shall be discontinued immediately until such time as the dangerous situation is corrected.~~

~~**3308.9 Post-display inspection.** After the display, the firing crew shall conduct an inspection of the fallout area for the purpose of locating unexploded aerial shells or live components. This inspection shall be conducted before public access to the site shall be allowed. Where fireworks are displayed at night and it is not possible to inspect the site thoroughly, the operator or designated assistant shall inspect the entire site at first light. A report identifying any shells that fail to ignite in, or discharge from, a mortar or fail to function over the fallout area or otherwise malfunction shall be filed with the fire code official.~~

~~**3308.10 Disposal.** Any shells found during the inspection required in Section 3308.9 shall not be handled until at least 15 minutes have elapsed from the time the shells were fired. The fireworks shall then be doused with water and allowed to remain for at least 5 additional minutes before being placed in a plastic bucket or fiberboard box. The disposal instructions of the manufacturer as provided by the fireworks supplier shall then be followed in disposing of the fireworks in accordance with Section 3304.10.~~

~~**3308.11 Retail display and sale.** Fireworks displayed for retail sale shall not be made readily accessible to the public. A minimum of one pressurized water portable fire extinguisher complying with Section 906 shall be located not more than 15 feet (4572 mm) and not less than 10 feet (3048 mm) from the hazard. "No Smoking" signs complying with Section 310 shall be conspicuously posted in areas where fireworks are stored or displayed for retail sale.~~

## CHAPTER 34 FLAMMABLE AND COMBUSTIBLE LIQUIDS

**3401.3 Referenced documents.** The applicable requirements of Chapter 27, other chapters of this code, the *International California Building Code* and the *International California Mechanical Code* pertaining to flammable liquids shall apply.

**3403.1 Electrical.** Electrical wiring and equipment shall be installed and maintained in accordance with the ~~NEPA-70~~ *California Electrical Code*.

**Table 3403.1.1** (footnotes)

For SI: 1 inch = 25.4 mm, 1 foot = 304.8 mm.

- a. Locations as classified in the ~~NEPA-70~~ *California Electrical Code*.
- b. When classifying extent of area, consideration shall be given to the fact that tank cars or tank vehicles can be spotted at varying points. Therefore, the extremities of the loading or unloading positions shall be used.
- c. The release of Class I liquids can generate vapors to the extent that the entire building, and possibly a zone surrounding it, are considered a Class I, Division 2 location.

**3403.1.3 Other applications.** The fire code official is authorized to determine the extent of the Class I electrical equipment and wiring location when a condition is not specifically covered by these requirements or the ~~NEPA-70~~ *California Electrical Code*.

**3403.6.1 Nonapplicability.** The provisions of Section 3403.6 shall not apply to gas or oil well installations; piping that is integral to stationary or portable engines, including aircraft, watercraft and motor vehicles; and piping in connection with boilers and pressure vessels regulated by the *International California Mechanical Code*.

**3404.2.1 Change of tank contents.** Tanks subject to change in contents shall be in accordance with 3404.2.7. Prior to change in contents, the fire code official is authorized to require testing of a tank.

Tanks that have previously contained Class I liquids shall not be loaded with Class II or Class III liquids until such vehicles and all piping, pumps, hoses and meters connected thereto have been completely drained and flushed.

**Exception:** *When approved by the Enforcing Agency the procedures prescribed in API (API-RP-2003) Recommended Practices 2003 entitled; Protection Against Ignitions Arising Out of Static, Lightning, and Stray*

*Currents may be used for changing tank contents.*

**3404.2.7.7 Design of supports.** The design of the supporting structure for tanks shall be in accordance with the *International California Building Code* and NFPA 30.

**3404.2.8.1 Listing required.** Vaults shall be listed in accordance with UL 2245.

**Exception:** Where approved by the fire code official, below-grade vaults are allowed to be constructed on site, provided that the design is in accordance with the *International California Building Code* and that special inspections are conducted to verify structural strength and compliance of the installation with the approved design in accordance with Section 1707 of the *International California Building Code*. Installation plans for below-grade vaults that are constructed on site shall be prepared by, and the design shall bear the stamp of, a professional engineer. Consideration shall be given to soil and hydrostatic loading on the floors, walls and lid; anticipated seismic forces; uplifting by ground water or flooding; and to loads imposed from above such as traffic and equipment loading on the vault lid.

**3404.2.8.2 Design and construction.** The vault shall completely enclose each tank. There shall be no openings in the vault enclosure except those necessary for access to, inspection of, and filling, emptying and venting of the tank. The walls and floor of the vault shall be constructed of reinforced concrete at least 6 inches (152 mm) thick. The top of an above-grade vault shall be constructed of noncombustible material and shall be designed to be weaker than the walls of the vault, to ensure that the thrust of an explosion occurring inside the vault is directed upward before significantly high pressure can develop within the vault. The top of an at-grade or below-grade vault shall be designed to relieve safely or contain the force of an explosion occurring inside the vault. The top and floor of the vault and the tank foundation shall be designed to withstand the anticipated loading, including loading from vehicular traffic, where applicable. The walls and floor of a vault installed below grade shall be designed to withstand anticipated soil and hydrostatic loading. Vaults shall be designed to be wind and earthquake resistant, in accordance with the *International California Building Code*.

**3404.2.8.9 Ventilation.** Vaults that contain tanks of Class I liquids shall be provided with an exhaust ventilation system installed in accordance with Section 2704.3. The ventilation system shall operate continuously or be designed to operate upon activation of the vapor or liquid detection system. The system shall provide ventilation at a rate of not less than 1 cubic foot per minute (cfm) per square foot of floor area [0.00508 m<sup>3</sup>/(s × m<sup>2</sup>)], but not less than 150 cfm (0.071m<sup>3</sup>/s). The exhaust system shall be designed to provide air movement across all parts of the vault floor. Supply and exhaust ducts shall extend to within 3 inches (76 mm), but not more than 12 inches (305 mm), of the floor. The exhaust system shall be installed in accordance with the *International California Mechanical Code*.

**3404.2.8.12 Liquid removal.** Means shall be provided to recover liquid from the vault. Where a pump is used to meet this requirement, the pump shall not be permanently installed in the vault. Electric-powered portable pumps shall be suitable for use in Class I, Division 1, or zone 0 locations, as defined in the ~~NFPA-70~~ *California Electrical Code*.

**3404.2.8.17 Classified area.** The interior of a vault containing a tank that stores a Class I liquid shall be designated a Class I, Division 1, or zone 0 location, as defined in the ~~NFPA-70~~ *California Electrical Code*.

**3404.2.9.1.2 Foam fire protection system installations.** Foam fire protection system installation. Where foam fire protection is required, it shall be installed in accordance with NFPA-11 (*Section 4.8*) and NFPA-11A.

**3404.2.9.3 Supports, foundations and anchorage.** Supports, foundations and anchorages for above-ground tanks shall be designed and constructed in accordance with NFPA 30 and the *International California Building Code*.

**3404.2.9.4 Stairs, platforms and walkways.** Stairs, platforms and walkways shall be of noncombustible construction and shall be designed and constructed in accordance with NFPA 30 and the *International California Building Code*.

**3404.2.9.6.1 Locations where above-ground tanks are prohibited.** Storage of Class I and II liquids in above-ground tanks outside of buildings is prohibited within the limits established by law as the limits of districts in which such storage is prohibited (see Section 3 of the Sample Ordinance for Adoption of the *International California Fire Code* on page v).

**3404.3.3.5 Shelf storage.** Shelving shall be of approved construction, adequately braced and anchored. Seismic requirements shall be in accordance with the ~~International~~ *California Building Code*.

**3404.3.7.1 General.** Quantities of liquids exceeding those set forth in Section 3404.3.4.1 for storage in control areas shall be stored in a liquid storage room complying with this section and constructed and separated as required by the ~~International~~ *California Building Code*.

**3404.3.8 Liquid storage warehouses.** Buildings used for storage of flammable or combustible liquids in quantities exceeding those set forth in Section 3404.3.4 for control areas and Section 3404.3.7 for liquid storage rooms shall comply with Sections 3404.3.8.1 through 3404.3.8.5 and shall be constructed and separated as required by the ~~International~~ *California Building Code*.

**3405.3.4 Location of processing vessels.** Processing vessels shall be located with respect to distances to lot lines of adjoining property which can be built on, in accordance with Tables 3405.3.4(1) and 3405.3.4(2).

**Exception:** Where the exterior wall facing the adjoining lot line is a blank wall having a fire-resistance rating of not less than 4 hours, the fire code official is authorized to modify the distances. The distance shall not be less than that set forth in the ~~International~~ *California Building Code*, and when Class IA or unstable liquids are involved, explosion control shall be provided in accordance with Section 911.

**3405.3.5.3 Quantities exceeding limits for control areas.** Quantities exceeding the maximum allowable quantity per control area indicated in Sections 3405.3.5.1 and 3405.3.5.2 shall be in accordance with the following:

1. For open systems, indoor use, dispensing and mixing of flammable and combustible liquids shall be within a room or building complying with the ~~International~~ *California Building Code* and Sections 3405.3.7.1 through 3405.3.7.5.
2. For closed systems, indoor use, dispensing and mixing of flammable and combustible liquids shall be within a room or building complying with the ~~International~~ *California Building Code* and Sections 3405.3.7 through 3405.3.7.4 and 3405.3.7.6.

**3405.3.7.1 Construction, location and fire protection.** Rooms or buildings classified in accordance with the ~~International~~ *California Building Code* as Group H-2 or H-3 occupancies based on use, dispensing or mixing of flammable or combustible liquids shall be constructed in accordance with the ~~International~~ *California Building Code*.

**3405.3.7.2 Basements.** In rooms or buildings classified in accordance with the ~~International~~ *California Building Code* as Group H-2 or H-3, dispensing or mixing of flammable or combustible liquids shall not be conducted in basements.

**3405.3.7.3 Fire protection.** Rooms or buildings classified in accordance with the ~~International~~ *California Building Code* as Group H-2 or H-3 occupancies shall be equipped with an approved automatic fire-extinguishing system in accordance with Chapter 9.

**3405.3.7.4 Doors.** Interior doors to rooms or portions of such buildings shall be self-closing fire doors in accordance with the ~~International~~ *California Building Code*.

**3405.3.7.5.1 Ventilation.** Continuous mechanical ventilation shall be provided at a rate of not less than 1 cubic foot per minute per square foot [0.00508m<sup>3</sup>/(s ×m<sup>2</sup>)] of floor area over the design area. Provisions shall be made for introduction of makeup air in such a manner to include all floor areas or pits where vapor can collect. Local or spot ventilation shall be provided when needed to prevent the accumulation of hazardous vapors. Ventilation system design shall comply with the ~~International~~ *California Building Code* and ~~International~~ *California Mechanical Code*.

**Exception:** Where natural ventilation can be shown to be effective for the materials used, dispensed or mixed.

**3406.2 Storage and dispensing of flammable and combustible liquids on farms and construction sites.** Permanent and temporary storage and dispensing of Class I and II liquids for private use on farms and rural areas and at construction sites, earth-moving projects, gravel pits or borrow pits shall be in accordance with Sections

3406.2.1 through 3406.2.8.1.

**Exception:** Storage and use of fuel oil and containers connected with oil-burning equipment regulated by Section 603 and the ~~International~~ *California Mechanical Code*.

**3406.2.3 Containers for storage and use.** Metal containers used for storage of Class I or II liquids shall be in accordance with DOTn requirements or shall be of an approved design.

Discharge devices shall be of a type that do not develop an internal pressure on the container. Pumping devices or approved self-closing faucets used for dispensing liquids shall not leak and shall be well-maintained. Individual containers shall not be interconnected and shall be kept closed when not in use.

Containers stored outside of buildings shall be in accordance with Section 3404 and the ~~International~~ *California Building Code*.

**3406.2.4.4 Locations where above-ground tanks are prohibited.** The storage of Class I and II liquids in above-ground tanks is prohibited within the limits established by law as the limits of districts in which such storage is prohibited (see Section 3 of the Sample Ordinance for Adoption of the ~~International~~ *California Fire Code* on page v).

**3406.2.8 Dispensing from tank vehicles.** Where approved, liquids used as fuels are allowed to be transferred from tank vehicles into the tanks of motor vehicles or special equipment, provided:

1. The tank vehicle's specific function is that of supplying fuel to motor vehicle fuel tanks.
2. The dispensing hose does not exceed 100 feet (30 480mm) in length.
3. The dispensing nozzle is an approved type.
4. The dispensing hose is properly placed on an approved reel or in a compartment provided before the tank vehicle is moved.
5. Signs prohibiting smoking or open flames within 25 feet (7620 mm) of the vehicle or the point of refueling are prominently posted on the tank vehicle.
6. Electrical devices and wiring in areas where fuel dispensing is conducted are in accordance with the ~~NEPA 70~~ *California Electrical Code*.
7. Tank vehicle-dispensing equipment is operated only by designated personnel who are trained to handle and dispense motor fuels.
8. Provisions are made for controlling and mitigating unauthorized discharges.

**3406.4.1 Building construction.** Buildings shall be constructed in accordance with the ~~International~~ *California Building Code*.

**3406.4.4 Ventilation.** Ventilation shall be provided for rooms, buildings and enclosures in which Class I liquids are pumped, used or transferred. Design of ventilation systems shall consider the relatively high specific gravity of the vapors. When natural ventilation is used, adequate openings in outside walls at floor level, unobstructed except by louvers or coarse screens, shall be provided. When natural ventilation is inadequate, mechanical ventilation shall be provided in accordance with the ~~International~~ *California Mechanical Code*.

**3406.5.1.11 Switch loading.** Tank vehicles or tank cars which have previously contained Class I liquids shall not be loaded with Class II or Class III liquids until such vehicles and all piping, pumps, hoses and meters connected thereto have been completely drained and flushed.

**Exception:** *When approved by the Enforcing Agency the procedures prescribed in API (API-RP-2003) Recommended Practices 2003 entitled; Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents may be used for changing tank contents.*

## CHAPTER 35 FLAMMABLE GASES

**3501.1 Scope.** The storage and use of flammable gases shall be in accordance with this chapter. Compressed gases shall also comply with Chapter 30 and cryogenic fluids shall also comply with Chapter 32. Bulk hydrogen compressed gas systems and bulk liquefied hydrogen gas systems shall comply with NFPA 55. Hydrogen motor fuel-dispensing stations and repair garages and their associated above-ground hydrogen storage systems shall also be designed and constructed in accordance with Chapter 22.

**Exceptions:**

1. Gases used as refrigerants in refrigeration systems (see Section 606).
2. Liquefied petroleum gases and natural gases regulated by Chapter 38.
3. Fuel-gas systems and appliances regulated under the ~~International Fuel Gas~~ *California Mechanical Code or the California Plumbing Code*.
4. Pyrophoric gases in accordance with Chapter 41.

**3503.1.4 Ignition source control.** Ignition sources in areas containing flammable gases in storage or in use shall be controlled in accordance with Section 2703.7.

**Exception:** Fuel gas systems connected to building service utilities in accordance with the ~~International Fuel Gas~~ *California Mechanical Code*.

**3503.1.5 Electrical.** Electrical wiring and equipment shall be installed and maintained in accordance with Section 605 and ~~NFPA-70~~ *California Electrical Code*.

**3503.1.5.1 Bonding of electrically conductive materials and equipment.** Exposed noncurrent-carrying metal parts, including metal gas piping systems, that are part of flammable gas supply systems located in a hazardous (electrically classified) location shall be bonded to a grounded conductor in accordance with the provisions of the ~~NFPA-70~~ *California Electrical Code*.

## CHAPTER 36 FLAMMABLE SOLIDS

**3606.2.2 Storage of greater than 1,000 cubic feet.** Magnesium storage in quantities greater than 1,000 cubic feet (28 m<sup>3</sup>) shall be separated into piles not larger than 1,000 cubic feet (28 m<sup>3</sup>) each. Piles shall be separated by aisles with a minimum width of not less than the pile height. Such storage shall not be located in nonsprinklered buildings of Type III, IV or V construction, as defined in the ~~International~~ *California Building Code*.

**3606.2.3 Storage in combustible containers or within 30 feet of other combustibles.** Where in nonsprinklered buildings of Type III, IV or V construction, as defined in the ~~International~~ *California Building Code*, magnesium shall not be stored in combustible containers or within 30 feet (9144 mm) of other combustibles.

**3606.4.2 Storage of 50 to 1,000 cubic feet.** Storage of fine magnesium scrap in quantities greater than 50 cubic feet (1.4 m<sup>3</sup>) [six 55-gallon (208 L) steel drums] shall be separated from other occupancies by an open space of at least 50 feet (15 240 mm) or by a fire barrier constructed in accordance with the ~~International~~ *California Building Code*.

**3606.5.5 Electrical equipment.** Electric wiring, fixtures and equipment in the immediate vicinity of and attached to dust-producing machines, including those used in connection with separator equipment, shall be of approved types and shall be approved for use in Class II, Division 1 hazardous locations in accordance with the ~~NFPA-70~~ *California Electrical Code*.

**3606.5.6 Grounding.** Equipment shall be securely grounded by permanent ground wires in accordance with the ~~NFPA-70~~ *California Electrical Code*.

## CHAPTER 37 HIGHLY TOXIC AND TOXIC MATERIALS

**3703.1.3 Treatment system—highly toxic liquids.** Exhaust scrubbers or other systems for processing vapors of highly toxic liquids shall be provided where a spill or accidental release of such liquids can be expected to release

highly toxic vapors at normal temperature and pressure. Treatment systems and other processing systems shall be installed in accordance with the ~~International~~ *California Mechanical Code*.

**3703.1.4.2 Separation—highly toxic solids and liquids.** In addition to the requirements set forth in Section 2703.9.8, highly toxic solids and liquids in storage shall be located in approved hazardous material storage cabinets or isolated from other hazardous material storage by construction in accordance with the ~~International~~ *California Building Code*.

**3704.2.2.7 Treatment systems.** The exhaust ventilation from gas cabinets, exhausted enclosures and gas rooms, and local exhaust systems required in Sections 3704.2.2.4 and 3704.2.2.5 shall be directed to a treatment system. The treatment system shall be utilized to handle the accidental release of gas and to process exhaust ventilation. The treatment system shall be designed in accordance with Sections 3704.2.2.7.1 through 3704.2.2.7.5 and ~~Section 510 Chapter 5~~ of the ~~International~~ *California Mechanical Code*.

**Exceptions:**

1. Highly toxic and toxic gases-storage. A treatment system is not required for cylinders, containers and tanks in storage when all of the following controls are provided:
  - 1.1. Valve outlets are equipped with gas-tight outlet plugs or caps.
  - 1.2. Handwheel-operated valves have handles secured to prevent movement.
  - 1.3. Approved containment vessels or containment systems are provided in accordance with Section 3704.2.2.3.
2. Toxic gases—use. Treatment systems are not required for toxic gases supplied by cylinders or portable tanks not exceeding 1,700 pounds (772 kg) water capacity when the following are provided:
  - 2.1. A *listed or approved* gas detection system with a sensing interval not exceeding 5 minutes.
  - 2.2. An *listed or approved* automatic-closing fail-safe valve located immediately adjacent to cylinder valves. The fail-safe valve shall close when gas is detected at the PEL by a gas detection system monitoring the exhaust system at the point of discharge from the gas cabinet, exhausted enclosure, ventilated enclosure or gas room. The gas detection system shall comply with Section 3704.2.2.10.

**3703.2.3.2 Treatment system—highly toxic liquids.** Exhaust scrubbers or other systems for processing vapors of highly toxic liquid shall be provided where a spill or accidental release of such liquids can be expected to release highly toxic vapors at normal temperature and pressure (NTP). Treatment systems and other processing systems shall be installed in accordance with the ~~International~~ *California Mechanical Code*.

**3704.2.2.8 Emergency power.** Emergency power in accordance with Section 604 and the ~~NFPA-70~~ *California Electrical Code* shall be provided in lieu of standby power where any of the following systems are required:

1. Exhaust ventilation system.
2. Treatment system.
3. Gas detection system.
4. Smoke detection system.
5. Temperature control system.
6. Fire alarm system.
7. Emergency alarm system.

**Exception:** Emergency power is not required for mechanical exhaust ventilation, treatment systems and temperature control systems where approved fail-safe engineered systems are installed.

**3705.3.1 Cabinets.** Ozone cabinets shall be constructed of approved materials and compatible with ozone. Cabinets shall display an approved sign stating: OZONE GAS GENERATOR—HIGHLY TOXIC—OXIDIZER. Cabinets shall be braced for seismic activity in accordance with the ~~International~~ *California Building Code*. Cabinets shall be mechanically ventilated in accordance with the ~~International~~ *California Mechanical Code* with a minimum of six air changes per hour. The average velocity of ventilation at makeup air openings with cabinet doors

closed shall not be less than 200 feet per minute (1.02 m/s).

**3705.3.2 Ozone gas generator rooms.** Ozone gas generator rooms shall be mechanically ventilated in accordance with the ~~International~~ *California Mechanical Code* with a minimum of six air changes per hour. Ozone gas generator rooms shall be equipped with a continuous gas detection system which will shut off the generator and sound a local alarm when concentrations above the permissible exposure limit occur. Ozone gas-generator rooms shall not be normally occupied, and such rooms shall be kept free of combustible and hazardous material storage. Room access doors shall display an approved sign stating: OZONE GAS GENERATOR—HIGHLY TOXIC—OXIDIZER.

## CHAPTER 38 LIQUEFIED PETROLEUM GASES

**3803.1 General.** LP-gas equipment shall be installed in accordance with the ~~International Fuel Gas~~ *California Mechanical Code* and NFPA 58, except as otherwise provided in this chapter.

**3803.2.1.7 Use for food preparation.** Where approved, listed LP-gas commercial food service appliances are allowed to be used for food-preparation within restaurants and in attended commercial food-catering operations in accordance with the ~~International Fuel Gas, the International~~ *California Mechanical Code* and NFPA58.

**3803.3 Location of equipment and piping.** Equipment and piping shall not be installed in locations where such equipment and piping is prohibited by the ~~International Fuel Gas~~ *California Mechanical Code*.

**3804.2 Maximum capacity within established limits.** Within the limits established by law restricting the storage of liquefied petroleum gas for the protection of heavily populated or congested areas, the aggregate capacity of any one installation shall not exceed a water capacity of 2,000 gallons (7570 L) (see Section 3 of the Sample Ordinance for Adoption of the ~~International~~ *California Fire Code* on page v).

**Exception:** In particular installations, this capacity limit shall be determined by the fire code official, after consideration of special features such as topographical conditions, nature of occupancy, and proximity to buildings, capacity of proposed LP-gas containers, degree of fire protection to be provided and capabilities of the local fire department.

**3809.11.2 Construction.** The construction of such buildings and rooms shall comply with requirements for Group H occupancies in the ~~International~~ *California Building Code*; Chapter 10 of NFPA 58, and both of the following:

1. Adequate vents shall be provided to the outside at both top and bottom, located at least 5 feet (1524 mm) from building openings.
2. The entire area shall be classified for the purposes of ignition source control in accordance with Section 6.2 of NFPA 58.

## CHAPTER 39 ORGANIC PEROXIDES

**3904.1.2 Distance from detached storage buildings to exposures.** In addition to the requirements of the ~~International~~ *California Building Code*, detached storage buildings shall be located in accordance with Table 3904.1.2.

## CHAPTER 40 OXIDIZERS

**4004.1.2 Distance from detached storage buildings to exposures.** In addition to the requirements of the ~~International~~ *California Building Code*, detached storage buildings shall be located in accordance with Table 4004.1.2.

## CHAPTER 41 PYROPHORIC MATERIALS

**4104.1.4 Separation from incompatible materials.** In addition to the requirements of Section 2703.9.8, indoor

storage of pyrophoric materials shall be isolated from incompatible hazardous materials by 1-hour fire barriers with openings protected in accordance with the ~~International~~ California Building Code.

**Exception:** Storage in approved hazardous materials storage cabinets constructed in accordance with Section 2703.8.7.

### CHAPTER 43 UNSTABLE (REACTIVE) MATERIALS

**4304.1 Indoor storage.** Indoor storage of unstable (reactive) materials in amounts exceeding the maximum allowable quantity per control area indicated in Table 2703.1.1(1) shall be in accordance with Sections 2701, 2703, 2704 and this chapter. In addition, Class 3 and 4 unstable (reactive) detonable materials shall be stored in accordance with the ~~International~~ California Building Code requirements for explosives.

### CHAPTER 46 CONSTRUCTION REQUIREMENTS FOR EXISTING BUILDINGS

~~907.3.1.3~~ **4603.6.3 Group I-2 and Group I-2.1.** An automatic fire alarm system that activates the occupant notification system in accordance with Section 907.6 shall be installed in existing Group I-2 and Group I-2.1 occupancies in accordance with Section 907.2.6.2.

**Exception:** Manual fire alarm boxes in resident or patient sleeping areas shall not be required at exits if located at all nurses' control stations or other constantly attended staff locations, provided such stations are visible and continuously accessible and that travel distances required in Section 907.5.2.1 are not exceeded.

~~907.3.1.9~~ **4603.6.8 Existing Group R 1 and Group R 2 High-rise.** Notwithstanding the provisions of Section 403-20 3412.23 of the California Building Code, every existing high-rise building used for the housing of a Group R-1 or Group R-2 Occupancies shall have installed therein a fire alarm system conforming to this subsection.

~~907.3.1.9.1~~ **4603.6.8.1 General.** Every apartment house and every hotel shall have installed therein an automatic or manually operated fire alarm system. Such fire alarm systems shall be so designed that all occupants of the building may be warned simultaneously.

~~907.3.1.9.2~~ **4603.6.8.2 Installation.** The installation of all fire alarm equipment shall be in accordance with this Code.

#### ~~907.3.1.10~~ **4603.6.9 Existing High-rise Buildings**

~~907.3.1.10.1~~ **4603.6.9.1 Fire alarm system.** Every existing high-rise building shall be provided with an approved fire alarm system. In department stores, retail sales stores and similar occupancies where the general public is admitted, such systems shall be of a type capable of alerting staff and employees. In office buildings and all other high-rise buildings, such systems shall be of a type capable of alerting all occupants simultaneously.

#### **Exceptions:**

1. In areas of public assemblage, the type and location of audible appliances shall be as determined by the enforcing agency.
2. When acceptable to the enforcing agency, the occupant voice notification system required by California Building Code Section 3412.21 may be used in lieu of the fire alarm system.

~~907.3.1.10.2~~ **4603.6.9.2 Existing systems.** Existing fire alarm systems, when acceptable to the enforcing agency, shall be deemed as conforming to the provisions of these regulations.

~~907.3.1.10.3~~ **4603.6.9.3 Annunciation.** When a new fire alarm system is installed, it shall be connected to an annunciator panel installed in a location approved by the enforcing agency.

For purposes of annunciation, zoning shall be in accordance with Section ~~907.9~~907.7.3.1:

**907.3.1.10.4 4603.6.9.4 Monitoring** Shall be in accordance with section ~~907.15~~907.7.5.

**907.3.1.10.5 4603.6.9.5 Systems Interconnection.** When an automatic fire detection system or automatic extinguishing system is installed, activation of such system shall cause the sounding of the fire alarm notification appliances at locations designated by the enforcing agency.

**907.3.1.10.6 4603.6.9.6 Manual fire alarm boxes.** A manual fire alarm box shall be provided in the locations designated by the enforcing agency. Such locations shall be where boxes are readily accessible and visible and in normal paths of daily travel by occupants of the building.

**907.3.1.10.7 4603.6.9.7 Emergency voice/alarm communication system.** An approved emergency voice/alarm commutation system shall be provided in every existing high-rise building which exceeds 150 feet (45720 mm) in height measured in the manner set forth in Section 403-2.4 of the California Building Code. Such system shall provide communication from a location available to and designated by the enforcing agency to not less than all public areas.

The emergency voice/alarm commutation system may be combined with a fire alarm system provide the combined system has been approved and listed by the State Fire Marshal. The sounding of a fire alarm signal in any given area or floor shall not prohibit voice communication to other areas of floors. Combination systems shall be designed to permit voice transmission to override the fire alarm signal, but the fire alarm signal shall not terminate in less than three minutes.

**907.3.1.10.8 4603.6.9.8 Fire department system.** When it is determined by test that portable fire department communication equipment is ineffective, a communication system acceptable to the enforcing agency shall be installed within the building to permit emergency communication between fire-suppression personnel.

**907.3.1.10.9 4603.6.9.9 Smoke control systems.** Existing air-circulation systems shall be provided with an override switch in a location approved by the enforcing agency which will allow for the manual control of shutdown of the systems.

**Exception:** Systems which serve only a single floor, or portion thereof, without any penetration by ducts or other means into adjacent floors.

**907.3.1.10.10 4603.6.9.10 Elevator recall smoke detection.** Smoke detection for emergency operation of elevators shall be provided in accordance with Section ~~607~~907.4.3.

**907.3.2 4603.7 Single- and multiple-station smoke alarms.** Single and multiple-station smoke alarms shall be installed in existing Group R and Group I-1 occupancies and in dwellings not classified as Group R occupancies in accordance with Sections 4603.7.1 through 4603.7.3.

**907.3.2.1 4603.7.1 Where required.** Existing Group R and Group I-1 occupancies and in dwellings not classified as Group R occupancies not already provided with single-station smoke alarms shall be provided with single-station smoke alarms. Installation shall be in accordance with Section 907.2.10, except as provided in Sections 4603.7.2 and 4603.7.3.

**907.3.2.3 4603.7.3 Power source.** Single-station smoke alarms shall receive their primary power from the building wiring provided that such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms with integral strobes that are not equipped with battery backup shall be connected to an emergency electrical system. Smoke alarms shall emit a signal when the batteries are low. Wiring shall be permanent and without a disconnecting switch other than as required for overcurrent protection.

**Exceptions:**

1. Smoke alarms are permitted to be solely battery operated in existing buildings where no construction is taking place.
2. Smoke alarms are permitted to be solely battery operated in buildings that are not served from a commercial power source.

3. Smoke alarms are permitted to be solely battery operated in existing areas of buildings undergoing alterations or repairs or construction, requiring a permit, not exceeding \$1000 that do not result in the removal of interior walls or ceiling finishes exposing the structure, unless there is an attic, crawl space or basement available which could provide access for building wiring without the removal of interior finishes.

~~907.3.2.4~~ **4603.7.4 Group R-3.1** *In all facilities housing a bedridden client, smoke alarms shall receive their primary power from the building wiring when such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms shall be electrically interconnected so as to cause all smoke alarms to sound a distinctive alarm signal upon actuation of any single smoke alarm. Such alarm signal shall be audible throughout the facility at a minimal level of 15 db above ambient noise level. These devices need not be interconnected to any other fire alarm device, have a control panel, or be electrically supervised or provided with emergency power.*

~~907.2.10.5.1~~ **4603.7.5.1** *Existing Buildings housing Group R-3 Occupancies established prior to the effective date of these regulations may have their use continued if they conform or are made to conform to provisions of these regulations to the extent that reasonable and adequate life safety against the hazards of fire, panic and explosion is substantially provided. Additional means of egress, the installation of automatic sprinkler systems, automatic fire alarm system or other life safety measures, may be required to provide reasonable and adequate safety.*

**Note:** *It is the intent of this sections that every existing occupancy need not mandatorily conform with the requirements for new construction. Reasonable judgment in the application of requirements must be exercised by the enforcing agency.*

~~907.2.10.5.1.2~~ **4603.7.5.2** *For purposes of clarification, Health and Safety Code section 13113.7 is repeated.*

(a) *Except as otherwise provided in this section, a smoke detector, approved and listed by the State Fire Marshal pursuant to Section 13114, shall be installed, in accordance with the manufacturer's instructions in each dwelling intended for human occupancy within the earliest applicable time period as follows:*

(1) *For all dwelling units intended for human occupancy, upon the owner's application on or after January 1, 1985, for a permit for alterations, repairs, or additions, exceeding one thousand dollars (\$1,000).*

(2) *For all other dwelling units intended for human occupancy on or after January 1, 1987.*

*However, if any local rule, regulation, or ordinance, adopted prior to the compliance dates specified in paragraphs (1) and (2) requires installation in a dwelling unit intended for human occupancy of smoke detector, which receive their power from the electrical system of the building and requires compliance with the local rule, regulation, or ordinance at a date subsequent to the dates specified in this section, the compliance date specified in the rule, regulation, or ordinance shall, but only with respect to the dwelling units specified in this section, take precedence over the dates specified in this section.*

*The State Fire Marshal may adopt regulations exempting dwellings intended for human occupancy with fire sprinkler systems from the provisions of this section, if he or she determines that a smoke detector is not reasonably necessary for fire safety in the occupancy.*

*Unless prohibited by local rules, regulations, or ordinances, a battery-operated smoke detector which otherwise meets the standards adopted pursuant to Section 13114 for smoke detectors, satisfies the requirements of this section.*

(b) *"Dwelling units intended for human occupancy," as used in this section, includes a duplex, lodging house, apartment complex, hotel, motel, condominium, stock cooperative, time-share project, or dwelling unit of a multiple-unit dwelling complex. For the purpose of this part, "dwelling units intended for human occupancy" does not include manufactured homes as defined in Section 18007, mobilehomes as defined in Section 18008, and commercial coaches as defined in 18001.8.*

(c) *The owner of each dwelling unit subject to this section shall supply and install smoke detectors required by this section in the locations and in the manner set forth in the manufacturer's instructions, as approved by the State Fire Marshal's regulations. In the case of apartment complexes and other multiple-dwelling complexes, a smoke detector shall be installed in the common stairwells. All fire alarm warning systems supplemental to the smoke detector shall also be listed by the State Fire Marshal.*

(d) *A high rise structure, as defined in subdivision (b) of Section 13210 and regulated by Chapter 3 (commencing with Section 13210), and which is used for purposes other than as dwelling units intended for human occupancy, is exempt from the requirements of this section.*

(e) *The owner shall be responsible for testing and maintaining detectors in hotels, motels, lodging houses, and common stairwells of apartment complexes and other multiple dwelling complexes.*

An owner or the owner's agent may enter any dwelling unit, efficiency dwelling unit, guest room, and suite owned by the owner for the purpose of installing, repairing, testing, and maintaining single station smoke detectors required by this section. Except in cases of emergency, the owner or owner's agent shall give the tenants of each such unit, room, or suite reasonable notice in writing of the intention to enter and shall enter only during normal business hours. Twenty-four hours shall be presumed to be reasonable notice in absence of evidence to the contrary.

The smoke detector shall be operable at the time that the tenant takes possession. The apartment complex tenant shall be responsible for notifying the manager or owner if the tenant becomes aware of an inoperable smoke detector within his or her unit. The owner or authorized agent shall correct any reported deficiencies in the smoke detector and shall not be in violation of this section for a deficient smoke detector when he or she has not received notice of the deficiency.

(f) A violation of this section is an infraction punishable by a maximum fine of two hundred dollars (\$200) for each offense.

(g) This section shall not affect any rights which the parties may have under any other provision of law because of the presence or absence of a smoke detector.

(h) This section shall not apply to the installation of smoke detectors in single-family dwellings or factory-built housing which is regulated by Section 13113.8, as added by Assembly Bill No. 2285 of the 1983-84 Regular Session.

~~907.2.10.5.3~~ ~~4603.7.5.3~~ For purposes of clarification, Health and Safety Code section 13113.8 is repeated.

(a) On and after January 1, 1986, every single-family dwelling and factory-built housing, as defined in Section 19971, which is sold shall have an operable smoke detector. The detector shall be approved and listed by the State Fire Marshal and installed in accordance with the State Fire Marshal's regulations. Unless prohibited by local rules, regulations, or ordinances, a battery-operated smoke detector shall be deemed to satisfy the requirements of this section.

(b) On and after January 1, 1986, the transferor of any real property containing a single-family dwelling, as described in subdivision (a), whether the transfer is made by sale, exchange, or real property sales contract, as defined in Section 2985 of the Civil Code, shall deliver to the transferee a written statement indicating that the transferor is in compliance with this section. The disclosure statement shall be either included in the receipt for deposit in a real estate transaction, an addendum attached thereto, or a separate document.

(c) The transferor shall deliver the statement referred to in subdivision (b) as soon as practicable before the transfer of title in the case of a sale or exchange, or prior to execution of the contract where the transfer is by a real property sales contract, as defined in Section 2985. For purposes of this subdivision, "delivery" means delivery in person or by mail to the transferee or transferor, or to any person authorized to act for him or her in the transaction, or to additional transferees who have requested delivery from the transferor in writing. Delivery to the spouse of a transferee or transferor shall be deemed delivery to a transferee or transferor, unless the contract states otherwise.

(d) This section does not apply to any of the following:

(1) Transfers which are required to be preceded by the furnishing to a prospective transferee of a copy of a public report pursuant to Section 11018.1 of the Business and Professions Code.

(2) Transfers pursuant to court order, including, but not limited to, transfers ordered by a probate court in the administration of an estate, transfers pursuant to a writ of execution, transfers by a trustee in bankruptcy, transfers by eminent domain, or transfers resulting from a decree for specific performance.

(3) Transfers to a mortgagee by a mortgagor in default, transfers to a beneficiary of a deed of trust by a trustor in default, transfers by any foreclosure sale after default, transfers by any foreclosure sale after default in an obligation secured by a mortgage, or transfers by a sale under a power of sale after a default in an obligation secured by a deed of trust or secured by any other instrument containing a power of sale.

(4) Transfers by a fiduciary in the course of the administration of a decedent's estate, guardianship, conservatorship, or trust.

(5) Transfers from one co-owner to one or more co-owners.

(6) Transfers made to a spouse, or to a person or persons in the lineal line of consanguinity of one or more of the transferors.

(7) Transfers between spouses resulting from a decree of dissolution of a marriage, from a decree of legal separation, or from a property settlement agreement incidental to either of those decrees.

(8) Transfers by the Controller in the course of administering the Unclaimed Property Law provided for in Chapter 7 (commencing with Section 1500) of Title 10 of Part 3 of the Code of Civil Procedure.

(9) Transfers under the provisions of Chapter 7 (commencing with Section 3691) or Chapter 8 (commencing with Section 3771) of Part 6 of Division 1 of the Revenue and Taxation Code.

(e) No liability shall arise, nor any action be brought or maintained against, any agent of any party to a transfer of title, including any person or entity acting in the capacity of an escrow, for any error, inaccuracy, or omission relating to the disclosure required to be made by a transferor pursuant to this section.

However, this subdivision does not apply to a licensee, as defined in Section 10011 of the Business and Professions Code, where the licensee participates in the making of the disclosure required to be made pursuant to this section with actual knowledge of the falsity of the disclosure.

(f) Except as otherwise provided in this section, this section shall not be deemed to create or imply a duty upon a licensee, as defined in Section 10011 of the Business and Professions Code, or upon any agent of any party to a transfer of title, including any person or entity acting in the capacity of an escrow, to monitor or ensure compliance with this section.

(g) No transfer of title shall be invalidated on the basis of a failure to comply with this section, and the exclusive remedy for the failure to comply with this section is an award of actual damages not to exceed one hundred dollars (\$100), exclusive of any court costs and attorney's fees.

(h) Local ordinances requiring smoke detectors in single-family dwellings may be enacted or amended. However, the ordinances shall satisfy the minimum requirements of this section.

(i) For the purposes of this section, "single-family dwelling" does not include a manufactured home as defined in Section 18007, a mobile home as defined in Section 18008, or a commercial coach as defined in Section 18001.8.

(j) This section shall not apply to the installation of smoke detectors in dwellings intended for human occupancy, as defined in and regulated by Section 13113.7 of the Health and Safety Code, as added by Senate Bill No. 1448 in the 1983-84 Regular Session.

**CHAPTER 4648  
MOTION PICTURE AND TELEVISION PRODUCTION STUDIO SOUND STAGES,  
APPROVED PRODUCTION FACILITIES, AND PRODUCTION LOCATIONS**

**4601-4801 GENERAL**

**4601.1-4801.1 Scope.** Production studios, sound stages, approved production facilities, and production locations used by the entertainment industry for the purpose of motion picture, television and commercial production shall be in accordance with the provisions of this article.

**4601.2-4801.2 Purpose.** The purpose of this article is to establish minimum requirements that will provide a reasonable degree of safety from fire, panic and explosion. Buildings and structures defined herein shall be in accordance with this article.

**4601.3-4801.3 DEFINITIONS.**

**APPROVED FIRE WATCH** are individuals provided with at least one approved means for notification of the fire department and their only duty shall be to perform constant patrols of the protected premises and keep watch for fires.

**APPROVED PRODUCTION FACILITY** is an existing building, or portion of a building, or a group of buildings altered for use by the entertainment industry for the purpose of motion picture, television and commercial production.

**PLATFORM** is part of a set, which is a floor or horizontal surface raised above stage floor level.

**PRODUCTION LOCATION** is any area or facility outside a production studio, approved production facility or sound stage used by the entertainment industry for the purpose of motion picture, television and commercial production.

**PRODUCTION STUDIO** is a building, portion of a building, or a group of buildings designed and constructed for use by the entertainment industry for the purpose of motion picture, television and commercial production.

**SET** is a structure built or assembled for the purpose of motion picture, television and commercial production.

**SOUND STAGE** is a building or portion of a building usually insulated from outside noise and natural light for use by the entertainment industry for the purpose of motion picture, television and commercial production.

## **4602 4802 OCCUPANCY CLASSIFICATION**

**4602.1 4802.1 Live audience stages.** Production facilities, sound stages and approved production studios with live audience stages shall be classified as Group A-1 Occupancies in accordance with the California Building Code.

**4602.2 4802.2 All other stages.** Production studios, sound stages and approved production facilities without live audience stages shall be classified as Group F-1 Occupancies in accordance with the California Building Code.

**Note:** Sections ~~4603-4803~~ through ~~4610-4810~~ apply only to Studio Sound Stages and Approved Production Facilities

## **4603-4803 REQUIRED PERMITS**

**4603.1 4803.1 Change in use.** A permit from the Fire Code Official shall be obtained any time a change in use or occupancy is intended by the owner (e.g., for live audience shows, wrap parties).

**4603.2 4803.2 Additional permits.** A permit shall be required for:

- a) Use of pyrotechnic special effects.
- b) Open flames.
- c) Flammable or combustible liquids, gases and dust.
- d) Hot work.
- e) Presence of motor vehicles within a building.
- f) Any additional permits as required by the Fire Code Official.

**4603.3 4803.3 Live audiences.** A permit shall be required for seating arrangements of all live audience stages.

## **4604 4804 GENERAL REQUIREMENTS**

**4604.1 4804.1 Housekeeping.** Provisions of this part shall maintain proper housekeeping in accordance with Chapter 3.

**4604.2 4804.2 Aisles.** Perimeter aisles within the sound stage and approved production facility shall be provided. Aisles required by this section shall have a minimum width of 4 feet (1219 mm). See Chapter 10 for maintenance requirements. Aisles required by this section shall have a minimum clear unobstructed height of 7 feet (2134 mm).

**4604.3 4804.3 Travel distance.** The maximum travel distance to any exit within the sound stage and approved production facility shall be 150 feet (45,720 mm).

**4604.4 4804.4 Exit doors.** Exit doors shall be equipped with panic hardware and swing in the direction of exit travel.

**4604.5 4804.5 Exit signs.** Illuminated exit signs shall be installed in accordance with the California Building Code.

**4604.6 4804.6 Exit illumination.** Exit illumination shall be provided in accordance with the California Building Code. In the event of power failure, exit path illumination shall be automatically provided by an approved emergency back-up system.

**4604.7 4804.7 Exit obstructions.** All means of egress shall be maintained in accordance with the provisions of Chapter 10, Section 1005.1.

**4604.8 4804.8 Foam plastics.** All foam plastics shall meet the requirements of Chapter 8, Sections 807.4.2.4 and 807.4.5.

**4604.9 4804.9 Decorative materials.** Drapes, drops, cut greens, etc., shall meet the flame retardant requirements of ~~Title 19~~ California Code of Regulations, Title 19, Division 1, Chapter 5, and Chapter 8, Sections 807.4.2.4 and 807.4.5.

## **4605 4805 FIRE-EXTINGUISHING SYSTEMS**

**4605.1 4805.1 Existing sound stages and approved production facilities.** All existing sound stages and approved production facilities equipped with an automatic fire sprinkler system shall be maintained in accordance with the provisions in Chapter 9.

**4605.2 4805.2 New sound stages.** All new sound stages shall be equipped with an approved automatic fire sprinkler system. The system shall be installed in accordance with the provisions in Chapter 9 and shall meet the minimum design requirements of an Extra Hazard, Group 2 system.

**4605.3 4805.3 Solid-ceiling sets and platforms.** All interior solid-ceiling sets over 600 square feet (55.7 m<sup>2</sup>) in area, and platforms (when provided) over 600 square feet (55.7 m<sup>2</sup>) in area and which exceed 3 feet (914 mm) in height shall be protected by one of the following:

1. An approved and listed heat detector system. Heat detectors shall be spaced 30 feet (9144 mm) on center or as required by the manufacturer's installation instructions. Detectors shall be connected to an approved and listed central, proprietary or remote station service or a local alarm, which will give an audible signal at a constantly attended location. Such system shall be installed in accordance with Chapter 9.
2. The ceiling shall be positioned to allow for the operation of the building's automatic fire sprinkler system after rehearsal, videotaping, filming, or broadcasting of programs has been completed for the day.
3. An approved fire watch.
4. Special hazards shall be reviewed by the Fire Code Official (see Additional Fire Protection Systems, Section 901.4.3).

## **4606 4806 FIRE-DETECTION EQUIPMENT**

**4606.1 4806.1 Fire alarm control units.** Fire alarm control units shall be California State Fire Marshal listed and shall be utilized in accordance with their listing. Control Units may be temporarily supported by sets, platforms or pedestals.

**4606.2 4806.2 Heat detectors.** Heat detection required by this article shall be defined as a portable system as it is intended to be reinstalled when platforms or sets are changed.

Heat detectors may be secured to standard outlet boxes which may be temporarily supported by sets, platforms or pedestals.

Heat detectors shall be provided for solid-ceiling sets and platforms where required by ~~4605.3~~ 4605.3 and ~~4611.14~~ 4811.14.

## **4607 4807 FIRE SAFETY OFFICERS.**

**4807.1** Where permits are required by the Fire Code, a requirement for standby fire safety officers shall be determined by the Fire Code Official on a case-by-case basis. Standby fire safety officers shall not be required when the provisions of this article are met.

## **4608 4808 ELECTRICAL REQUIREMENTS**

**4608.1 4808.1 General.** All electrical equipment including lighting, cabling and temporary power, such as portable generators, shall be maintained in good working order and shall comply with the provisions of the California Electrical Code.

**4608.2 4808.2 Lighting and power requirements.** A studio sound stage and approved production facility shall be provided with a minimum of 35 watts per square foot of permanently installed power dedicated for the distribution of production lighting and power. Mobile generators may be utilized for auxiliary power.

**4608.3 4808.3 Distribution.** Distribution equipment shall be designed for sound stage use. The wiring to such

equipment shall be considered permanent and shall comply with applicable provisions of the California Electrical Code. Temporary feeders shall not be tapped from panelboards and switchboards where deadfront covers have to be removed.

**~~4608.4~~ 4808.4 Installations.** Permanent or temporary electrical installations shall be installed in accordance with the California Electrical Code and this code. Such equipment shall not obstruct exits, means of egress or fire department access, unless approved by the Fire Code Official.

**~~4608.5~~ 4808.5 Generators.** Portable, mobile or stationary power-generating equipment may be used to supplement building electrical power for temporary use. Equipment shall be located at a pre-designated location as approved by the Fire Code Official.

Temporary auxiliary power cables supplied from mobile generators or adjacent buildings may pass through exterior walls and interior fire-resistive assemblies provided an approved through-penetration fire-stop system is utilized for protection of the opening.

#### **~~4609-4809~~ MECHANICAL EQUIPMENT**

**~~4609.1~~ 4809.1 Existing equipment.** All mechanical equipment used as part of the building ventilation system shall be maintained in good working order and shall comply with the provisions of the California Mechanical Code.

**~~4609.2~~ 4809.2 Auxiliary equipment.** All auxiliary heating, ventilation and air-conditioning equipment shall be approved and listed for the intended use. Flexible duct, if utilized, shall be noncombustible. Such auxiliary equipment shall not obstruct exits, means of egress or fire department access.

**~~4610-4810~~ DESIGN REQUIREMENTS** The Fire Code Official shall be provided with certification that approved production facilities and studio sound stages will sustain the anticipated loads of sets, props or other temporary modifications.

Where the anticipated loads exceed the design criteria for an approved production facility and studio sound stage, the building or portions thereof shall be modified for the additional loads.

#### **~~4611-4811~~ PRODUCTION LOCATIONS**

**~~4611.1~~ 4811.1 General.** This chapter shall apply to Production Locations.

**~~4611.2~~ 4811.2 Permits.** A permit shall be obtained, unless waived by the Fire Code Official for any of the activities that follow:

- a) Use of pyrotechnic special effects, see Section 3308.1.1 and ~~Title 19~~, California Code of Regulations, Title 19, Division 1, Chapter 6.
- b) Open flames.
- c) Flammable or combustible liquids, gases and dust.
- d) Hot work.
- e) Presence of motor vehicles within a building.
- f) Tents and canopies, see Chapter 24.
- g) Any additional permits as required by the AHJ.

**~~4611.3~~ 4811.3 Pyrotechnic special effects and open flames.** The use of pyrotechnic special effects and open flames shall be subject to the approval of the Fire Code Official.

**~~4611.4~~ 4811.4 Standby fire personnel.** A requirement for standby fire safety officers shall be determined by the Fire Code Official on a case-by-case basis.

**~~4611.5~~ 4811.5 Foamed plastic materials.** All foam plastics shall meet the requirements of Chapter 8, Sections 807.4.2.4 and 807.4.5.

**4611.6 4811.6 Smoking.** When the Fire Code Official determines that hazardous conditions necessitate controlled use of smoking materials, smoking may be prohibited or limited to designated smoking areas.

**4611.7 4811.7 Structural loads.** Sets, scenery and other equipment shall not impact the structural integrity of a building or structure. Consultation with a building official or structural engineer may be required.

**4611.8 4811.8 Electrical requirements.**

**4611.8.1 4811.8.1 General.** All electrical equipment including lighting, cabling and temporary power, such as portable generators, shall be maintained in good working order and shall comply with the provisions of the California Electrical Code.

**4611.8.2 4811.8.2 Distribution.** Temporary feeders shall not be tapped from panelboards and switchboards where deadfront covers have to be removed.

**4611.8.3 4811.8.3 Installations.** Electrical installations shall be installed in accordance with the California Electrical Code. Such equipment shall not obstruct exits, means of egress or fire department access, unless approved by the Fire Code Official.

**4611.8.4 4811.8.4 Generators.** Portable, mobile or stationary power-generating equipment may be used to supplement building electrical power for temporary use. Equipment shall be placed in a location acceptable to the Fire Code Official.

**4611.9 4811.9 Fire department access.** Required emergency vehicle access shall be maintained. Any deviations are subject to approval by the Fire Code Official.

**4611.10 4811.10 Means of egress.** The production location shall be provided with means of egress appropriate for the intended use as approved by the Fire Code Official.

**4611.11 4811.11 Fire protection systems and equipment.** Functional fire protection systems and equipment shall be maintained in an operable condition, unless approved by the Fire Code Official. Disconnecting or altering of fire protection systems and/or equipment shall be prohibited, unless otherwise approved by the Fire Code Official with alternate means of protection provided.

**4611.12 4811.12 Fire hydrants and fire appliances.** Hydrants, standpipes and Fire Department Connections (FDC) shall not be obstructed, blocked or rendered inoperable in accordance with Chapter 9, unless approved by the Fire Code Official.

**4611.13 4811.13 Fire extinguishers.** Approved fire extinguishers shall be provided as required by the Fire Code Official.

**4611.14 4811.14 Solid-ceiling sets and platforms.** In buildings with existing fire protection systems and where production intends to construct solid-ceiling sets over 600 square feet (55.7 m<sup>2</sup>) in area, and platforms over 600 square feet (55.7 m<sup>2</sup>) in area and which exceed 3 feet (914 mm) in height shall be protected by one of the following:

1. An approved and listed heat detector system. Heat detectors shall be spaced 30 feet (9144 mm) on center or as required by the manufacturer's installation instructions. Detectors shall be connected to an approved and listed central, proprietary or remote station service or a local alarm, which will give an audible signal at a constantly attended location. Such system shall be installed in accordance with Chapter 9.
2. The ceiling shall be positioned to allow for the operation of the building's automatic fire sprinkler system after rehearsal, videotaping, filming, or broadcasting of programs has been completed for the day.
3. An approved fire watch.
4. Special hazards shall be reviewed by the enforcing agency (see additional fire protection systems, Section 901.4.3.).

**4611.15 4811.15 Buildings without fire protection systems.** Special hazards shall be reviewed by the Fire Code Official (see special hazards Section 901.4.3).

#### **APPENDIX CHAPTER 4 SPECIAL DETAILED REQUIREMENTS BASED ON USE AND OCCUPANCY**

**425.2.2** Pursuant to Health and Safety Code Section 13133, regulations of the state fire marshal pertaining to Occupancies classified as Residential Facilities (RF) and Residential-care Facilities for the Elderly (RCFE) shall apply uniformly throughout the state and no city, county, city and county, including a charter city or charter county, or fire protection district shall adopt or enforce any ordinance or local rule or regulation relating to fire and panic safety which is inconsistent with these regulations. A city, county, city and county, including a charter city or charter county may pursuant to Health and Safety Code Section 13143.5, or a fire protection district may pursuant to Health and Safety Code Section 13869.7, adopt standards more stringent than those adopted by the state fire marshal that are reasonably necessary to accommodate local climate, geological, or topographical conditions relating to roof coverings for Residential-care Facilities for the Elderly.

**Exception:** Local regulations relating to roof coverings in facilities licensed as a Residential Care Facility for the Elderly (RCFE) per Health and Safety Code Section 13133.

#### **425.3 Building height and area provisions.**

**425.3.2 Limitations six or less clients.** Group R-3.1 occupancies where clients are housed above the first story, having more than two stories in height or having more than 3,000 square feet (279 m<sup>2</sup>) of floor area above the first story shall not be of less than one-hour fire-resistance-rated construction throughout.

In Group R-3.1 Occupancies housing a bedridden client, the client sleeping room shall not be located above or below the first story.

**EXCEPTION:** Clients who become bedridden as a result of a temporary illness as defined in Health and Safety Code Sections 1566.45, 1568.0832, and 1569.72. A temporary illness is an illness, which persists for 14 days or less. A bedridden client may be retained in excess of the 14 days upon approval by the Department of Social Services and may continue to be housed on any story in a Group R-~~Division 2~~-3.1 occupancy classified as a licensed residential facility.

Every licensee admitting or retaining a bedridden resident shall, within 48 hours of the resident's admission or retention in the facility, notify the local fire authority with jurisdiction of the estimated length of time the resident will retain his or her bedridden status in the facility.

**425.3.3 Limitations seven or more clients.** Group R-4 occupancies where nonambulatory clients are housed above the first story and there is more than 3,000 square feet (279 m<sup>2</sup>) of floor area above the first story or housing more than 16 clients above the first story shall be constructed of not less than one-hour fire-resistance-rated construction throughout.

**425.3.4 Nonambulatory elderly clients.** Group R-4 occupancies housing nonambulatory elderly clients shall be of not less than one-hour fire-resistance-rated construction throughout.

#### **425.4 Type of construction provisions.**

#### **425.5 Fire-resistance-rated construction provisions.**

#### **425.7 Fire Protection system provisions.**

#### **425.8 Means of egress provisions.**

#### **425.8.3 Egress arrangements.**

**425.8.3.1** Egress through adjoining dwelling units shall not be permitted.

**425.8.3.4 Intervening rooms.** A means of exit shall not pass through more than one intervening room. A means of egress shall not pass through kitchens, storerooms, closets, garages or spaces used for similar purposes.

**Exception:** Kitchens which do not form separate rooms by construction.

#### **425.8.4 Corridors.**

**425.8.6.2** Group R-3.1 occupancies may continue to use existing stairways (except for winding and spiral stairways which are not permitted as a required means of egress) provided the stairs have a maximum rise of 8 inches (203 mm) with a minimum run of 9 inches (229 mm). The minimum stairway width may be 30 inches (762 mm).

**425.8.7 Floor separation.** Group R-3.1 occupancies shall be provided with a non-fire resistance constructed floor separation at stairs which will prevent smoke migration between floors. Such floor separation shall have equivalent construction of 0.5 inch (12.7 mm) gypsum wallboard on one side of wall framing.

**Exceptions:**

1. Occupancies with at least one exterior exit from floors occupied by clients.
2. Occupancies provided with automatic fire sprinkler systems complying with chapter 9.

**425.8.7.1 Doors within floor separations.** Doors within such floor separations shall be tight fitting solid wood at least 1 3/8 inches (35 mm) in thickness. Door glazing shall not exceed 1296 square inches (32 918 mm<sup>2</sup>) with no dimension greater than 54 inches (1372 mm). Such doors shall be positive latching, smoke gasketed and shall be automatic-closing by smoke detection.

**425.8.8 Fences and gates.** Grounds of a Residential Care for the Elderly facility serving Alzheimer clients may be fenced and gates therein equipped with locks, provided safe dispersal areas are located not less than 50 feet (15 240 mm) from the buildings. Dispersal areas shall be sized to provide an area of not less than 3 square feet (0.28m<sup>2</sup>) per occupant. Gates shall not be installed across corridors or passageways leading to such dispersal areas unless they comply with egress requirements.

**425.8.9 Basement exits.** One exit is required to grade level when the basement is accessible to clients.

**425.8.10 Delayed egress locks.** See Section ~~4008.1.8-6~~1008.1.9.7.

**425.9 Request for alternate means of protection for facilities housing bedridden clients.** Request for alternate means of protection shall apply to Sections 425 through 425.9. Request for approval to use an alternative material, assembly or materials, equipment, method of construction, method of installation of equipment, or means of protection shall be made in writing to the local fire enforcing agency by the facility, client or the client's authorized representative. Sufficient evidence shall be submitted to substantiate the need for an alternate means of protection.

The facility, client or the client's representative or the local fire enforcing agency may request a written opinion from the State Fire Marshal concerning the interpretation of the regulations promulgated by the State Fire Marshal for a particular factual dispute. The State Fire Marshal shall issue the written opinion within 45 days following the request.

Approval of a request for use of an alternative material, assembly or materials, equipment, method of construction, method of installation of equipment, or means of protection made pursuant to this section shall be limited to Group R, 3.1 Occupancies housing a bedridden client.

Approvals made by the local fire enforcing agency and the written opinion by the State Fire Marshal shall be applicable only to the requesting facility and shall not be construed as establishing any precedent for any future request by that facility or any other facility.

## **APPENDIX BB [SFM]**

**FIRE-FLOW REQUIREMENTS FOR BUILDINGS**

**SECTION BB102  
DEFINITIONS**

**BB102.1** For the purpose of Appendix III-A, certain terms are defined as follows:

**FIRE AREA** is the floor area, in square feet, used to determine the required fire flow.

**FIRE FLOW** is the flow rate of a water supply, measured at 20 psi (137.9 kPa) residual pressure, that is available for firefighting.

**SECTION BB103  
MODIFICATIONS**

**BB103.1** An alternative method of providing water for fire protection or any other alternative in lieu of providing the water may be enforced when deemed appropriate by the fire chief and the state fire marshal.

**SECTION BB104  
FIRE AREA**

**BB104.1 General.** The fire area shall be the total floor area of all floor levels within the exterior walls, and under the horizontal projections of the roof of a building, except as modified in Section 4.

**BB104.2 Area separation.** Portions of buildings which are separated by one or more four-hour area separation walls constructed in accordance with the Building Code, without openings and provided with a 30-inch (762 mm) parapet, are allowed to be considered as separate fire areas.

**BB104.3 Type I and Type IB construction.** The fire area of buildings constructed of Type I and Type IB construction shall be the area of the three largest successive floors.

**SECTION BB105  
FIRE-FLOW REQUIREMENTS FOR BUILDINGS**

**BB105.1** The minimum fire flow and flow duration for school buildings shall be as specified in Table BB105.1.

**Exception:** A reduction in required fire flow of up to 75 percent, is allowed when the building is provided with an approved automatic sprinkler system.

**TABLE BB105.1  
MINIMUM REQUIRED FIRE-FLOW AND FLOW DURATION FOR BUILDINGS**

FIRE AREA (square feet)					FIRE-FLOW (gallons per minute) <sup>b</sup>	FLOW DURATION (hours)
Type IA and IB <sup>a</sup>	Type IIA and IIIA <sup>a</sup>	Type IV and V-A <sup>a</sup>	Type IIB and IIIB <sup>a</sup>	Type V-B <sup>a</sup>		
0-22,700	0-12,700	0-8,200	0-5,900	0-3,600	1,500	2
22,701-30,200	12,701-17,000	8,201-10,900	5,901-7,900	3,601-4,800	1,750	
30,201-38,700	17,001-21,800	10,901-12,900	7,901-9,800	4,801-6,200	2,000	
38,701-48,300	21,801-24,200	12,901-17,400	9,801-12,600	6,201-7,700	2,250	
48,301-59,000	24,201-33,200	17,401-21,300	12,601-15,400	7,701-9,400	2,500	
59,001-70,900	33,201-39,700	21,301-25,500	15,401-18,400	9,401-11,300	2,750	
70,901-83,700	39,701-47,100	25,501-30,100	18,401-21,800	11,301-13,400	3,000	3

83,701-97,700	47,101-54,900	30,101-35,200	21,801-25,900	13,401-15,600	3,250	4
97,701-112,700	54,901-63,400	35,201-40,600	25,901-29,300	15,601-18,000	3,500	
112,701-128,700	63,401-72,400	40,601-46,400	29,301-33,500	18,001-20,600	3,750	
128,701-145,900	72,401-82,100	46,401-52,500	33,501-37,900	20,601-23,300	4,000	
145,901-164,200	82,101-92,400	52,501-59,100	37,901-42,700	23,301-26,300	4,250	
164,201-183,400	92,401-103,100	59,101-66,000	42,701-47,700	26,301-29,300	4,500	
183,401-203,700	103,101-114,600	66,001-73,300	47,701-53,000	29,301-32,600	4,750	
203,701-225,200	114,601-126,700	73,301-81,100	53,001-58,600	32,601-36,000	5,000	
225,201-247,700	126,701-139,400	81,101-89,200	58,601-65,400	36,001-39,600	5,250	
247,701-271,200	139,401-152,600	89,201-97,700	65,401-70,600	39,601-43,400	5,500	
271,201-295,900	152,601-166,500	97,701-106,500	70,601-77,000	43,401-47,400	5,750	
295,901-Greater	166,501-Greater	106,501-115,800	77,001-83,700	47,401-51,500	6,000	
—	—	115,801-125,500	83,701-90,600	51,501-55,700	6,250	
—	—	125,501-135,500	90,601-97,900	55,701-60,200	6,500	
—	—	135,501-145,800	97,901-106,800	60,201-64,800	6,750	
—	—	145,801-156,700	106,801-113,200	64,801-69,600	7,000	
—	—	156,701-167,900	113,201-121,300	69,601-74,600	7,250	
—	—	167,901-179,400	121,301-129,600	74,601-79,800	7,500	
—	—	179,401-191,400	129,601-138,300	79,801-85,100	7,750	
—	—	191,401-Greater	138,301-Greater	85,101-Greater	8,000	

For SI: 1 square foot = 0.0929 m<sup>2</sup>, 1 gallon per minute = 3.785 L/m, 1 pound per square inch = 6.895kPa.

a. Types of construction are based on the California Building Code.

b. Measured at 20 psi.

## APPENDIX CC [SFM] FIRE HYDRANT LOCATIONS AND DISTRIBUTION

### SECTION CC101 SCOPE

**CC101.1** Fire hydrants shall be provided in accordance with this appendix for the protection of any school buildings, or portions thereof hereafter constructed for which review and approval are required under Subdivision (a) of Section ~~39140-17280~~ of the ~~Education-Government~~ Code.

### SECTION CC102 LOCATION

**CC102.1** Fire hydrants shall be provided along required fire apparatus access roads and adjacent public streets.

### SECTION CC103 NUMBER OF FIRE HYDRANTS

**CC103.1** The minimum number of fire hydrants available to a building shall not be less than that listed in Table CC105.1. The number of fire hydrants available to a complex or subdivision shall not be less than that determined by spacing requirements listed in Table CC105.1 when applied to fire apparatus access roads and perimeter streets from

which fire operations could be conducted.

**SECTION CC104  
CONSIDERATION OF EXISTING FIRE HYDRANTS**

**CC104.1** Existing fire hydrants on public streets are allowed to be considered as available. Existing fire hydrants on adjacent properties shall not be considered available unless fire apparatus access roads extend between properties and easements are established to prevent obstruction of such roads.

**SECTION CC105  
DISTRIBUTION OF FIRE HYDRANTS**

**CC105.1** The average spacing between fire hydrants shall not exceed that listed in Table CC105.1.

**Exception:** A deficiency of up to 10 percent shall not be allowed when existing fire hydrants provide all or a portion of the required fire hydrant service.

Regardless of the average spacing, fire hydrants shall be located such that all points on streets and access roads adjacent to a building are within the distances listed in Table CC105.1.

**CC105.2** When public or private water mains are not available to supply fire flow [not within 1,000 feet (304,800 mm) of the pro-posed building], the following alternatives shall be used:

1. Building(s) shall be protected by an automatic sprinkler system

**Exception:** Portable (relocatable) buildings, as defined in California Education Code Section 17742.5(e), which requires that portable buildings be designed and constructed to be relocatable over public streets, shall be designed and constructed for relocation without the separation of the roof or floor from the building and when measured at the most exterior walls, shall have a floor area not in excess of 2,000 square feet (186m<sup>2</sup>). Such portable buildings shall be separated from other structures in groupings not to exceed 9,100 square feet (845 m<sup>2</sup>) in building area (pursuant to Table 503, California Building Code, for Type V-B buildings). Further area increases shall be as approved by the local fire authority having jurisdiction and the state fire marshal.

The water for sprinklers may be supplied by the domestic system, a pressure tank, a gravity tank or other means in accordance with NFPA 13. Water tanks shall be installed in accordance with NFPA 22. (See the California Building Code, Chapter 9.)

2. When the adequate fire flow is not available and the water for sprinklers is provided from a source other than a public water supply, the amount of water to supply the system shall be calculated using the area/density method or the room design method as delineated in NFPA 13. The calculated duration of water flow to sprinklers shall not be less than 15 minutes to 10 heads.
3. The sprinkler system shall have a water flow alarm monitored by an approved central, proprietary or remote station service or a local alarm which will give audible and visual signals at a constant attended location.
4. When this alternative is utilized and the calculated water duration to a sprinkler is less than NFPA 13 recommendations, the area increases and fire resistive substitutions allowed in Chapter 5 of the California Building Code shall not be permitted.

**TABLE CC105.1  
NUMBER AND DISTRIBUTION OF FIRE HYDRANTS**

FIRE-FLOW REQUIREMENT (gpm)	MINIMUM NUMBER OF HYDRANTS	AVERAGE SPACING BETWEEN HYDRANTS <sup>a, b, c</sup> (feet)	MAXIMUM DISTANCE FROM ANY POINT ON STREET OR ROAD FRONTAGE TO A HYDRANT <sup>d</sup>
--------------------------------	-------------------------------	---	---

1,750 or less	1	500	250
2,000-2,250	2	450	225
2,500	3	450	225
3,000	3	400	225
3,500-4,000	4	350	210
4,500-5,000	5	300	180
5,500	6	300	180
6,000	6	250	150
6,500-7,000	7	250	150
7,500 or more	8 or more <sup>e</sup>	200	120

For SI: 1 foot = 304.8 mm, 1 gallon per minute = 3.785 L/m.

- a. Reduce by 100 feet for dead-end streets or roads.
- b. Where streets are provided with median dividers which can be crossed by fire fighters pulling hose lines, or where arterial streets are provided with four or more traffic lanes and have a traffic count of more than 30,000 vehicles per day, hydrant spacing shall average 500 feet on each side of the street and be arranged on an alternating basis up to a fire-flow requirement of 7,000 gallons per minute and 400 feet for higher fire-flow requirements.
- c. Where new water mains are extended along streets where hydrants are not needed for protection of structures or similar fire problems, fire hydrants shall be provided at spacing not to exceed 1,000 feet to provide for transportation hazards.
- d. Reduce by 50 feet for dead-end streets or roads.
- e. One hydrant for each 1,000 gallons per minute or fraction thereof.

**APPENDIX H  
HAZARDOUS MATERIALS MANAGEMENT PLANS AND  
HAZARDOUS MATERIALS INVENTORY STATEMENTS  
(See Sections 2701.5.1 and 2701.5.2)**

**SECTION H1  
SCOPE**

**H1.1 Scope.** Hazardous materials inventory statements (HMIS) and hazardous materials management plans (HMMP) which are required by the chief pursuant to Chapter 27 shall be provided for hazardous materials in accordance with Appendix H.

**Exceptions:** 1. Materials which have been satisfactorily demonstrated not to present a potential danger to public health, safety or welfare, based upon the quantity or condition of storage, when approved.

2. Chromium, copper, lead, nickel and silver need not be considered hazardous materials for the purposes of Appendix H unless they are stored in a friable, powdered or finely divided state.

Proprietary and trade secret information shall be protected under the laws of the state or jurisdiction having authority.

**SECTION H2  
HAZARDOUS MATERIALS INVENTORY STATEMENTS (HMIS)**

**H2.1 When Required.** A separate HMIS shall be provided for each building, including its appurtenant structures, and each exterior facility in which hazardous materials are stored.

The hazardous materials inventory statement shall list by hazard class all hazardous materials stored. The hazardous

materials inventory statement shall include the following information for each hazardous material listed:

1. Hazard class.
2. Common or trade name.
3. Chemical name, major constituents and concentrations if a mixture. If a waste, the waste category.
4. Chemical Abstract Service number (CAS number) found in 29 Code of Federal Regulations (C.F.R.).
5. Whether the material is pure or a mixture, and whether the material is a solid, liquid or gas.
6. Maximum aggregate quantity stored at any one time.
7. Storage conditions related to the storage type, temperature and pressure.

**H2.2 Changes to HMIS.** An amended HMIS shall be provided within 30 days of the storage of any hazardous materials which changes or adds a hazard class or which is sufficient in quantity to cause an increase in the quantity which exceeds 5 percent for any hazard class.

### **SECTION H3 HAZARDOUS MATERIALS MANAGEMENT PLAN (HMMP)**

**H3.1 General.** Applications for a permit to store hazardous materials shall include an HMMP standard form or short form in accordance with Section H3.3 and shall provide a narrative description of the operations and processes taking place at the facility. See Figure A-H-1.

**H3.2 Information Required.** The HMMP standard form shall include the information detailed in Section H3.2.

**H3.2.1 General Information.** General information, including business name and address, emergency contacts, business activity, business owner or operator, SIC code, number of employees and hours, Dunn and Bradstreet number, and signature of owner, operator or designated representative.

**H3.2.2 General site plan.** A general site plan drawn at a legible scale which shall include, but not be limited to, the location of buildings, exterior storage facilities, permanent access ways, evacuation routes, parking lots, internal roads, chemical loading areas, equipment cleaning areas, storm and sanitary sewer accesses, emergency equipment and adjacent property uses. The exterior storage areas shall be identified with the hazard class and the maximum quantities per hazard class of hazardous materials stored. When required by the chief, information regarding the location of wells, flood plains, earthquake faults, surface water bodies and general land uses within 1 mile (1.609 km) of the facility boundaries shall be included.

**H3.2.3 Building floor plan.** A building floor plan drawn to a legible scale which shall include, but not be limited to, hazardous materials storage areas within the building and shall indicate rooms, doorways, corridors, means of egress and evacuation routes. Each hazardous materials storage facility shall be identified by a map key which lists the individual hazardous materials, their hazard class and quantity present for each area.

**H3.2.4 Hazardous materials handling.** Information showing that activities involving the handling of hazardous materials between the storage areas and manufacturing processes on site are conducted in a manner to prevent the accidental release of such materials.

**H3.2.5 Chemical capability and separation.** Information showing procedures, controls, signs or other methods used to ensure separation and protection of stored materials from factors which could cause accidental ignition or reaction of ignitable, reactive or incompatible materials in each area.

**H3.2.6 Monitoring program.** Information including, but not limited to, the location, type, manufacturer's specifications, if applicable, and suitability of monitoring methods for each storage facility when required.

**H3.2.7 Inspection and recording keeping.** Schedules and procedures for inspecting safety and monitoring and emergency equipment. The permittee shall develop and follow a written inspection procedure acceptable to the chief for inspecting the facility for events or practices which could lead to unauthorized discharges of hazardous materials. Inspections shall be conducted at a frequency appropriate to detect problems prior to a discharge. An inspection check sheet shall be developed to be used in conjunction with routine inspections. The check sheet shall provide for

the date, time and location of inspection; note problems and dates and times of corrective actions taken; and include the name of the inspector and the countersignature of the designated safety manager for the facility.

**H3.2.8 Employee training.** A training program appropriate to the types and quantities of materials stored or used shall be conducted to prepare employees to safely handle hazardous materials on a daily basis and during emergencies. The training program shall include:

1. Instruction in safe storage and handling of hazardous materials, including maintenance of monitoring records.
2. Instruction in emergency procedures for leaks, spills, fires or explosions, including shutdown of operations and evacuation procedures, and
3. Record-keeping procedures for documenting training given to employees.

**H3.2.9 Emergency response.** A description of facility emergency procedures is to be provided.

**H3.3 HMMP Short Form—(Minimal Storage Site).** A facility shall qualify as a minimal storage site if the quantity of each hazardous material stored in one or more facilities in an aggregate quantity for the facility is 500 pounds (227 kg) or less for solids, 55 gallons (208.2 L) or less for liquids, or 200 cubic feet (5.7 m<sup>3</sup>) or less at NTP for compressed gases and does not exceed the threshold planning quantity as listed in 40 C.F.R., Part 355, Sections 302 and 304. The applicant for a permit for a facility which qualifies as a minimal storage site is allowed to file the short form HMMP. Such plan shall include the following components:

1. General facility information,
2. A simple line drawing of the facility showing the location of storage facilities and indicating the hazard class or classes and physical state of the hazardous materials being stored,
3. Information describing that the hazardous materials will be stored and handled in a safe manner and will be appropriately contained, separated and monitored, and
4. Assurance that security precautions have been taken, employees have been appropriately trained to handle the hazardous materials and react to emergency situations, adequate labeling and warning signs are posted, adequate emergency equipment is maintained, and the disposal of hazardous materials will be in an appropriate manner.

## **SECTION H4 MAINTENANCE OF RECORDS**

**H4.1 Hazardous materials inventory statements and hazardous materials management plans shall be maintained by the permittee for a period of not less than three years after submittal of updated or revised versions. Such records shall be made available to the chief upon request.**

### **FIGURE A-H-1 SAMPLE FORMAT HAZARDOUS MATERIALS MANAGEMENT PLAN (HMMP) INSTRUCTIONS**

#### **SECTION I—FACILITY DESCRIPTION**

##### **1.1 Part A**

1. Fill out Items 1 through 11 and sign the declaration.
2. Only Part A of this section is required to be updated and submitted annually, or within 30 days of a change.

##### **1.2 Part B—General Facility Description (Site Plan)**

1. Provide a site plan on 8 ½-by 11-inch (215 mm by 279 mm) paper, using letters on the top and bottom margins and numbers on the right and left side margins, showing the location of all buildings, structures, chemical loading areas, parking lots, internal roads, storm and sanitary sewers, wells, and adjacent property uses. Indicate the approximate scale, northern direction and date the drawing was completed.
2. List all special land uses within 1 mile (1.609 km).

##### **1.3 Part C—Facility Storage Map (Confidential Information)**

1. Provide a floor plan of each building on 8 ½- by 11-inch (215 mm by 279 mm) paper, using letters on the top and bottom margins and numbers on the right and left side margins, with approximate scale and northern direction,

showing the location of each storage area. Mark map clearly "Confidential—Do not disclose" for trade-secret information as specified by federal, state and local laws.

2. Identify each storage area with an identification number, letter, name or symbol.

3. Show the following:

3.1 Accesses to each storage area.

3.2 Location of emergency equipment.

3.3 The general purpose of other areas within the facility.

3.4 Location of all aboveground and underground tanks to include sumps, vaults, below-grade treatment systems, piping, etc.

4. Map key. Provide the following on the map or in a map key or legend for each storage area:

4.1 A list of hazardous materials, including wastes.

4.2 Hazard class of each hazardous waste.

4.3 The maximum quantity for hazardous materials.

4.4 Include the contents and capacity limit of all tanks at each area and indicate whether they are above or below ground.

4.5 List separately any radioactives, cryogenics and compressed gases for each facility.

4.6 Trade-secret information shall be listed as specified by federal, state and local laws.

## **SECTION II—HAZARDOUS MATERIALS INVENTORY STATEMENT (HMIS)**

### **2.1 Part A—Declaration**

Fill out all appropriate information.

### **2.2 Part B—Inventory Statement**

1. You must complete a separate inventory statement for all waste and nonwaste hazardous materials. List all hazardous materials in alphabetical order by hazard class.

2. **Inventory Statement Instructions:**

<b>Column</b>	<b>Information Required</b>
---------------	-----------------------------

1 Provide hazard class for each material.

2 Nonwaste. Provide the common or trade name of the regulated material.

Waste. In lieu of trade names, you may provide the waste category.

3 Provide the chemical name and major constituents and concentrations, if a mixture.

4 Enter the chemical abstract service number (CAS number) found in 29 C.F.R. For mixtures, enter the CAS number of the mixture as a whole if it has been assigned a number distinct from its constituents. For a mixture that has no CAS number, leave this item blank or report the CAS numbers of as many constituent chemicals as possible.

5 Enter the following descriptive codes as they apply to each material. You may list more than one code, if applicable.

P = Pure

M = Mixture

S = Solid

L = Liquid

G = Gas

6 6.1 Provide the maximum aggregate quantity of each material handled at any one time by the business. For underground tanks, list the maximum volume [in gallons (liters)] of the tank..

6.2 Enter the estimated average daily amount on site during the past year.

7 Enter the units used in Column 6 as:

LB = Pounds

GA = Gallons

CF = Cubic Feet

8 Enter the number of days that the material was present on site (during the last year).

9 Enter the storage codes below for type, temperature and pressure.

**Type**

- A = Aboveground Tank
- B = Belowground Tank
- C – Tank inside Building
- D = Steel Drum
- E = Plastic or Nonmetallic Drum
- F = Can
- G = Carboy
- H = Silo
- I = Fiber Drum
- J = Bag
- K = Box
- L = Cylinder
- M = Glass Bottle or Jug
- N = Plastic Bottles or Jugs
- O = Tote Bin
- P = Tank Wagon
- Q = Rail Car
- R = Other

**Temperature**

- 4 = Ambient
- 5 = Greater than Ambient
- 6 = Less than Ambient,  
but not Cryogenic [less than -150°F (-101.1°C)]
- 7 = Cryogenic conditions [less than -150°F (-101.1°C)]

**Pressure**

- 1 = Ambient (Atmospheric)
- 2 = Greater than Ambient (Atmospheric)
- 3 = Less than Ambient (Atmospheric)

10 For each material listed, provide the SARA hazard class as listed below. You may list more than one class. These categories are defined in 40 C.F.R. 370.3.

**Physical Hazards**

- F = Fire
- P = Sudden Release of Pressure
- R = Reactivity

**Health Hazards**

- I = Immediate (Acute)
- D = Delayed (Chronic)

11 **Waste Only.** For each waste, provide the total estimated amount of hazardous waste handled throughout the course of the year.

**SECTION III—SEPARATION AND MONITORING**

**3.1 Part A—Aboveground**

Fill out Items 1 through 6, or provide similar information for each storage area shown on the facility map. Use additional sheets as necessary.

**3.2 Part B—Underground**

1. Complete a separate page for each underground tank, sump, vault, below-grade treatment system, etc.
2. Check the type of tank and method(s) that applies to your tank(s) and piping, and answer the appropriate questions. Provide any additional information in the space provided or on a separate sheet.

**SECTION IV—WASTE DISPOSAL**

Check all that apply and list the associated wastes for each method checked.

**SECTION V—RECORDING KEEPING**

Include a brief description of your inspection procedures. You are also required to keep an inspection log and recordable discharge log, which are designed to be used in conjunction with routine inspections for all storage facilities or areas. Place a check in each box that describes your forms. If you do not use the sample forms, provide

copies of your forms for review and approval.

**SECTION VI—EMERGENCY-RESPONSE PLAN**

1. This plan should describe the personnel, procedures and equipment available for responding to a release or threatened release of hazardous materials that are stored, handled or used on site.
2. A check or a response under each item indicates that a specific procedure is followed at the facility, or that the equipment specified is maintained on site.
3. If the facility maintains a more detailed emergency-response plan on site, indicate this in Item 5. This plan shall be made available for review by the inspecting jurisdiction.

**SECTION VII—EMERGENCY RESPONSE TRAINING PLAN**

1. This plan should describe the basic training plan used at the facility.
2. A check in the appropriate box indicates the training is provided or the records are maintained.
3. If the facility maintains a more detailed emergency-response training plan, indicate this in Item 4. This plan shall be made available for review by the inspecting jurisdiction.

**FIGURE A-H-1—(Continued)  
HAZARDOUS MATERIALS MANAGEMENT PLAN  
SECTION I: FACILITY DESCRIPTION**

**PART A—GENERAL INFORMATION**

1. Business Name: \_\_\_\_\_ Phone: \_\_\_\_\_  
Address: \_\_\_\_\_

2. Person Responsible for the Business:

Name	Title	Phone
_____	_____	_____

3. Emergency Contacts:

Name	Title	Home	Work
Number	Number		
_____	_____	_____	_____
_____	_____	_____	_____

4. Person Responsible for the Application/Principal Contact:

Name	Title	Phone
_____	_____	_____

5. Property Owner:

Name	Address	Phone
_____	_____	_____

6. Principal Business Activity: \_\_\_\_\_

7. Number of Employees: \_\_\_\_\_

8. Number of Shifts: \_\_\_\_\_

9. Hours of Operation: \_\_\_\_\_

10. SIC Code: \_\_\_\_\_

11. Dunn and Bradstreet Number: \_\_\_\_\_

12. Declaration

I certify that the information above and on the following parts is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Print Name: \_\_\_\_\_ Title: \_\_\_\_\_

(Must be signed by owner/operator or designated representative)

**PART B—GENERAL FACILITY**

**DESCRIPTION/SITE PLAN**

(Use grid format below.)

Special land uses within 1 mile (1.609 km): \_\_\_\_\_

**PART C—FACILITY MAP**

(Use grid format below.)

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	
1															1
2															2
3															3
4															4
5															5
6															6
7															7
8															8
9															9
10															10
11															11
12															12
13															13
14															14
15															15
16															16
17															17

BUSINESS NAME _____												DATE _____	
ADDRESS _____						CITY _____						PAGE _____ OF _____	

**SECTION II: HAZARDOUS MATERIALS INVENTORY STATEMENT**

**PART A—DECLARATION**

1. Business Name: \_\_\_\_\_

2. Address: \_\_\_\_\_

3. Declaration:

*Under penalty of perjury, I declare the above and subsequent information, provided as part of the hazardous materials inventory statement, is true and correct.*

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Print Name: \_\_\_\_\_ Title: \_\_\_\_\_

(Must be signed by owner/operator or designated representative)

**FIGURE A-II-E-1—(Continued)**

**PART B—HAZARDOUS MATERIALS INVENTORY STATEMENT**

(1) HAZARD CLASS	(2) COMMON/TRADE NAME	(3) CHEMICAL NAME, COMPONENTS AND CONCENTRATION	(4) CHEMICAL ABSTRACT SERVICE NO.	(5) PHYSICAL STATE	(6) MAXIMUM QUANTITY ON HAND AT ANY TIME	(7) UNITS	(8) DAYS ON SITE	(9) STORAGE CODE (TYPE, PRES., TEMP.)	(10) SARA CLASS	(11) ANNUAL WASTE THROUGHPUT

**SECTION III: SEPARATION, SECONDARY CONTAINMENT AND MONITORING**

**PART A—ABOVEGROUND STORAGE AREAS**

Storage Area Identification (as shown on facility map): \_\_\_\_\_

1. Storage Type:

- |                           |                       |
|---------------------------|-----------------------|
| _____ Original Containers | _____ Safety Cans     |
| _____ Inside Machinery    | _____ Bulk Tank       |
| _____ 55-gallon (208.2 L) | _____ Outside Barrels |

*Drums or Storage Shed*  
 *Pressurized Vessel*  
 *Other:* \_\_\_\_\_

2. *Storage Location:*  
 *Inside Building*                       *Outside Building*  
 *Secured*

3. *Separation:*  
 *All Materials*                       *One-hour Separation*  
 *Compatible Wall/Partition*  
 *Separated by 20 Feet (6096 mm)*                       *Approved Cabinets*  
 *Other:* \_\_\_\_\_

4. *Secondary Containment:*  
 *Approved Cabinet*                       *Secondary Drums*  
 *Tray*                       *Bermed, Coated Floor*  
 *Vaulted Tank*                       *Double-wall Tank*  
 *Other:* \_\_\_\_\_

5. *Monitoring:*  
 *Visual*                       *Continuous*  
 *Other:* \_\_\_\_\_  
*Attach specifications if necessary*

6. *Monitoring Frequency:*  
 *Daily*                       *Weekly*  
 *Other:* \_\_\_\_\_  
*Attach specifications if necessary*

**APPENDIX H**  
**FIGURE A-II-E-1—(Continued)**

**SECTION III: SEPARATION, CONTAINMENT AND MONITORING**  
**PART B—UNDERGROUND**

**SINGLE-WALL TANKS AND PIPING**

*Tank Area Identification (as shown on facility map):* \_\_\_\_\_

1.  *Backfill Vapor Wells—*  
*Model and Manufacturer:* \_\_\_\_\_

*Continuous or Monthly Testing:* \_\_\_\_\_

2.  *Groundwater Monitoring Wells*

3.  *Monthly Precision Tank Test*

4.  *Piping—*  
*Monitoring Method:* \_\_\_\_\_  
*Frequency:* \_\_\_\_\_

5.  *Other:* \_\_\_\_\_

---

**DOUBLE-WALL TANKS AND PIPING**

Tank Area Identification (as shown on facility map):

1. Method of monitoring the annular space: \_\_\_\_\_

2. Frequency:

\_\_\_\_\_ Continuous      \_\_\_\_\_ Daily      \_\_\_\_\_ Weekly

\_\_\_\_\_ Other: \_\_\_\_\_

3. List the type of secondary containment for piping: \_\_\_\_\_

4. List the method of monitoring the secondary containment for piping: \_\_\_\_\_

5. Are there incompatible materials within the same vault?

\_\_\_\_\_ Yes      \_\_\_\_\_ No

If yes, how is separate secondary containment provided? \_\_\_\_\_

**Note:** If you have continuous monitoring equipment, you shall maintain copies of all service and maintenance work. Such reports shall be made available for review on site, and shall be submitted to the fire prevention bureau upon request.

Attach additional sheets as necessary.

**SECTION IV: WASTE DISPOSAL**

\_\_\_\_\_ Discharge to the Sanitary Sewer—Wastes: \_\_\_\_\_      \_\_\_\_\_ Pretreatment—Wastes: \_\_\_\_\_

\_\_\_\_\_ Licensed Waste Hauler—Wastes: \_\_\_\_\_      \_\_\_\_\_ Recycle—Wastes: \_\_\_\_\_

\_\_\_\_\_ Other—Describe Method: \_\_\_\_\_  
Wastes: \_\_\_\_\_

\_\_\_\_\_ No Waste

**SECTION V: RECORD KEEPING**

Description of our inspection program: \_\_\_\_\_

\_\_\_\_\_ We will use the attached sample forms in our inspection program.

\_\_\_\_\_ We will not use the sample forms. We have attached a copy of our own forms.

**SECTION VI: EMERGENCY RESPONSE PLAN**

1. In the event of an emergency, the following shall be notified:

A. On-site Responders:

<b>Name</b>	<b>Title</b>	<b>Phone</b>
_____	_____	_____
_____	_____	_____

B. Method of Notification to Responder:

\_\_\_\_\_ Automatic Alarm \_\_\_\_\_ Phone  
\_\_\_\_\_ Manual Alarm \_\_\_\_\_ Verbal  
\_\_\_\_\_ Other: \_\_\_\_\_  
\_\_\_\_\_

C. **Agency** **Phone Number**

Fire Department: \_\_\_\_\_

State Office of Emergency: \_\_\_\_\_

Services: \_\_\_\_\_

Other: \_\_\_\_\_  
\_\_\_\_\_

2. Designated Local Emergency Medical Facility:

<b>Name</b>	<b>Address</b>	<b>Phone (24 hours)</b>
_____	_____	_____

3. Mitigation Equipment:

A. Monitoring Devices:

\_\_\_\_\_ Toxic or flammable gas detection  
\_\_\_\_\_ Fluid detection  
\_\_\_\_\_ Other: \_\_\_\_\_  
\_\_\_\_\_

B. Spill Containment:

\_\_\_\_\_ Absorbants \_\_\_\_\_ Other: \_\_\_\_\_  
\_\_\_\_\_

C. Spill Control and Treatment:

\_\_\_\_\_ Vapor Scrubber \_\_\_\_\_ Mechanical Ventilation  
\_\_\_\_\_ Pumps/vacuums \_\_\_\_\_ Secondary Containment  
\_\_\_\_\_ Neutralizer \_\_\_\_\_ Other: \_\_\_\_\_  
\_\_\_\_\_

4. Evacuation:

\_\_\_\_\_ Immediate area evacuation routes posted  
\_\_\_\_\_ Entire building evacuation procedures developed  
\_\_\_\_\_ Assembly areas preplanned  
\_\_\_\_\_ Evacuation maps posted  
\_\_\_\_\_ Other: \_\_\_\_\_  
\_\_\_\_\_

5. Supplemental hazardous materials emergency response plan on site.

Location: \_\_\_\_\_

Responsible Person: \_\_\_\_\_

Phone: \_\_\_\_\_

## **SECTION VII: EMERGENCY-RESPONSE TRAINING PLAN**

1. Person responsible for the emergency-response training plan:

Name	Title	Phone
_____	_____	_____

2. Training Requirements:

A. All employees trained in the following as indicated:

- \_\_\_\_\_ Procedures for internal alarm/notification
- \_\_\_\_\_ Procedures for notification of external emergency-response organization
- \_\_\_\_\_ Location and content of the emergency-response plan

B. Chemical handlers are trained in the following as indicated:

- \_\_\_\_\_ Safe methods for handling and storage of hazardous materials
- \_\_\_\_\_ Proper use of personal protective equipment
- \_\_\_\_\_ Locations and proper use of fire- and spill-control equipment
- \_\_\_\_\_ Specific hazards of each chemical to which they may be exposed

C. Emergency-response team members are trained in the following:

- \_\_\_\_\_ Procedures for shutdown of operations
- \_\_\_\_\_ Procedures for using, maintaining and replacing facility emergency and monitoring equipment

3. The following records are maintained for all employees:

- \_\_\_\_\_ Verification that training was completed by the employee
- \_\_\_\_\_ Description of the type and amount of introductory and continuing training
- \_\_\_\_\_ Documentation on and description of emergency-response drills conducted at the facility

4. A more comprehensive and detailed emergency-response training plan is maintained on site.

Location: \_\_\_\_\_

Responsible Person: \_\_\_\_\_

Phone: \_\_\_\_\_

**Notation:**

Authority: Health and Safety Code Sections 1250, 1569.72, 1569.78, 1568.02, 1502, 1597.44, 1597.65, 13108, 13143, 13143.9, 13146, 13210, 13211, 17921, 18949.2, California Education Code Article 7.5, Sections 17074.50, 17074.52 and 17074.54.

References: Health and Safety Code Sections 13143, 13211, 18949.2, 25500 through 25545, Chapter 6.95 and Title 19, Division 2, Chapter 4

**[61. Reprint various provisions of California Code of Regulations, Title 19, Division 1 provisions following the CFC Sections noted below.]**

**301.1 Scope...**

**[California Code of Regulations, Title 19, Division 1, §3.14] Fire Hazard.**

No person, including but not limited to the State and its political subdivisions, operating any occupancy subject to California Code of Regulations, Title 19, Division 1 regulations shall permit any fire hazard, as defined in this article, to exist on premises under their control, or fail to take immediate action to abate a fire hazard when requested to do so by the enforcing agency.

NOTE: "Fire Hazard" as used in California Code of Regulations, Title 19, Division 1 regulations means any condition, arrangement, or act which will increase, or may cause an increase of, the hazard or menace of fire to a greater degree than customarily recognized as normal by persons in the public service of preventing, suppressing or

extinguishing fire; or which may obstruct, delay, or hinder, or may become the cause of obstruction, delay or hindrance to the prevention, suppression, or extinguishment of fire.

**[California Code of Regulations, Title 19, Division 1, §3.19(a ) through (g)] Housekeeping.**

Every building or portion of a building governed by California Code of Regulations, Title 19, Division 1 regulations shall be maintained in a neat orderly manner, free from any condition that would create a fire or life hazard or a condition which would add to or contribute to the rapid spread of fire. Provisions shall be made for the proper storage and disposal of waste materials and rubbish consistent with the following:

(a) All basements, cellars, floors, closets, attics, and other similar places not open to continuous observation shall be free from combustible litter and rubbish at all times.

NOTE: Such storage may be permitted in these areas only when protected by approved automatic extinguishing systems or fire-resistive separations.

(b) All combustible waste material and rubbish shall be stored in approved containers or shall be stored in a manner approved by the enforcing agency as being consistent with standard fire prevention practices until such waste material and rubbish is removed from the premises or otherwise disposed of in a proper manner. Nonmetallic rubbish containers with a capacity of less than 30 gallons shall be manufactured of materials tested in accordance with and shall comply with U.L. Standard 242 "Nonmetallic Containers for Waste Paper" (Rev.3-93) which is incorporated by reference. Nonmetallic rubbish containers with a capacity of 30 gallons or more shall be manufactured of materials having a peak rate of heat release not exceeding 300 kW/m<sup>2</sup> that meet ASTM Standard 1354-90A, "Standard Test Method for Heat and Visible Smoke Release for Materials and Products Using an Oxygen Consumption Calorimeter" (Rev. 8-91) which is incorporated by reference. Such containers shall be equipped with an integrated self-closing lid and be permanently labeled indicating capacity and peak rate of heat release.

(c) Approved self-closing metal containers shall be provided and maintained in all rooms or locations where oily rags, oily waste, paint rags, or similar materials subject to spontaneous ignition are used, or are stored temporarily. Such containers shall be emptied daily.

(d) Ashes shall not be placed in, on, or near combustible material, but shall be placed in approved metal containers, until removed from the premises or otherwise properly disposed of.

(e) No dry vegetation shall be permitted to exist within 20 feet of any building or occupancies subject to California Code of Regulations, California Code of Regulations, Title 19, Division 1 regulations.

(f) Except when permitted by the enforcing agency, boiler rooms, mechanical rooms, transformer and switchgear vaults and electrical panel rooms, shall not be used for storage.

(g) Electric motors, filters on heating equipment, and grease hoods shall be checked periodically and kept clean and maintained in a safe operating condition.

**304.1 Waste accumulation prohibited...**

**[California Code of Regulations, Title 19, Division 1, §3.07(a)] Clearances.**

(a) General. No combustible material shall be placed or stored within 10 feet of any building or structure.

**304.1.2 Vegetation...**

**[California Code of Regulations, Title 19, Division 1, §3.07(b)] Clearances.**

(b) Ground Clearance. The space surrounding every building or structure shall be maintained in accordance with the following:

Any person that owns, leases, controls, operates, or maintains any building or structure in, upon, or adjoining any mountainous area or forest-covered lands, brush covered lands, or grass-covered lands, or any land which is covered with flammable material, shall at all times do all of the following:

(1) Maintain around and adjacent to such building or structure a firebreak made by removing and clearing away, for a distance of not less than 30 feet on each side thereof or to the property line, whichever is nearer, all flammable vegetation or other combustible growth. This section does not apply to single specimens of trees, ornamental shrubbery, or similar plants which are used as ground cover, if they do not form a means of rapidly transmitting fire from the native growth to any building or structure.

(2) Maintain around and adjacent to any such building or structure additional fire protection or firebreak made by removing all bush, flammable vegetation, or combustible growth which is located from 30 feet to 100 feet

from such building or structure or to the property line, whichever is nearer, as may be required by the enforcing agency if he finds that, because of extra hazardous conditions, a firebreak of only 30 feet around such building or structure is not sufficient to provide reasonable fire safety. Grass and other vegetation located more than 30 feet from such building or structure and less than 18 inches in height above the ground may be maintained where necessary to stabilize the soil and prevent erosion.

(3) Remove that portion of any tree which extends within 10 feet of the outlet of any chimney or stovepipe.  
(4) Cut and remove all dead or dying portions of trees located adjacent to or overhanging any building.  
(5) Maintain the roof of any structure free of leaves, needles, or other dead vegetative growth.  
(6) Provide and maintain at all times a screen over the outlet of every chimney or stovepipe that is attached to any fireplace, stove, or other device that burns any solid or liquid fuel. The screen shall be constructed of nonflammable material with openings of not more than ½ inch in size.

(7) Vegetation around all applicable buildings and structures shall be maintained in accordance with the following laws and regulations:

(A) Public Resources Code Section 4291.

(B) California Code of Regulations Title 14 - Natural Resources, Division 1.5 - Department of Forestry and Fire Protection, "General Guideline to Create Defensible Space."

(C) California Government Code Section 51182.

(D) California Code of Regulations, Title 24, Part 9.

### **304.3 Containers...**

#### **California Code of Regulations, Title 19, Division 1, §3.19(b) and (c) Housekeeping.**

Every building or portion of a building governed by California Code of Regulations, Title 19, Division 1 regulations shall be maintained in a neat orderly manner, free from any condition that would create a fire or life hazard or a condition which would add to or contribute to the rapid spread of fire. Provisions shall be made for the proper storage and disposal of waste materials and rubbish consistent with the following:

(b) All combustible waste material and rubbish shall be stored in approved containers or shall be stored in a manner approved by the enforcing agency as being consistent with standard fire prevention practices until such waste material and rubbish is removed from the premises or otherwise disposed of in a proper manner. Nonmetallic rubbish containers with a capacity of less than 30 gallons shall be manufactured of materials tested in accordance with and shall comply with U.L. Standard 242 "Nonmetallic Containers for Waste Paper" (Rev.3-93) which is incorporated by reference. Nonmetallic rubbish containers with a capacity of 30 gallons or more shall be manufactured of materials having a peak rate of heat release not exceeding 300 kW/m<sup>2</sup> that meet ASTM Standard 1354-90A, "Standard Test Method for Heat and Visible Smoke Release for Materials and Products Using an Oxygen Consumption Calorimeter" (Rev. 8-91) which is incorporated by reference. Such containers shall be equipped with an integrated self-closing lid and be permanently labeled indicating capacity and peak rate of heat release.

(c) Approved self-closing metal containers shall be provided and maintained in all rooms or locations where oily rags, oily waste, paint rags, or similar materials subject to spontaneous ignition are used, or are stored temporarily. Such containers shall be emptied daily.

### **308.1.1 Where prohibited...**

#### **California Code of Regulations, Title 19, Division 1, §3.25(a) and (b) Open Flame Devices.**

(a) Open flame devices shall be prohibited in every Group A, E, I, R-2.1, R-3.1 and R-4 Occupancy.

#### **EXCEPTIONS:**

(1) Fuel burning elements of approved appliances shall not be considered as open flame devices.

(2) Upon approval of the enforcing agency, open flame devices may be used under the following conditions.

(A) When necessary for ceremonial or theatrical purposes under such restrictions as may be deemed necessary to avoid danger of ignition of combustible materials or injury to occupants.

(B) In approved and stable candle holders on individual tables of dining establishments.

(b) Under no circumstances shall hand held open flame devices such as exposed candles be permitted for any purpose in any occupancy within the scope of California Code of Regulations, Title 19, Division 1 regulations.

### **310.2 Prohibited areas...**

#### **California Code of Regulations, Title 19, Division 1, §3.32(a) and (b) Smoking.**

(a) Smoking shall not be permitted in any Group E Occupancy as defined in California Code of Regulations, Title 24, Part 2, except as provided in California Code of Regulations, Title 19, Division 1, subsection (b) below.

(b) The governing board of any school district maintaining a community college or high school may adopt rules and regulations permitting the smoking and possession of tobacco on the campus of a community college or high school or while under the authority of school personnel by pupils of the community college or high school; provided that such rules and regulations shall not permit students to smoke in any classroom or other enclosed facility which any student is required to smoke in any classroom or other enclosed facility which any student is required to occupy or which is customarily occupied by nonsmoking students. Areas designated for smoking shall be approved by the enforcing agency.

NOTE: See Section 48901 of the Education Code relating to the smoking or possession of tobacco by pupils.

**[California Code of Regulations, Title 19, Division 1, §3.32(d)] Smoking.**

(d) Smoking shall be prohibited in any patient room of a Group I, R-2.1, R-3.1 or R-4. Occupancy utilizing air-induced mattresses. No Smoking – Open Flame signs shall be installed as specified in NFPA 99B, Hypobaric Facilities, 2005 edition.

**310.3 “No Smoking” signs...**

**[California Code of Regulations, Title 19, Division 1, §3.32(c)] Smoking.**

(c) Approved no smoking signs shall be posted on all stages and platforms of Group A Occupancies. Smoking shall not be permitted on stages or platforms except in approved designated areas and as necessary for theatrical, opera or similar productions.

**404.1 General...**

**[California Code of Regulations, Title 19, Division 1, §3.10] Evacuation of Buildings.**

Upon notification of fire, conduct of any fire drill, upon activation of the fire alarm, or upon orders of the fire authority having jurisdiction, buildings or structures within the scope of California Code of Regulations, Title 19, Division 1 regulations shall be immediately evacuated or occupants shall be relocated in accordance with established plans.

**404.2 Where Required...**

**[California Code of Regulations, Title 19, Division 1, §3.13(c)(1)] Fire Drills. (Organized Camps)**

(c) Organized Camps.

(1) Every organized camp shall institute fire training programs for all employees in the use of all fire extinguishing equipment and methods of evacuation, and shall establish procedures which shall, as far as possible, be followed in the event of fire or any other emergency. If located in a forest area a plan shall be prepared for the evacuation of the camp in case of an approaching forest fire or other emergency.

**404.3.2 Fire safety plans...**

**[California Code of Regulations, Title 19, Division 1, §3.13(a)(2)] Fire Drills. (Group E Occupancies)**

(a) Group E Occupancies.

(2) Emergency Pre-Fire Planning. Each school principal, district superintendent or day nursery manager shall, in cooperation with the enforcing agency, prepare procedures to be followed in case of fire or other emergency. They should include the following:

(A) Posting of the telephone number of the fire department in the office and/or at the main switchboard.

(B) Assignment of a responsible person to call the fire department upon notification of any fire or activation of the alarm system for any reason other than fire drills.

(C) Posting in a conspicuous place in each classroom or assembly area a plan showing paths of travel to evacuate the room in case of emergency and including an alternate route.

(D) Posting in each classroom instructions to be followed by the teacher. These should include:

1. Maintaining of order during evacuation.

2. Removal of roll call book and calling of roll when designated evacuation area is reached.

**[California Code of Regulations, Title 19, Division 1, §3.13(b)] Fire Drills. (College and University)**

(b) College and University Pre-Fire Planning. The Chancellor, President, or his designated representative, shall, in cooperation with the enforcing agency, propose procedures to be followed in case of fire or other emergency in accordance with the provisions of California Code of Regulations, Title 19, Division 1, Section 3.13 (a)(2).

**404.5.1 Distribution...**

**[California Code of Regulations, Title 19, Division 1, §3.09 Emergency Planning and Information.]**

(a) All office buildings 2 or more stories in height (except highrise buildings as defined by Health and Safety Code Section 13210).

(1) Owner(s) or operator(s) shall employ either one of the following methods of providing emergency procedures and information to the building occupants:

(A) Emergency procedures information published in the form of a leaflet, brochure, or pamphlet shall be available to all persons entering the building. Emergency procedures information shall be located immediately inside all entrances to the building, as determined by the authority having jurisdiction. Locations shall be clearly marked; or,

(B) A floor plan providing emergency procedures information shall be posted at every stairway landing, at every elevator landing, and immediately inside all public entrances to the building. The information shall be posted so that it describes the represented floor level and can be easily seen immediately upon entering the floor level or the building. Emergency procedures information shall be printed with a minimum of 3/16-inch high non-decorative lettering providing a sharp contrast to the background.

(2) Emergency procedures information shall provide all ambulatory, nonambulatory, and the physically disabled, instructions to be followed in the event of an emergency. Emergency procedures information shall include, but not be limited to the following:

(A) Location of exits and fire alarm initiating stations, if required;

(B) what the fire alarm, if required, sounds and looks like (audible and visual warning devices);

(C) fire department emergency telephone number 911; and,

(D) the prohibition of elevator use during emergencies, if any.

(b) Hotels, Motels and Lodging houses.

(1) Every guestroom available for rental in a hotel, motel, or lodging house shall have clearly visible emergency procedures information printed on a floor plan representative of the floor level and posted on the interior of each entrance door or immediately adjacent to such door. The owner/operator of a hotel, motel, or lodging house may, in lieu of posting emergency procedures information in each guestroom, provide such information through the use of leaflets, brochures, pamphlets, videotapes, or any other method as approved by the authority having jurisdiction. Oral communication in itself does not fulfill the intent of this section. However, oral communication can be incorporated as a part of the transfer of emergency procedures information. When emergency procedures information signage is posted on the interior of the guestroom entrance door, the bottom of the information shall not be located more than 4-feet above the floor level. Visually impaired persons shall receive instructions of a type they will understand, for example: taping of instructions, instructions in braille, or other appropriate methods.

(2) Each method of providing information shall include, but not be limited to that described in subsection (a)(2)(A-D).

(3) Hotels, motels, and lodging houses shall maintain at the registration desk a list noting the guestrooms assigned to guests with disabilities when such guests have indicated that they have special emergency evacuation requirements. The innkeeper shall, at the innkeeper's option, do one of the following:

(1) provide a place on the registration form for physically disabled guests who have such requirements to so identify themselves;

(2) provide a notice on the room key jacket advising guests with disabilities who have special emergency evacuation requirements to so notify the front desk; or

(3) utilize such other means for allowing such guests with disabilities to so identify themselves as may be approved by the authority having jurisdiction.

(c) Hotels, motels, lodging houses, highrise office buildings, and Group I, Division 1 and 2 occupancies as defined in the State Building Code (except honor farms and conservation camps).

(1) Emergency procedures information printed on a floor plan shall be posted at every stairway landing, at every elevator landing, and immediately inside all public entrances to the building. The information shall be representative of the floor level and be posted so that the bottom edge of such information is not located more than 4-feet above the floor, where it can be easily identified. Emergency procedures information shall be printed with a minimum of 3/16-inch non-decorative lettering providing a sharp contrast to the background.

(2) Emergency procedures information shall include, but not be limited to that described in subsection (a)(2)(A-D).

(d) Owner(s) and operator(s) of hotels, motels, lodging houses, highrise office buildings, and Group I, Division 1 and 2 occupancies as defined in the State Building Code (except honor farms and conservation camps) shall appoint a Fire Safety Director, who shall:

(1) Report to owner(s) or operator(s):

(2) coordinate fire safety activities of the facility with the authority having jurisdiction;

(3) conduct, or cause to be conducted, all training as described in subsection (e), for all building employees and maintain records of dates, subjects, and attendance of each training session; and,

(4) develop and maintain a written facility emergency plan acceptable to the authority having jurisdiction. Upon request, the facility emergency plan shall be made physically available at the respective facility to the authority having jurisdiction. Facility emergency plans shall include, but not be limited to the following:

(A) Fire department emergency telephone number 911;

(B) other emergency response telephone numbers;

(C) evacuation or relocation plan for the building occupants;

(D) duties of the Fire Safety Director and other designated emergency personnel;

(E) building employee responsibilities in case of emergency, including individual assignment and reporting responsibilities; and,

(F) procedures to identify and assist the non-ambulatory and physically disabled.

(5) assure that the requirements of subsection (d)(4)(F), procedures to identify and assist the non-ambulatory and physically disabled are accomplished as follows:

(A) Hotels, motels, and lodging houses shall comply with subsection

(b)(3):

(B) owner(s) or operator(s) of highrise office buildings shall maintain a list of all permanent building tenants who have disabilities. Building owner(s) or operator(s) shall be notified in writing by those who have disabilities. Information provided in the list shall include any special emergency evacuation needs and permanent work location of such physically disabled persons. The list shall be located in the building manager's office;

(C)(3) Group I, Division 1 and 2 occupancies as defined in the State Building Code (except honor farms and conservation camps) shall comply with normal hospital policies of assisting patients and guests during an emergency evacuation.

(e) Hotels, motels, lodging houses, and highrise office buildings shall conduct annually, emergency procedures training for individuals listed in subsection (d)(3). Group I, Division 1 and 2 occupancies as defined in the State Building Code (except honor farms and conservation camps) shall conduct quarterly fire emergency training for individuals listed in subsection (d)(3).

(1) Fire Safety Directors and their designated emergency personnel shall receive training in the identification and use of facility fire safety equipment, communication procedures, people movement procedures, fire prevention practices, and their duties outlined in their respective emergency plan. The training curriculum shall be approved by, and made available to the authority having jurisdiction.

(2) Individuals designated in subsection (d)(3) shall receive training covering the identification and use of facility fire safety equipment, fire prevention practices, and appropriate procedures to follow in the event of a fire.

(3) Actual evacuation or relocation of building occupants pursuant to procedures contained in the emergency plan shall be conducted at least annually by those individuals designated in subsection (d)(3). Appropriate records, including dates, floors or building involved, and persons conducting evacuation or relocation procedures shall be maintained and made immediately available to the authority having jurisdiction upon their request. The authority having jurisdiction shall be notified not less than 48 hours in advance of such planned evacuation or relocation.

Exception: In hotels, motels, lodging houses, and Group I, Division 1 and 2 occupancies as defined in the State Building Code, guests and patients are not required to participate in evacuation or relocation of the building. In hotels,

motels, lodging houses, Group I, Division 1 and 2 occupancies as defined in the State Building Code, and highrise office buildings, on-duty personnel who have security or maintenance related responsibilities, and designated management personnel approved by the fire authority having jurisdiction shall not be required to participate in any drill but, they shall provide an alternate method approved by the authority having jurisdiction to measure their knowledge of their respective duties pursuant to the emergency plan.

(f) Emergency procedures signage posted prior to the effective date of these regulations may be continued in use until one year after such effective date of these regulations.

#### **405.2 Frequency...**

##### **[California Code of Regulations, Title 19, Division 1, §3.13(a)(1)] Fire Drills. (Group E Occupancies)**

###### (a) Group E Occupancies.

(1) General. Every person and public officer managing, controlling, or in charge of any public, private, or parochial school shall cause the fire alarm signal to be sounded upon the discovery of fire. Every person and public officer managing, controlling, or in charge of any public, private, or parochial school, other than a two-year community college, shall cause the fire alarm signal to be sounded not less than once every calendar month at the elementary and intermediate levels, and not less than twice yearly at the secondary level, in the manner prescribed in California Code of Regulations, Title 24, Part 2, Section 907.

A fire drill shall be held at the secondary level not less than twice every school year.

##### **[California Code of Regulations, Title 19, Division 1, §3.13(c)(2) and (3)] Fire Drills. (Organized Camps)**

###### (c) Organized Camps.

(2) Within 24 hours after arrival, every group of persons attending an organized camp shall be made familiar with the method by which the fire alarm may be activated and with the procedures to be followed upon notification of fire.

(3) At least 1 fire drill shall be held within 24 hours of the commencement of each camping session. Additional drills shall be conducted at least once each week thereafter. When sessions exceed a 7 day period, at least 1 drill shall be held during night-time sleeping hours.

#### **408.3 Group E occupancies and Group R-2 college and university buildings.....**

##### **[California Code of Regulations, Title 19, Division 1, §3.13(a)(1)] Fire Drills. (Group E Occupancies)**

###### (a) Group E Occupancies.

(1) General. Every person and public officer managing, controlling, or in charge of any public, private, or parochial school shall cause the fire alarm signal to be sounded upon the discovery of fire. Every person and public officer managing, controlling, or in charge of any public, private, or parochial school, other than a two-year community college, shall cause the fire alarm signal to be sounded not less than once every calendar month at the elementary and intermediate levels, and not less than twice yearly at the secondary level, in the manner prescribed in California Code of Regulations, Title 24, Part 2, Section 907.

A fire drill shall be held at the secondary level not less than twice every school year.

#### **503.2 Specifications...**

##### **[California Code of Regulations, Title 19, Division 1, §3.05(a)] Fire Department Access and Egress. (Roads)**

(a) Roads. Required access roads from every building to a public street shall be all-weather hard-surfaced (suitable for use by fire apparatus) right-of-way not less than 20 feet in width. Such right-of-way shall be unobstructed and maintained only as access to the public street.

EXCEPTION: The enforcing agency may waive or modify this requirement if in his opinion such all-weather hard-surfaced condition is not necessary in the interest of public safety and welfare.

#### **504.1 Required access...**

**[California Code of Regulations, Title 19, Division 1, §3.05(b)] Fire Department Access and Egress. (Roofs)**

*(b) Roofs. No person shall install or maintain any security barrier such as barbed wire fencing, razor wire fencing, chain link fencing, or any other fencing material, cable, aerial, antenna, or other obstruction on the roof of any commercial establishment in such a manner as to obstruct or render egress or access hazardous in the event of fire or other emergency.*

*EXCEPTION: Guy wire, rods and aerial antenna masts may be attached to a roof structure having a slope of less than 30 degrees provided there is full clearance of seven feet or more between the roof and said obstruction. Guy wire or rods required to support aerial or antenna masts may be attached to a roof structure a lateral distance from the mast not in excess of one –sixth the height of the mast.*

**603.5 Heating appliances...**

**[California Code of Regulations, Title 19, Division 1, §3.17(a) and (b)] Guards for Heating Appliances.**

*Every heating appliance in any occupancy governed by California Code of Regulations, Title 19, Division 1 regulations which does not have protective features incorporated in its design, shall be provided with guards that will provide protection against ignition of clothing and other combustible material.*

*(a) Appliances employing open flame radiated heat shall have fixed and substantially constructed metallic guards located not less than ten inches (10") from the radiating flame and the guard members shall be spaced not more than two inches (2") apart.*

*(b) Cabinet type appliances that are not provided with an inner combustion chamber and an air circulating space between the combustion chamber and the outer shell, shall have fixed and substantially constructed metallic guards located not less than three inches (3") from the shell and spaced not more than two inches (2") apart.*

**603.8 Incinerators...**

**[California Code of Regulations, Title 19, Division 1, §3.20] Incinerators.**

*Unless other approved means are provided for the prompt disposal of rubbish, an approved incinerator shall be provided and maintained for the disposal of combustible waste. Incinerators shall be constructed, located, and maintained in such manner that waste material can be safely burned at any hour of the day, where local ordinances permit.*

*Fuel-fired and garbage burning incinerators shall be constructed and maintained in conformance with NFPA 82-2005 Incinerators, Waste and Linen Handling Systems and Equipment or U.L. 791-2006 Standard for Residential Incinerators, whichever is applicable.*

**801.1 Scope...**

**[California Code of Regulations, Title 19, Division 1, §1172] Purpose.**

*California Code of Regulations, Title 19, Division 1, Chapter 8 have been prepared and adopted for the purpose of establishing minimum standards for the prevention of fire and for the protection of life and property against fire and panic through the use of flame-retardant chemicals, fabrics and materials.*

**[California Code of Regulations, Title 19, Division 1, §1173] Scope.**

*California Code of Regulations, Title 19, Division 1, Chapter 8 shall govern the manufacture, sale and application of flame-retardant chemicals used in connection with fabrics or materials required to be treated and maintained in a flame-retardant condition as provided in Sections 13115 or 1311 of the Health and Safety Code. These rules and regulations shall also apply to fabrics or materials inherently nonflammable and, they shall also establish minimum fire-resistive standards for such fabrics or materials.*

*California Code of Regulations, Title 19, Division 1, Chapter 8 shall also establish minimum standards and specific procedures for the approval of flame-retardant chemicals, flame retardant materials and flame retardant applicator concerns.*

**[California Code of Regulations, Title 19, Division 1, §1174] Basis.**

*California Code of Regulations, Title 19, Division 1, Chapter 8 are based upon the presumption of fact that fabrics and similar materials commonly known to be flammable increase, or may cause the increase of, the hazard or menace of fire; that proper and adequate flame-retardant treatment through the use of certain chemicals is possible whereby the danger to life and property from fire and panic can be materially reduced; and, that there do exist certain*

fabrics and materials which by nature are nonflammable.

## 802.1 Terms defined in Chapter 2...

### **[California Code of Regulations, Title 19, Division 1, §1191] Approved.**

"Approved" means approved by the State Fire Marshal.

### **[California Code of Regulations, Title 19, Division 1, §1196] Flame Retardant Chemical.**

"Flame-Retardant Chemical" as used herein means any chemical, chemical compound or chemical mixture which when properly applied to a fabric or material will render such fabric or material incapable of supporting combustion to the extent that it will successfully withstand the tests and meet the specifications promulgated by the State Fire Marshal.

### **[California Code of Regulations, Title 19, Division 1, §1201] Nonflammable Material.**

"Nonflammable Material" as used herein means a fabric or material which is inherently flame-resistant to the extent that it will meet the requirements of the fire resistance test herein prescribed, but shall not include materials which must be chemically treated or processed after manufacture to make them flame-resistant.

### **[California Code of Regulations, Title 19, Division 1, §1202] Place of Public Assemblage.**

"Place of Public Assemblage" as used herein means any occupancy mentioned in Sections 13115 or 13119 of the Health and Safety Code.

## 803.5 Textiles...

### **[California Code of Regulations, Title 19, Division 1, §3.21(a) and (b)] Interior Finish of Decorative Material.**

(a) Unframed Rigid Combustible Decorative Material. Rigid combustible decorative material and assemblies of materials not more than ¼ inch in thickness used for folding doors, room dividers, decorative screens and similar applications, which do not create concealed spaces and which are installed with exposed edges, shall be flame resistant in accordance with the following:

(1) Test specimen shall be 12 inches wide and 24 inches long. Four specimens shall be tested, two in each direction of the material.

(2) The specimen shall be suspended vertically with its lower edge 2 inches above the top of a 3/8 inch diameter Bunsen Burner. The test shall be performed in a draft-free area.

(3) The flames from the burner shall be 4 inches long and shall be adjusted with sufficient air supply to eliminate any yellow flame tips but without any distinct inner blue cone.

(4) The specimen shall be exposed to the flame at each corner and at not less than one other point along the lower edge. Each exposure shall be of sufficient duration to determine if the material will ignite and continue to burn, but shall be not less than 20 seconds.

(5) The criteria for acceptance shall be as follows:

(A) There shall be not more than intermittent flaming appreciably beyond the area exposed to the test flame.

(B) No flame shall reach the top of the specimen.

(C) On removing the test flame there shall be not more than one second of after flaming except there may be nonprogressive flaming of short duration in areas of accumulated char which were directly exposed to the test flame.

(b) Framed Rigid Combustible Decorative Material. Rigid combustible decorative material and assemblies of materials not more than ¼ inch in thickness used for folding doors, room dividers, decorative screens and similar applications, and which are installed with all edges protected, shall conform to the following:

(1) All exposed edges shall be protected with frames of metal or other noncombustible material, or solid wood of minimum ¼ inch dimension.

(2) The total square foot area of the material shall not exceed ten percent of that of the floor area of the room in which the material is installed.

(3) When tested as follows, no flames shall reach the top edge of the specimen.

The test shall be conducted in a draft free area, on a specimen of the material 12 inches by 12 inches suspended at a 45 degree angle from the horizontal with the upper and lower edges in a horizontal plane. The test flame shall be 3 inches long from a Bunsen Burner of approximately ½ inch inside diameter with the air supply completely shut off. The burner shall be so positioned so that its top is 1 inch vertically below a point on the lower surface of the test specimen, 1 inch up from its lower horizontal edge, and mid-way between the inclined edges. The

exposure to the test flame and the duration of test shall be for a period of 2 minutes.

## **806.2 Artificial vegetation.....**

### **[California Code of Regulations, Title 19, Division 1, §3.08]. Decorative Materials.**

In every Group A, E, I, R-1, R-2, R-2.1, R-3.1 and R-4 occupancies all drapes, hangings, curtains, drops, and all other decorative material, including Christmas trees, that would tend to increase the fire and panic hazard shall be made from a nonflammable material, or shall be treated and maintained in a flame-retardant condition by means of a flame-retardant solution or process approved by the State Fire Marshal, as set forth in California Code of Regulations, Title 19, Division 1, Chapter 8. Exits, exit lights, fire alarm sending stations, wet standpipe hose cabinets, and fire extinguisher locations shall not be concealed, in whole or in part, by any decorative material.

#### **EXCEPTIONS:**

- (a) Cubical curtains and individual patient room window curtains and drapes in Group I, R-2.1, R-3.1 and R-4 occupancies.
- (b) Window curtains and drapes within dwelling units of Group R-1 and R-2 occupancies.
- (c) Christmas trees within dwelling units of Group R-1 and R-2 occupancies.

## **807.1.2 Combustible decorative materials...**

### **[California Code of Regulations, Title 19, Division 1, §3.08]. Decorative Materials.**

In every Group A, E, I, R-1, R-2, R-2.1, R-3.1 and R-4 occupancies all drapes, hangings, curtains, drops, and all other decorative material, including Christmas trees, that would tend to increase the fire and panic hazard shall be made from a nonflammable material, or shall be treated and maintained in a flame-retardant condition by means of a flame-retardant solution or process approved by the State Fire Marshal, as set forth in California Code of Regulations, Title 19, Division 1, Chapter 8. Exits, exit lights, fire alarm sending stations, wet standpipe hose cabinets, and fire extinguisher locations shall not be concealed, in whole or in part, by any decorative material.

#### **EXCEPTIONS:**

- (a) Cubical curtains and individual patient room window curtains and drapes in Group I, R-2.1, R-3.1 and R-4 occupancies.
- (b) Window curtains and drapes within dwelling units of Group R-1 and R-2 occupancies.
- (c) Christmas trees within dwelling units of Group R-1 and R-2 occupancies.

### **[California Code of Regulations, Title 19, Division 1, §1273.1] Fabrics for Interior Use.**

Fabrics as described in California Code of Regulations, Title 19, Division 1, 1272(c) intended for interior use shall be tested in their original condition only and shall meet the requirements for fire resistance outlined in California Code of Regulations, Title 19, Division 1, Section 1273.3.

### **[California Code of Regulations, Title 19, Division 1, §1273.2] Fabrics for Exterior Use.**

Fabrics as described in California Code of Regulations, Title 19, Division 1, 1272(c) intended for exterior use shall meet the requirements for fire resistance outlined in California Code of Regulations, Title 19, Division 1, 1273.3, and, in addition, they shall meet the requirements for fire resistance outlined in California Code of Regulations, Title 19, Division 1, 1237, both in their original state and after accelerated weathering.

## **807.2 Acceptance criteria and reports...**

### **[California Code of Regulations, Title 19, Division 1, §1321.1] Fabric and Material Certification.**

All concerns in whose name an approved flame-resistant fabric or material is registered shall issue approved certificates of flame resistance covering all such products sold for use in occupancies governed by the statutes. Copies shall be furnished to the buyer as well as the State Fire Marshal and the local fire authority of the customer's city. These certificates shall be delivered within 10 days after the product is shipped and shall be filled out completely and signed by an authorized representative of the concern.

In addition to the required description on the reverse side of the certificate as to yardage or quantity, color and kind, notation should be made of the manufacturer's production or lot control number, the purchase order or invoice number, and, where possible, the ultimate location and use.

**[California Code of Regulations, Title 19, Division 1, §1324] Job Labeling.**

To every article that is treated and to every roll or package of registered approved fabric or material a small label or tag shall be securely affixed, bearing the following information:

- (a) The Seal of Registration of the State Fire Marshal of California.
- (b) Name and registration number of the concern responsible for the job or production.
- (c) Name of the registered chemical used or the registered fabric or material.
- (d) Date the chemical was applied, or the fabric or material was produced.
- (e) The statement, "This article must be re-treated after washing or drycleaning by systems with soap and water added" (if treated with a "Type II" chemical).

This information may be stamped, printed or stenciled on the article if so desired.

Concerns which treat or manufacture yardage goods may print or stencil their name, or the name of their fabric if registered, on the salvage (at least once every three yards) instead of affixing the label or tag as above.

**[California Code of Regulations, Title 19, Division 1, §1325] Labeling Required.**

No drape, hanging, curtain, drop or similar decorative material or exterior fabric which has been treated by a registered flame-retardant application concern, either as yardage or after fabrication, or which is made from a registered approved fabric shall be installed after the effective date of these rules and regulations [California Code of Regulations, Title 19, Division 1, Chapter 8] in any place or under any condition governed by Sections 13115 and 13119 of the Health and Safety Code unless such drape, hanging, curtain, drop, or similar decorative material or exterior fabric shall be labeled as required by California Code of Regulations, Title 19, Division 1, Section 1324.

**[California Code of Regulations, Title 19, Division 1, §1326] Retreatment.**

In cases where instructions are issued by the State Fire Marshal requiring retreatment or replacement of fabrics or materials previously treated with a flame-retardant chemical or registered as an approved fabric or material, the retreatment or replacement shall be made within ten (10) days after date of the order so requiring. A new certificate of flame resistance covering each such retreatment shall be delivered as for an original job as is provided for by California Code of Regulations, Title 19, Division 1, Section 1321. A new sample of the retreated fabric or material shall be attached to the certificate of flame resistance submitted to the State Fire Marshal.

**[California Code of Regulations, Title 19, Division 1, §1327] Installation.**

The standard fire resistance tests presume installation of approved registered fabrics in a normal vertical position. Some decorative materials installed otherwise, such as in narrow strips or suspended overhead in a horizontal position, may exhibit different burning characteristics. Since it is not feasible to devise tests for all such installations differing from normal, they must be judged on an individual basis. Where indicated, the State Fire Marshal may perform such additional tests as he deems necessary to insure adequate fire resistance of materials as installed.

**808.1 Wastebaskets and linen containers in Group I-2 and I-3 occupancies....**

**[California Code of Regulations, Title 19, Division 1, §3.19(b) and (c) Housekeeping.**

Every building or portion of a building governed by California Code of Regulations, Title 19, Division 1 regulations shall be maintained in a neat orderly manner, free from any condition that would create a fire or life hazard or a condition which would add to or contribute to the rapid spread of fire. Provisions shall be made for the proper storage and disposal of waste materials and rubbish consistent with the following:

(b) All combustible waste material and rubbish shall be stored in approved containers or shall be stored in a manner approved by the enforcing agency as being consistent with standard fire prevention practices until such waste material and rubbish is removed from the premises or otherwise disposed of in a proper manner. Nonmetallic rubbish containers with a capacity of less than 30 gallons shall be manufactured of materials tested in accordance with and shall comply with U.L. Standard 242 "Nonmetallic Containers for Waste Paper" (Rev.3-93) which is incorporated by reference. Nonmetallic rubbish containers with a capacity of 30 gallons or more shall be manufactured of materials having a peak rate of heat release not exceeding 300 kW/m<sup>2</sup> that meet ASTM Standard 1354-90A, "Standard Test Method for Heat and Visible Smoke Release for Materials and Products Using an Oxygen Consumption Calorimeter" (Rev. 8-91) which is incorporated by reference. Such containers shall be equipped with an integrated self-closing lid and be permanently labeled indicating capacity and peak rate of heat release.

(c) Approved self-closing metal containers shall be provided and maintained in all rooms or locations where oily rags, oily waste, paint rags, or similar materials subject to spontaneous ignition are used, or are stored temporarily. Such containers shall be emptied daily.

#### **901.6 Inspection, testing and maintenance...**

##### **[California Code of Regulations, Title 19, Division 1, §1.14] Maintenance.**

Every fire alarm system or device, sprinkler system, fire extinguisher, fire hose, fire resistive assembly or any other fire safety assembly, device, material or equipment installed and retained in service in any building or structure subject to California Code of Regulations, Title 19, Division 1 regulations shall be maintained in an operable condition at all times in accordance with California Code of Regulations, Title 19, Division 1 regulations and with their intended use.

##### **[California Code of Regulations, Title 19, Division 1, §3.24] Maintenance of Equipment.**

All fire alarm systems, fire detection systems, automatic sprinkler or extinguishing systems, communication systems, and all other equipment, material or systems required by California Code of Regulations, Title 19, Division 1 shall be maintained in an operable condition at all times. Upon disruption or diminishment of the fire protective qualities of such equipment, material or systems, immediate action shall be instituted to effect a reestablishment of such equipment material or systems to their original normal and operational condition.

##### **[California Code of Regulations, Title 19, Division 1, §904(a)] Required Inspection, Testing, and Maintenance Frequencies.**

(a) All automatic fire extinguishing systems, including systems installed as an alternate to other building requirements, shall be inspected, tested, and maintained in accordance with the following frequencies. Local authorities may require more frequent inspection, testing and maintenance and additional procedures.

##### **[California Code of Regulations, Title 19, Division 1, §904(a)(1)] Required Inspection, Testing, and Maintenance Frequencies.**

(1) Water-based fire protection systems shall be inspected, tested and maintained in accordance with the frequencies required by NFPA 25 (2002 edition) including and Annexes A, B, C, D, and E as amended by the State of California. (Published as NFPA 25, 2006 California Edition).

##### **[California Code of Regulations, Title 19, Division 1, §904(b)] Required Inspection, Testing, and Maintenance Frequencies.**

(b) When proof of the installation date of standpipe systems or automatic fire sprinkler systems cannot be furnished, such systems shall receive initial testing and maintenance by July 1, 1985.

##### **[California Code of Regulations, Title 19, Division 1, §904.2(a)] Testing and Maintenance Requirements.**

(a) All testing and maintenance on automatic fire extinguishing systems in accordance with Health & Safety Code Section 13195 shall be performed by those licensed in accordance with Health and Safety Code Section 13196.5.

##### **EXCEPTIONS:**

- (1) The State Fire Marshal may waive in writing licensing of fire departments which conduct fire sprinkler and standpipe system testing and maintenance.
- (2) Service on fire alarm systems and industrial systems as specified in 13196.5(b) and (c) Health and Safety Code may be conducted without a license.
- (3) Testing and maintenance on automatic fire extinguishing systems exempted in writing by the State Fire Marshal, when the building owner or occupant has the staff and equipment to conduct testing and maintenance.

##### **[California Code of Regulations, Title 19, Division 1, §904.2(b)] Testing and Maintenance Requirements.**

(b) Any testing and maintenance of automatic fire extinguishing systems shall be performed in accordance with these requirements.

##### **EXCEPTIONS:**

- (1) The State Fire Marshal may waive in writing the requirement that testing and maintenance be performed in accordance with these requirements when a licensee can demonstrate that a system cannot functionally be

tested and maintained in accordance with the California Code of Regulations, Title 19, Division 1, Chapter 5

(2) If at any time a licensee encounters a specialized or modified system which cannot be tested and maintained in accordance with California Code of Regulations, Title 19, Division 1, Chapter 5 the licensee shall contact the State Fire Marshal and test and maintain the system as directed.

(A) The intent of this section is to cover automatic fire extinguishing systems as originally designed, installed and approved by the Authority Having Jurisdiction. It is not, however, intended to require that such systems be upgraded to current adopted standards.

**[California Code of Regulations, Title 19, Division 1, §904.2(h)] Testing and Maintenance Requirements.**

(h) At the time of testing and maintenance, building management shall be consulted to avoid unnecessary disturbance of normal building operation.

**[California Code of Regulations, Title 19, Division 1, §904.2(i)] Testing and Maintenance Requirements.**

(i) The licensee shall contact the local fire authority having jurisdiction prior to testing and maintenance of a system when required by the local fire authority having jurisdiction to do so.

**901.6.1 Standards...**

**[California Code of Regulations, Title 19, Division 1, §904.1(a)] Inspection Requirements.**

(a) A license shall not be required to perform inspections. Inspections may be conducted by any person designated by the building owner or occupant who has developed competence through training and experience.

**[California Code of Regulations, Title 19, Division 1, §904.2(g)] Testing and Maintenance Requirements.**

(g) Prior to activating any fire alarm component of an automatic fire extinguishing system, the licensee shall insure that the licensee is capable of restoring the fire alarm system.

**901.6.2 Records...**

**[California Code of Regulations, Title 19, Division 1, §904.1(b)] Inspection Requirements.**

(b) Records of all inspections shall be retained on the premises by the building or system owner for a period of five years after the next required inspection.

**[California Code of Regulations, Title 19, Division 1, §904.2(c)] Testing and Maintenance Requirements.**

(c) Records of all testing and maintenance shall be retained on the premises by the building or system owner for a period of five years after the next required test or maintenance.

**[California Code of Regulations, Title 19, Division 1, §904.2(j)] Testing and Maintenance Requirements.**

(j) It is the responsibility of the contractor, company or licensee to provide a written report of the test and maintenance results to the building owner and the local fire authority having jurisdiction at the completion of the testing and maintenance.

**901.7 Systems out of service...**

**[California Code of Regulations, Title 19, Division 1, §904.1(c)] Inspection Requirements.**

(c) The owner or occupant shall promptly correct or repair deficiencies, damaged parts, or impairments found while performing the inspection, test, and maintenance requirements of this standard. Recalled products shall be replaced or remedied. Such replacement or remedial product shall be installed in accordance with the listing requirements, the manufacturer's instructions and the appropriate NFPA installation standards. A recalled product is a product subject to a statute or administrative regulation specifically requiring the manufacturer, importer, distributor, wholesaler, or retailer of a product, or any combination of such entities, to recall the product, or a product voluntarily recalled by a combination of such entities.

**[California Code of Regulations, Title 19, Division 1, §904.2(d)] Testing and Maintenance Requirements.**

(d) The building or system owner shall insure immediate correction of any deficiencies noted during the service. A tag or label shall be affixed to a system only after all deficiencies have been corrected. The owner or occupant shall promptly correct or repair deficiencies, damaged parts, or impairments found while performing the

inspection, test, and maintenance requirements of this standard. Recalled products shall be replaced or remedied. Such replacement or remedial product shall be installed in accordance with the listing requirements, the manufacturer's instructions and the appropriate NFPA installation standards. A recalled product is a product subject to a statute or administrative regulation specifically requiring the manufacturer, importer, distributor, wholesaler, or retailer of a product, or any combination of such entities, to recall the product, or a product voluntarily recalled by a combination of such entities.

**[California Code of Regulations, Title 19, Division 1, §904.2(e)] Testing and Maintenance Requirements.**

(e) At the time of testing and maintenance, or at any time parts are replaced, an itemized invoice showing work performed and parts replaced shall be provided by the licensee to the system owner. If testing and maintenance is performed more than thirty (30) days prior to the next required testing and maintenance date, the invoice shall bear a statement indicating the system was tested and maintained early.

**[California Code of Regulations, Title 19, Division 1, §904.2(f)] Testing and Maintenance Requirements.**

(f) The licensee shall offer to return all replaced parts to the system owner or owners representative, except those parts that are required to be returned to the manufacturer under conditions of warranty.

**902.1 Definitions...**

**[California Code of Regulations, Title 19, Division 1, §902.4(b)] "E" Definitions**

(b) Engineered Fixed Extinguishing System. A system which is custom designed for a particular hazard, using components which are approved or listed only for their broad performance characteristics. Components may be arranged into a variety of configurations. These systems shall include but not be limited to:

- (1) Dry Chemical Systems
- (2) Carbon Dioxide Systems
- (3) Halogenated Agent Systems
- (4) Steam Systems
- (5) High Expansion Foam Systems
- (6) Foam Extinguishing Systems
- (7) Liquid Agent Systems
- (8) Clean Agent Systems

**[California Code of Regulations, Title 19, Division 1, §902.9(a)] "I" Definitions.**

(a) Inspection. A visual examination of a system or portion thereof to verify that it appears to be in operating condition and is free of physical damage.

**[California Code of Regulations, Title 19, Division 1, §902.12(a)] "M" Definitions.**

(a) Maintenance. Work performed to keep equipment operable or to make repairs.

**[California Code of Regulations, Title 19, Division 1, §902.15(a)] "P" Definitions.**

(a) Pre-Engineered Fixed Extinguishing System. A system where the number of components and their configurations are included in the description of the systems approval and listing. These systems shall include but not be limited to:

- (1) Dry Chemical Systems
- (2) Carbon Dioxide Systems
- (3) Halogenated Agent systems
- (4) Liquid Agent Systems
- (5) Clean Agent Systems

**[California Code of Regulations, Title 19, Division 1, §902.18(a)] "S" Definitions.**

(a) Service. The performance of testing and maintenance on an automatic fire extinguishing system.

**[California Code of Regulations, Title 19, Division 1, §902.19(a)] "T" Definitions.**

(a) Testing. A procedure used to determine the status of a system as intended by conducting periodic physical checks.

## 904.1 General...

### **[California Code of Regulations, Title 19, Division 1, §904(a)(2)] Required Inspection, Testing, and Maintenance Frequencies.**

(2) Engineered and pre-engineered fixed extinguishing systems shall be inspected, tested and maintained at least semi-annually, and immediately after a system activation.

### **[California Code of Regulations, Title 19, Division 1, §904(c)] Required Inspection, Testing, and Maintenance Frequencies.**

(c) Engineered and pre-engineered fixed extinguishing systems, regardless of installation date, shall be inspected, tested and maintained within the time periods specified in California Code of Regulations, Title 19, Division 1, Section 904(a)(2) above.

### **[California Code of Regulations, Title 19, Division 1, §904.7(a) through (c)] Inspection, Testing, and Maintenance Requirements for Engineered and Pre-Engineered Fixed Extinguishing Systems.**

Inspection, Testing, and Maintenance shall be performed in accordance with:

- (a) California Code of Regulations, Title 19, Division 1, Section 904(a)(2).
- (b) the manufacturer's written instructions, which are approved and on file with the Office of the State Fire Marshal; and
- (c) the applicable standards adopted in California Code of Regulations, Title 24, Part 9, (California Fire Code)

## 904.11.5 Portable fire extinguishers for commercial cooking equipment...

### **[California Code of Regulations, Title 19, Division 1, §573(a) through (c)] Fire Extinguisher Size and Placement for Commercial Cooking Operations.**

(a) Fire extinguishers with a Class K rating shall be provided for hazards where there is a potential for fires involving combustible cooking media (vegetable or animal oils and fats).

(b) Maximum travel distance shall not exceed 30 feet (9.15) from the hazard to the extinguishers.

(c) Additional fire extinguishers, required for the control of other classes of fires, shall be provided for commercial cooking areas as required by California Code of Regulations Title 19, Division 1, Section 567.

## 906.1 Where required

### **[California Code of Regulations, Title 19, Division 1, §3.29(a) through (d)] Portable Fire Extinguishing Equipment.**

(a) General. Portable fire extinguishers conforming to the requirements of California Code of Regulations Title 19, Division 1, Chapter 3, shall be installed and maintained in accordance with guides established therein.

(b) Special Coverage. Additional Class A, B, and C units of adequate extinguishing potential shall be provided for any other hazard as determined by the enforcing agency.

(c) Group A Occupancies.

(1) One additional Class 2-A unit shall be provided in Group A Occupancies as follows:

(A) On each side of the stage or platform.

EXCEPTION: Platforms 1000 square feet or less in area need have only one such extinguishing unit.

(B) On each side of every fly gallery.

(C) In basements beneath the stage or platform.

(D) In every hallway or passageway leading to a dressing room.

(E) In every property room, carpenter shop, or similar workroom.

(2) Not less than one 10-B: C unit (not less than 4-B:C for existing extinguishers in existing occupancies) shall be provided:

(A) For each motor and fan room.

(B) Adjacent to each switchboard on the stage or platform.

(C) For each motion picture machine in projection rooms.

EXCEPTION: One 20-B:C unit (not less than 8-B:C for existing extinguishers in existing occupancies) in each projection room may be accepted as providing substantially equal protection.

(3) The enforcing agency may allow modifications or deviations relative to the number and location of portable fire extinguishers as required by this section provided such authority finds that the basic intent of this section

and the ease of accessibility to extinguishers is otherwise achieved.

(d) Group R-2.1, R-3.1 and R-4 Occupancies. In Group R-2.1, R-3.1 and R-4 Occupancies a continuously attached garden hose, equipped with a water flow control nozzle, may be provided in lieu of one or more required fire extinguishers when acceptable to the enforcing agency. The location and length of such hose shall be as designated or approved by the enforcing agency.

NOTE: It is recommended that wherever possible portable fire extinguishers be located adjacent to manual fire alarm sending stations.

**[California Code of Regulations, Title 19, Division 1, §565(a)] Selection of Fire Extinguishers.**

(a) The selection of extinguishers for a given situation shall be determined by the authority having jurisdiction in accordance with adopted codes or ordinances. The character of the fires anticipated, the construction and occupancy of the individual property, the vehicle or hazard to be protected, ambient-temperature conditions, and other factors shall be considered. The number, size, placement, and limitations of use of extinguishers required shall be determined by using California Code of Regulations, Title 19, Division 1, Sections 567 through 573.

**906.2 General requirements...**

**[California Code of Regulations, Title 19, Division 1, §565.1(a) through (c)] Classification of Hazards.**

(a) Light (Low) Hazard. Locations where the total amounts of Class A combustible materials, including furnishings, decorations and contents, is of minor quantity. These shall include buildings or rooms occupied as offices, classrooms, churches, assembly halls, etc. This classification anticipates that the majority of the contents are either noncombustible or so arranged that a fire is not likely to spread rapidly. Small amounts of Class B flammables used for duplicating machines, art departments, etc., are included provided that they are kept in closed containers and safely stored.

(b) Ordinary (Moderate) Hazard. Locations where the total amounts of Class A combustibles and Class B flammables are present in greater amounts than expected under Light (Low) Hazard occupancies. These occupancies could consist of offices, classrooms, mercantile shops and allied storage, light manufacturing, research operations, auto showrooms, parking garages, workshop or support service areas of Light (Low) Hazard occupancies, and warehouses containing Class I or Class II commodities.

(c) Extra (High) Hazard. Locations where the total amount of Class A combustibles and Class B flammables are present, in storage, production use, and/or finished product over and above those expected and classed as Ordinary (Moderate) Hazards. These occupancies could consist of woodworking, vehicle repair, aircraft and boat servicing, individual product display showrooms, product convention center displays, storage and manufacturing processes such as painting, dipping, coating, including flammable liquid handling. Also, included in warehousing of, or in-process storage of other Class I and Class II commodities.

**[California Code of Regulations, Title 19, Division 1, §565.2(a) through (e)] Selection by Hazard.**

(a) Extinguishers shall be selected for the specific class or classes of hazards to be protected in accordance with the following subdivisions (b)(c)(d) and (e).

(b) Extinguishers for protecting Class A hazards shall be selected from the following: Water-type, halogenated agent types, multipurpose dry chemical and wet chemical type.

(c) Extinguishers for protection of Class B hazards shall be selected from the following: carbon dioxide, dry chemical types, halogenated agent types, and water-type and water chemical extinguishers rated for Class B hazards.

(d) Extinguishers for protection of Class C hazards shall be selected from the following: carbon dioxide, dry chemical types, halogenated agent types, and water mist types rated for Class C. Carbon dioxide extinguishers equipped with metal horns are not considered safe for use on fires in energized electrical equipment and, therefore, are not classified for use on Class C hazards.

(e) Extinguishers and extinguishing agents for the protection of Class D hazards shall be of types approved for use on the specific combustible metal hazard.

**[California Code of Regulations, Title 19, Division 1, §566(a) through (f)] Application for Specific Hazards.**

(a) Class B Fire Extinguishers for Pressurized Flammable Liquids and Pressurized Gas Fires. Fires of this nature are considered to be a special hazard. Class B fire extinguishers containing agents other than dry chemical are relatively ineffective on this type of hazard due to stream and agent characteristics. Selection of extinguishers for this type of hazard shall be made on the basis of recommendations by manufactures of this specialized equipment.

The system used to rate extinguishers on Class B fires (flammable liquids in depth) is not applicable to these types of hazards. It has been determined that special nozzle design and rates of agent application are required to cope with such hazards. Caution: It is undesirable to attempt to extinguish this type of fire unless there is reasonable assurance that the source of fuel can be promptly shut off.

(b) Fire extinguishers provided for the protection of cooking appliances that use combustible cooking media (vegetable or animal oils and fats) shall be listed and labeled Class K fires.

(c) Three-dimensional Class B Fires. A three dimensional Class B fire involves Class B materials in motion such as pouring, running or dripping flammable liquids and generally includes vertical as well as one or more horizontal surfaces. Fires of this nature are considered to be a special hazard. Selection of extinguishers for this type of hazard shall be made on the basis of recommendations by manufacturers of this specialized equipment. The system used to rate extinguishers on Class B fires (flammable liquids in depth) is not directly applicable to this type of hazard.

(d) Water Soluble Flammable Liquid Fires (Polar Solvents). Extinguishers used for the protection of water soluble flammable liquids, such as alcohols, acetones, esters, ketones, etc., shall be selected in accordance with Section 565.2. AFFF type and FFFP type fire extinguishers shall not be used for the protection of water soluble flammable liquids, such as alcohols, acetone, esters, ketones, etc., unless specifically referenced on the extinguisher nameplate.

(e) Electronic Equipment Fires. Extinguishers for the protection of delicate electronic equipment shall be selected from the following: carbon dioxide type or a halogenated agent type, or a distilled water mist type with a minimum Class A:C Rating.

(f) In patient care areas and sleeping rooms of health care facilities, fire extinguishers, including the agents and expelling means, should be selected and utilized which would not be detrimental to patients and are appropriate for the type of fire expected, such as distilled water mist type fire extinguishers with a minimum "2-A:C" Rating.

**[California Code of Regulations, Title 19, Division 1, §567.8] Installation Temperatures.**

Water-type (water, AFFF, FFFP) extinguishers shall not be installed in areas where temperatures are outside the range of 40°F to 120°F (4°C to 49°C). Other types shall not be installed in areas where temperatures are outside the range of -40°F to 120°F (-40°C to 49°C). Fire extinguishers shall not be exposed to temperatures outside of the range shown on the fire extinguisher label.

EXCEPTION NO. 1: Where fire extinguishers are installed in locations subject to temperatures outside these ranges, they shall be of a type approved and listed for the temperature to which they are exposed, or they shall be placed in an enclosure capable of maintaining the stipulated temperature range.

EXCEPTION NO 2: Fire extinguishers containing plain water only can be protected to temperatures as low as -40°F (-40°C) by the addition of an antifreeze stipulated on the extinguisher nameplate. Calcium chloride solutions shall not be used in stainless steel fire extinguishers.

EXCEPTION NO. 3: Some fire extinguishes are approved or listed for use at temperatures as low as -65°F (-54°C).

**[California Code of Regulations, Title 19, Division 1, §574.1] Frequency of Inspection.**

Fire extinguishers shall be manually inspected when initially placed in service. Thereafter extinguishers shall be manually inspected at least monthly by the building owner, occupant, or his/her authorized agent or electronically monitored. Fire extinguishers shall be inspected at more frequent intervals when circumstances require as determined by the Authority Having Jurisdiction.

**[California Code of Regulations, Title 19, Division 1, §574.2] Inspection Procedures.**

(a) In addition to California Code of Regulations, Title 19, Division 1, Section 574.1 fire extinguishers shall be manually inspected in accordance with this section if they are located where any of the following conditions exist:

- (1) High frequency of fires in the past.
- (2) Extra (high) hazard areas.
- (3) Location that make fire extinguishers susceptible to mechanical or physical damage.
- (4) Exposure to abnormal temperatures or corrosive atmospheres.

(b) Manual inspection of extinguishers shall include a check of at least the following items:

- (1) Located in designated place.
- (2) No obstruction to access or visibility.
- (3) Operating instructions on nameplate legible and facing outward.
- (4) Safety seals and tamper indicators not broken or missing.
- (5) Examine for obvious physical damage, corrosion, leakage or clogged nozzle.

- (6) Pressure gauge reading or indicator in the operable range or position.
- (7) Fullness determined by weighing or hefting.
- (8) For wheeled units, the condition of tires, wheels, carriage, hose, and nozzle shall also be checked.
- (9) For non-rechargeable extinguishers using push-to-test pressure indicators, test the indicator.
- (c) Electronic monitoring shall include monitoring of the following items:
  - (1) Located in the designated place.
  - (2) No obstruction to access or visibility.
  - (3) Pressure gauge reading or indicator in the operable range or position.

**[California Code of Regulations, Title 19, Division 1, §567.1] Operating Conditions.**

Portable extinguishers shall be maintained in a fully charged and operable condition, and kept in their designated places at all times when they are not being used.

**[California Code of Regulations, Title 19, Division 1, §574.3] Corrective Action.**

When an inspection of any extinguisher reveals a deficiency in any of the conditions listed in Title 19, Division 1, Sections 574.2(b)(c), immediate corrective action shall be taken.

**[California Code of Regulations, Title 19, Division 1, §574.4] Nonrechargeable Extinguishers.**

When an inspection of any nonrechargeable fire extinguisher reveals a deficiency in any of the conditions listed in (3), (4), (5), (6), (7) or (9) of Title 19, Division 1, Section 574.2(b), it shall be discharged and removed from service.

EXCEPTION: Nonrechargeable extinguishers containing a halon agent shall be removed from service, not discharged, and returned to the manufacturer or local fire extinguisher distributor having the capability of recovering the halon agent.

**[California Code of Regulations, Title 19, Division 1, §575.10] Out of Service.**

Fire extinguishers removed from service for maintenance or recharge shall be replaced by fire extinguishers suitable for the type of hazard protected and shall be of at least equal rating.

**[California Code of Regulations, Title 19, Division 1, §591.5] Replacement Extinguishers.**

Portable fire extinguishers shall not be removed from the premises for hydrostatic testing or any other purpose, without first replacing the extinguisher with a unit rated for the hazard being protected. The customer's original unit shall be returned within 60 calendar days.

**[California Code of Regulations, Title 19, Division 1, §596.7(a) and (b)] Removal of Tag.**

- (a) No person shall remove any tag, collar or label required by Title 19, Division 1, Chapter 3, Article 9 from a portable fire extinguisher except when service is performed.
- (b) No person shall deface, modify, or alter any tag collar or label required by California Code of Regulations, Title 19, Division 1 Chapter 3, Article 9 to be attached to any portable fire extinguisher.

**[California Code of Regulations, Title 19, Division 1, §574.5(a) through (c)] Inspection Record Keeping.**

(a) The fire extinguisher owner shall maintain records of all fire extinguishers inspected, including those extinguishers that were found to require corrective actions. Records shall be maintained until next required maintenance.

(b) At least monthly, the date the manual inspection was performed and the initials of the person performing the inspection shall be recorded on a tag or label attached to the fire extinguisher, or an inspection checklist maintained on file, or an electronic system (e.g. bar coding) that provides a permanent record.

(c) Fire extinguishers being inspected via electronic monitoring, whereby the extinguisher causes a signal at a control unit when a deficiency in any of the conditions listed in California Code of Regulations, Title 19, Division 1, Section 574.2(c) occurs shall provide record keeping in the form of an electronic event log at the control panel.

**906.3 Size and distribution...**

**[California Code of Regulations, Title 19, Division 1, §567(a) through (k)] Distribution of Fire Extinguishers.**

(a) The minimum number of fire extinguishers needed to protect a property shall be determined as outlined in this section. Additional extinguishers may be installed to provide more suitable protection.

(b) Fire extinguishers shall be provided for the protection of both the building structure and the occupancy hazards contained therein.

(c) Required building protection shall be provided by fire extinguishers suitable for Class A fires.

(d) Occupancy hazard protection shall be provided by fire extinguishers suitable for such Class A, B, C, D, or K fire potentials as may be present.

(d) Extinguishers provided for building protection may be considered also for the protection of occupancies having a Class A fire potential.

(f) Buildings having an occupancy hazard subject to Class B and/or Class C fires shall have a standard complement of Class A fire extinguishers for building protection, plus additional Class B and/or Class C extinguishers. Where fire extinguishers have more than one letter classification (such as 2-A:20-B:C), they may be considered to satisfy the requirements of each letter class. When using multi-purpose extinguishers for the protection of Class B hazards, the maximum travel distances described in California Code of Regulations, Title 19, Division 1, Section 568, Table 2 must be observed.

(g) Rooms or areas shall be classified generally as light (low) hazard, ordinary (moderate) hazard, or extra (high) hazard. Limited areas of greater or lesser hazard shall be protected as required.

(h) On each floor level, the area protected and the travel distances shall be based on fire extinguishers installed in accordance with California Code of Regulations, Title 19, Division 1, Section 568, Tables 2 and 3.

(i) Fire extinguishers shall not be obstructed or obscured from view.

EXCEPTION: In large rooms, and in certain locations where visual obstruction cannot be completely avoided, means shall be proved to indicate the fire extinguisher's location.

(j) Fire extinguishers shall be conspicuously located along normal paths of travel where they will be readily accessible and immediately available in the event of a fire.

(k) Where wheeled extinguishers are installed, aisles and doorways through which such extinguishers are to be moved shall have a clear and unobstructed width not less than one foot (1 ft) wider than the overall width of the extinguisher.

**[California Code of Regulations, Title 19, Division 1, §568(a) through (e)] Fire Extinguisher Size and Placement for Class A Hazards.**

(a) Minimum sizes of fire extinguishers for the listed grades of hazards shall be provided on the basis of Title 19, Division 1, Section 568, Table 2, except as modified by Title 19, Division 1, Section 568(d). Extinguishers shall be located so that the maximum travel distances shall not exceed those specified in California Code of Regulations, Title 19, Division 1, Section 568, Table 2, except as modified by California Code of Regulations, Title 19, Division 1, Section 568(d).

(b) Certain smaller fire extinguishers which are charged with a multipurpose dry chemical or halogenated agent are rated on Class B and Class C fires, but having insufficient effectiveness to earn the minimum 1-A rating even though they have value in extinguishing smaller Class A fires. They shall not be used to meet the requirements of California Code of Regulations, Title 19, Division 1, Section 568, Table 2.

**Title 19, Division 1, Section 568, Table 2**

	<b><u>Light (Low) Hazard Occupancy</u></b>	<b><u>Ordinary (Moderate) Hazard Occupancy</u></b>	<b><u>Extra (High) Hazard Occupancy</u></b>
<u>Minimum rated single extinguisher</u>	<u>2-A</u>	<u>2-A</u>	<u>4-A*</u>
<u>Maximum floor area per unit of A</u>	<u>3,000 sq ft</u>	<u>1,500 sq ft</u>	<u>1,000 sq ft</u>
<u>Maximum floor area for extinguisher</u>	<u>11,250 sq ft</u>	<u>11,250 sq ft</u>	<u>11,250 sq ft</u>
<u>Maximum travel distance to extinguisher</u>	<u>75 ft</u>	<u>75 ft</u>	<u>75 ft</u>

\*Two 2 ½ gal (9.46 L) water type extinguishers can be used to fulfill the requirement of one 4-A rated extinguisher.

**Note: 1 ft =0.305 m**

1 sq ft =0.0929m<sup>2</sup>

(c) Extinguishers as specified in California Code of Regulations, Title 19, Division 1, Section 568, Table 2 may be replaced by uniformly spaced 1 ½ inch (3.810 cm) hose stations for use by the occupants of the building. When hose stations are so provided they shall conform to Part 9, Title 24, California Code of Regulations, Chapter 9. The location of hose stations and the placement of fire extinguishers shall be in such a manner that the hose stations do not replace more than every other extinguisher.

(d) Where the floor area of a building is less than that specified in California Code of Regulations, Title 19, Division 1, Section 568, Table 2, at least one extinguisher of the minimum size recommended shall be provided.

(e) The protection requirements may be fulfilled with extinguishers of a higher rating provided the travel distance from anywhere in the building to such larger extinguishers shall not exceed 75 ft. (22.7m), as shown in California Code of Regulations, Title 19, Division 1, Section 568, Table 2 above.

**[California Code of Regulations, Title 19, Division 1, §569(a) through (c)] Fire Extinguisher Size and Placement for Class B Fires Other than for Fires in Flammable Liquids of Appreciable Depth.**

(a) Minimum sizes of fire extinguishers for the listed grades of hazard shall be provided on the basis of California Code of Regulations, Title 19, Division 1, Section 569, Table 3. Extinguishers shall be located so that the maximum travel distances from anywhere in the building shall not exceed those specified in the table used.

EXCEPTION: Extinguishers of lesser rating, desired for small specific hazards within the general hazard area, may be used, but shall not be considered as fulfilling any part of the requirements of California Code of Regulations, Title 19, Division 1, Section 569, Table 3.

**Title 19, Division 1, Section 569, Table 3**

<u>Type of Hazard</u>	<u>Basic Minimum Extinguisher Rating</u>	<u>Maximum travel Distance to Extinguishers (in feet)</u>	<u>(in meters)</u>
<u>Light (low)</u>	<u>5B</u> <u>10B</u>	<u>30</u> <u>50</u>	<u>9.15</u> <u>15.25</u>
<u>Ordinary (moderate)</u>	<u>10B</u> <u>20B</u>	<u>30</u> <u>50</u>	<u>9.15</u> <u>15.25</u>
<u>Extra (high)</u>	<u>40B</u> <u>80B</u>	<u>30</u> <u>50</u>	<u>9.15</u> <u>15.25</u>

Note 1: The specified rating does not imply that fires of the magnitudes indicated by these ratings will occur, but rather to give the operators more time and agent to handle difficult spill fires that may occur.

Note 2: For fires involving water soluble flammable liquids see California Code of Regulations, Title 19, Division 1, Section 566(d).

Note 3: For specific hazard applications see California Code of Regulations, Title 19, Division 1, Section 566.

(b) Two or more extinguishers of lower rating shall not be used to fulfill the protection requirements of California Code of Regulations, Title 19, Division 1, Section 569, Table 3.

(c) The protection requirements may be fulfilled with extinguishers of high ratings provided the travel distance to such larger extinguishers shall not exceed 50 ft. (15.25 m) as shown in California Code of Regulations, Title 19, Division 1, Section 569, Table 3.

**[California Code of Regulations, Title 19, Division 1, §570(a) through (e)]. Fire Extinguisher Size and Placement for Class B Fires in Flammable Liquids of Appreciable Depth.**

(a) Portable fire extinguishers shall not be installed as the sole protection for flammable liquid hazards of appreciable depth [greater than ¼ in. (0.64 cm)] where the surface area exceeds 10 sq. ft. (0.93 m<sup>2</sup>).

EXCEPTION: Where personnel who are trained in extinguishing fires in the protected hazards are available on the premises, the maximum surface area shall not exceed 20 sq. ft. (1.86 m<sup>2</sup>).

(b) For flammable liquid hazards of appreciable depth, a Class B fire extinguisher shall be provided on the basis of at least two numerical units of Class B extinguishing potential per sq ft (0.0929 m<sup>2</sup>) of flammable liquid surface of the largest hazard area. Fire fires involving cooking grease or water-soluble flammable liquids, see California Code of Regulations, Title 19, Division 1, Section 566 (b) and 566 (d).  
EXCEPTION: AFFF or FFFP type extinguishers may be provided on the basis of a 1B rating of protection per sq ft of hazard.

(c) Two or more extinguishers of lower ratings shall not be used in lieu of the extinguisher required for the largest hazard area.

EXCEPTION: Up to three AFFF or FFFP extinguishers may be used to fulfill the requirements provided the sum of the Class B ratings meets or exceeds the value required for the largest hazard area.

(d) Travel distances for portable extinguishers shall not exceed 50 feet (15.25 m) as shown in California Code of Regulations, Title 19, Division 1, Section 569, Table 3.

(e) Scattered or widely separated hazards shall be individually protected. An extinguisher in the proximity of a hazard shall be carefully located to be accessible in the presence of a fire without undue danger to the operator.

**[California Code of Regulations, Title 19, Division 1, §571(a)] Fire Extinguisher Size and Placement for Class C Hazards.**

(a) Fire extinguishers with Class C ratings shall be required where energized electrical equipment can be encountered which would require a nonconducting extinguishing medium. This requirement includes situations where fire either directly involves or surrounds electrical equipment. Since the fire itself is a Class A or Class B hazard, the fire extinguishers shall be sized and located on the basis of the anticipated Class A or B hazard.

Note: Electrical equipment should be de-energized as soon as possible to prevent reigniting.

**906.4 Cooking grease fires...**

**[California Code of Regulations, Title 19, Division 1, §573(a) through (c)] Fire Extinguisher Size and Placement for Commercial Cooking Operations.**

(a) Fire extinguishers with a Class K rating shall be provided for hazards where there is a potential for fires involving combustible cooking media (vegetable or animal oils and fats).

(b) Maximum travel distance shall not exceed 30 feet (9.15) from the hazard to the extinguishers.

(c) Additional fire extinguishers, required for the control of other classes of fires, shall be provided for commercial cooking areas as required by California Code of Regulations, Title 19, Division 1, Section 567.

**906.5 Conspicuous location...**

**[California Code of Regulations, Title 19, Division 1, §567.5] Physical Damage Protection.**

Extinguishers installed under conditions where they are subject to physical damage, (e.g., from impact, vibration, the environment) shall be adequately protected.

**906.6 Unobstructed and unobscured...**

**(Insert CFC Table 906.3(1) FIRE EXTINGUISHERS FOR CLASS A FIRE HAZARDS)**

**(Insert CFC Table 906.3(2) FLAMMABLE OR COMBUSTIBLE LIQUIDS WITH DEPTHS OF LESS THAN OR EQUAL TO 0.25-INCH)**

**906.7 Hangers and brackets...**

**[California Code of Regulations, Title 19, Division 1, §567.3] Installation.**

Portable fire extinguishers other than wheeled types shall be securely installed on the hanger or in the bracket supplied or placed in cabinets or wall recesses. The hanger or bracket shall be securely and properly anchored to the mounting surface in accordance with the manufacturer's instructions. Wheeled-type fire extinguishers shall be located in a designated location.

**[California Code of Regulations, Title 19, Division 1, §567.4] Brackets.**

Extinguishers installed under conditions where they are subject to dislodgement shall be installed in brackets

specifically designed to cope with this problem.

**[California Code of Regulations, Title 19, Division 1, §567.6] Mounting.**

Fire extinguishers having a gross weight not exceeding 40 lbs (18.14kg) shall be installed so that the top of the fire extinguisher is not more than 5 ft. (1.53m) above the floor. Fire extinguishers having a gross weight greater than 40 lbs. (18.14kg) (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3-1/2 ft. (1.07 m) above the floor. In no case shall the clearance between the bottom of the extinguisher and the floor be less than 4 in. (10.2 cm).

**906.8 Cabinets...**

**[California Code of Regulations, Title 19, Division 1, §567.2] Cabinets.**

Cabinets housing extinguishers shall not be locked.

EXCEPTION: Where extinguishers are subject to malicious use, locked cabinets may be used provided they include a means of emergency access and are approved by the authority having jurisdiction.

**[California Code of Regulations, Title 19, Division 1, §567.7] Sealed Cabinets.**

Where extinguishes are installed in closed cabinets, which are exposed to elevated temperatures, the cabinets shall be provided with screened openings and drains.

**907.2.25.2 Camp fire alarm...**

**[California Code of Regulations, Title 19, Division 1, §3.12] Fire Alarm.**

Every organized camp shall provide and maintain an audible appliance or audible appliances suitable for sounding a fire alarm. Such audible appliance or audible appliances may be of any type acceptable to the enforcing agency provided they are distinctive in tone from all other signaling devices or systems and shall be audible throughout the camp premises.

When an automatic fire alarm system is provided, all audible appliances and fire alarm signals as required by this section shall be of the same type as that used in the automatic system.

**1002 Definitions**

**BLEACHERS...**

**[California Code of Regulations, Title 19, Division 1, §4.1(a)] Definitions.**

(a) Burglar bars –Security bars located on the inside or outside of a door or window of a residential dwelling.

**RAMP...**

**[California Code of Regulations, Title 19, Division 1, §4.1 (b)] Definitions.**

(b) Residential Dwelling –A house, apartment, motel, hotel, or other type of residential dwelling subject to the State Housing Law (Part. 1.5 (commencing with Section 17910), Division 13) of Health and Safety Code and a manufactured home, mobilehome, and multiunit manufactured housing as defined in Part 2 (commencing with Section 18000) of Division 13 of the Health and Safety Code.

**1003.7 Elevators, escalators and moving walks...**

**[California Code of Regulations, Title 19, Division 1, §3.31] Restraint.**

Restraint shall not be permitted in any building except in Group I Occupancies constructed for such use in accordance with the provisions of California Code of Regulations, Title 24, Part 2.

**1004.1 Design occupant load...**

**[California Code of Regulations, Title 19, Division 1, §3.27] Overcrowding.**

The number of occupants of any building, structure, or portion thereof, shall not exceed the permitted or

posted capacity.

#### 1004.3 Posting of occupant load...

**[California Code of Regulations, Title 19, Division 1, §3.30] Posting of Room Capacity.**

Any room having an occupant load of 50 or more persons where fixed seats are not installed, and which is used for assembly, classroom, dining, drinking, or similar purposes, shall have the capacity of the room posted in a conspicuous place near the main exit from the room. Posting shall be by means of a durable sign having a contrasting color from the background to which it is attached. Signs shall be of an approved type and shall be maintained in a legible manner by the owner or his authorized agent and shall indicate the number of occupants permitted for each room use. No person shall deface or remove such signs except as authorized by the enforcing agency.

#### 1014.4 Aisles...

**[California Code of Regulations, Title 19, Division 1, §3.06(a)] Bonding of Chairs and Spacing of Tables.**

(a) Bonding of Chairs. In every Group A and Group E Occupancy, all loose seats, folding chairs, or similar seating facilities that are not fixed to the floor shall be bonded together in groups of not less than 3.

**EXCEPTIONS:**

- (1) When not more than 299 such seats, chairs, or facilities are provided, bonding thereof may be deleted.
- (2) The bonding of chairs shall not be required when tables are provided as when the occupancy is used for dining or similar purposes.
- (3) Upon approval of the enforcing agency, the bonding of chairs shall not be required when the placement and location of such chairs do not obstruct any required exit or any line of egress toward required exits and do not constitute a fire hazard as defined in California Code of Regulations, Title 19, Division 1, Section 3.14.

#### 1014.4.3 Seating at tables...

**[California Code of Regulations, Title 19, Division 1, §3.06(b)] Bonding of Chairs and Spacing of Tables.**

(b) Spacing of Tables. In occupancies having rectangular conference or banquet type tables, such tables shall be placed not less than 54 inches apart and not less than 36 inches from walls.

#### 1028.12 Seat stability...

**[California Code of Regulations, Title 19, Division 1, §3.06(a)] Bonding of Chairs and Spacing of Tables.**

(a) Bonding of Chairs. In every Group A and Group E Occupancy, all loose seats, folding chairs, or similar seating facilities that are not fixed to the floor shall be bonded together in groups of not less than 3.

**EXCEPTIONS:**

- (1) When not more than 299 such seats, chairs, or facilities are provided, bonding thereof may be deleted.
- (2) The bonding of chairs shall not be required when tables are provided as when the occupancy is used for dining or similar purposes.
- (3) Upon approval of the enforcing agency, the bonding of chairs shall not be required when the placement and location of such chairs do not obstruct any required exit or any line of egress toward required exits and do not constitute a fire hazard as defined in California Code of Regulations, Title 19, Division 1, Section 3.14.

#### 1029.4 Operational constraints...

**[California Code of Regulations, Title 19, Division 1, §4.2] Labeling.**

Burglar bars shall not be sold in California at wholesale or retail unless warning information as specified in California Code of Regulations, Title 19, Division 1, Section 4.3 is provided either on the packaging or provided inside the packaging along with the burglar bars.

**[California Code of Regulations, Title 19, Division 1, §4.3(a) through (c)] Warning Information.**

(a) Warning information located on or in burglar bar packaging shall contain the following information:

(1) Warning that the burglar bars are intended to deter or delay intruders, they are not intended to prevent entry.

(2) A reprint of the following requirements from California Building Code, Part 2, Chapter 10:

"Bars, grilles, grates or similar devices may be installed on emergency escape or rescue windows, doors or window wells, or any required exit door, provided:

1. The devices are equipped with approved release mechanisms which are operable from the inside without the use of a key or special knowledge or effort; and

2. The building is equipped with smoke detectors alarms installed in accordance with the 1995 California Building Code, Part 2, Section 907.

Such bars, grilles, grates or similar devices shall be equipped with an approved release device for use by the fire department only on the exterior side for the purpose of fire department emergency access, when required by the authority having jurisdiction."

(3) A statement regarding the necessity of installing early warning smoke alarms (as required by the California Building Code, Part 2, Section 907) and planning occupant's escape routes and meeting places.

(4) Contact the local building and fire official to determine if a local ordinance requires a building permit prior to installation and if the burglar bars are required to have a release mechanism on the outside for use by the fire department in the event of a fire emergency.

(5) Written directions and illustrations on the operation of the emergency escape release mechanisms. These directions shall include a warning that the mechanisms be tested on a monthly basis.

(b) The textual information required by this section shall be printed in a minimum 12 –point non –decorative lettering providing a sharp contrast to the background.

(c) Graphical information required by this section shall be of sufficient size to clearly illustrate the intended actions.

**[California Code of Regulations, Title 19, Division 1, §4.4] Warning Information Location.**

When placed on burglar bar packaging, the information required by California Code of Regulations, Title 19, Division 1, Section 4.3 shall be conspicuously located and shall not be covered or made illegible by product advertising not required by Section 4.3.

**[California Code of Regulations, Title 19, Division 1, §4.5(a)] Contractor or Installer Disclosures.**

Any contractor or installer of burglar bars shall provide the owner of the residential dwelling the warning information required pursuant to California Code of Regulations, Title 19, Division 1, Section 4.3 prior to installing burglar bars.

**[California Code of Regulations, Title 19, Division 1, §4.6(a) and (b)] Prohibited Installations.**

No person shall install for profit unopenable burglar bars on a residential dwelling:

(a) Where the California Building Code requires openable burglar bars for emergency escape or rescue, or

(b) On mobilehomes, manufactured homes, or multiunit manufactured housing unless at least one window or door to the exterior in each bedroom is openable for emergency escape or rescue.

**1030.1 General...**

**[California Code of Regulations, Title 19, Division 1, §3.11(a) through (d)] Exits, Aisles, Ramps, Corridors and Passageways.**

(a) No person shall install, place or permit the installation or placement of any bed, chair, equipment, concession, turnstile, ticket office or anything whatsoever, in any manner which would block or obstruct the required width of any exit.

(b) No person shall install, place or permit the installation or placement of any combustible material or equipment in or exposed to any exit.

**EXCEPTIONS:**

(1) Furniture or equipment constructed of wood or other material of similar combustibility may be permitted in an exit or exposed to an exit when approved by the enforcing agency.

(2) When approved by the enforcing agency, combustible materials, may be permitted in exit foyers and lobbies.

(c) No person shall install, place or permit the installation or placement of any storage material of any kind in any exit regardless of the required width of such exit.

**EXCEPTION: Personal material located in metal lockers in Groups B and E Occupancies as defined in California**

Code of Regulations, Title 24, Part 2.

(d) Aisles shall not be occupied by any person for whom seating is not available.

#### 2401.1 Scope...

**[California Code of Regulations, Title 19, Division 1, §303.(a) and (b)] Scope.**

(a) The provisions of California Code of Regulations, Title 19, Division 1, Chapter 2 apply to the sale, offering for sale, manufacture for sale, rental and use of tents within this state.

(b) For building standards relating to tents and membrane structures, see California Code of Regulations, Title 24, Part 9.

#### 2402.1 Definitions...

#### TENT...

**[California Code of Regulations, Title 19, Division 1, §310.(a) through (c)] Definitions.**

(a) Tent. A shelter, structure or enclosure made of fabric or similar pliable material.

(b) Large tent. A tent designed for use by 10 or more people.

(c) Small tent. A tent designed for use by less than 10 People.

#### 2403.8.2 Location...

**[California Code of Regulations, Title 19, Division 1, §312.] Parking of Vehicles.**

Vehicles necessary to the operation of the establishment, shall be parked at least twenty feet (20') from any tent. No other vehicle shall be parked less than one hundred feet (100') from any tent except vehicles parked on a public street shall park at least twenty feet (20') from any tent.

#### 2404.1 General...

**[California Code of Regulations, Title 19, Division 1, §340.] Existing Small Tents.**

Existing small tents are exempt from California Code of Regulations, Title 19, Division 1, Chapter 2.

**[California Code of Regulations, Title 19, Division 1, §341.] Existing Membrane Structures and Other (Large) Existing Tents.**

Existing membranes of membrane structures and large (10 or more capacity) existing tents may continue to be used provided evidence of satisfactory flame resistance is available to the enforcing authority. Such evidence may be in the form of certification that the fabric passes the standard small scale flame resistance test as set forth in California Code of Regulations, Title 19, Division 1, Chapter 8 regulations or through passage of effective field tests.

**[California Code of Regulations, Title 19, Division 1, §321.] Abatement of Fire or Panic Hazards.**

Any condition that presents a fire hazard, would contribute to the rapid spread of fire, interfere with the rapid exit of persons from the tents, or interfere with or delay the extinguishment of a fire, shall be immediately corrected as ordered by the enforcing authority.

**[California Code of Regulations, Title 19, Division 1, §315.(a)] Flame Resistance Standards.**

(a) All tent fabrics and all interior decorative fabrics or materials shall be flame resistant in accordance with appropriate standards set forth in California Code of Regulations, Title 19, Division 1, Chapter 8.

Tent tops and sidewalls shall be made either from fabric which has been flame resistant treated with an approved exterior chemical process by an approved application concern, or from inherently flame resistant fabric approved and listed by the State Fire Marshal.

**[California Code of Regulations, Title 19, Division 1, §332.(a)] Flame Resistance.**

(a) All tents manufactured for sale, sold, rented, offered for sale, or used in California shall be made from nonflammable material or one of the following flame resistant fabrics or material approved by the State Fire Marshal:

(1) Fabrics complying with the State Fire Marshal's requirements for flame resistance for exterior use, as set forth in California Code of Regulations, Title 19, Division 1, Chapter 8 or,

(2) Fabrics complying with the flame resistance requirements set forth in "A Specification for Flame Resistance Materials Used in Camping Tentage" published in 1975 by Canvas Products Association International, hereinafter referred to as CPAI-84.

EXCEPTIONS:

(1) Tents used for committal services at cemeteries

(2) Tents or similar fabric enclosures used within a sound stage or equivalent enclosure equipped with an overhead automatic fire extinguishing system.

**2404.3 Label...**

**[California Code of Regulations, Title 19, Division 1, §334.] Requirements Pertaining to All Tents.**

All tents manufactured for sale in California shall be labeled in accordance with the appropriate provisions of California Code of Regulations, Title 19, Division 1, Section 335.

**[California Code of Regulations, Title 19, Division 1, §335.(a) and (b)] Labeling of Tents.**

(a) Each section of top and sidewall in large tents shall have a durable label, permanently affixed, bearing the following information:

(1) The Seal of Registration.

(2) If treated fabric, the name and registration number of the approved application concern and approved chemical used, and the date of treatment.

(3) If registered fabric, the trade name and registration number of the approved fabric, and the date of production.

In lieu of attached labels, the required information may be applied directly to the fabric by print, stamp or stencil.

(b) Small tents shall have a permanently affixed label bearing the information in California Code of Regulations, Title 19, Division 1, Section 335, subsection (a), or shall comply with the provisions specified in CPAI-84 (1975) which reads as follows:

(1) Certification. A statement that the materials used in the manufacture of the item meet the flame resistance requirements of CPAI-84.

(2) Manufacturer Identification. An identification of the manufacturer of the item. If the item bears a private label, it shall identify the private labeler and shall also contain a code mark which will permit the seller of the item to identify the manufacturer to the purchaser upon request.

(3) Code Number. A number enabling the manufacturer to identify from his records the suppliers and suppliers' lot numbers of the certified materials used in the item. The manufacturer shall also maintain records identifying the parties to whom he sold camping tentage. Further, he shall maintain records identifying items manufactured from lots of certified material. Records shall be maintained for four (4) years.

(4) Warning label.

**24 pt. type**

**WARNING**

**16 pt. type**

**KEEP ALL FLAME AND  
HEAT SOURCES AWAY  
FROM THIS TENT FABRIC**

**12 pt. type**

**This tent is made with flame resistant fabric which meets CPAI-84 specifications. It is not fire proof. The fabric will burn if left in continuous contact with any flame source.**

**The application of any foreign substance to the tent fabric may render the flame resistant properties ineffective .**

This warning label or its equivalent must be permanently affixed to the tent at one conspicuous location, and

must block letters on a white background. The first paragraph of the body of the label must be placed in a conspicuous location on each carton containing the tent.

#### **2404.4 Certification...**

**[California Code of Regulations, Title 19, Division 1, §315.(d)] Flame Resistance Standards.**

(d) Certificates of Flame Resistance or other documentation affirming the requirements of California Code of Regulations, Title 19, Division 1, Section 315, subsection(a) shall be made available upon request of the enforcement authority.

#### **2404.5 Combustible materials...**

**[California Code of Regulations, Title 19, Division 1, §315.(b)] Flame Resistance Standards.**

(b)Sawdust, shavings, or other combustible material used on the floor or ground shall be made flame resistant or when approved by the enforcing authority shall be kept adequately damp when tent is occupied.

**[California Code of Regulations, Title 19, Division 1, §326.(b)] Hazard Abatement.**

(b) Hay, straw, trash and other similar flammable material shall be stored more than 50 feet from any tent except upon approval of the enforcing authority.

EXCEPTION: Tents to which the public is not admitted.

#### **2404.6 Smoking...**

**[California Code of Regulations, Title 19, Division 1, §316.] Smoking Prohibited.**

Smoking is not permitted in any tent, and in any adjacent areas where hay or other highly flammable materials are kept. "No Smoking" signs shall be conspicuously posted in all tents open to the public and wherever otherwise specified by the enforcing authority.

#### **2404.7 Open or exposed flame...**

**[California Code of Regulations, Title 19, Division 1, §317.] Fireworks and Open Flames.**

Fireworks, open flame or any device emitting flame or spark shall not be used in or immediately adjacent to any tent while open to the public, except when approved in writing by the enforcing authority.

#### **2404.12 Portable fire extinguishers...**

**[California Code of Regulations, Title 19, Division 1, §319.(a) through (c)] Fire Extinguishers and Other Fire Protection Equipment.**

(a) One Class 2-A fire extinguisher shall be provided in every tent having a floor area between 500 square feet and 1,000 square feet plus one 2-A fire extinguisher in each auxiliary adjacent tent. One additional extinguisher shall be provided for each additional 2000 square feet or fraction thereof.

(b) At least one Class 10 B-C fire extinguisher shall be provided with each generator or transformer.

(c) At least one Class 10 B-C fire extinguisher shall be provided in kitchen, dining areas, and at locations where flammable or combustible liquids or flammable gases are used, stored, or dispensed.

#### **2404.13 Fire protection equipment...**

**[California Code of Regulations, Title 19, Division 1, §319.(d) and (e)] Fire Extinguishers and Other Fire Protection Equipment.**

(d) Tents having a capacity of 1,000 or more persons shall be protected on each of the long sides with fire hose lines of at least 1 ½ inch internal diameter and of sufficient length to reach either end of the tent. The water supply shall be either from the public water mains or from tanks having a capacity of not less than 500 gallons. There shall be at least 65 pounds of flowing pressure at the nozzle of the hose line when a ½ inch tip is used.

(e) The enforcing authority may modify or waive any of the requirements of this section [Title 19, Division 1, Section 319] and may accept other types of fire extinguishing equipment in lieu of that required by Title 19, Division 1 regulations if, in the authorities' opinion, reasonable and adequate protection will be afforded.

2404.16.1 General...

**[California Code of Regulations, Title 19, Division 1, §325.] Liquefied Petroleum Gas.**

Liquefied petroleum gas shall not be stored or used in connection with any tent unless the storage containers, equipment, fittings, appliances, placement, use and operation complies with the provisions of California Code of Regulations, Title 8, Article 5, Subchapter 1, Chapter 4.

2404.17.2 Flammable and combustible liquid storage...

**[California Code of Regulations, Title 19, Division 1, §324.(a) and (b)] Flammable and Combustible Liquids.**

(a) Liquids having a flash point below 200°F shall not be stored in any tent nor less than 50 feet from any tent.

(b) Flammable or combustible liquids shall be stored and dispensed in accordance with the provisions of the California Fire Code. The enforcing authority may permit limited quantities of flammable or combustible liquids required for display and normal merchandizing.

2404.20 Standby personnel...

**[California Code of Regulations, Title 19, Division 1, §320.] Fire Safety Personnel.**

The owners or operators of any tent used as a place of assemblage shall provide at least one qualified fire safety person in every tent having a capacity of 500 persons and one additional qualified person for each 1,000 additional persons or fraction thereof. Such persons shall be on duty in the tent at all times when the tent is open to the public. They shall be proficient in the handling of fire extinguishers and equipment and shall be familiar with the fire and panic safety regulations. The individual designated under this section shall meet the approval of the fire authority having jurisdiction.

EXCEPTION: The enforcing authority may waive or modify the provisions of this section if, in his opinion, public safety will not be jeopardized.

2404.21 Vegetation removal...

**[California Code of Regulations, Title 19, Division 1, §326.(a)] Hazard Abatement.**

(a) All flammable vegetation within 50 feet of any tent shall be removed.

2404.22 Waste material...

**[California Code of Regulations, Title 19, Division 1, §326.(c)] Hazard Abatement.**

(c) Combustible waste shall not be permitted to accumulate on the grounds either inside or outside of tents. Such waste shall be stored in approved containers until removed from the premises.

3001.1 Scope...

**[California Code of Regulations, Title 19, Division 1, §3.18(a) and (b)] Hazardous Areas.**

(a) General. Occupancies or portions thereof used or intended to be used as operating rooms, surgeries, delivery rooms, storage rooms and similar hazardous locations in which flammable or nonflammable mixtures of gases are used or stored shall be maintained in accordance with the provisions of NFPA 99-2005 Inhalation Anesthetics, NFPA 99-2005 Laboratories, NFPA 99-2005 Hyperbaric Facilities, NFPA 55-2010 Bulk Oxygen Systems at Consumer Sites, and this section.

(b) Containers. Cylinders and fittings for compressed gases shall conform to the regulations of the Federal Department of Transportation.

Compressed gas cylinders shall be clearly marked with the name of the gas contained therein. Cylinders shall bear color markings and labels conforming to the following:

<b><u>Gas</u></b>	<b><u>Color</u></b>
(1) <u>Oxygen</u> .....	<u>Green</u>
(2) <u>Carbon Dioxide</u> .....	<u>Gray</u>
(3) <u>Nitrous Oxide</u> .....	<u>Light Blue</u>

- (4) Cyclopropane ..... Orange
- (5) Helium ..... Brown
- (6) Ethlene ..... Red
- (7) Carbon Dioxide and Oxygen ..... Gray and Green
- (8) Helium and Oxygen ..... Brown and Green

Note: Polished metal or chrome-plated cylinders shall have color tags in addition to color labels.

When deemed necessary by the enforcing agency compressed gas cylinders shall be secured by chains, metal straps, or other approved materials to prevent overturning.

### 3401.1 Scope and application...

**[California Code of Regulations, Title 19, Division 1, §3.15] Flammable and Combustible Liquids.**

Flammable and combustible liquids shall not be placed, stored or handled in any occupancy within the scope of California Code of Regulations, Title 19, Division 1 regulations except as provided in the California Fire Code.

### 3801.1 Scope...

**[California Code of Regulations, Title 19, Division 1, §3.22(a) and (c)] Liquefied Petroleum Gas.**

(a) When liquefied petroleum gas is used, the storage and handling thereof shall conform to the appropriate provisions referenced in California Code of Regulations, Title 19, Division 1, Sections 3.02 and 3.03.

(c) California Code of Regulations, Title 8, Section 475 is hereby adopted as a part of Title 19, Division 1 regulations.

### 3803.2.1.4 Group E and I occupancies...

**[California Code of Regulations, Title 19, Division 1, §3.22(b)] Liquefied Petroleum Gas.**

(b) All liquefied petroleum gas tanks located in school yards shall be surrounded by a rugged steel fence or equivalent. Tanks in other occupancies shall also be so protected if in the opinion of the enforcement agency such protection is needed to prevent unauthorized tampering. The fence shall be at least 6 feet in height and, if it completely surrounds the tank, shall be located a minimum of 3 feet from the tanks. Fenced areas shall be locked when unattended.

## Appendix Chapter 4

### 425.3 Building height and area provisions.

**[California Code of Regulations, Title 19, Division 1, §3.23] Nonambulatory Housing in Group R-2.1, R-3.1 and R-4 Occupancies.** Nonambulatory persons in Group R-2.1, R-3.1 and R-4 Occupancies shall not be housed above the first floor unless the building is of Type IA or Type IIA construction.

#### 425.3.1 One or two stories...

**[California Code of Regulations, Title 19, Division 1, §3.26] Operators Statement – Group I, R-2.1, R-3.1 and R-4 Occupancies.** Every person, firm or corporation maintaining or operating any Group I or R-2.1, R-3.1 or R-4 Occupancy shall provide an operators statement in accordance with Section 13132 of the Health and Safety Code which reads as follows:

“13132. Every person, firm or corporation maintaining or operating any facility for the care of the mentally handicapped shall file a statement with the fire authority having jurisdiction within five days of the admission or readmission of a patient stating that such patient is an ambulatory or a nonambulatory person and enumerating the reasons for such classification. Such a statement shall also be filed for each existing patient within 30 days of the effective date of this section.

Any statement required to be filed pursuant to this section shall be certified as to its correctness by the person attending such patient.

It shall be unlawful for any person, firm, or corporation required to file a statement pursuant to this section to include false statements therein. Any such act shall be in violation of this section and subject to the provisions of Section 13112.”

