



M E M O R A N D U M

Date: June 5, 2002

To: Kim Peters, Project Director
Real Estate Services Division
Project Management Branch

From: Department of General Services – Real Estate Services Division
Building and Property Management Branch
Environmental Safety Health and Operations Program

Subject: BATESON ATRIUM REPAIR PROJECT –
HEALTH AND SAFETY CLEARANCE FOR ATRIUM DECK

At 4:55 p.m. this afternoon, I received verification from Network Environmental Systems (NES) that mold remediation clearance has been achieved for the atrium deck in the Bateson Building, located at 1600 9th Street, Sacramento, CA. The data submitted from NES concludes that the atrium air quality is similar in distribution to the outside mold levels and the outdoor mold levels are at greater concentrations than interior mold spore levels in the atrium and occupied spaces of the building.

All Bateson atrium repair work shall continue, noting inclusion of air quality monitoring wherever necessary as documentation that the building shall be operated and maintained in a manner that is safe, ensuring that all health and safety standards apply to affected tenants, employees, and construction staff that repair damaged atrium deck areas. Demolition and construction work continues in accordance with all applicable health and safety regulations that apply to the tenants, employees, and construction workers in the building.

Should additional monitoring be needed, those results will be provided for your reference. If there are any questions, please contact me at (916) 375-4956. Thank you.

Vincent Paul, Manager
BPM Environmental Safety Health and Operations Program
Real Estate Services Division