

Sorry to do this so piecemeal. Here is another clarification. If there is no space in front of the space or aisle, then I am presuming the intent is that the charger can be located **within** the access aisle rather than beyond 'the projected width of'.

11B-812.10.4 Location. *EV chargers shall be adjacent to, and within the projected width of the vehicle space being served.*

Exceptions:

1. *EV chargers serving more than one EVCS shall be adjacent to, and within the combined projected width of the vehicle spaces being served.*
2. *For alterations at existing facilities where an accessible route or general circulation path is not provided adjacent to the head end of the vehicle space or access aisle, the EV charger may be located within **the projected width of** the access aisle 36 inches (914 mm) maximum from the head end of the space.*

Janis Kent FAIA, CASp, Architect

Certified Access Specialist

Stepping Thru Accessibility

phone — 562-426-9363

web site — www.SteppingThruAccessibility.com

email — janisk@SteppingThruAccessibility.com