

One other item. The wording on the accessible route to the charger is not clear. It sounds like we need to have a 48" space between the vehicle space and the charger - this does not match up with the diagram. I would suggest changing it to connecting rather than between

11B-812.5.2 Accessible route to EV charger. *An accessible route complying with Section 11B-402 shall be provided **between** the vehicle space and the EV charger which serves it.*

Janis Kent FAIA, CASp, Architect

Certified Access Specialist

Stepping Thru Accessibility

phone — 562-426-9363

web site — www.SteppingThruAccessibility.com

email — janisk@SteppingThruAccessibility.com