

Dennis - I am reviewing the EVCS and noticed what could be considered an error.

I believe the following should be a maximum not a minimum

11B-812.7.2 Marking. *Access aisles at vehicle spaces shall be marked with a painted borderline around their perimeter. The area within the borderlines shall be marked with hatched lines a **minimum** of 36 inches (914 mm) on center. The color of the borderlines, hatched lines, and letters shall contrast with that of the surface of the access aisle. The blue color required for identification of access aisles for accessible parking shall not be used. Access aisle markings may extend beyond the minimum required length.*

Also, there is no technical information for the color of the words EV Charging Only and should have the same information as as 11B-812.7.2 which is only for the access aisle

11B-812.9 Surface marking. *EVCS vehicle spaces shall provide surface marking stating "EV CHARGING ONLY" in letters 12 inches (305 mm) high minimum. The centerline of the text shall be a maximum of 6 inches (152 mm) from the centerline of the vehicle space and its lower corner at, or lower side aligned with, the end of the parking space length.*

Also, did we ever address diagonal pull-up EVCS? I am presuming this would be similar to diagonal parking, but we may want to provide the information that this is possible otherwise there might be a lot of confusion similar to the regular accessible diagonal stalls

Janis Kent FAIA, CASp, Architect

Certified Access Specialist

Stepping Thru Accessibility

phone — 562-426-9363

web site — www.SteppingThruAccessibility.com

email — janisk@SteppingThruAccessibility.com