

STATE OF CALIFORNIA
GOVERNMENT OPERATIONS AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
Email: cbsc@dgs.ca.gov

Office Use Item No. _____

PARTICIPATION COMMENTS FOR THE NOTICE DATED OCTOBER 28, 2015
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: NOVEMBER 12, 2015 (no later than 5:00 pm)

Date: 10 November 2015

From:

Andrew Henning
Name (Print or type)


(Signature)

CAL FIRE – Office of the State Fire Marshal (SFM)

Agency, jurisdiction, chapter, company, association, individual, etc.

1131 S St, Sacramento, CA 95815

Street

City

State

Zip

Andrew.henning@fire.ca.gov

Email address

(916) 445-8527

Phone number

I/We (do)(do not) agree with:

The Agency proposed modifications As Submitted on Section No. Chapter 44 and R324

and request that this section or reference provision be recommended:

Approve Disapprove Further Study Required Approve as Amended

Suggested Revisions to the Text of the Regulations:

Item 1- The SFM should repeal the state amendments shown in CRC Chapter 44 for NFPA 13 and NFPA 13R. The CRC should show the edition adopted of NFPA 13 and NFPA 13R and direct the code user to the CBC for state amendments.

Item 2- There are two sections R324.7.2.6 within the CRC. Section R324.7.2.6 Locations of DC conductors should be changed to Section R324.7.2.7. Also the language defining the applicable sections from Section R324.3 and R324.7 should be amended to include R324.7.2.6 and R324.7.2.7.

Reason:

Item 1- Based on Health and Safety Code §18930 9-point criteria (1)
By printing the NFPA 13 and NFPA 13R state amendments within the CRC it would duplicate the CBC.

Item 2- Based on Health and Safety Code §18930 9-point criteria (1 and 6)
These are editorial changes to correct duplicate section numbers and to include state amendments into the scoping provisions.