

11-A. HCD proposes to adopt Chapter 8, Section R806.5 from the 2015 International Residential Code into the 2016 California Residential Code with new and existing amendments as follows:

****Informative Note**** Section R806.5 as originally proposed has been withdrawn and replaced with the following section.

**SECTION R806
ROOF VENTILATION**

R806.5 Unvented attic and unvented enclosed rafter assemblies. Unvented attics and unvented enclosed roof framing assemblies created by ceilings that are applied directly to the underside of the roof framing members and structural roof sheathing applied directly to the top of the roof framing members/rafters, shall be permitted where all the following conditions are met:

1. The unvented attic space is completely within the building thermal envelope.
2. No interior Class I vapor retarders are installed on the ceiling side (attic floor) of the unvented attic assembly or on the ceiling side of the unvented enclosed roof framing assembly.
3. Where wood shingles or shakes are used, a minimum 1/4-inch (6.4 mm) vented airspace separates the shingles or shakes and the roofing underlayment above the structural sheathing.
4. In Climate Zones ~~5, 6, 7 and 8~~, 1, 14 and 16, any air-impermeable insulation shall be a Class II vapor retarder, or shall have a Class III vapor retarder coating or covering in direct contact with the underside of the insulation.

4.1 A Class I or Class II vapor retarder shall be installed on the indirectly conditioned space side of all insulation in an unvented attic with air-permeable insulation, for condensation control.

See Title 24, Part 6 the California Energy Code, FIGURE 100.1-A —California Climate Zones.

5. Insulation shall be located in accordance with the following:
 - 5.1. Item 5.1.1, 5.1.2, 5.1.3 or 5.1.4 shall be met, depending on the air permeability of the insulation directly under the structural roof sheathing. *No insulation shall be required when roof tiles, wood shingles or wood shakes, or any other roofing system using battens and no continuous underlayment is installed. A continuous layer underlayment shall be considered to exist if sheathing, roofing paper or any continuous layer ~~which has~~ having a perm rate of no more than one perm under the dry cup method is present.*
 - 5.1.1. Where only air-impermeable insulation is provided, it shall be applied in direct contact with the underside of the structural roof sheathing.
 - 5.1.2. Where air-permeable insulation is provided inside the building thermal envelope, it shall be installed in accordance with Section 5.1. In addition to the air-permeable insulation installed directly below the structural sheathing, rigid board or sheet insulation ~~with an R-value of R-4~~ shall be installed directly above the structural roof sheathing in accordance with the R-values in Table R806.5 for condensation control.
 - 5.1.3. Where both air-impermeable and air-permeable insulation are provided, the air-impermeable insulation shall be applied in direct contact with the underside of the structural roof sheathing ~~in accordance with Item 5.1.4~~ and shall be in accordance with the R-values in Table R806.5 for condensation control. The air-permeable insulation shall be installed directly under the air-impermeable insulation.
 - 5.1.4. Alternatively, sufficient rigid board or sheet insulation shall be installed directly above the structural roof sheathing to maintain the monthly average temperature of the underside of the structural roof sheathing above 45°F (7°C). For calculation purposes, an interior air temperature of 68°F (20°C) is assumed and the exterior air temperature is assumed to be the monthly average outside air temperature of the three coldest months.
 - 5.2. Where preformed insulation board is used as the air-impermeable insulation layer, it shall be sealed at the perimeter of each individual sheet interior surface to form a continuous layer.

**TABLE R806.5
INSULATION FOR CONDENSATION CONTROL**

CLIMATE ZONE	MINIMUM RIGID BOARD ON <u>OR</u> AIR-IMPERMEABLE INSULATION R-VALUE ^{a, b}
2B and 3B <u>6-15</u> tile roof only	0 (none required)
1, 2A, 2B, 3A, 3B, 3C <u>3-15</u>	R-5
4C <u>1&2</u>	R-10
4A, 4B <u>16</u>	R-15
5	R-20
6	R-25
7	R-30
8	R-35

- ~~a. Contributes to but does not supersede the requirements in Section N1103.2.1.~~
- ~~b. Alternatively, sufficient continuous insulation shall be installed directly above the structural roof sheathing to maintain the monthly average temperature of the underside of the structural roof sheathing above 45°F (7°C). For calculation purposes, an interior air temperature of 68°F (20°C) is assumed and the exterior air temperature is assumed to be the monthly average outside air temperature of the three coldest months.~~