

STATE OF CALIFORNIA
STATE AND CONSUMER SERVICES AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: BSC@dgs.ca.gov

Office Use Item No. _____

PARTICIPATION COMMENTS FOR THE NOTICE DATED MARCH 18, 2008
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: MAY 12, 2008

Date: May 12, 2008

From: Jed Waldman
Name (Print or type)

CA Dept of Public Health - IAQ Program
Agency, jurisdiction, chapter, company, association, individual, etc.

850 Marina Bay Pkwy Richmond CA 94804
Street City State Zip

I/We (do) (do not) agree with:

The Agency proposed modifications As Submitted on Section No. 805 Indoor Moisture Control.

and request that this section or reference provision be recommended:

Approved Disapproved Held for Further Study Approved as Amended

to the proposing state agency.

Suggested Revisions to the Text of the Regulations:

Add subsection(s) that provide for verification of compliance with mold and moisture management requirements during design, construction, acceptance, and occupancy phases. Reference *Greenguard GGBS MP.001, Mold and Moisture Management Standard for New Construction*, when approved. Available from Ethleen Howell at 800-427-9681 (ehowell@greenguard.org). See Table 7.1-7.4

Reason: [The reason should be concise. If the request is for "Disapproval," "Further Study," or "Approve As Amend", identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

There is a need for more explicit guidance and clearer definition of mold & moisture control requirements for building construction (H&SC 18930 (a) 3).