

**From:** RONALD FISHER [mailto:rfish254@msn.com]  
**Sent:** Wednesday, October 07, 2009 12:17 PM  
**To:** CBSC (General Mail)  
**Subject:**

California Building Standards Commission  
2525 Natomas Park Drive, Suite 130  
Sacramento, CA 95833  
Attention: Dave Walls, Executive Director

To Whom It May Concern:

OSHPD currently enforces the California Code of Regulations, Title 24, Part 5, 2007 California Plumbing Code which is based on the 2006 Uniform Plumbing Code with California amendments. I am in favor of repealing Section 604.1, Exception 1 – Amendment prohibiting the use of CPVC piping in health facilities.

The California OSHPD plumbing code should be revised to allow for the universal use of CPVC. I think it is time that California joined the other 49 states in allowing the use of this cost-effective alternative.

The most recent Environmental Impact Report confirms that CPVC can be used safely.

In addition, it has a 50+ year proven track record of reliable performance that is not compromised by aggressive water and/or soil conditions. And, it represents a positive step in making needed medical facilities more affordable in California due to its material and labor cost savings.

Californians deserve to have a choice when it comes to piping materials the same choice that is available in the other 49 states.

The code needs to change to reflect the current economic environment.

Ronald R. Fisher  
8326 Devenir Ave.  
Downey, CA 90242