

STATE OF CALIFORNIA  
STATE AND CONSUMER SERVICES AGENCY  
CALIFORNIA BUILDING STANDARDS COMMISSION  
2525 NATOMAS PARK DR., SUITE 130  
SACRAMENTO, CA 95833  
(916) 263-0916 Phone  
(916) 263-0959 Fax  
Email: [cbcs@dgs.ca.gov](mailto:cbcs@dgs.ca.gov)

Office Use Item No. \_\_\_\_\_


**PARTICIPATION COMMENTS FOR THE NOTICES DATED APRIL 22, 2011**  
Written comments are to be sent to the above address.

**WRITTEN COMMENT DEADLINE: JUNE 6, 2011**

Date: June 6, 2011

From:

Edward R. Osann  
Name (Print or type)

  
(Signature)

-- Natural Resources Defense Council  
Agency, jurisdiction, chapter, company, association, individual, etc.

1314 Second Street, Santa Monica CA 90401  
Street City State Zip

I/We (do not) agree with:

The Agency proposed modifications As Submitted on Table No. 4.303.2

and request that this section or reference provision be recommended:

Approved  Disapproved  Held for Further Study  Approved as Amended

**Suggested Revisions to the Text of the Regulations:**

**Revise the value shown for "Lavatory faucets, residential" in the Maximum Flow Rate at  $\geq 20$  Percent Reduction column from "1.5 gpm" to "1.0 gpm".**

**Reason:** [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

In response to point 7 of the 9-point criteria, we note that the pending version of the International Code Council's International Green Construction Code proposes a value of 1.0 gpm for residential lavatory faucets. Standards incorporated into CALGreen should be at least as efficient as the IGCC, unless there are California-specific reasons to do otherwise.

