

**EMERGENCY EXPRESS TERMS  
FOR  
PROPOSED BUILDING STANDARDS  
OF THE  
CALIFORNIA BUILDING STANDARDS COMMISSION (CBSC)  
IN THE  
2010 CALIFORNIA GREEN BUILDING STANDARDS CODE  
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 11**

LEGEND FOR EXPRESS TERMS

1. Existing California amendments or code language being modified appears in *italics*, with modified language underlined.
2. Repealed text appears in ~~strikeout~~.

**EXPRESS TERMS**

**SECTION 5.106  
SITE DEVELOPMENT**

...

~~**5.106.8 Light pollution reduction.** Meet lighting power requirements in the California Energy Code, CCR, Title 24, Part 6, and design interior and exterior lighting such that zero direct beam illumination leaves the building site. Comply with lighting zones 1-4 and lighting zone characteristics as defined in Chapter 10 of the California Administrative Code, CCR, Title 24, Part 1, using the following strategies:~~

- ~~1. Shield all exterior luminaires or provide cutoff luminaires per Section 132 (b) of the California Energy Code.~~
- ~~2. Contain interior lighting within each source.~~
- ~~3. Allow no more than .01 horizontal footcandles to escape 15 feet beyond the site boundary.~~
- ~~4. Automatically control exterior lighting dusk to dawn to turn off or lower light levels during inactive periods.~~

~~**Exceptions:**~~

- ~~1. CCR, Title 24, Part 2, Chapter 12, Section 1205.6 for campus lighting requirements for parking facilities and walkways~~
- ~~2. Emergency lighting and lighting required for nighttime security~~

Notation

Authority: Health and Safety Code Sections 18930.5, 18934.5, 18938(b) and Government Code 14617.

Reference: Health and Safety Code Sections 18930.5, 18934.5, 18937 and 18938.