

GOLDEN WEST PLUMBING, INC.

1247 N Batavia Street, Orange, CA 92867

Phone 714-997-9991 Fax 714-997-7626

CSLB#317026 C-36

JUN 06 2008

REAL ESTATE
SERVICES DIVISION

California Department of General Services
Real Estate Services Division
Professional Services Branch, Environmental Services Section
707 Third Street, Third Floor, MS 509
West Sacramento, CA 95605-9052

Attn: Valerie Namba, Senior Environmental Planner

RE: Comments on Draft Environmental Impact Report on PEX Tubing

My comments on the DEIR are as follows:

We have been installing Uponor Wirsbo AquaPEX tubing since 2001. During that time, we have installed approximately 1,000 systems and have not had any call backs from end users complaining about taste and odor from their PEX water distribution system. Additionally, since we have been installing PEX water distribution systems we have not had any call backs due to premature failures of the system. We have had numerous failures of copper systems over the past 20 years and in areas where copper is failing, the PEX water distribution system has virtually eliminated any call backs. We continue to replace failing copper systems with PEX tubing, where approved, with great success and to the satisfaction of the end users.


In most application PEX tubing is being installed above slab, eliminating the concern of permeation of contaminated soils. The exception is the installation of PEX tubing to island sinks. In these applications, we have not experienced any call backs concerning permeation of any chemicals into the potable water system. Since the island sinks are in the interior of the slab, the tubing is virtually protected from coming into contact with harmful contaminants that are applied after the structure is built.

Since we have been installing PEX tubing, we have not experienced any failures of PEX tubing, whether installed in a typical water distribution system or in a recirculation system. I can not state the same thing for copper installations. We have replaced numerous copper systems due to pinhole leaks that have occurred in as little as 6 months.

We strongly encourage the adoption of PEX tubing into the California Plumbing Code.

Thank you for your consideration.

Sincerely,


Wayne Taylor, General Manager
Golden West Plumbing, Inc.