

COMMISSION ACTION MATRIX
AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING & DEV. [06/10]

TITLE (CODE)
CCR, TITLE 24, PART 5 (2010 California Plumbing Code)

LEGEND:

Item numbers refer to those presented to the Code Advisory Committees (CAC)s

(CAC)s:

- ACCESS = Accessibility
- BFO = Building, Fire & Other
- HF = Health Facilities
- PEME = Plumbing, Electrical, Mechanical, and Energy
- SDLF = Structural Design/Lateral Forces
- GB = Green Building

Actions:

- AA = Approve as amended
- AS = Approve as submitted
- D = Disapprove
- FS = Further Study
- W/D = Withdrawn by agency

Amendments, if indicated by agency:

- S = Statutory
- E = Existing
- N = New

Matrix Paper Color (Used for Comm. Action):

- GREEN = uncontested items
- YELLOW = challenged items
- SALMON = W/D, no action required

2010 CYCLE AD HOC CODE ADVISORY COMMITTEE

CHAPTER 4 - PLUMBING FIXTURES AND FIXTURE FITTINGS – Office of Statewide Health Planning and Development (OSHDP)

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHDP-6/10-1	<i>Table 4-2</i>	E	AA			CAC RECOMMENDATION: Remove <i>Airborne infection isolation anteroom</i> and <i>Protective environment anteroom</i> from table.	