

**FINAL EXPRESS TERMS  
FOR  
PROPOSED BUILDING STANDARDS  
OF THE  
DIVISION OF THE STATE ARCHITECT**

**REGARDING PROPOSED CHANGES TO  
CALIFORNIA REFERENCED STANDARDS CODE  
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 12**

**REGARDING  
EXCESS FLOW ACTUATED AUTOMATIC GAS SHUTOFF VALVES**

**LEGEND FOR EXPRESS TERMS**

1. Existing California amendments or code language being modified: All such language appears in regular font, modified language is underlined.
2. New California amendments: All such language appears underlined and in regular font.
3. Repealed text: All such language appears in ~~strikeout~~.

**CCR, T-24, PT 12:**

CHAPTER 12-16-2

ENGINEERING REGULATION—QUALITY AND DESIGN OF THE MATERIALS OF CONSTRUCTION

STANDARD 12-16-2

CALIFORNIA STANDARD FOR RESIDENTIAL EXCESS FLOW  
ACTUATED AUTOMATIC GAS SHUTOFF VALVES

(See Chapter 16, *California Building Code* and for Earthquake-Actuated Gas Shutoff Valves  
see Sec. 1211.18, Chapter 12, *California Plumbing Code*)

DIVISION OF THE STATE ARCHITECT

Authority: Sections 19200-19204, Health and Safety Code.

Reference: Section 19201.5 and 19202, Health and Safety Code

Division I—CONSTRUCTION  
SCOPE

Sec. 12-16-201. The ~~“CSA U.S. REQUIREMENTS FOR EXCESS FLOW VALVES NO. 3-92,”~~ January 6, 2000 American Society for Testing and Materials (ASTM) F2138-09 Standard Specification for Excess Flow Valves for Natural Gas Service, shall be the applicable standard used by the Division of the State Architect for certification of these devices.

Sec. 12-16-201.1. Each installation of a customer-owned device that satisfies this standard must be done in accordance with the *California Plumbing Code*.

Notation

Authority: Sections 19200-19204, Health and Safety Code.

Reference: Section 19201.5 and 19202, Health and Safety Code

-----  
Related Code Change: **CCR, T-21, DIV 1, CH 1, SUBCH 6, SECS 1393, 1394, 1396**

Code changes proposed to CCR, Title 21 would be submitted to the Office of Administrative Law.