

STATE OF CALIFORNIA  
STATE AND CONSUMER SERVICES AGENCY  
CALIFORNIA BUILDING STANDARDS COMMISSION  
2525 NATOMAS PARK DR., SUITE 130  
SACRAMENTO, CA 95833  
(916) 263-0916 Phone  
(916) 263-0959 Fax  
Email: cbsc@dgs.ca.gov

Office Use Item No. \_\_\_\_\_

**PARTICIPATION COMMENTS FOR THE NOTICE DATED AUGUST 24, 2012**  
Written comments are to be sent to the above address.

**WRITTEN COMMENT DEADLINE: OCTOBER 8, 2012**

Date: October 5, 2012

From:

Richard LeWarne  
Name (Print or type)

*Richard LeWarne*  
(Signature)

Monterey County Health Department, Environmental Health Bureau  
Agency, jurisdiction, chapter, company, association, individual, etc.

1270 Natividad Road                      Salinas                      CA                      93906  
Street    City    State    Zip

I do not agree with:

The Agency proposed modifications As Submitted on Section 1604.10.

and request that this section or reference provision be recommended:

Approved     Disapproved     Held for Further Study     Approved as Amended

**Suggested Revisions to the Text of the Regulations:**

**Add a subsection indicating whether the setbacks in Table 16.02.4 are applicable to treated graywater for clarification or if there are different setbacks.**

**Add a subsection that addresses operational and design requirements for high production graywater systems (e.g. 5,000 gpd or 10,000+ gpd) such as Technical, Managerial, and Financial capability for entities managing these type of systems, requirement of Grade II Operator, SCADA system, appropriate sensors to monitor the appropriate characteristics of the treated graywater to determine if the treatment system is operating correctly etc.**

**Reason:** [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

Proposed amendments would provide clarification to implementing Agencies regarding setbacks and high production graywater systems per H&S Code Section 19830(a)(6).