

STATE OF CALIFORNIA
STATE AND CONSUMER SERVICES AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbsc@dgs.ca.gov

Office Use Item No. _____


PARTICIPATION COMMENTS FOR THE NOTICE DATED AUGUST 24, 2012
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: OCTOBER 8, 2012

Date: 5 October 2012

From:

Carol Corr
(AA) Name (Print or type)


(Signature)

KAISER PERMANENTE

Agency, jurisdiction, chapter, company, association, individual, etc.

1800 Harrison Street Oakland CA 94612
Street City State Zip

I/We (do)(do not) agree with:

The Agency proposed modifications As Submitted on Section No. 1224.29.1.4 Modular Toilet

and request that this section or reference provision be recommended:

Approved Disapproved Held for Further Study Approved as Amended

Suggested Revisions to the Text of the Regulations:

1224.29.1.4 Modular Toilet. *Modular toilet/sink combination units located within a privacy curtain may be used within each patient space or private room. The toilet fixture shall be completely contained within cabinetry when not in use. ~~This fixture shall not be equipped with a bedpan washing attachment.~~ Exhaust ventilation requirements shall comply with the California Mechanical Code.*

Reason:

- (8) The applicable national specifications, published standards, and model codes have been incorporated therein as provided in this part, where appropriate.
- This added requirement is not cited in any other model code.
 - The bed pan washing attachment is a standard feature on most modular toilets.
 - When not allowed with the modular toilet, will force hospitals to install a separate bedpan washing hose on the wall adding cost to the project, or
 - If bedpan washing is not provided in the room, staff will be required to carry the dirty bedpan through the corridor with the possibility of spilling.