

STATE OF CALIFORNIA
STATE AND CONSUMER SERVICES AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbsc@dgs.ca.gov

Office Use Item No. _____


PARTICIPATION COMMENTS FOR THE NOTICE DATED AUGUST 24, 2012
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: OCTOBER 8, 2012

Date: 5 October 2012

From:

Carol Corr
(AA) Name (Print or type)


(Signature)

KAISER PERMANENTE

Agency, jurisdiction, chapter, company, association, individual, etc.

1800 Harrison Street Oakland CA 94612
Street City State Zip

I/We (do)(do not) agree with:

The Agency proposed modifications As Submitted on Section No. 1224.4.4.1.1 sub sections 4, 5, 6
and request that this section or reference provision be recommended:

Approved Disapproved Held for Further Study Approved as Amended

Suggested Revisions to the Text of the Regulations:

Delete unnumbered text below 6; it repeats the information in three numbered items, 4, 5, 6.

....6. Ventilation. The ventilation shall be provided as required by the California Mechanical Code for airborne infection isolation room.

~~Airborne infection isolation exam/treatment room perimeter walls, ceiling, and floor, including penetrations, shall be sealed tightly so that air does not infiltrate the environment from the outside or from other spaces.~~

~~Airborne infection isolation exam/treatment room(s) shall have self-closing devices on all room exit doors.~~

~~The ventilation shall be provided as required by the California Mechanical Code for an airborne infection isolation room.~~

1224.4.4.1.1 Airborne infection isolation exam/treatment anteroom.

Reason: Unnumbered text appears to be in error and duplicates information in numbered items.