

STATE OF CALIFORNIA
STATE AND CONSUMER SERVICES AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbsc@dgs.ca.gov

Office Use Item No. _____


PARTICIPATION COMMENTS FOR THE NOTICE DATED AUGUST 24, 2012
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: OCTOBER 8, 2012

Date: 5 October 2012

From:

Carol Corr
(BP) Name (Print or type)


(Signature)

KAISER PERMANENTE

Agency, jurisdiction, chapter, company, association, individual, etc.

1800 Harrison Street Oakland CA 94612
Street City State Zip

We do not agree with:

[] The Agency proposed modifications As Submitted on Section No. **1226.5.5**

and request that this section or reference provision be recommended:

[] Approved [] Disapproved [] Held for Further Study [] Approved as Amended

Suggested Revisions to the Text of the Regulations:

1226.5.5 Radiological/imaging service space. *When x-ray examination services, computerized tomography scanning, magnetic resonance imaging, ultrasound, and/or mammography services are provided, the radiological/imaging services space shall comply with the provisions of this section.*

1226.5.5.1 Support spaces for radiological/imaging services. *The following spaces are common to the imaging service area and are minimum requirements:*

1226.5.5.1.1 Patient toilet room(s). *In service spaces with procedure rooms that do not require dedicated patient toilets, provide a minimum of one patient toilet room within the service space, refer to Section 1226.4.14.1.*

1226.5.5.1.2 Outpatient change area. *A separate space shall be provided where outpatients change from street clothing. This shall include provisions for clothing storage, space for clothing change and gowning area. Dressing rooms shall be provided convenient to the imaging rooms.*

1226.5.5.1.3 Staff facilities. *In service space of three or more procedure rooms, staff toilet room(s) internal to the service space.*

1226.5.5.1.4 Handwashing fixtures. *Handwashing fixture(s) shall be located within the unit.*