

**COMMISSION ACTION MATRIX**  
**AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING & DEV. [06/12]**

**TITLE (CODE)**  
**CCR, TITLE 24, PART 5 (2013 California Plumbing Code)**

**LEGEND:**

Item numbers refer to those presented to the Code Advisory Committees (CAC)s

**(CAC)s:**

- ACCESS = Accessibility
- BFO = Building, Fire & Other
- HF = Health Facilities
- PEME = Plumbing, Electrical, Mechanical, and Energy
- SDLF = Structural Design/Lateral Forces
- GB = Green Building

**Actions:**

- AA = Approve as amended
- AS = Approve as submitted
- D = Disapprove
- FS = Further Study
- W/D = Withdrawn by agency

**Amendments, if indicated by agency:**

- S = Statutory
- E = Existing
- N = New

**Matrix Paper Color (Used for Comm. Action):**

- GREEN = uncontested items
- YELLOW = challenged items
- SALMON = W/D, no action required

**PEME CODE ADVISORY COMMITTEE OSHPD**

**CHAPTER 1**  
**ADMINISTRATION**  
**DIVISION I**  
**CALIFORNIA ADMINISTRATION**

**[ Adopt entire 2013 Uniform Plumbing Code (UPC) Chapter and carry forward existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4. ]**

**CHAPTER 2 - DEFINITIONS – Office of Statewide Health Planning and Development (OSHPD)**

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter and carry forward existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4 with the following modifications:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-1	CHAPTER 2	E	AA		Section 217-Address definition of OSHPD 3SE Item (2)Primary Care clinics that do not provide abortion services And Coordinate with Part 4 comments On Item (4)Primary care clinics performing invasive procedures  Editorial: correct table 4-2 to 4A	DEFINITIONS	

**CHAPTER 3 - GENERAL REQUIREMENTS – Office of Statewide Health Planning and Development (OSHPD)**

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter and carry forward existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4 with the following modifications:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-2	CHAPTER 3	N	AS			GENERAL REQUIREMENTS - (Adopting CHAPTER 3 is adopting all articles and sections listed below)	
OSHPD-6/12-3	<del>Section 315.1.1</del> 314.8	N	AS		Editorial	<i>Modify existing Section by adding the words: and relative humidity</i>	

**CHAPTER 4 - PLUMBING FIXTURES AND FIXTURE FITTINGS – Office of Statewide Health Planning and Development (OSHPD)**

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter and carry forward existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4 with the following modifications:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-4	CHAPTER 4	N	AS			GENERAL REQUIREMENTS - (Adopting CHAPTER 4 is adopting all articles and sections listed below)	
OSHPD-6/12-5	Section 410.3	N	AS			Flushometer Valves add language - . <u>[OSHPD 1, 2, 3, and 4] Sensor operated flush valves shall be capable of functioning during loss of normal power.</u>	
OSHPD-6/12-6	<del>Section 412.3.1-</del> <u>[OSHPD 1, 2, 3, and 4] Separate toilet facilities shall be provided for the use of patients, staff personnel and visitors.</u>	N	AS			<u>Exception for OSHPD 3 Primary Care Clinics Only: Where a facility contains no more than three examination and/or treatment rooms, the patient toilet shall be permitted to serve waiting areas.</u>	
OSHPD-6/12-7	Table 4-2	E	AS			<i>Modify Table and footnotes as indicated in ET</i>	

**CHAPTER 5 - WATER HEATERS – Office of Statewide Health Planning and Development (OSHPD)**

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter for OSHPD 1, 2, 3 & 4 without amendments:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-8	CHAPTER 5	N	AS			WATER HEATERS - Adopt CHAPTER 5 in its entirety	

## CHAPTER 6 WATER SUPPLY AND DISTRIBUTION

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter 6 and carry forward existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4 with the following modifications:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-9	CHAPTER 6	N	AS			WATER SUPPLY AND DISTRIBUTION - (Adopting CHAPTER 6 is adopting all articles and sections listed below)	
OSHPD-6/12-10	Section 604.1 <i>Exception:</i>	E	AS			(1) [OSHPD 1, 2, 3 & 4]	
OSHPD-6/12-11	Section 609.9	E	AS			Disinfection of Potable Water System: [OSHPD 1, 2, 3 & 4] <i>Not required for [OSHPD 3SE]</i>	
OSHPD-6/12-12	<del>Section 609.11</del>	E	AS			<del>[OSHPD 1, 2, 3 &amp; 4] Refer to Title 24, Part 2 of the California Building Code for seismic anchorage and bracing requirements and accommodations for building displacements.</del>	
OSHPD-6/12-13	<del>Section 612.0</del>	E	AS		Editorial: change section in the ET from 612 to another section number as 612 is already taken by the 2012 UPC	<del>[OSHPD 1, 2, 3 &amp; 4] <i>Not required for [OSHPD 3SE]. Domestic Hot-Water Distribution Systems for Health Facilities and Clinics</i></del>	
OSHPD-6/12-14	Section 614.4.1 <i>with exceptions</i>	E	AA		Editorial: 1. add the word "source and" to 2 <sup>nd</sup> paragraph 2. coordinate the use of the words "Water Conservation/Water Rationing Plan"	Strike language, add language and revise exceptions as indicated in Express Terms	
OSHPD-6/12-15	Section 614.4.2	E	AS			Add language as indicated in Express Terms	

## CHAPTER 7 SANITARY DRAINAGE

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter and carry forward existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4 with the following modifications:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-16	CHAPTER 7	N	AS			SANITARY DRAINAGE - (Adopting CHAPTER 7 is adopting all articles and sections listed below)	
OSHPD-6/12-17	Section 701.1.2.1	N	AS			[OSHPD 1, 2, 3 & 4] <i>ABS and PVC installations are not allowed.</i>	

OSHDP-6/12-18	<u>Sections 727.0 &amp; 727.1</u>	N	AS			<i>727.0 [OSHDP 1] Emergency Sanitary Drainage. 727.1- Strike and replace language as indicated</i>	
---------------	-----------------------------------	---	----	--	--	---	--

### CHAPTER 8 INDIRECT WASTES

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter for OSHPD 1, 2, 3 & 4 without amendments:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHDP-6/12-19	CHAPTER 8	E	AS			INDIRECT WASTES – Adopt entire Chapter 8 without amendments.	

### CHAPTER 9 VENTS

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter and carry forward existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4 with the following modifications:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHDP-6/12-20	CHAPTER 9	E	AS			VENTS	
OSHDP-6/12-21	<i>Section 906.2.1</i>	N	AS			<i>[OSHPD 1, 2, 3 &amp; 4, except OSHPD 3SE]</i>	

### CHAPTER 10 TRAPS AND INTERCEPTORS

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter and carry forward existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4 with the following modifications:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHDP-6/12-22	CHAPTER 10	N	AS			TRAPS AND INTERCEPTORS - (Adopting CHAPTER 10 is adopting all articles and sections listed below)	
OSHDP-6/12-23	Section 1014.1A	E	AS			[OSHPD 1, 2, 3 & 4] The Authority Having Jurisdiction <del>is</del> the individual official, board... – add "is"	
OSHDP-6/12-24	Section 1014.1B	E	AS			[OSHPD 1, 2, 3 & 4] Grease <del>traps</del> <u>interceptors</u> shall not... modify language as indicated.	
OSHDP-6/12-25	Section 1015.6	E	AS			[OSHPD 1, 2, 3 & 4] Grease <del>traps</del> <u>interceptors</u>	

						shall not... modify language as indicated.	
--	--	--	--	--	--	--	--

### CHAPTER 11 STORM DRAINAGE

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter and carry forward the existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4.

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-26	CHAPTER 11	E	AS			STORM DRAINAGE - carry forward the existing amendments	

### CHAPTER 12 FUEL PIPING

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter for OSHPD 1, 2, 3 & 4 without amendments.

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-27	CHAPTER 12	E	AS			FUEL PIPING – Adopt unamended	

### CHAPTER 13 HEALTH CARE FACILITIES AND MEDICAL GAS AND VACUUM SYSTEMS

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter as amended and carry forward the existing amendments of the 2010 California Plumbing Code (CPC) for OSHPD 1, 2, 3 & 4.

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-28	CHAPTER 13	E	AS			HEALTH CARE FACILITIES AND MEDICAL GAS AND VACUUM SYSTEMS – Adopt Chapter as amended and carry forward the existing amendments	

### CHAPTER 14 MANDATORY REFERENCED STANDARDS

Adopt entire 2012 Uniform Plumbing Code (UPC) Chapter for OSHPD 1, 2, 3 & 4 without amendments:

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-29	CHAPTER 14	E	AS			MANDATORY REFERENCED STANDARDS	

**CHAPTER 15  
FIRESTOP PROTECTION**

**CHAPTER 16  
NON-POTABLE WATER REUSE SYSTEMS**

**[ Chapters are not adopted for OSHPD 1, 2, 3 & 4.]**

**APPENDIX CHAPTER A – RECOMMENDED RULES FOR SIZING THE WATER SUPPLY SYSTEM**

Adopt entire 2012 Uniform Plumbing Code (UPC) Appendix for OSHPD 1, 2, 3 & 4 without amendments.

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-30	APPENDIX CHAPTER A	N	AS			RECOMMENDED RULES FOR SIZING THE WATER SUPPLY SYSTEM – Adopt unamended	

**APPENDIX CHAPTER B –EXPLANATORY NOTES ON COMBINATION WASTE AND VENT SYSTEMS**

Adopt entire 2012 Uniform Plumbing Code (UPC) Appendix for OSHPD 1, 2, 3 & 4 without amendments.

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHPD-6/12-31	APPENDIX CHAPTER B	N	AS			RECOMMENDED RULES FOR SIZING THE WATER SUPPLY SYSTEM – Adopt unamended	

**APPENDIX CHAPTER D – SIZING STORM WATER DRAINAGE SYSTEMS**

Adopt entire 2012 Uniform Plumbing Code (UPC) Appendix for OSHPD 1, 2, 3 & 4 without amendments.

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHDPD-6/12-32	APPENDIX CHAPTER D	E	AS			SIZING STORM WATER DRAINAGE SYSTEMS – Adopt unamended	

APPENDIX CHAPTER E  
MANUFACTURED/MOBIL HOME PARKS AND RECREATIONAL VEHICLE PARKS

APPENDIX F  
FIREFIGHTER BREATHING AIR REPLENISHMENT SYSTEMS

APPENDIX G [DWR]  
GRAYWATER SYSTEMS

**[APPENDIX Chapters E, F, and G are not adopted for OSHPD 1, 2, 3 & 4.]**

**APPENDIX CHAPTER I – SIZING INSTALLATION STANDARDS**

Adopt entire 2012 Uniform Plumbing Code (UPC) Appendix for OSHPD 1, 2, 3 & 4 without amendments.

Item Number	Code Section	Type of amendment (S, E, N)	CAC: (AS, AA, D, FS)	Agency Response to CAC (A, D, W/D)	45-Day Comments (AS, AA, D, FS)	Annotations	CBSC Action (AS, AA, D, FS)
OSHDPD-6/12-33	APPENDIX CHAPTER I	E	AS			SIZING INSTALLATION STANDARDS – Adopt unamended	

**APPENDIX K  
PRIVATE SEWAGE DISPOSAL SYSTEMS**

**APPENDIX L  
ALTERNATE PLUMBING SYSTEMS**

**[ Appendix Chapters K & L are not adopted for OSHPD 1, 2, 3 & 4.]**

