

STATE OF CALIFORNIA
STATE AND CONSUMER SERVICES AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbssc@dgs.ca.gov

Office Use Item No. _____


PARTICIPATION COMMENTS FOR THE NOTICE DATED AUGUST 31, 2012
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: OCTOBER 15, 2012

Date: 9/20/2012

From: Mikal Nicholls

Name (Print or type)


(Signature)

San Diego County Office of Education, Educational Facilities

Agency, jurisdiction, chapter, company, association, individual, etc.

6401 Linda Vista Road, Rm 412, San Diego, CA 92111

Street

City

State

Zip

I/We (do) do not agree with:

The Agency proposed modifications As Submitted on Section No. 4-333 (a)

and request that this section or reference provision be recommended:

Approved Disapproved Held for Further Study Approved as Amended

Suggested Revisions to the Text of the Regulations:

Section 4-333 (a) allows a geotechnical engineer to inspect their own design which is contrary to Section 4-333 (b) and (c) and the spirit of third party inspection by DSA certified inspector(s). Further, in alternative delivery method contracts, such as design-build or power purchase agreements, the contractor would be self certifying a critical structural component of the work.

Suggest geotechnical engineer technically supervise, but not be allowed to inspect similar to other engineering disciplines.

Reason: [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]