

STATE OF CALIFORNIA
STATE AND CONSUMER SERVICES AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbsc@dgs.ca.gov


Office Use Item No. _____

PARTICIPATION COMMENTS FOR THE NOTICE DATED OCTOBER 26, 2012
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: DECEMBER 10, 2012

Date: December 10, 2012

From: Michael Apodaca, Public Works Manager of Public Services
Name (Print or type)


(Signature)

City of Irvine
Agency, jurisdiction, chapter, company, association, individual, etc.
6427 Oak Canyon Irvine CA 92623
Street City State Zip

I/We (do)(do not) agree with:

The Agency proposed modifications As Submitted on Section No. **11B-406.3.2 Turning Space**

A turning space 48 inches (1219 mm) minimum by 48 inches (1219 mm) minimum shall be provided at the bottom of the curb ramp. The slope of the turning space in all directions shall be 1:48 maximum.

and request that this section or reference provision be recommended:

Approved Disapproved Held for Further Study Approved as Amended

Suggested Revisions to the Text of the Regulations:

11B-406.3.2 Turning Space.

A turning space 48 inches (1219 mm) minimum by 48 inches (1219 mm) minimum shall be provided at the bottom of the curb ramp, **when determined feasible by the local agency**. The slope of the turning space in all directions shall be 1:48 maximum.

Reason: [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

The street grades dictate the slopes at the diagonal curb ramps. If the turning space is required, the reconstruction of the intersections would not be compatible with the grade of the street and thus cause a safety hazard to vehicular traffic. Reference Health and Safety Code Section 18930(a)(3).

HEALTH & SAFETY CODE SECTION 18930

SECTION 18930. APPROVAL OR ADOPTION OF BUILDING STANDARDS; ANALYSIS AND CRITERIA; REVIEW CONSIDERATIONS; FACTUAL DETERMINATIONS

- (a) Any building standard adopted or proposed by state agencies shall be submitted to, and approved or adopted by, the California Building Standards Commission prior to codification. Prior to submission to the commission, building standards shall be adopted in compliance with the procedures specified in Article 5 (commencing with Section 11346) of Chapter 3.5 of Part 1 of Division 3 of Title 2 of the Government Code. Building standards adopted by state agencies and submitted to the commission for approval shall be accompanied by an analysis written by the adopting agency or state agency that proposes the building standards which shall, to the satisfaction of the commission, justify the approval thereof in terms of the following criteria:
- (1) The proposed building standards do not conflict with, overlap, or duplicate other building standards.
 - (2) The proposed building standard is within the parameters established by enabling legislation and is not expressly within the exclusive jurisdiction of another agency.
 - (3) The public interest requires the adoption of the building standards.
 - (4) The proposed building standard is not unreasonable, arbitrary, unfair, or capricious, in whole or in part.
 - (5) The cost to the public is reasonable, based on the overall benefit to be derived from the building standards.
 - (6) The proposed building standard is not unnecessarily ambiguous or vague, in whole or in part.
 - (7) The applicable national specifications, published standards, and model codes have been incorporated therein as provided in this part, where appropriate.
 - (A) If a national specification, published standard, or model code does not adequately address the goals of the state agency, a statement defining the inadequacy shall accompany the proposed building standard when submitted to the commission.
 - (B) If there is no national specification, published standard, or model code that is relevant to the proposed building standard, the state agency shall prepare a statement informing the commission and submit that statement with the proposed building standard.
 - (8) The format of the proposed building standards is consistent with that adopted by the commission.
 - (9) The proposed building standard, if it promotes fire and panic safety as determined by the State Fire Marshal, has the written approval of the State Fire Marshal.