

**From:** Roger N Fish [mailto:[rogerf@sfsu.edu](mailto:rogerf@sfsu.edu)]  
**Sent:** Thursday, November 08, 2012 2:44 PM  
**To:** DSA Access2013@DGS; CBSC@DGS  
**Cc:** Simon Y Lam; Roger N Fish  
**Subject:** Proposed 11B-216.2 Building Sign Designations

To Whom It May Concern,

In regards to the wording of this section, it is not clear that signs are required to be installed at permanent rooms and spaces. The code is explicit at toilet rooms, exits, and stairs however it is arguable that the code is requiring signs elsewhere.

Recommend the following:

“11B-216.2 Designations. Interior and exterior signs identifying permanent rooms and spaces shall comply...” change to read **“11B-216.2 Designations. Interior and exterior signs shall be provided to identify permanent rooms and spaces where not otherwise required by this code and shall comply...”**

Submitted by:

Roger N Fish, Director of Design and Construction  
Capital Planning, Design and Construction  
San Francisco State University  
Tel.: 415-338-6017  
Fax: 415-338-2960  
Email: [rogerf@sfsu.edu](mailto:rogerf@sfsu.edu)