

Reason: [The reason should be concise if the request is for “Disapproval,” “Further Study,” or “Approve As Amend” and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

HEALTH & SAFETY CODE SECTION 18930(a)(3 through 6)

The concept of “close proximity” was in the Division’s December 23, 2013 Draft Express Terms and should be retained in the final rules.

On touch screens, potential tactile overload of a mechanical keypad with many buttons for the keypad does not exist. Therefore the accessibility function button will stand out and can easily be located at the perimeter of the active display. Its location is further enhanced by the specified height of the button above the finish floor (see 11B-411.2.1.3.2), the International Symbol of Accessibility, and the three raised dots (see 11B-411.2.1.2.3).