

STATE OF CALIFORNIA
GOVERNMENT OPERATIONS AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbsc@dgs.ca.gov

Office Use Item No. DSAAE 01/13
Received on 3/31/14

PARTICIPATION COMMENTS FOR THE NOTICE DATED MARCH 21, 2014
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: MAY 5, 2014

Date: 03/31/2014

From:

Martin Cooper
Name (Print or type)


(Signature)

City of Foster City

Agency, jurisdiction, chapter, company, association, individual, etc.

610 Foster City Blvd. Foster City CA 94404
Street City State Zip

I/We (do)(do not) agree with:

The Agency proposed modifications As Submitted on Section No. 11B-603.4

and request that this section or reference provision be recommended:

Approved Disapproved Held for Further Study Approved as Amended

by the reviewing Code Advisory Committee.

Suggested Revisions to the Text of the Regulations:

11B-603.4 Coat hooks, shelves and medicine cabinets. Coat hooks shall be located within one of the reach ranges specified in Section 11B-308. Shelves shall be located 40 inches (1016 mm) minimum and 48 inches (1219 mm) maximum above the finish floor. ~~Medicine cabinets shall be located with a usable shelf no higher than 44 inches (1118 mm) maximum above the finish floor~~ provide at least one usable shelf which complies with Section 11B-308.

Reason: [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

Medicines and other items need to be within the reach ranges of 11B-308, not just the medicine cabinet self. Most medicine cabinets are installed over counters and would necessitate obstructed reach. The public interest requires the adoption of the building standards.