STATE OF CALIFORNIA
GOVERNMENT OPERATIONS AGENCY
CALIFORNIA BUILDING STANDARDS COMMISSION
2525 NATOMAS PARK DR., SUITE 130
SACRAMENTO, CA 95833
(916) 263-0916 Phone
(916) 263-0959 Fax
Email: cbsc@dgs.ca.gov

Office Use Item No. _____

PARTICIPATION COMMENTS FOR THE NOTICE DATED APRIL 25, 2014
Written comments are to be sent to the above address.

WRITTEN COMMENT DEADLINE: JUNE 9, 2014

Date: JUNE 9, 2014

From: Daniel Gleiberman
Name (Print or type) (Signature)

SLOAN VALVE COMPANY
Agency, jurisdiction, chapter, company, association, individual, etc.

14505 Astronautics Lane Huntington Beach CA 92647
Street City State Zip

I/We (do) (do not) agree with:

[X] The Agency proposed modifications As Submitted on Section No. 5.303.3.4.4

and request that this section or reference provision be recommended:

[ ] Approved [ ] Disapproved [ ] Held for Further Study [X] Approved as Amended

Suggested Revisions to the Text of the Regulations:

please see attached

Reason: [The reason should be concise if the request is for "Disapproval," "Further Study," or "Approve As Amend" and identify at least one of the 9-point criteria (following) of Health and Safety Code §18930.]

Approved as Amended for Section 5.303.3.4.4
Submitted by: Daniel Gleibmerman, Sloan Valve Company
Proposed changes denoted in red

5.303.3.4.4 Metering faucets. Metering faucets shall not deliver more than 0.20~~5~~ gallons per cycle

Reason based on 9-point Criteria California H&SC 18930:

Section 403.1.2.3 of the adopted Cal Green (Residential Mandatory Measures) establishing the maximum flow rates for metering facuets at 0.25 gallons per cycle. The changes proposed above are necessary in order to make the findings of critera number 1 (removes conflict), 3 (public interest is served by the nonresidential and residential requirements being the same), 4 (consistency between Chapter 4 and Chapter 5 will remove the arbitrary and unreasonable conflict that now exists)and 6 (consistency will remove the ambiguity and confusion that now exist).