

**15-DAY EXPRESS TERMS
FOR
PROPOSED BUILDING STANDARDS
OF THE
OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT**

**REGARDING PROPOSED CHANGES TO
2007 CALIFORNIA ELECTRICAL CODE
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 3**

LEGEND FOR EXPRESS TERMS

1. Existing California amendments or code language being modified: All such language appears in *italics*, modified language is underlined, repealed language appears in ~~strikeout~~.
2. New California amendments: All such language appears double underlined and in italics.
3. Repealed text: All such language appears in ~~double strikeout~~.
4. Rationale: The justification for the change is shown after each section or series of related changes.
5. Notation: Authority and reference citations are provided at the end of each article.

EXPRESS TERMS

ARTICLE 700 – EMERGENCY SYSTEMS

...

VI. Overcurrent Protection

700.27 Coordination. Emergency system(s) overcurrent devices shall be selectively coordinated with all supply side overcurrent protective devices. [Not required for OSHPD 1, 2, 3, & 4]

Rationale:

The Initial Statement of Reasons that was submitted with the 45-day Express Terms accurately reflected the intent to apply this article only to OSHPD 3. The proposed change reflects the original intent of OSHPD to apply Article 700.27 to OSHPD 3 only.

Notation:

Authority: Health & Safety Code §1226, 1275, 129790 & 129850 and Government Code §11152.5

Reference: Health & Safety Code §1226, 1275, 129790 & 129850

ARTICLE 701 – LEGALLY REQUIRED STANDBY SYSTEMS

IV. Overcurrent Protection

...

701.18 Coordination. Legally required standby system(s) overcurrent devices shall be selectively coordinated with all supply side overcurrent protective devices. [Not required for OSHPD 1, 2, 3, & 4]

Rationale:

The Initial Statement of Reasons that was submitted with the 45-day Express Terms accurately reflected the intent to apply this article only to OSHPD 3. The proposed change reflects the original intent of OSHPD to apply Article 701.18 to OSHPD 3 only.

Notation:

Authority: Health & Safety Code §1226, 1275, 129790 & 129850 and Government Code §11152.5

Reference: Health & Safety Code §1226, 1275, 129790 & 129850