

## **American Coatings Association Public Comment**

**4.504.2 Finish material pollutant control.** Finish materials shall comply with this section.

Suggested modification:

**4.504.2 Finish material pollutant control.** Finish materials [installed inside the building weatherproofing envelope at the project site](#) shall comply with this section.

Original paragraph (Page 31 of 193)

**4.504.2.2 Paints and coatings.** Architectural paints and coatings shall comply with VOC limits in Table 1 of the ARB Architectural Suggested Control Measure, as shown in Table 4.504.3, unless more stringent local limits apply. The VOC content limit for coatings that do not meet the definitions for the specialty coatings categories listed in Table 4.504.3 shall be determined by classifying the coating as a Flat, Nonflat or Nonflat-High Gloss coating, based on its gloss, as defined in subsections 4.21, 4.36, and 4.37 of the 2007 California Air Resources Board, Suggested Control Measure, and the corresponding Flat, Nonflat or Nonflat-High Gloss VOC limit in Table 4.504.3 shall apply.

**4.504.2.2 Paints and coatings.** Architectural paints and coatings shall comply with [the 2007 California Air Resources Suggested Control Measure for Architectural Coatings](#) VOC limits [as applicable in Table 1 of the ARB Architectural Suggested Control Measure](#), as shown in Table 4.504.3, unless more stringent local [regulatory](#) limits apply. The VOC content limit for [regulated](#) coatings that do not meet the definitions for the specialty coatings categories listed in Table 4.504.3 shall be determined by classifying the coating as a Flat, Nonflat or Nonflat-High Gloss coating, based on its gloss, as defined in subsections 4.21, 4.36, and 4.37 of the 2007 California Air Resources Board, Suggested Control Measure, and the corresponding Flat, Nonflat or Nonflat-High Gloss VOC limit in Table 4.504.3 shall apply.