

Nearman, Michael@DGS

From: Davis, Stephanie@DGS
Sent: Monday, September 19, 2011 2:26 PM
To: Taylor, Jane@DGS; Nearman, Michael@DGS
Subject: FW: CDPH 15-Day Notice of Proposed Action & Express Terms

-----Original Message-----

From: Joe Loyer [mailto:Jmloyer@energy.state.ca.us]
Sent: Monday, September 19, 2011 2:11 PM
To: Davis, Stephanie@DGS
Cc: Craig Hoellwarth; Gary Flamm
Subject: Re: CDPH 15-Day Notice of Proposed Action & Express Terms

Ms Davis,

The California Energy Commission has no formal comments to make regarding the CDPH 15-day notice of Proposed Action & Express Terms for Code of Regulations, Title 24, Part 2 Volume 2, Chapter 31B, Public Pools, Division I - General.

We support the removal of the minimum footcandle level language for pool decks in Section 3115B. However, removing such language may result in subjective evaluations as to how much lighting is appropriate. We recommend that a statement be inserted that pool deck lighting shall meet the recommended lighting requirements in the Illuminating Engineering Society of North America, Lighting Handbook, 10th Edition.

"When the pool is to be used at night, pool deck areas and emergency egress areas shall be provided with a minimum of 3 foot candle lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Deck lighting shall meet the recommended lighting requirements in the Illuminating Engineering Society of North America, Lighting Handbook, 10th Edition. "

Thank you for the opportunity to comment.

-Joe Loyer
Mechanical Engineer
California Energy Commission

>>> "Davis, Stephanie@DGS" <Stephanie.Davis@dgs.ca.gov> 9/12/2011 4:42
>>> PM >>>

Attached is CDPH's Notice of Proposed Action & Express Terms for their 15-Day comment period. The comment period begins 9/13/11 and ends 9/28/2011. For questions and comments regarding this email, please contact Michael Nearman at (916) 263-0916.

Stephanie Davis

Assistant to the Executive Director, Jim McGowan

California Building Standards Commission

2525 Natomas Park Drive, Suite 130

Sacramento, CA 95833

(916) 263-1835

(916) 263-0959 Fax