

**EXPRESS TERMS  
FOR  
PROPOSED BUILDING STANDARDS  
OF THE  
OFFICE OF THE STATE FIRE MARSHAL  
REGARDING UL 1703 FIRE CLASSIFICATION PROVISIONS  
IN THE 2013 CALIFORNIA BUILDING CODE,  
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 2  
EMERGENCY RULEMAKING**

---

The Office of the State Fire Marshal (OSFM) proposes to make necessary changes to the 2013 edition of the California Building Code (CBC) relating to the adopted reference standard UL 1703 and Fire Classifications.

**Legend for Express Terms:**

1. New California amendment: *California language appears underlined and in Italics.*
  2. Repealed text: Shown as ~~Strikeout~~.
- 

***1505.9 Photovoltaic panels and modules.*** *Effective January 1, 2015, Rooftop mounted photovoltaic systems shall be tested, listed and identified with a fire classification in accordance with UL 1703. The fire classification shall comply with Table 1505.1 based on the type of construction of the building.*

**Notation:**

Authority: Health and Safety Code Sections 13108, 13110, 13143, 13210, 13211, 18949.2  
References: Health and Safety Code Sections 13110, 13143, 13211, 18949.2

---