

Chapter 12-16-1
ENGINEERING REGULATION—QUALITY AND
DESIGN OF THE MATERIALS OF CONSTRUCTION

STANDARD 12-16-1

CALIFORNIA STANDARD FOR EARTHQUAKE-ACTUATED AUTOMATIC GAS SHUTOFF SYSTEMS
(See Chapter 16, California Building Code and Chapter 12, California Plumbing Code.)

DIVISION OF THE STATE ARCHITECT

Authority: Sections 19180–19183, Health and Safety Code.
Reference: Section 19182, Health and Safety Code.

Division 1—CONSTRUCTION

Scope

Sec. 12-16-101. The American Society of Civil Engineers requirements for "Earthquake-Actuated Automatic Gas Shutoff Devices," ASCE 25-97 (copyright 1998 by ASCE), shall be the applicable standard used by the Division of the State Architect for the certification of these devices.

|| c Sec. 12-16-101.1. *Each installation of a customer-owned device*
|| A *that satisfies this standard must be done in accordance with the*
|| C *California Plumbing Code.*
|| C