FINAL EXPRESS TERMS
FOR
PROPOSED BUILDING STANDARDS
OF THE
DIVISION OF THE STATE ARCHITECT - STRUCTURAL SAFETY (DSA-SS AND DSA-SS/CC)

REGARDING PROPOSED CHANGES TO
CALIFORNIA REFERENCED STANDARDS CODE
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 12

The California Building Standards Code (California Code of Regulations, Title 24, Parts 1, 2, 3, 4, 5, 6, 8, 9, 10, 11, and 12) is published in its entirety every three years and is applicable to all buildings for which an application for a building permit is made during the Code's effective period. Each triennial edition of the California Building Standards Code becomes effective 180 days after its publication.

DSA is proposing the following editorial amendments to the 2013 edition of CCR Title 24, California Referenced Standards Code (CRSC) Part 12, to be incorporated into the 2016 triennial edition of the CRSC.

LEGEND FOR FINAL EXPRESS TERMS (combination of 45-day and 15-day changes)
1. For 45-day and 15-Day changes, existing California amendments or code language being modified appears in *italics*, with modified language underlined.
2. For 45-day and 15-Day changes, repealed text appears in ~~strikeout~~.

EXPRESS TERMS

CHAPTER 12-1
ADMINISTRATION

…

~~**CHAPTER 12-12**~~

~~**ENGINEERING REGULATION-QUALITY AND DESIGN**~~
~~**OF THE MATERIALS OF CONSTRUCTION**~~

~~**STANDARD 12-12-1**~~

~~**CALIFORNIA STANDARD FOR EARTHQUAKE-ACTUATED GAS SHUTOFF VALVES**~~
~~**(See Chapter 12, *California Plumbing Code.)***~~

~~**DIVISION OF THE STATE ARCHITECT**~~
~~**Authority:** Sections 19180-19183, Health and Safety Code.~~
~~**Reference:** Section 19182, Health and Safety Code.~~

~~**Division I-CONSTRUCTION**~~

~~**SCOPE**~~

~~**Sec. 12-12-101**. The American Society of Civil Engineers requirements for "Earthquake-Actuated Automatic Gas Shutoff Devices," ANSI/ASCE/SEI 25-06 (Copyright 2008 by ASCE), shall be the applicable standard used by the Division of the State Architect for the certification of these devices.~~

~~**Sec. 12-12-101.1.** Each installation of a customer-owned device that satisfies this standard must be done in accordance with the *California Plumbing Code*.~~

…

Chapter 12-16-1

**ENGINEERING REGULATIONS-QUALITY AND DESIGN
OF THE MATERIALS OF CONSTRUCTION**

STANDARD 12-16-1

**CALIFORNIA STANDARD FOR EARTHQUAKE-ACTUATED AUTOMATIC GAS SHUTOFF SYSTEMS
(See CCR Title 24, Part 2, Chapters 16 and 16A, and CCR Title 24, Part 5, ~~Chapter 16, *California Building Code* and~~ Chapter 12~~, *California Plumbing Code*~~.)**

DIVISION OF THE STATE ARCHITECT
Authority: Sections 19180-19183, Health and Safety Code.
Reference: Section 19182, Health and Safety Code.

Division I-CONSTRUCTION

SCOPE

Sec. 12-16-101. The American Society of Civil Engineers requirements for "Earthquake-Actuated Automatic Gas Shutoff Devices," ~~ASCE~~ANSI/ASCE/SEI 25-~~97~~06 (copyright ~~1998~~2008 by ASCE), shall be the applicable standard used by the Division of the State Architect for the certification of these devices.

Sec. 12-16-101.1. Each installation of a customer-owned device that satisfies this standard must be done in accordance with the *California Plumbing Code (CCR Title 24, Part 5)*.

…

Chapter 12-16-2

**ENGINEERING REGULATIONS-QUALITY AND DESIGN
OF THE MATERIALS OF CONSTRUCTION**

STANDARD 12-16-2

CALIFORNIA STANDARD FOR RESIDENTIAL EXCESS FLOW ACTUATED

AUTOMATIC GAS SHUTOFF VALVES

(See CCR Title 24, Part 5, ~~Chapter 16, *California Building Code* and for Earthquake-Actuated Gas Shutoff Valves see Section 1211.18,~~ Chapter 12~~, *California Plumbing Code*~~.)

DIVISION OF THE STATE ARCHITECT
Authority: Sections 19200-19204, Health and Safety Code.
Reference: Sections 19201.5 and 19202, Health and Safety Code.

Division I-CONSTRUCTION

SCOPE

Sec. 12-16-201. The American Society for Testing and Materials (ASTM) F2138-12~~09~~ Standard Specification for Excess Flow Valves for Natural Gas Service, and the American National Standards Institute (ANSI) Z21.93-13/CSA 6.30-13 Excess Flow Valves for Natural and LP Gas with Pressure up to 5 psig, shall be the applicable standards used by the Division of the State Architect for certification of these devices.

Sec. 12-16-201.1. Each installation of a customer-owned device that satisfies this standard must be done in accordance with the *California Plumbing Code (CCR Title 24, Part 5).*

…