

17800 CLOSED CIRCUIT TELEVISION (CCTV)

.100 LOCATIONS

- A. Pedestrian Sallyport: The tower adjacent to the entrance building shall be provided with a system consisting of a minimum of three cameras, positioned to view all persons entering and exiting the pedestrian sallyport, and a monitor with automatic and manual switching to either camera.
- B. Vehicle Sallyport: The tower adjacent to the vehicle sallyport shall be provided with a system consisting of a sufficient number of cameras (minimum of 2) to provide full surveillance of all sallyport gates, vehicle areas, and the officers station simultaneously. One monitor shall be provided with lock-on capability. One monitor with automatic sequencing to all vehicle sallyport cameras shall be provided.
- C. Central Control shall be provided with monitor extensions from the vehicle and pedestrian sallyports at sites without armed security perimeter (tower), and may be required at sites with armed security perimeters when the CCTV is adjunct to or is an essential part of the site security perimeter.
- D. Security Housing Unit (SHU): The system shall consist of two cameras mounted in heavy-duty weather-proof housings located to provide surveillance of each SHU yard. Two monitors, each with a real-time recorder, shall be provided in SHU control rooms. Minimum mounting height of cameras shall be 24 feet above ground level.
- E. Administrative Segregation (270 ASU): The system shall consist of a minimum of two cameras mounted in heavy-duty, weather-proof housings located to provide surveillance of each administrative segregation yard. Two monitors, each with a video real-time recorder, shall be provided in Administration Segregation housing unit control rooms. One monitor shall be fed from a quad processor and controller. Minimum mounting height of cameras shall be 24 feet above ground level.
- F. Administrative Segregation (ASU): The system shall consist of a minimum of one camera for each Small Management Yard and a minimum of two cameras for the Circulation Space between the ASU Building and Small Management Yard. All cameras shall be mounted in heavy-duty, weatherproof housings.
- G. General Visiting (Non-Level IV): The system shall consist of one omniscan hemispherical pan and tilt discreet surveillance camera system to provide surveillance of the general visiting room. The internal dimensions shall allow 360° horizontal (pan) and 90° vertical (tilt) angle travel and provide zoom-lens package up to 15.5 inches with a wide angle of 12.5 millimeters. One control unit to provide auto and manual control of pan and tilt unit and lens. One monitor and one video recorder shall be provided at the officer station. One camera with 200-meter lens and controls shall be provided.
- H. Level IV General Visiting Rooms located in the Central and Complex Services Buildings:
 - 1. CCTV coverage of the General Visiting rooms shall utilize cameras that have pan/tilt/zoom capability. Provide a sufficient number of cameras for full coverage of the room without panning.
 - 2. Locate one monitor at the Officer's Station within each visiting room. Recording equipment shall be located in the Security and Investigations area in Central Services.
- I. Level IV and Youth Offender Program (YOP) Yards:
 - 1. A sufficient number of fixed CCTV cameras shall be furnished in order to provide for full surveillance of the yards. In addition to the fixed cameras, provide one strategically-located camera in each yard that has pan/tilt/zoom capability.
 - 2. Coverage of the enclosed yard area in front of the Facility Program Support Services (FPSS) building shall also be provided by use of fixed cameras.

3. Monitors shall be located in the S & I area of Central Services, based on the following criteria:
 - a. Provide one monitor with split-screen imaging for monitoring of the fixed cameras located in each yard, including the YOP yard.
 - b. Provide one monitor with split-screen imaging for monitoring the area in front of each two FPSS buildings.
 - c. Provide one monitor for each two facilities to enlarge and view selected video from either the fixed cameras or the pan/tilt/zoom cameras. Control of the pan/tilt/zoom cameras shall be via staff located in the S & I area.

.200 CAMERAS/RECORDERS/MONITORS

- A. Cameras shall be mounted rigid, with fixed focal length lenses, except where effective surveillance requires the inclusion of such features as motion control and/or zoom lenses.
- B. Cameras shall be inaccessible to inmates and shall be housed in security-type enclosures.
 1. Enclosures shall be weather-tight with accessories necessary to permit effective use in adverse weather and provide temperature protection.
- C. Cameras shall be solid-state, color and shall utilize a solid-state high-resolution image sensor, capable of producing a well-defined, readily-identifiable image at illumination levels of 0.2 fc footcandles (2.0 lux). Cameras shall be shock resistant and operate on low voltage D.C.
- D. Monitors shall be minimum 12 inch, high resolution color type with all solid-state circuitry and regulated power supply.
- E. Recorders shall be real-time with date and time generator.

END OF DOCUMENT